



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school has replaced all fixtures that have lead levels above 19ppb. The school has also implemented a flushing program means of reducing lead in drinking water fixtures.

School District Name: Auburn

School Name: Chinook Elementary

School Code: 3439

Address: 3502 Auburn Way S, Auburn WA 98092

County: King

Number of Samples Collected: 54

Date Collected: 06/19/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	10582	First Draw	Bubbler	Outside 200, gymnasium	1	07/10/2018	6:20 AM
2.	11402	First Draw	Tap	Health Room	<1	07/10/2018	
3.	11403	First Draw	Tap	Workroom in Main Office	26	07/10/2018	
4.	11404	First Draw	Bubbler	Main Office	2	07/10/2018	
5.	11405	First Draw	Tap	Staff Lounge	<1	07/10/2018	
6.	11406	First Draw	Tap	Kitchen	2	07/10/2018	Food Prep Sink, used that morning
7.	11407	First Draw	Bubbler	Room 201	2	07/10/2018	Left hand sink
8.	11408	First Draw	Tap	Room 201	3	07/10/2018	
9.	11409	First Draw	Bubbler	Room 201	13	07/10/2018	Right hand sink
10.	11410	First Draw	Tap	Room 201	4	07/10/2018	
11.	11411	First Draw	Tap	Room 202	4	07/10/2018	Bubbler not used
12.	11412	First Draw	Tap	Room 202	2	07/10/2018	Bubbler not used, right hand sink
13.	11413	First Draw	Bubbler	Room 301	10	07/10/2018	
14.	11414	First Draw	Tap	Room 301	2	07/10/2018	
15.	11415	First Draw	Bubbler	Room 302	4	07/10/2018	
16.	11416	First Draw	Tap	Room 302	3	07/10/2018	
17.	11417	First Draw	Bubbler	Room 303	4	07/10/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
18.	11418	First Draw	Tap	Room 303	4	07/10/2018	
19.	11419	First Draw	Bubbler	Room 304	<1	07/10/2018	
20.	11420	First Draw	Tap	Room 304	2	07/10/2018	
21.	11421	First Draw	Bubbler	Down Hall from Room 303	7	07/10/2018	
22.	11422	First Draw	Bubbler	Room 305	4	07/10/2018	
23.	11423	First Draw	Tap	Room 305	6	07/10/2018	
24.	11424	First Draw	Bubbler	Room 306	5	07/10/2018	
25.	11425	First Draw	Tap	Room 306	1	07/10/2018	
26.	11426	First Draw	Bubbler	Room 401	5	07/10/2018	
27.	11427	First Draw	Tap	Room 401	5	07/10/2018	
28.	11428	First Draw	Bubbler	Room 402	3	07/10/2018	
29.	11429	First Draw	Tap	Room 402	8	07/10/2018	
30.	11430	First Draw	Bubbler	Across from Room 402	1	07/10/2018	
31.	11431	First Draw	Bubbler	Room 406	1	07/10/2018	
32.	11432	First Draw	Tap	Room 406	8	07/10/2018	
33.	11433	First Draw	Bubbler	Room 407	4	07/10/2018	
34.	11434	First Draw	Tap	Room 407	8	07/10/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
35.	11435	First Draw	Bubbler	Room 408	2	07/10/2018	
36.	11436	First Draw	Tap	Room 408	14	07/10/2018	
37.	11437	First Draw	Bubbler	Room 409	8	07/10/2018	
38.	11438	First Draw	Tap	Room 409	25	07/10/2018	
39.	11439	First Draw	Bubbler	Room 410	2	07/10/2018	
40.	11440	First Draw	Tap	Room 410	11	07/10/2018	
41.	11441	First Draw	Bubbler	Room 501	3	07/10/2018	
42.	11442	First Draw	Tap	Room 501	29	07/10/2018	
43.	11443	First Draw	Bubbler	Room 504	2	07/10/2018	
44.	11444	First Draw	Tap	Room 504	6	07/10/2018	
45.	11445	First Draw	Bubbler	Across from Room 504	1	07/10/2018	
46.	11446	First Draw	Bubbler	Room 506	6	07/10/2018	
47.	11447	First Draw	Tap	Room 506	9	07/10/2018	
48.	11448	First Draw	Bubbler	Room 507	4	07/10/2018	
49.	11449	First Draw	Tap	Room 507	7	07/10/2018	
50.	11450	First Draw	Bubbler	Room 508	8	07/10/2018	
51.	11451	First Draw	Tap	Room 508	9	07/10/2018	
52.	11452	First Draw	Bubbler	Room 509	9	07/10/2018	
53.	11453	First Draw	Tap	Room 509	15	07/10/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
54.	11454			Room 504	<1	07/10/2018	03475 blank sample