



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Evergreen Heights Elementary

School Code: 3745

School District Name: Auburn

Address: 5602 S 316th St Auburn WA 98001

County: King

Number of Samples Collected: 46

Date Collected: 06/22/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	12449	First Draw	Bubbler	Outside Gym	4	07/17/2018	5:03 AM
2.	12450	First Draw	Tap	Kitchen Main Sink	<1	07/17/2018	Tap on left
3.	12451	First Draw	Tap	Kitchen Main Sink	4	07/17/2018	Tap on right
4.	12452	First Draw	Bubbler	Room 403	3	07/17/2018	
5.	12453	First Draw	Tap	Room 403	3	07/17/2018	No aerator
6.	12454	First Draw	Bubbler	Room 404	3	07/17/2018	
7.	12455	First Draw	Tap	Room 404	2	07/17/2018	Tap Dripping
8.	12456	First Draw	Bubbler	Room 409	2	07/17/2018	
9.	12457	First Draw	Tap	Room 409	4	07/17/2018	
10.	12458	First Draw	Bubbler	Room 410	5	07/17/2018	
11.	12459	First Draw	Tap	Room 410	19	08/20/2018	Slightly yellow water
12.	12460	First Draw	Bubbler	Room 415	2	07/17/2018	
13.	12461	First Draw	Tap	Room 415	1	07/17/2018	
14.	12462	First Draw	Bubbler	Room 416	3	07/17/2018	
15.	12463	First Draw	Tap	Room 416	3	07/17/2018	Tap drips
16.	12464	First Draw	Bubbler	Room 215	3	07/17/2018	
17.	12465	First Draw	Tap	Room 215	8	07/17/2018	Tap drips
18.	12466	First Draw	Bubbler	Room 214	2	07/17/2018	
19.	12467	First Draw	Tap	Room 214	9	07/17/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
20.	12468	First Draw	Bubbler	Room 210	4	07/17/2018	
21.	12469	First Draw	Tap	Room 210	7	07/17/2018	
22.	12470	First Draw	Bubbler	Room 209	5	07/17/2018	
23.	12471	First Draw	Tap	Room 209	9	07/17/2018	
24.	12472	First Draw	Bubbler	Room 203	4	07/17/2018	
25.	12473	First Draw	Tap	Room 203	7	07/17/2018	
26.	12474	First Draw	Bubbler	Room 204	11	07/17/2018	
27.	12475	First Draw	Tap	Room 204	21	07/17/2018	Water hammer and loose handle
28.	12476	First Draw	Bubbler	Room 115	11	07/17/2018	
29.	12477	First Draw	Tap	Room 115	10	07/17/2018	
30.	12478	First Draw	Bubbler	Room 116	5	07/17/2018	
31.	12479	First Draw	Tap	Room 116	4	07/17/2018	
32.	12480	First Draw	Tap	Health Room	4	07/17/2018	
33.	12481	First Draw	Tap	Staff Lounge	16	07/17/2018	
34.	12482	First Draw	Bubbler	Room 303	5	07/17/2018	
35.	12483	First Draw	Tap	Room 303	11	07/17/2018	No aerator
36.	12484	First Draw	Bubbler	Room 304	5	07/17/2018	
37.	12485	First Draw	Tap	Room 304	2	07/17/2018	No aerator
38.	12486	First Draw	Bubbler	Room 309	3	07/17/2018	6:06 AM

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
39.	12487	First Draw	Tap	Room 309	11	07/17/2018	
40.	12488	First Draw	Bubbler	Room 310	5	07/17/2018	
41.	12489	First Draw	Tap	Room 310	9	07/17/2018	
42.	12490	First Draw	Bubbler	Room 315	3	07/17/2018	6:11 AM
43.	12491	First Draw	Tap	Room 315	7	07/17/2018	
44.	12492	First Draw	Bubbler	Room 316	4	07/17/2018	6:13 AM
45.	12493	First Draw	Tap	Room 316	7	07/17/2018	No aerator
46.	12494	Blank		Near main entrance	<1	07/17/2018	03394