



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school has replaced all fixtures that have lead levels above 19ppb. The school has also implemented a flushing program means of reducing lead in drinking water fixtures.

School Name: Gildo Rey Elementary

School Code: 3669

School District Name: Auburn

Address: 1005 37th St SE , Auburn WA 98002

County: King

Number of Samples Collected: 58

Date Collected: 06/21/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	11488	First Draw	Bubbler	Outside Gym	1	7/19/2018	
2.	11489	First Draw	Tap	Kitchen, back sink	<1	7/19/2018	Food Prep Sink
3.	11490	First Draw	Tap	Kitchen, back sink	1	7/19/2018	Food Prep Sink
4.	11491	First Draw	Bubbler	Room 118	11	7/19/2018	Sink on left hand-side
5.	11492	First Draw	Tap	Room 118	10	7/19/2018	Sink on left-hand side
6.	11493	First Draw	Bubbler	Room 118	14	7/19/2018	Sink on right-hand side
7.	11494	First Draw	Tap	Room 118	8	7/19/2018	Sink on right-hand side
8.	11495	First Draw	Bubbler	Room 117	4	7/19/2018	Sink on left-hand side
9.	11496	First Draw	Tap	Room 117	13	08/29/2018	Sink on left-hand side
10.	11497	First Draw	Bubbler	Room 117	15	7/19/2018	Sink on right-hand side
11.	11498	First Draw	Tap	Room 117	9	7/19/2018	Sink on right-hand side
12.	11499	First Draw	Tap	Staff Lounge	1	7/19/2018	
13.	11500	First Draw	Tap	Workroom 104	8	7/19/2018	
14.	12381	First Draw	Tap	Nurses Office	6	7/19/2018	
15.	12382	First Draw	Bubbler	Room 301	66	08/29/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
16.	12383	First Draw	Tap	Room 301	21	7/19/2018	
17.	12384	First Draw	Bubbler	Room 302	25	7/19/2018	
18.	12385	First Draw	Tap	Room 302	22	7/19/2018	
19.	12389	First Draw	Bubbler	Room 303	8	7/19/2018	
20.	12410	First Draw	Tap	Room 303	11	08/29/2018	
21.	12411	First Draw	Bubbler	Room 304	7	7/19/2018	
22.	12412	First Draw	Tap	Room 304	10	7/19/2018	
23.	12413	First Draw	Bubbler	Room 305	9	7/19/2018	
24.	12414	First Draw	Tap	Room 305	13	08/29/2018	
25.	12415	First Draw	Bubbler	Room 306	14	7/19/2018	
26.	12416	First Draw	Tap	Room 306	22	08/29/2018	
27.	12417	First Draw	Bubbler	Room 307	6	7/19/2018	
28.	12418	First Draw	Tap	Room 307	6	7/19/2018	No aerator
29.	12419	First Draw	Tap	300 Workroom	15	7/19/2018	
30.	12420	First Draw	Bubbler	Room 401	5	7/19/2018	
31.	12421	First Draw	Tap	Room 401	28	08/29/2018	
32.	12422	First Draw	Bubbler	Room 402	7	7/19/2018	
33.	12423	First Draw	Tap	Room 402	14	08/29/2018	
34.	12424	First Draw	Bubbler	Room 403	13	7/19/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
35.	12425	First Draw	Tap	Room 403	16	08/29/2018	
36.	12426	First Draw	Bubbler	Room 404	13	7/19/2018	
37.	12427	First Draw	Tap	Room 404	24	7/19/2018	
38.	12428	First Draw	Bubbler	Room 405	9	08/26/2018	
39.	12429	First Draw	Tap	Room 405	29	7/19/2018	
40.	12431	First Draw	Bubbler	Room 406	19	7/19/2018	
41.	12431	First Draw	Tap	Room 406	12	7/19/2018	
42.	12432	First Draw	Bubbler	Room 407	9	7/19/2018	
43.	12433	First Draw	Tap	Room 407	15	7/19/2018	
44.	12434	First Draw	Bubbler	Room 501	13	7/19/2018	
45.	12435	First Draw	Tap	Room 501	9	7/19/2018	
46.	12436	First Draw	Bubbler	Room 502	7	7/19/2018	
47.	12437	First Draw	Tap	Room 502	13	7/19/2018	
48.	12438	First Draw	Bubbler	Room 503	21	7/19/2018	
49.	12439	First Draw	Tap	Room 503	17	7/19/2018	
50.	12440	First Draw	Bubbler	Room 504	18	7/19/2018	
51.	12441	First Draw	Tap	Room 504	10	7/19/2018	
52.	12442	First Draw	Bubbler	Room 505	10	7/19/2018	
53.	12443	First Draw	Tap	Room 505	19	08/29/2018	
54.	12444	First Draw	Bubbler	Room 506	16	08/29/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
55.	12445	First Draw	Tap	Room 506	17	08/29/2018	
56.	12446	First Draw	Bubbler	Room 507	14	7/19/2018	
57.	12447	First Draw	Tap	Room 507	9	7/19/2018	
58.	12448	Blank		Room 507	<1	7/19/2018	04261