



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Lea Hill Elementary
School Code: 3525
School District Name: Auburn
Address: 30908 124th Ave SE, Auburn WA 98092
County: King
Number of Samples Collected: 58
Date Collected: 06/20/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	11394	First Draw	Tap	Kitchen	<1	08/30/2018	6:20 AM, used by staff
2.	11401	First Draw		Kitchen	<1	08/30/2018	
3.	11455	First Draw	Bubbler	Outside Gym	2	08/30/2018	
4.	11456	First Draw	Tap	Nurses Office	13	08/30/2018	
5.	11457	First Draw	Tap	Staff Lounge	12	08/30/2018	
6.	11458	First Draw	Tap	Staff Work Room	19	08/30/2018	No aerator
7.	11459	First Draw	Bubbler	Room 606	1	08/30/2018	Some calcification on bubbler
8.	11460	First Draw	Tap	Room 606	1	08/30/2018	
9.	11461	First Draw	Bubbler	Room 605	<1	08/30/2018	
10.	11462	First Draw	Tap	Room 605	4	08/30/2018	
11.	11463	First Draw	Bubbler	Room 604	<1	08/30/2018	
12.	11464	First Draw	Tap	Room 604	1	08/30/2018	
13.	11465	First Draw	Bubbler	Room 603	<1	08/30/2018	
14.	11466	First Draw	Tap	Room 603	1	08/30/2018	
15.	11467	First Draw	Bubbler	Room 602	<1	08/30/2018	
16.	11468	First Draw	Tap	Room 602	3	08/30/2018	
17.	11469	First Draw	Bubbler	Drinking fountain across from Room 602	1	08/30/2018	
18.	11470	First Draw	Bubbler	Room 601	<1	08/30/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
19.	11471	First Draw	Tap	Room 601	<1	08/30/2018	
20.	11472	First Draw	Bubbler	Room 502	<1	08/30/2018	
21.	11473	First Draw	Tap	Room 502	<1	08/30/2018	
22.	11474	First Draw	Bubbler	Room 501	<1	08/30/2018	
23.	11475	First Draw	Tap	Room 501	<1	08/30/2018	
24.	11476	First Draw	Bubbler	Room 500	<1	08/30/2018	
25.	11477	First Draw	Tap	Room 500	<1	08/30/2018	
26.	11478	First Draw	Bubbler	Room 503	1	08/30/2018	
27.	11479	First Draw	Tap	Room 503	4	08/30/2018	
28.	11480	First Draw	Bubbler	Room 406	6	08/30/2018	
29.	11481	First Draw	Tap	Room 406	2	08/30/2018	
30.	11482	First Draw	Bubbler	Room 405	1	08/30/2018	
31.	11483	First Draw	Tap	Room 405	1	08/30/2018	
32.	11484	First Draw	Bubbler	Room 404	1	08/30/2018	
33.	11485	First Draw	Tap	Room 404	<1	08/30/2018	
34.	11486	First Draw	Bubbler	Room 403	1	08/30/2018	
35.	11487	First Draw	Tap	Room 403	2	08/30/2018	
36.	12386	First Draw	Bubbler	Room 402	2	08/30/2018	
37.	12387	First Draw	Tap	Room 402	1	08/30/2018	
38.	12388	First Draw	Bubbler	Across from Room 402	1	08/30/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
39.	12390	First Draw	Bubbler	Room 401	1	08/30/2018	
40.	12391	First Draw	Tap	Room 401	1	08/30/2018	
41.	12392	First Draw	Bubbler	Room 306	<1	08/30/2018	
42.	12393	First Draw	Tap	Room 306	<1	08/30/2018	
43.	12394	First Draw	Bubbler	Room 305	1	08/30/2018	
44.	12395	First Draw	Tap	Room 305	<1	08/30/2018	
45.	12396	First Draw	Bubbler	Room 304	1	08/30/2018	
46.	12397	First Draw	Tap	Room 304	1	08/30/2018	
47.	12398	First Draw	Bubbler	Room 303	2	08/30/2018	
48.	12399	First Draw	Tap	Room 303	2	08/30/2018	
49.	12400	First Draw	Bubbler	Room 302	<1	08/30/2018	
50.	12401	First Draw	Tap	Room 302	2	08/30/2018	
51.	12402	First Draw	Bubbler	Across from Room 302	1	08/30/2018	
52.	12403	First Draw	Bubbler	Room 301	<1	08/30/2018	
53.	12404	First Draw	Tap	Room 301	1	08/30/2018	
54.	12405	First Draw	Bubbler	Portable 661	1	08/30/2018	
55.	12406	First Draw	Tap	Portable 661	2	08/30/2018	
56.	12407	First Draw	Bubbler	Portable 662	2	08/30/2018	
57.	12408	First Draw	Tap	Portable 662	5	08/30/2018	
58.	12409	Blank		Near entrance	<1	08/30/2018	03447

