



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Pioneer Elementary
School Code: 3227
School District Name: Auburn
Address: 2301 M Street, Auburn WA 98002
County: King
Number of Samples Collected: 49
Date Collected: 06/15/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	10972	First Draw	Tap	Nurses Office	1	08/24/2018	6:15 AM
2.	11352	First Draw	Bubbler	Across from Main Office	3	08/24/2018	
3.	11353	First Draw	Tap	Kitchen Sink in Back	<1	08/24/2018	Tap used that morning
4.	11354	First Draw		Kitchen Sink in Back	<1	08/24/2018	
5.	11355	First Draw	Bubbler	Drinking fountain across from Room 302	2	08/24/2018	
6.	11356	First Draw	Bubbler	Room 301	<1	08/24/2018	
7.	11357	First Draw	Tap	Room 301	<1	08/24/2018	
8.	11358	First Draw	Bubbler	Room 302	1	08/24/2018	
9.	11359	First Draw	Tap	Room 302	1	08/24/2018	
10.	11360	First Draw	Bubbler	Room 303	<1	08/24/2018	
11.	11361	First Draw	Tap	Room 303	<1	08/24/2018	
12.	11362	First Draw	Bubbler	Room 304	<1	08/24/2018	
13.	11363	First Draw	Tap	Room 304	1	08/24/2018	
14.	11364	First Draw	Bubbler	Room 305	<1	08/24/2018	
15.	11365	First Draw	Tap	Room 305	1	08/24/2018	
16.	11366	First Draw	Bubbler	Room 306	1	08/24/2018	
17.	11367	First Draw	Tap	Room 306	<1	08/24/2018	
18.	11368	First Draw	Bubbler	Room 406	<1	08/24/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
19.	11369	First Draw	Tap	Room 406	<1	08/24/2018	
20.	11370	First Draw	Bubbler	Room 405	1	08/24/2018	
21.	11371	First Draw	Tap	Room 405	<1	08/24/2018	leaks
22.	11372	First Draw	Bubbler	Room 404	<1	08/24/2018	
23.	11373	First Draw	Tap	Room 404	3	08/24/2018	
24.	11374	First Draw	Bubbler	Room 403	<1	08/24/2018	
25.	11375	First Draw	Tap	Room 403	1	08/24/2018	
26.	11376	First Draw	Bubbler	Room 402	1	08/26/2018	
27.	11377	First Draw	Tap	Room 402	<1	08/26/2018	
28.	11378	First Draw	Bubbler	Across from Room 402	<1	08/26/2018	
29.	11379	First Draw	Bubbler	Room 401	<1	08/26/2018	
30.	11380	First Draw	Tap	Room 401	1	08/26/2018	
31.	11381	First Draw	Bubbler	Room 501	<1	08/26/2018	
32.	11382	First Draw	Tap	Room 501	<1	08/26/2018	
33.	11383	First Draw	Bubbler	Room 502	1	08/26/2018	
34.	11384	First Draw	Tap	Room 502	1	08/26/2018	
35.	11385	First Draw	Bubbler	Room 601	<1	08/27/2018	
36.	11386	First Draw	Tap	Room 601	21	08/27/2018	
37.	11387	First Draw	Bubbler	Room 602	2	08/27/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
38.	11388	First Draw	Tap	Room 602	<1	08/27/2018	
39.	11389	First Draw	Bubbler	Across from Room 602	<1	08/27/2018	
40.	11390	First Draw	Bubbler	Room 603	<1	08/27/2018	
41.	11391	First Draw	Tap	Room 603	1	08/27/2018	
42.	11392	First Draw	Tap	Room 604	2	08/27/2018	
43.	11393	First Draw	Bubbler	Room 604	<1	08/27/2018	
44.	11395	First Draw	Bubbler	Room 605	2	08/27/2018	
45.	11396	First Draw	Tap	Room 605	1	08/27/2018	
46.	11397	First Draw	Bubbler	Room 606	1	08/27/2018	
47.	11398	First Draw	Tap	Room 606	3	08/27/2018	
48.	11399	Blank		Room 606	<1	08/27/2018	03444
49.	11400	First Draw	Tap	K Street Head Start Building	<1	08/27/2018	Kitchen Tap