



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Washington Elementary

School Code: 2326

School District Name: Auburn

Address: 20 E St NE, Auburn WA 98002

County: King

Number of Samples Collected: 53

Date Collected: 06/12/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	10849	First Draw	Tap	Kitchen Middle Island	2	07/26/2018	6:20 AM, No aerator
2.	10850	First Draw	Pot Filler	Kitchen Middle	269	07/26/2018	
3.	10851	First Draw	Bubbler	Room 200	<1	07/26/2018	
4.	10852	First Draw	Tap	Room 200	<1	07/26/2018	
5.	10853	First Draw	Bubbler	Room 202	<1	07/26/2018	
6.	10854	First Draw	Tap	Room 202	<1	07/26/2018	
7.	10855	First Draw	Bubbler	Room 206	<1	07/26/2018	
8.	10856	First Draw	Tap	Room 206	<1	07/26/2018	
9.	10857	First Draw	Bubbler	Room 207	<1	07/26/2018	
10.	10858	First Draw	Tap	Room 207	<1	07/26/2018	
11.	10859	First Draw	Bubbler	Room 205	<1	07/26/2018	
12.	10860	First Draw	Tap	Room 205	<1	07/26/2018	
13.	10861	First Draw	Bubbler	Room 201	<1	07/26/2018	
14.	10862	First Draw	Tap	Room 201	<1	07/26/2018	
15.	10863	First Draw	Bubbler	500 gym	<1	07/26/2018	
16.	10864	First Draw	Bubbler	Room 501	2	07/26/2018	
17.	10865	First Draw	Tap	Room 501	15	07/26/2018	
18.	10866	First Draw		Storage Water	<1	07/26/2018	
19.	10867	First Draw	Tap	Room 102 nurses	<1	07/26/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
20.	10868	First Draw	Bubbler	Room 109	<1	07/26/2018	
21.	10869	First Draw	Tap	Room 109	<1	07/26/2018	
22.	10870	First Draw	Bubbler	Room 110	<1	07/26/2018	
23.	10871	First Draw	Tap	Room 110	<1	07/26/2018	
24.	10872	First Draw	Bubbler	By Room 111	<1	07/26/2018	Left side
25.	10873	First Draw	Bubbler	By Room 111	<1	07/26/2018	Right Side
26.	10874	First Draw	Bottle Filler	By Room 111	<1	07/26/2018	Right Side
27.	10875	First Draw	Bubbler	Room 402	1	07/26/2018	
28.	10876	First Draw	Tap	Room 402	1	07/26/2018	
29.	10877	First Draw	Bubbler	Room 403	<1	07/26/2018	
30.	10878	First Draw	Tap	Room 403	<1	07/26/2018	
31.	10879	First Draw	Bubbler	Room 409	<1	07/26/2018	
32.	10880	First Draw	Tap	Room 409	<1	07/26/2018	
33.	10881	First Draw	Bubbler	Room 408	<1	07/26/2018	
34.	10882	First Draw	Tap	Room 408	1	07/26/2018	
35.	10883	First Draw	Bubbler	Room 407	<1	07/26/2018	
36.	10884	First Draw	Tap	Room 407	<1	07/26/2018	
37.	10885	First Draw	Bubbler	Room 401	<1	07/26/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
38.	10886	First Draw	Tap	Room 401	<1	07/26/2018	
39.	10887	First Draw	Bubbler	Room 303	<1	07/26/2018	
40.	10888	First Draw	Tap	Room 303	<1	07/26/2018	
41.	10889	First Draw	Bubbler	Room 308	<1	07/26/2018	
42.	10890	First Draw	Tap	Room 308	<1	07/26/2018	
43.	10891	First Draw	Bubbler	Room 309	<1	07/26/2018	
44.	10892	First Draw	Tap	Room 309	<1	07/26/2018	
45.	10893	First Draw	Bubbler	Room 310	<1	07/26/2018	
46.	10894	First Draw	Tap	Room 310	1	07/26/2018	No aerator
47.	10895	First Draw	Bubbler	Room 304	<1	07/26/2018	
48.	10896	First Draw	Tap	Room 304	<1	07/26/2018	No aerator
49.	10897	First Draw	Bubbler	Room 302	<1	07/26/2018	
50.	10898	First Draw	Tap	Room 302	<1	07/26/2018	
51.	10899	Blank		Near Room 111	<1	07/26/2018	05807
52.	10900	First Draw	Tap	Staff Lounge	<1	07/26/2018	
53.	10901	First Draw	Tap	Custodian sink	<1	07/26/2018	Drinks from tap

