

West Auburn High School Water Quality Action Plan

School Information

School Name(s): West Auburn High School

School District: Auburn School District

County: King County

Sampling and Testing Information

School Name	Sampling Date	Date Test Results Received	Sampling and Testing Provider
West Auburn Senior High School	9/19/2025	11/1/2025	☒ DOH (for sampling and testing) ☐ Other: [Click here to enter sampling and testing provider name(s)]

Testing Requirements

[RCW 28A.210.410](#) and [RCW 43.70.830](#) require all drinking water outlets in public schools built, or with all plumbing replaced, before 2016 be tested for lead at least once between July 1, 2014, and June 30, 2026. Retesting shall occur at least once every five years thereafter. Drinking water sampling and testing must be done in partnership with DOH or contracted through an [accredited lab](#).

Action Plan Requirements

If test results reveal elevated lead levels above 5 parts per billion (ppb) at any outlet used for drinking or cooking, an action plan must be developed. If your school has an existing action plan, you have the option of updating the existing plan to meet the following requirements instead of creating a new one.

Per [RCW 28A.210.410](#), a school's action plan must meet the following requirements:

- The action plan shall be developed in consultation with DOH or your local health jurisdiction and in accordance with [DOH's technical guidance](#).

- Consult with the Office of the Superintendent of Public Instruction (OSPI) when seeking funding for remediation activities. The OSPI [Lead in Water Remediation Grant](#) is a potential source of funding.
- Before the action plan is officially adopted, it must be shared publicly with opportunity for public comment.
- For testing that occurred after July 25, 2021, the deadline for adopting the action plan is six months after receiving elevated lead test results.
- The action plan must include:
 - 1) **Mitigation measures** implemented since receiving elevated lead test results.
 - 2) A schedule of **remediation activities** that adhere to the [technical guidance](#). The schedule may be based on the availability of state or federal funding for remediation activities.
 - 3) A plan for **post-remediation sampling and testing** to confirm remediation activities have reduced lead concentrations at drinking water outlets to 5 or fewer ppb

Action Plan

Mitigation Measures

Mitigation measures are immediate (temporary or permanent) actions, such as shutting off an outlet or marking as “hand wash only,” to stop access to drinking water with elevated lead concentrations. Outlets with lead concentrations exceeding 15 ppb must be shut off immediately upon receiving test results in accordance with the [technical guidance](#).

The DOH has identified 13 drinking water outlets with elevated lead levels requiring mitigation at West Auburn Senior High.

Mitigation measures have been implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure (Indicate temporary or permanent)	Date Implemented
1)	9/19/2025	410536	West Auburn Senior High School	Sink in classroom 502	20	Replacement of Faucet, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
2)	9/19/25	410522	West Auburn Senior High School	Sink - multi-compartment in room 112	10	Replacement of Faucet, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
3)	9/19/2025	410719	West Auburn Senior High School	Fountain/Tap Combo room 405	10	Replacement of Bubbler, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
4)	9/19/2025	410714	West Auburn Senior High School	Fountain/Tap Combo room 401	9	Replacement of Bubbler, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
5)	9/19/2025	410712	West Auburn Senior High School	Kitchen Sink	8	Replacement of Faucet, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026

6)	9/19/2025	410523	West Auburn Senior High School	Sink - Multi-compartment room 112	7	Replacement of Faucet, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
7)	9/19/2025	410526	West Auburn Senior High School	Fountain/Tap Combo room 201	7	Replacement of Bubbler, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
8)	9/19/2025	410527	West Auburn Senior High School Main	Fountain/Tap Combo room 202	7	Replacement of Bubbler, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
9)	9/19/2025	410537	West Auburn Senior High School Main	Fountain/Tap Combo room 206	7	Replacement of Bubbler, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
10)	9/19/2025	410534	West Auburn Senior High School	Fountain/Tap Combo Room 205	6	Replacement of Bubbler, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
11)	9/19/2025	410713	West Auburn Senior High School	Fountain/Tap Combo Room 401	6	Replacement of Bubbler, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
12)	9/19/2025	410716	West Auburn Senior High School	Fountain/Tap Combo Room 404	6	Replacement of Bubbler, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026
13)	9/19/2025	410717	West Auburn Senior High School	Fountain/Tap Combo Room 404	6	Replacement of Bubbler, hoses, angle stops, and Brass tee. ☐ temporary ☒ permanent	2/20/2026

Remediation Schedule

Remediation activities are short-term or permanent control measures to reduce lead concentrations in drinking water to 5 ppb or less. Per RCW 28A.210.410, outlets that have elevated lead levels (above 5 ppb) must be identified, remediated (if not permanently mitigated), and retested. Refer to the [technical guidance](#) for remediation options.

The DOH has identified 13 drinking water outlets with elevated lead levels requiring mitigation at West Auburn Senior High.

Remediation activities have been or will be implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Remediation Activity	Planned or Completed Implementation Date
1)	9/19/2025	410536	West Auburn Senior High School	Sink in classroom 502	20	Replacement of Faucet, hoses, angle stops, and Brass tee.	2/20/2026
	12/30/25	411173	West Auburn Senior High School	Sink in classroom 502	13	Hand Wash only signage posted due to not being able to meet the allowable limit	2/20/2026
2)	9/19/25	410522	West Auburn Senior High School	Sink - Multi-compartment in room 112	10	Replacement of Bubbler, hoses, angle stops, and Brass tee.	2/20/2026
3)	9/19/2025	410719	West Auburn Senior High School	Fountain/Tap Combo room 405	10	Replacement of Faucet	2/20/2026
	12/30/25		West Auburn Senior High School Main	Fountain/Tap Combo room 405	10	Replacement of hoses, angle stops, and Brass tee.	2/20/2026

4)	9/19/2025	410714	West Auburn Senior High School	Fountain/Tap Combo room 401	9	Replacement of Faucet, hoses, angle stops, and Brass tee.	2/20/2026
5)	9/19/2025	410712	West Auburn Senior High School	Kitchen Sink	8	Replacement of Faucet, hoses, angle stops, and Brass tee.	2/20/2026
6)	9/19/2025	410523	West Auburn Senior High School	Sink - Multi-compartment room 112	7	Replacement of Faucet, hoses, angle stops, and Brass tee.	2/20/2026
7)	9/19/2025	410526	West Auburn Senior High School	Fountain/Tap Combo room 201	7	Replacement of Faucet, hoses, angle stops, and Brass tee.	2/20/2026
8)	9/19/2025	410527	West Auburn Senior High School Main	Fountain/Tap Combo room 202	7	Replacement of Faucet, hoses, angle stops, and Brass tee.	2/20/2026
	12/30/25	411176	West Auburn Senior High School Main	Fountain/Tap Combo room 202	6	Replacement of hoses, angle stops, and Brass tee.	2/20/2026
9)	9/19/2025	410537	West Auburn Senior High School Main	Fountain/Tap Combo room 206	7	Replacement of Faucet	2/20/2026
	12/30/25	411174	West Auburn Senior High School Main	Fountain/Tap Combo room 206	6	Replacement of hoses, angle stops, and Brass tee.	02/26/2026
10)	9/19/2025	410534	West Auburn Senior High School	Fountain/Tap Combo Room 205	6	Replacement of Faucet	2/20/2026

	12/30/25	411175	West Auburn Senior High School Main	Fountain/Tap Combo Room 205	12	Replacement of hoses, angle stops, and Brass tee.	2/20/2026
11)	9/19/2025	410713	West Auburn Senior High School	Fountain/Tap Combo Room 401	6	Replacement of Faucet, hoses, angle stops, and Brass tee.	2/20/2026
12)	9/19/2025	410716	West Auburn Senior High School	Fountain/Tap Combo Room 404	6	Replacement of Faucet, hoses, angle stops, and Brass tee.	2/20/2026
13)	9/19/2025	410717	West Auburn Senior High School	Fountain/Tap Combo Room 404	6	Replacement of Faucet, hoses, angle stops, and Brass tee.	2/20/2026

Communication Plan

The Auburn School District Maintenance and operations department will communicate information about the plan for remedial action to reduce lead concentrations in drinking water through the district's webpage. This information will be communicated annually until post-remediation retesting does not detect an elevated lead level (above 5 ppb) at any drinking water outlet.

Contact Information

The following person(s) is the main point of contact for more information related to this action plan.

Name: Brian Humphreys

Role: Director of Maintenance and Operations

Email: bhumphreys@auburn.wednet.edu

Phone: 253-931-4955

Preferred contact method: ☒ Email ☒ Phone