

Outlets Exceeding the Lead Action Level

Laborator y ID	Outlet location	Outlet Type	Lead Level (ppb)1st round test 12/6/25	Imediate action plan notes	Remedial plan notes	outlet replacement	taken out of service	Filter installed and replaced	signage	supervision	continuing education	Flushing	Engineering controls	Retest preformed July 31, 2026	post remediation Lead Level (ppb)	Retest preformed 9/1/2026	post remediation Lead Level (ppb)	taken out of service until further notice	put back in service	Maintenance and Monitoring of back in service outlets
PQ elementary School																				
PQ ES-008	Beginning of north wing to the left Hall to exterior	Water Fountain		This Fountain has been out of service for many years, after clearance from DOH for PFOA's we tested our water fountains before clearing for online service. This fountain came back elevated	We replaced old style fountain that was in place with filtered bottle fill station immediately. Retested and are waiting for results in order to put in service.	☒	☒	☒	☐	☐	☒	☐	☐	☒	17.6		☒	☐	☒	Retested with new bottle fill station and filter. Cleared for service
PQ ES-019	Back of C-34 Multi-Purpose room	Classroom Sink	12.8	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner.	This will be removed during Phase 2 of capital projects	☐	☐	☐	☒	☐	☐	☐	☐	☐			☐	☐	☐	
PQ ES-021	C-34A Service room inside of Multi-purpose room deep bay sink	Kitchen Sink	39.3	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☒	☐			☐	☐	☐	
PQ ES-032	B-9 Spec Ed. Bathroom on left at the beginning of south wing hall	Restroom Sink	50	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner. I talked with teacher and confirmed this is still being followed.	Faucet has been replaced in the past, we will replace older water stop supply valve that may contain lead solder	☒	☐	☐	☒	☒	☐	☐	☐	☐			☐	☐	☐	
PQ ES-033	B-8 Boys Bathroom on right at the beginning of south wing hall	Restroom Sink	5.8	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐			☐	☐	☐	
PQ ES-056	S-26	Classroom Sink	5.2	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner. I talked with teacher and confirmed this is still being followed.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐			☐	☐	☐	
PQ ES-057	S-25	Classroom Sink	5.4	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner. I talked with teacher and confirmed this is still being followed.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐			☐	☐	☐	
PQ ES-059	C-21 Double bay sink inside service area	Kitchen Sink	5.4	Signage for "handwashing only Do Not Drink" is in place and currently this sink is not being used for washing produce and cooking, but it will be needed in the future. I spoke with Kitchen staff about restrictions in which they were already aware.	Faucet, and plumbing up to lead filter will be replaced with lead free components and we will retest before being used for cooking.	☒	☐	☒	☒	☒	☒	☐	☐	☒			☐	☐	☒	Plumbing leading to the sink and the faucet were replaced as well as a lead filter was replaced. Retest shows less than .5 PPB which is below the lead level and cleared for service.
PQ ES-067	Gym Lobby boys bathroom (left sink)	Restroom Sink	7.4	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐			☐	☐	☐	
PQ ES-071	Gym lobby girls bathroom (left sink)	Restroom Sink	21.2	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐			☐	☐	☐	
PQ ES-072	Gym lobby girls bathroom (right sink)	Restroom Sink	25.9	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐			☐	☐	☐	
North Salem high school / middle school																				
HS/MS-026	C-67 Main office (Kitchenette)	Office sink	6.3	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐			☐	☐	☐	

HS/MS-029	C-64 Nurse's back exam room	Nurse's office	13.9	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner. I talked with nurses to confirm the water was not being consumed.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐		☐		☐	☐	
HS/MS-170	W-21 Science Lab Prep room/Green house room (Non Supervised)	Classroom Sink	14.8	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐		☐		☐	☐	
HS/MS-246	C-54 Kitchen MS cafe side (from kitchen) 1st on Right (handwashing sink)	Kitchen sink	11.9	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner. I talked with Kitchen staff to confirm they are aware of faucet restrictions.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐		☐		☐	☐	
HS/MS-252	C-54 Kitchen (small sink in island) Handwashing	Kitchen sink	9.7	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner. I talked with Kitchen staff to confirm they are aware of faucet restrictions.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐		☐		☐	☐	
HS/MS-253	C-54 Kitchen Big bay sinks (Left) Dishwashing	Kitchen sink	11.8	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner. I talked with Kitchen staff to confirm they are aware of faucet restrictions.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐		☐		☐	☐	
HS/MS-254	C-54 Kitchen Big bay sinks (Middle) Dishwashing	Kitchen sink	8.8	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner. I talked with Kitchen staff to confirm they are aware of faucet restrictions.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐		☐		☐	☐	
HS/MS-265	C-54 Kitchen MS cafe side (Handwashing sink) From kitchen 1st on the Left	Kitchen sink	7	This sink has already been labeled for "handwashing only Not for drinking use"and continues to be used in that manner. I talked with Kitchen staff to confirm they are aware of faucet restrictions.	Signage maintained and continued education about restrictions on faucet	☐	☐	☐	☒	☒	☒	☐	☐	☐		☐		☐	☐	