



September 27, 2026

Gary Bowers
Sullivan BOCES
15 Sullivan Ave
Liberty, NY 12754

RE: Project: Reuben Pollack Education Ctr.
Pace Project No.: 70450313

Dear Gary Bowers:

Enclosed are the analytical results for sample(s) received by the laboratory on September 17, 2026. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Newburgh

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads "Felicia Morgan-Nichols".

Felicia Morgan-Nichols
felicia.morgan-nichols@pacelabs.com
(845) 562-0890
Project Manager

Enclosures

cc:



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Table of Contents

Sections:

-2-

Section 1: Cert Page	3
Section 2: Results	4
Section 3: Quality Control	15
Section 4: Qualifiers	20
Section 5: QC Cross Reference	21
Section 6: Chain of Custody	23
6.1: Chain of Custody	23

1

2

3

4

5

6



CERTIFICATIONS

Project: Reuben Pollack Education Ctr.
Pace Project No.: 70450313

Pace Analytical Services, LLC- Newburgh, NY
315 Fullerton Avenue, Newburgh, NY 12550
New Jersey Certification #: NY015

New York Certification #: 10142 Primary Accrediting Body
Connecticut Certification #: PH-0823

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M1		Lab ID: 70450313001		Collected: 09/17/26 06:45	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 18:00	7439-92-1	
Sample: M2		Lab ID: 70450313002		Collected: 09/17/26 06:28	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 18:15	7439-92-1	
Sample: M3		Lab ID: 70450313003		Collected: 09/17/26 05:17	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS, DW Digestion		Analytical Method: EPA 200.8, Rev. 5.4 Preparation Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	11.5	ug/L	1.0	1	09/23/26 10:17	09/24/26 18:39	7439-92-1	
Sample: M4		Lab ID: 70450313004		Collected: 09/17/26 05:18	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS, DW Digestion		Analytical Method: EPA 200.8, Rev. 5.4 Preparation Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	4.8	ug/L	1.0	1	09/23/26 10:17	09/24/26 19:07	7439-92-1	
Sample: M5		Lab ID: 70450313005		Collected: 09/17/26 05:19	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 18:26	7439-92-1	
Sample: M6		Lab ID: 70450313006		Collected: 09/17/26 05:21	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 18:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M7		Lab ID: 70450313007		Collected: 09/17/26 05:22	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 18:33	7439-92-1	
Sample: M8		Lab ID: 70450313008		Collected: 09/17/26 06:11	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	1.2	ug/L	1.0	1		09/21/26 18:37	7439-92-1	
Sample: M9		Lab ID: 70450313009		Collected: 09/17/26 06:13	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 18:40	7439-92-1	
Sample: M10		Lab ID: 70450313010		Collected: 09/17/26 06:15	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 18:44	7439-92-1	
Sample: M11		Lab ID: 70450313011		Collected: 09/17/26 06:17	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 18:48	7439-92-1	
Sample: M12		Lab ID: 70450313012		Collected: 09/17/26 06:18	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 18:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M13		Lab ID: 70450313013		Collected: 09/17/26 06:20	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 18:55	7439-92-1	
Sample: M14		Lab ID: 70450313014		Collected: 09/17/26 06:21	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 19:10	7439-92-1	
Sample: M15		Lab ID: 70450313015		Collected: 09/17/26 06:22	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 19:14	7439-92-1	
Sample: M16		Lab ID: 70450313016		Collected: 09/17/26 06:24	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 19:18	7439-92-1	
Sample: M17		Lab ID: 70450313017		Collected: 09/17/26 06:25	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 19:21	7439-92-1	
Sample: M18		Lab ID: 70450313018		Collected: 09/17/26 05:41	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 19:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M19		Lab ID: 70450313019		Collected: 09/17/26 05:42	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 19:29	7439-92-1	
Sample: M22		Lab ID: 70450313020		Collected: 09/17/26 05:44	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 19:32	7439-92-1	
Sample: M23		Lab ID: 70450313021		Collected: 09/17/26 05:45	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 19:36	7439-92-1	
Sample: M24		Lab ID: 70450313022		Collected: 09/17/26 05:46	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 19:40	7439-92-1	
Sample: M25		Lab ID: 70450313023		Collected: 09/17/26 05:47	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 19:58	7439-92-1	
Sample: M26		Lab ID: 70450313024		Collected: 09/17/26 05:48	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 20:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M27		Lab ID: 70450313025		Collected: 09/17/26 05:50	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 20:17	7439-92-1	
Sample: M28		Lab ID: 70450313026		Collected: 09/17/26 05:51	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 20:20	7439-92-1	
Sample: M29		Lab ID: 70450313027		Collected: 09/17/26 05:52	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 20:24	7439-92-1	
Sample: M30		Lab ID: 70450313028		Collected: 09/17/26 05:53	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 20:28	7439-92-1	
Sample: M31		Lab ID: 70450313029		Collected: 09/17/26 05:54	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 20:39	7439-92-1	
Sample: M32		Lab ID: 70450313030		Collected: 09/17/26 05:55	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 20:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M33		Lab ID: 70450313031		Collected: 09/17/26 05:56	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS, DW Digestion		Analytical Method: EPA 200.8, Rev. 5.4 Preparation Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1	09/23/26 10:17	09/24/26 19:14	7439-92-1	
Sample: M34		Lab ID: 70450313032		Collected: 09/17/26 05:57	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 20:46	7439-92-1	
Sample: M35		Lab ID: 70450313033		Collected: 09/17/26 05:58	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 20:50	7439-92-1	
Sample: M36		Lab ID: 70450313034		Collected: 09/17/26 05:59	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 20:54	7439-92-1	
Sample: M37		Lab ID: 70450313035		Collected: 09/17/26 06:00	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 21:01	7439-92-1	
Sample: M38		Lab ID: 70450313036		Collected: 09/17/26 05:38	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 21:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M39		Lab ID: 70450313037		Collected: 09/17/26 05:39	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 21:09	7439-92-1	
Sample: M40		Lab ID: 70450313038		Collected: 09/17/26 05:28	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 21:12	7439-92-1	
Sample: M41		Lab ID: 70450313039		Collected: 09/17/26 05:29	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 21:23	7439-92-1	
Sample: M42		Lab ID: 70450313040		Collected: 09/17/26 05:30	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 21:27	7439-92-1	
Sample: M43		Lab ID: 70450313041		Collected: 09/17/26 05:31	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 21:31	7439-92-1	
Sample: M44		Lab ID: 70450313042		Collected: 09/17/26 05:32	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 21:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M46		Lab ID: 70450313043		Collected: 09/17/26 05:27	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	1.6	ug/L	1.0	1		09/21/26 21:38	7439-92-1	
Sample: M50		Lab ID: 70450313044		Collected: 09/17/26 06:37	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 21:49	7439-92-1	
Sample: M51		Lab ID: 70450313045		Collected: 09/17/26 06:36	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 22:11	7439-92-1	
Sample: M52		Lab ID: 70450313046		Collected: 09/17/26 06:35	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 22:15	7439-92-1	
Sample: M53		Lab ID: 70450313047		Collected: 09/17/26 05:25	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/23/26 16:48	7439-92-1	
Sample: M54		Lab ID: 70450313048		Collected: 09/17/26 05:32	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 22:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M55		Lab ID: 70450313049		Collected: 09/17/26 06:09	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/23/26 16:55	7439-92-1	
Sample: M56		Lab ID: 70450313050		Collected: 09/17/26 06:09	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 22:30	7439-92-1	
Sample: M57		Lab ID: 70450313051		Collected: 09/17/26 05:53	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 22:34	7439-92-1	
Sample: M59		Lab ID: 70450313052		Collected: 09/17/26 06:06	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 22:37	7439-92-1	
Sample: M60		Lab ID: 70450313053		Collected: 09/17/26 06:06	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 22:41	7439-92-1	
Sample: M61		Lab ID: 70450313054		Collected: 09/17/26 05:26	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 22:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M64		Lab ID: 70450313055		Collected: 09/17/26 06:33	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 22:59	7439-92-1	
Sample: M65		Lab ID: 70450313056		Collected: 09/17/26 06:33	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/23/26 17:01	7439-92-1	
Sample: M66		Lab ID: 70450313057		Collected: 09/17/26 06:39	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 23:07	7439-92-1	
Sample: M67		Lab ID: 70450313058		Collected: 09/17/26 06:39	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 23:10	7439-92-1	
Sample: M68		Lab ID: 70450313059		Collected: 09/17/26 06:40	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 23:14	7439-92-1	
Sample: M69		Lab ID: 70450313060		Collected: 09/17/26 06:40	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/21/26 23:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



ANALYTICAL RESULTS

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Sample: M70		Lab ID: 70450313061		Collected: 09/17/26 06:43	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/22/26 00:09	7439-92-1	
Sample: M71		Lab ID: 70450313062		Collected: 09/17/26 06:43	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/22/26 00:21	7439-92-1	
Sample: M72		Lab ID: 70450313063		Collected: 09/17/26 06:32	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/22/26 00:24	7439-92-1	
Sample: M73		Lab ID: 70450313064		Collected: 09/17/26 06:31	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/22/26 00:28	7439-92-1	
Sample: M74		Lab ID: 70450313065		Collected: 09/17/26 06:31	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/22/26 00:35	7439-92-1	
Sample: M75		Lab ID: 70450313066		Collected: 09/17/26 06:30	Received: 09/17/26 10:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		09/22/26 00:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



QUALITY CONTROL DATA

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

QC Batch 475672

QC Batch Method: EPA 200.8, Rev. 5.4

Analysis Method: EPA 200.8, Rev. 5.4

Analysis Description: NB 200.8 ICPMS, DW Digestion

Laboratory: Pace Analytical Services - Newburgh

Associated Lab Samples: 70450313003, 70450313004, 70450313031

METHOD BLANK: 2563928

Matrix: Drinking Water

Associated Lab Samples: 70450313003, 70450313004, 70450313031

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	09/24/26 18:25	

LABORATORY CONTROL SAMPLE: 2563929

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.4	103	85-115	

MATRIX SPIKE SAMPLE: 2563931

Parameter	Units	70450313003 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	11.5	50	63.6	104	70-130	

SAMPLE DUPLICATE: 2563930

Parameter	Units	70450313003 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	11.5	11.4	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



QUALITY CONTROL DATA

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

QC Batch 475076

Analysis Method: EPA 200.8, Rev. 5.4

QC Batch Method: EPA 200.8, Rev. 5.4

Analysis Description: NB 200.8 ICPMS DW No Prep

Laboratory: Pace Analytical Services - Newburgh

Associated Lab Samples: 70450313001, 70450313002, 70450313005, 70450313006, 70450313007, 70450313008, 70450313009, 70450313010, 70450313011, 70450313012, 70450313013, 70450313014, 70450313015, 70450313016, 70450313017, 70450313018, 70450313019, 70450313020, 70450313021, 70450313022

METHOD BLANK: 2561088

Matrix: Water

Associated Lab Samples: 70450313001, 70450313002, 70450313005, 70450313006, 70450313007, 70450313008, 70450313009, 70450313010, 70450313011, 70450313012, 70450313013, 70450313014, 70450313015, 70450313016, 70450313017, 70450313018, 70450313019, 70450313020, 70450313021, 70450313022

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	09/21/26 17:52	

LABORATORY CONTROL SAMPLE: 2561089

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.7	101	85-115	

MATRIX SPIKE SAMPLE: 2561091

Parameter	Units	70450313001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	56.5	113	70-130	

MATRIX SPIKE SAMPLE: 2561093

Parameter	Units	70450313013 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	59.9	119	70-130	

SAMPLE DUPLICATE: 2561090

Parameter	Units	70450313001 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



QUALITY CONTROL DATA

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

QC Batch 475079

Analysis Method: EPA 200.8, Rev. 5.4

QC Batch Method: EPA 200.8, Rev. 5.4

Analysis Description: NB 200.8 ICPMS DW No Prep

Laboratory: Pace Analytical Services - Newburgh

Associated Lab Samples: 70450313023, 70450313024, 70450313025, 70450313026, 70450313027, 70450313028, 70450313029, 70450313030, 70450313032, 70450313033, 70450313034, 70450313035, 70450313036, 70450313037, 70450313038, 70450313039, 70450313040, 70450313041, 70450313042, 70450313043

METHOD BLANK: 2561101

Matrix: Water

Associated Lab Samples: 70450313023, 70450313024, 70450313025, 70450313026, 70450313027, 70450313028, 70450313029, 70450313030, 70450313032, 70450313033, 70450313034, 70450313035, 70450313036, 70450313037, 70450313038, 70450313039, 70450313040, 70450313041, 70450313042, 70450313043

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	09/21/26 19:43	

LABORATORY CONTROL SAMPLE: 2561102

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.5	103	85-115	

MATRIX SPIKE SAMPLE: 2561104

Parameter	Units	70450313023 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	65.8	130	70-130	

MATRIX SPIKE SAMPLE: 2561106

Parameter	Units	70450313034 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	59.2	118	70-130	

SAMPLE DUPLICATE: 2561103

Parameter	Units	70450313023 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



QUALITY CONTROL DATA

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

QC Batch 475084

QC Batch Method: EPA 200.8, Rev. 5.4

Analysis Method: EPA 200.8, Rev. 5.4

Analysis Description: NB 200.8 ICPMS DW No Prep

Laboratory: Pace Analytical Services - Newburgh

Associated Lab Samples: 70450313044, 70450313045, 70450313046, 70450313047, 70450313048, 70450313049, 70450313050, 70450313051, 70450313052, 70450313053, 70450313054, 70450313055, 70450313056, 70450313057, 70450313058, 70450313059, 70450313060

METHOD BLANK: 2561118

Matrix: Water

Associated Lab Samples: 70450313044, 70450313045, 70450313046, 70450313047, 70450313048, 70450313049, 70450313050, 70450313051, 70450313052, 70450313053, 70450313054, 70450313055, 70450313056, 70450313057, 70450313058, 70450313059, 70450313060

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	09/21/26 21:42	

LABORATORY CONTROL SAMPLE: 2561119

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.6	103	85-115	

MATRIX SPIKE SAMPLE: 2561121

Parameter	Units	70450313044 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	44.7	89	70-130	

MATRIX SPIKE SAMPLE: 2561123

Parameter	Units	70450313054 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	57.3	115	70-130	

SAMPLE DUPLICATE: 2561120

Parameter	Units	70450313044 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



QUALITY CONTROL DATA

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

QC Batch 475354

QC Batch Method: EPA 200.8, Rev. 5.4

Analysis Method: EPA 200.8, Rev. 5.4

Analysis Description: NB 200.8 ICPMS DW No Prep

Laboratory: Pace Analytical Services - Newburgh

Associated Lab Samples: 70450313061, 70450313062, 70450313063, 70450313064, 70450313065, 70450313066

METHOD BLANK: 2562337

Matrix: Water

Associated Lab Samples: 70450313061, 70450313062, 70450313063, 70450313064, 70450313065, 70450313066

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	09/21/26 23:21	

LABORATORY CONTROL SAMPLE: 2562338

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.7	101	85-115	

MATRIX SPIKE SAMPLE: 2562340

Parameter	Units	70446666001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.3	50	53.6	101	70-130	

MATRIX SPIKE SAMPLE: 2562342

Parameter	Units	70450313064 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	49.1	98	70-130	

SAMPLE DUPLICATE: 2562339

Parameter	Units	70446666001 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	3.3	3.4	0	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



QUALIFIERS

Project: Reuben Pollack Education Ctr.
Pace Project No.: 70450313

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70450313003	M3	EPA 200.8, Rev. 5.4	475672	EPA 200.8, Rev. 5.4	475986
70450313004	M4	EPA 200.8, Rev. 5.4	475672	EPA 200.8, Rev. 5.4	475986
70450313031	M33	EPA 200.8, Rev. 5.4	475672	EPA 200.8, Rev. 5.4	475986
70450313001	M1	EPA 200.8, Rev. 5.4	475076		
70450313002	M2	EPA 200.8, Rev. 5.4	475076		
70450313005	M5	EPA 200.8, Rev. 5.4	475076		
70450313006	M6	EPA 200.8, Rev. 5.4	475076		
70450313007	M7	EPA 200.8, Rev. 5.4	475076		
70450313008	M8	EPA 200.8, Rev. 5.4	475076		
70450313009	M9	EPA 200.8, Rev. 5.4	475076		
70450313010	M10	EPA 200.8, Rev. 5.4	475076		
70450313011	M11	EPA 200.8, Rev. 5.4	475076		
70450313012	M12	EPA 200.8, Rev. 5.4	475076		
70450313013	M13	EPA 200.8, Rev. 5.4	475076		
70450313014	M14	EPA 200.8, Rev. 5.4	475076		
70450313015	M15	EPA 200.8, Rev. 5.4	475076		
70450313016	M16	EPA 200.8, Rev. 5.4	475076		
70450313017	M17	EPA 200.8, Rev. 5.4	475076		
70450313018	M18	EPA 200.8, Rev. 5.4	475076		
70450313019	M19	EPA 200.8, Rev. 5.4	475076		
70450313020	M22	EPA 200.8, Rev. 5.4	475076		
70450313021	M23	EPA 200.8, Rev. 5.4	475076		
70450313022	M24	EPA 200.8, Rev. 5.4	475076		
70450313023	M25	EPA 200.8, Rev. 5.4	475079		
70450313024	M26	EPA 200.8, Rev. 5.4	475079		
70450313025	M27	EPA 200.8, Rev. 5.4	475079		
70450313026	M28	EPA 200.8, Rev. 5.4	475079		
70450313027	M29	EPA 200.8, Rev. 5.4	475079		
70450313028	M30	EPA 200.8, Rev. 5.4	475079		
70450313029	M31	EPA 200.8, Rev. 5.4	475079		
70450313030	M32	EPA 200.8, Rev. 5.4	475079		
70450313032	M34	EPA 200.8, Rev. 5.4	475079		
70450313033	M35	EPA 200.8, Rev. 5.4	475079		
70450313034	M36	EPA 200.8, Rev. 5.4	475079		
70450313035	M37	EPA 200.8, Rev. 5.4	475079		
70450313036	M38	EPA 200.8, Rev. 5.4	475079		
70450313037	M39	EPA 200.8, Rev. 5.4	475079		
70450313038	M40	EPA 200.8, Rev. 5.4	475079		
70450313039	M41	EPA 200.8, Rev. 5.4	475079		
70450313040	M42	EPA 200.8, Rev. 5.4	475079		
70450313041	M43	EPA 200.8, Rev. 5.4	475079		
70450313042	M44	EPA 200.8, Rev. 5.4	475079		
70450313043	M46	EPA 200.8, Rev. 5.4	475079		
70450313044	M50	EPA 200.8, Rev. 5.4	475084		
70450313045	M51	EPA 200.8, Rev. 5.4	475084		
70450313046	M52	EPA 200.8, Rev. 5.4	475084		
70450313047	M53	EPA 200.8, Rev. 5.4	475084		
70450313048	M54	EPA 200.8, Rev. 5.4	475084		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Reuben Pollack Education Ctr.

Pace Project No.: 70450313

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70450313049	M55	EPA 200.8, Rev. 5.4	475084		
70450313050	M56	EPA 200.8, Rev. 5.4	475084		
70450313051	M57	EPA 200.8, Rev. 5.4	475084		
70450313052	M59	EPA 200.8, Rev. 5.4	475084		
70450313053	M60	EPA 200.8, Rev. 5.4	475084		
70450313054	M61	EPA 200.8, Rev. 5.4	475084		
70450313055	M64	EPA 200.8, Rev. 5.4	475084		
70450313056	M65	EPA 200.8, Rev. 5.4	475084		
70450313057	M66	EPA 200.8, Rev. 5.4	475084		
70450313058	M67	EPA 200.8, Rev. 5.4	475084		
70450313059	M68	EPA 200.8, Rev. 5.4	475084		
70450313060	M69	EPA 200.8, Rev. 5.4	475084		
70450313061	M70	EPA 200.8, Rev. 5.4	475354		
70450313062	M71	EPA 200.8, Rev. 5.4	475354		
70450313063	M72	EPA 200.8, Rev. 5.4	475354		
70450313064	M73	EPA 200.8, Rev. 5.4	475354		
70450313065	M74	EPA 200.8, Rev. 5.4	475354		
70450313066	M75	EPA 200.8, Rev. 5.4	475354		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/27/2026 05:34 PM

ENV-FRM-CORQ-0019 v01 082123 ©

Sullivan County BOCES Lead in Water Chain of Custody Format
RPEC Main Campus 9/17/26

66 water samples

Sample #	AREA	Date	Time of Sample
M1	RPEC Tin Barn Utility Sink	9/17/26	0645
M2	RPEC Tin Barn Hand Sink in Counter	9/17/26	0628
M3	RPEC Special Ed Kitchen 2 bay dishwash right	9/17/26	0517
M4	RPEC Special Ed Kitchen 2 bay dishwash left	9/17/26	0518
M5	RPEC Special Ed Kitchen 1 bay by Dawn's office left	9/17/26	0519
M6	RPEC Special Ed Kitchen 1 bay by Dawn's office right	9/17/26	0521
M7	RPEC Special Ed Kitchen island 1 bay	9/17/26	0522
M8	RPEC A7 ALC hand sink	9/17/26	0611
M9	RPEC A10 class sink	9/17/26	0613
M10	RPEC Secondary Nurse's Office hand sink	9/17/26	0615
M11	RPEC B7 class sink	9/17/26	0617
M12	RPEC B11 class sink	9/17/26	0618
M13	RPEC B12 class sink	9/17/26	0620
M14	RPEC B14 class sink	9/17/26	0621
M15	RPEC B15 class sink	9/17/26	0622
M16	RPEC B18 class sink	9/17/26	0624
M17	RPEC B20 class sink	9/17/26	0625
M18	RPEC E2 class sink	9/17/26	0541
M19	RPEC E2 bubbler fountain	9/17/26	0542
M20	RPEC E1 ALC class sink	9/17/26	NA
M21	RPEC E1 ALC bubbler fountain	9/17/26	NA
M22	RPEC E3 class sink	9/17/26	0544
M23	RPEC E3 bubbler fountain	9/17/26	0545
M24	RPEC E4 class sink	9/17/26	0546
M25	RPEC E4 bubbler fountain	9/17/26	0547
M26	RPEC E5 class sink	9/17/26	0548
M27	RPEC E5 bubbler fountain	9/17/26	0550
M28	RPEC E6 class sink	9/17/26	0551
M29	RPEC E6 bubbler fountain	9/17/26	0552
M30	RPEC E7 class sink	9/17/26	0553
M31	RPEC E7 bubbler fountain	9/17/26	0554
M32	RPEC E8 class sink	9/17/26	0555
M33	RPEC E8 bubbler fountain	9/17/26	0556
M34	RPEC E9 class sink	9/17/26	0557
M35	RPEC E9 bubbler fountain	9/17/26	0558
M36	RPEC E10 class sink	9/17/26	0559
M37	RPEC E10 bubbler fountain	9/17/26	0600
M38	RPEC Gym @ Restroom bottle fill	9/17/26	0538
M39	RPEC Gym @ Restroom bubbler fountain	9/17/26	0539
M40	RPEC Culinary Kitchen hand sink by Hallway	9/17/26	0528
M41	RPEC Culinary Kitchen pot wash sink, left	9/17/26	0529
M42	RPEC Culinary Kitchen pot wash sink, right	9/17/26	0530
M43	RPEC Culinary Kitchen, Exterior Wall, 2 bay sink w/ 1 faucet	9/17/26	0531
M44	RPEC Culinary Kitchen, Exterior Wall, hand sink	9/17/26	0532
M45	RPEC Culinary corner coffee sink by restrooms	9/17/26	NA

Updated 9/17/2026

WO#: 70450313

PM: FMN Due Date: 10/01/26
CLIENT: NB-SC.BOCES

M46	RPEC CTE Office, kitchenette sink	9/17/26	0527
M47	RPEC Cosmetology Nail Drying Room, hand sink	9/17/26	NA
M48	RPEC Cosmetology I, class sink	9/17/26	NA
M49	RPEC Cosmetology II, class sink	9/17/26	NA
M50	RPEC F Building Room F6, class sink	9/17/26	0637
M51	RPEC F Building, Room F4, class sink	9/17/26	0636
M52	RPEC F Bld Kitchen, kitchenette sink	9/17/26	0635
M53	RPEC Special Ed Kitchen. ice machine	9/17/26	0525
M54	RPEC Culinary kitchen, ice machine	9/17/26	0532
M55	RPEC Main Lobby, bottle fill	9/17/26	0609
M56	RPEC Main Lobby, bubbler fountain	9/17/26	0609
M57	RPEC E Wing Hallway, bottle fill	9/17/26	0553
M58	RPEC E Wing Hallway, bubbler fountain	9/17/26	NA
M59	RPEC Spec Ed Cafeteria, bottle fill	9/17/26	0606
M60	RPEC Spec Ed Cafeteria, bubbler fountain	9/17/26	0606
M61	RPEC C Wing Hallway, bottle fill only	9/17/26	0526
M62	RPEC D Wing Hallway @ Cosmo, bottle fill	9/17/26	NA
M63	RPEC D Wing Hallway @ Cosmo, bubbler fountain	9/17/26	NA
M64	RPEC F Building Hallway, bottle fill	9/17/26	0633
M65	RPEC F Building Hallway, bubbler fountain	9/17/26	0633
M66	RPEC G Mod Building Hallway, bubbler fountain, far right	9/17/26	0639
M67	RPEC G Mod Building Hallway, bubbler fountain, center	9/17/26	0639
M68	RPEC G Mod Building, bottle fill	9/17/26	0640
M69	RPEC G Mod Building, bubbler fountain, Left	9/17/26	0640
M70	RPEC H Building Lobby, bottle fill	9/17/26	0643
M71	RPEC H Building Lobby, bubbler fountain	9/17/26	0643
M72	RPEC F Building, Men's Restroom, bath sink	9/17/26	0632
M73	RPEC F Building, Women's Restroom, bath sink, left	9/17/26	0631
M74	RPEC F Building, Women's Restroom, bath sink, right	9/17/26	0631
M75	RPEC F Building, Hallway Staff Restroom, bath sink	9/17/26	0630

M20 – Removed

M21 – Removed

M45 – Permanently out of service

M47 – Remodeled, no water to sink

M48 – Remodeled, no water to sink

M49 – Remodeled, no water to sink

M58 – Turned off

M62 – Removed during remodel

M63 – Removed during remodel

WO# : 70450313

PM: FMN

Due Date: 10/01/26

CLIENT: NB-SC.BOCES

Updated 9/17/2026

DC#_Title: ENV-FRM-NEWB-0002 v02_Sample Condition Upon Receipt Form
Effective Date: 12/15/2025

WO#: 70450313

Client Name:

Project #

PM: FMN

Due Date: 10/01/26

CLIENT: NB-SC. BOCES

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☒ Commercial ☐ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Temperature Blank Present: ☐ Yes ☐ No

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziplog ☐ None ☐ Other

Type of Ice: Wet Blue None

Thermometer Used: IRG4

Correction Factor: 0 @ 20C

☐ Samples on ice, cooling process has begun

Cooler Temperature(°C): 20.4

Cooler Temperature Corrected(°C):

Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

Date and Initials of person examining contents:

	COMMENTS:
Chain of Custody Present: ☒ Yes ☐ No	1.
Chain of Custody Filled Out: ☒ Yes ☐ No	2.
Chain of Custody Relinquished: ☒ Yes ☐ No	3.
Sampler Name & Signature on COC: ☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time: ☐ Yes ☐ No	5.
Short Hold Time Analysis (<72hr): ☐ Yes ☒ No	6.
Rush Turn Around Time Requested: ☐ Yes ☒ No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) ☒ Yes ☐ No	8.
Correct Containers Used: ☒ Yes ☐ No	9.
-Pace Containers Used: ☒ Yes ☐ No	
Containers Intact: ☒ Yes ☐ No	10.
Filtered volume received for Dissolved tests ☐ Yes ☐ No ☒ N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: ☒ Yes ☐ No	12. <u>SAMPLES labeled "M1-M75" AR</u>
-Includes date/time ID/Analysis- Matrix: SL (WT) OIL OTHER	

Date and Initials of person checking preservation:

All containers needing preservation have been ☐ Yes ☐ No ☒ N/A	13. ☐ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
pH paper Lot #	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, ☐ Yes ☐ No ☒ N/A	
NAOH>12 Cyanide)	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).	
Per Method, VOA pH is checked after analysis	
Samples checked for dechlorination: ☐ Yes ☐ No ☒ N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added:
KI starch test strips Lot #	14.
Residual chlorine strips Lot #	Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulf ☐ Yes ☐ No ☒ N/A	15.
Lead Acetate Strips Lot #	Positive for Sulfide? Y N
Headspace in ALK Bottle (>6mm): ☐ Yes ☐ No ☒ N/A	
Headspace in Odor Bottle (>6mm): ☐ Yes ☐ No ☒ N/A	
Headspace in VOA Vials (>6mm): ☐ Yes ☐ No ☒ N/A	16.
Trip Blank Present: ☐ Yes ☐ No ☒ N/A	17.
Trip Blank Custody Seals Present ☐ Yes ☐ No ☒ N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.

Please note that highlighted samples were not received. -> SEE NOTES MADE BY CLIENT. - AR