

HARRISON TOWNSHIP SCHOOL DISTRICT



Margaret Q. Peretti, Ed.D.
Superintendent of School

Lisa Ridgway
Interim Business Administrator

Lisa Heenan
Chief Academic Officer

AnnaLisa Rodano
Harrison Elementary Principal

Lori Hynes, Ed. D
Director of Student Services

Karen Russo, Ed.D.
Pleasant Valley Principal

Chad Flexon
Harrison Elementary Supervisor of Instruction

Diane Eisenhart
Instructional Supervisor

Christine Fellona
Pleasant Valley Assistant Principal

June 11, 2025

Dear Pleasant Valley School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community, and in accordance with the Department of Education regulations at N.J.A.C. 6A:26-12.4, Epic Environmental Services, LLC tested our building's drinking water for lead.

In accordance with the Department of Education regulations, Harrison Township School District will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15.5 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Harrison Township School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 79 outlets sampled at the Pleasant Valley School, three first draw sample tested above the lead action level established by the US Environmental Protection Agency for lead in drinking water (15.5 µg/l [ppb]). Of the follow-up samples analyzed, none tested above the lead action level.

The table below identifies the drinking water outlets that tested above the 15.5 µg/l for lead with the associated first draw and follow-up flush sample lead levels, as well as what temporary remedial action Harrison Township School District has taken - or plans to take - to reduce the levels of lead at these locations.

Sample Location	First Draw Result in $\mu\text{g/l}$	Follow-up flush Result in $\mu\text{g/l}$	Remedial Action
Bubbler – Room A120 ID# PVS-DW-A120	3610	2.88	LOCATION REMOVED FROM SERVICE and sink will be hand washing only
Bubbler – Room A119 ID# PVS-DW-A119	35.4	NONE DETECTED	LOCATION REMOVED FROM SERVICE and sink will be hand washing only
Sink – Room B108 ID# PVS-SO-B108 B	37.0	4.48	Labeled as hand washing only

Summary of Actions Taken

The following actions were taken regarding the Pleasant Valley School's lead in school drinking water exceedance:

1. All drinking water outlets were immediately shut off where any first draw test result revealed lead concentrations greater than $15\mu\text{g/l}$ (ppb); in our case one bubbler location was removed.
2. Harrison Township School District changed any sink locations to be labeled as hand washing only.
3. Alternate drinking water is being provided to students and staff of the school from other existing outlets tested below lead action levels in any test

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers, and lakes. Lead enters drinking water primarily because of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes, and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning, can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at <https://www.harrisontwp.k12.nj.us/> . For more information about water quality in our schools, contact Dr. Margaret "Missy" Peretti at (856) 478-2016.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Dr. Margaret "Missy" Peretti
Superintendent of Schools

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090
LIMS Reference ID: AD22090
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Pleasant Valley Elementary School

Customer PO: NJ-DOE (25-1042C)
EMSL Sales Rep: Justin Monturano
Received: 05/22/2025 09:30
Reported: 06/10/2025 13:00

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PVS - FB Lims Reference ID: AD22090-01 Matrix: Drinking Water Sampled: 05/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 16:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - WC - GYM 2 Lims Reference ID: AD22090-02 Matrix: Drinking Water Sampled: 05/18/25 08:32:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 16:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - WC - GYM 3 Lims Reference ID: AD22090-03 Matrix: Drinking Water Sampled: 05/18/25 08:33:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 16:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - WC - GYM 4 Lims Reference ID: AD22090-04 Matrix: Drinking Water Sampled: 05/18/25 08:33:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 16:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - WC - HALL 1A Lims Reference ID: AD22090-05 Matrix: Drinking Water Sampled: 05/18/25 08:34:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 16:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - WC - HALL 1B Lims Reference ID: AD22090-06 Matrix: Drinking Water Sampled: 05/18/25 08:34:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 16:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - KIT1 Lims Reference ID: AD22090-07 Matrix: Drinking Water Sampled: 05/18/25 08:36:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 16:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - KIT2 Lims Reference ID: AD22090-09 Matrix: Drinking Water Sampled: 05/18/25 08:38:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 16:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - IM - KIT Lims Reference ID: AD22090-11 Matrix: Drinking Water Sampled: 05/18/25 08:40:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 16:56	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090**LIMS Reference ID:** AD22090**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Pleasant Valley Elementary School

Customer PO:

NJ-DOE (25-1042C)

EMSL Sales Rep:

Justin Monturano

Received:

05/22/2025 09:30

Reported:

06/10/2025 13:00

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PVS - SO - LIB									
				Lims Reference ID:	AD22090-12 Matrix: Drinking Water			Sampled: 05/18/25 08:42:00	
Metals									
Lead	2.87		1	1.00	µg/L	06/03/25 14:23	06/05/25 16:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - WC - HALL 2									
				Lims Reference ID:	AD22090-14 Matrix: Drinking Water			Sampled: 05/18/25 08:45:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 17:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - BF - HALL 2									
				Lims Reference ID:	AD22090-15 Matrix: Drinking Water			Sampled: 05/18/25 08:45:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 17:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - WC - HALL 3									
				Lims Reference ID:	AD22090-16 Matrix: Drinking Water			Sampled: 05/18/25 08:46:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 17:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - BF - HALL 3									
				Lims Reference ID:	AD22090-17 Matrix: Drinking Water			Sampled: 05/18/25 08:46:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 17:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B117A									
				Lims Reference ID:	AD22090-18 Matrix: Drinking Water			Sampled: 05/18/25 08:50:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 17:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B117B									
				Lims Reference ID:	AD22090-20 Matrix: Drinking Water			Sampled: 05/18/25 08:51:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 17:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B117C									
				Lims Reference ID:	AD22090-22 Matrix: Drinking Water			Sampled: 05/18/25 08:53:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 17:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B117D									
				Lims Reference ID:	AD22090-24 Matrix: Drinking Water			Sampled: 05/18/25 08:55:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 17:21	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090**LIMS Reference ID:** AD22090**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Pleasant Valley Elementary School

Customer PO:

NJ-DOE (25-1042C)

EMSL Sales Rep:

Justin Monturano

Received:

05/22/2025 09:30

Reported:

06/10/2025 13:00

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PVS - SO - B117E Lims Reference ID: AD22090-26 Matrix: Drinking Water Sampled: 05/18/25 08:56:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 17:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B117F Lims Reference ID: AD22090-28 Matrix: Drinking Water Sampled: 05/18/25 08:58:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 14:23	06/05/25 17:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B118 Lims Reference ID: AD22090-30 Matrix: Drinking Water Sampled: 05/18/25 09:00:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B127 Lims Reference ID: AD22090-32 Matrix: Drinking Water Sampled: 05/18/25 09:02:00									
Metals									
Lead	3.98		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B119 Lims Reference ID: AD22090-34 Matrix: Drinking Water Sampled: 05/18/25 09:04:00									
Metals									
Lead	7.45		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B126 Lims Reference ID: AD22090-36 Matrix: Drinking Water Sampled: 05/18/25 09:05:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B125 Lims Reference ID: AD22090-38 Matrix: Drinking Water Sampled: 05/18/25 09:07:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B121 Lims Reference ID: AD22090-40 Matrix: Drinking Water Sampled: 05/18/25 09:09:00									
Metals									
Lead	5.92		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B124 Lims Reference ID: AD22090-42 Matrix: Drinking Water Sampled: 05/18/25 09:11:00									
Metals									
Lead	6.35		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:28	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090**LIMS Reference ID:** AD22090**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Pleasant Valley Elementary School

Customer PO:

NJ-DOE (25-1042C)

EMSL Sales Rep:

Justin Monturano

Received:

05/22/2025 09:30

Reported:

06/10/2025 13:00

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PVS - DW - B123 Lims Reference ID: AD22090-44 Matrix: Drinking Water Sampled: 05/18/25 09:13:00									
Metals									
Lead	1.58		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - C104 Lims Reference ID: AD22090-46 Matrix: Drinking Water Sampled: 05/18/25 09:21:00									
Metals									
Lead	8.11		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - NUR Lims Reference ID: AD22090-48 Matrix: Drinking Water Sampled: 05/18/25 09:22:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - NURRR Lims Reference ID: AD22090-50 Matrix: Drinking Water Sampled: 05/18/25 09:24:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - MAIN Lims Reference ID: AD22090-52 Matrix: Drinking Water Sampled: 05/18/25 09:26:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - FAC Lims Reference ID: AD22090-54 Matrix: Drinking Water Sampled: 05/18/25 09:28:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A123 Lims Reference ID: AD22090-56 Matrix: Drinking Water Sampled: 05/18/25 09:31:00									
Metals									
Lead	1.22		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A117 Lims Reference ID: AD22090-58 Matrix: Drinking Water Sampled: 05/18/25 09:33:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A122 Lims Reference ID: AD22090-60 Matrix: Drinking Water Sampled: 05/18/25 09:35:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:53	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090
LIMS Reference ID: AD22090
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Pleasant Valley Elementary School

Customer PO: NJ-DOE (25-1042C)
EMSL Sales Rep: Justin Monturano
Received: 05/22/2025 09:30
Reported: 06/10/2025 13:00

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PVS - DW - A121 Lims Reference ID: AD22090-62 Matrix: Drinking Water Sampled: 05/18/25 09:37:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A118 Lims Reference ID: AD22090-64 Matrix: Drinking Water Sampled: 05/18/25 09:39:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A120 Lims Reference ID: AD22090-66 Matrix: Drinking Water Sampled: 05/18/25 09:40:00									
Metals									
Lead	3610		50	50.0	µg/L	06/03/25 16:52	06/04/25 16:03	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: PVS - DW - A120 (Flush) Lims Reference ID: AD22090-67 Matrix: Drinking Water Sampled: 05/18/25 09:41:00									
Metals									
Lead	2.88		1	1.00	µg/L	06/09/25 11:30	06/09/25 22:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A119 Lims Reference ID: AD22090-68 Matrix: Drinking Water Sampled: 05/18/25 09:42:00									
Metals									
Lead	35.4		1	1.00	µg/L	06/03/25 15:48	06/05/25 18:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A119 (Flush) Lims Reference ID: AD22090-69 Matrix: Drinking Water Sampled: 05/18/25 09:43:00									
Metals									
Lead	ND		1	1.00	µg/L	06/09/25 11:30	06/09/25 22:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A102 Lims Reference ID: AD22090-70 Matrix: Drinking Water Sampled: 05/18/25 09:43:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 19:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A112 Lims Reference ID: AD22090-72 Matrix: Drinking Water Sampled: 05/18/25 09:45:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 19:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - WC - HALL 5A Lims Reference ID: AD22090-74 Matrix: Drinking Water Sampled: 05/18/25 09:47:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 19:57	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090**LIMS Reference ID:** AD22090**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Pleasant Valley Elementary School

Customer PO:

NJ-DOE (25-1042C)

EMSL Sales Rep:

Justin Monturano

Received:

05/22/2025 09:30

Reported:

06/10/2025 13:00

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PVS - WC - HALL 5B									
			Lims Reference ID:		AD22090-75	Matrix: Drinking Water		Sampled: 05/18/25 09:48:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 19:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A103									
			Lims Reference ID:		AD22090-76	Matrix: Drinking Water		Sampled: 05/18/25 09:49:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A111									
			Lims Reference ID:		AD22090-78	Matrix: Drinking Water		Sampled: 05/18/25 09:50:00	
Metals									
Lead	8.11		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A104									
			Lims Reference ID:		AD22090-80	Matrix: Drinking Water		Sampled: 05/18/25 09:52:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A110									
			Lims Reference ID:		AD22090-82	Matrix: Drinking Water		Sampled: 05/18/25 09:54:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A105									
			Lims Reference ID:		AD22090-84	Matrix: Drinking Water		Sampled: 05/18/25 09:55:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A109									
			Lims Reference ID:		AD22090-86	Matrix: Drinking Water		Sampled: 05/18/25 09:56:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - A106									
			Lims Reference ID:		AD22090-88	Matrix: Drinking Water		Sampled: 05/18/25 09:59:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - A108A									
			Lims Reference ID:		AD22090-90	Matrix: Drinking Water		Sampled: 05/18/25 10:03:00	
Metals									
Lead	10.8		1	1.00	µg/L	06/03/25 18:58	06/05/25 20:22	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012522090**LIMS Reference ID:** AD22090**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]
 80 Fork Bridge Road
 Pittsgrove, NJ 08318
 (856) 205-1077
 jeberts@epicenviro.com

Project Name:

Pleasant Valley Elementary School

Customer PO:

NJ-DOE (25-1042C)

EMSL Sales Rep:

Justin Monturano

Received:

05/22/2025 09:30

Reported:

06/10/2025 13:00

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PVS - SO - A108B Lims Reference ID: AD22090-92 Matrix: Drinking Water Sampled: 05/18/25 10:04:00									
Metals									
Lead	8.84		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - A108C Lims Reference ID: AD22090-94 Matrix: Drinking Water Sampled: 05/18/25 10:05:00									
Metals									
Lead	2.95		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - A108D Lims Reference ID: AD22090-96 Matrix: Drinking Water Sampled: 05/18/25 10:06:00									
Metals									
Lead	3.98		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - A108E Lims Reference ID: AD22090-98 Matrix: Drinking Water Sampled: 05/18/25 10:07:00									
Metals									
Lead	10.3		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - A108F Lims Reference ID: AD22090-AA Matrix: Drinking Water Sampled: 05/18/25 10:08:00									
Metals									
Lead	7.06		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW-C101 H Lims Reference ID: AD22090-AC Matrix: Drinking Water Sampled: 05/18/25 10:12:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW-C101 G Lims Reference ID: AD22090-AE Matrix: Drinking Water Sampled: 05/18/25 10:14:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B112 A Lims Reference ID: AD22090-AG Matrix: Drinking Water Sampled: 05/18/25 10:18:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 16:58	06/05/25 20:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B112 B Lims Reference ID: AD22090-AI Matrix: Drinking Water Sampled: 05/18/25 10:19:00									
Metals									
Lead	3.06		1	1.00	µg/L	06/03/25 17:02	06/05/25 20:57	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090**LIMS Reference ID:** AD22090**EMSL Customer ID:** EPIC62


Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Pleasant Valley Elementary School

Customer PO: NJ-DOE (25-1042C)
EMSL Sales Rep: Justin Monturano
Received: 05/22/2025 09:30
Reported: 06/10/2025 13:00

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PVS - SO - B112 C Lims Reference ID: AD22090-AK Matrix: Drinking Water Sampled: 05/18/25 10:20:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B112 D Lims Reference ID: AD22090-AM Matrix: Drinking Water Sampled: 05/18/25 10:21:00									
Metals									
Lead	13.2		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B112 E Lims Reference ID: AD22090-AO Matrix: Drinking Water Sampled: 05/18/25 10:22:00									
Metals									
Lead	4.69		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B112 F Lims Reference ID: AD22090-AQ Matrix: Drinking Water Sampled: 05/18/25 10:23:00									
Metals									
Lead	7.32		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - WC - HALL 4 B Lims Reference ID: AD22090-AS Matrix: Drinking Water Sampled: 05/18/25 10:27:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B102 Lims Reference ID: AD22090-AT Matrix: Drinking Water Sampled: 05/18/25 10:28:00									
Metals									
Lead	1.10		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B111 Lims Reference ID: AD22090-AV Matrix: Drinking Water Sampled: 05/18/25 10:30:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B103 Lims Reference ID: AD22090-AX Matrix: Drinking Water Sampled: 05/18/25 10:31:00									
Metals									
Lead	4.65		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B110 Lims Reference ID: AD22090-AZ Matrix: Drinking Water Sampled: 05/18/25 10:33:00									
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:22	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090**LIMS Reference ID:** AD22090**EMSL Customer ID:** EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Pleasant Valley Elementary School

Customer PO: NJ-DOE (25-1042C)
EMSL Sales Rep: Justin Monturano
Received: 05/22/2025 09:30
Reported: 06/10/2025 13:00

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PVS - DW - B104									
Lims Reference ID:				AD22090-BB Matrix: Drinking Water				Sampled: 05/18/25 10:35:00	
Metals									
Lead	6.26		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B109									
Lims Reference ID:				AD22090-BD Matrix: Drinking Water				Sampled: 05/18/25 10:37:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - DW - B105									
Lims Reference ID:				AD22090-BF Matrix: Drinking Water				Sampled: 05/18/25 10:38:00	
Metals									
Lead	1.64		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B108 A									
Lims Reference ID:				AD22090-BH Matrix: Drinking Water				Sampled: 05/18/25 10:41:00	
Metals									
Lead	5.53		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B108 B									
Lims Reference ID:				AD22090-BJ Matrix: Drinking Water				Sampled: 05/18/25 10:42:00	
Metals									
Lead	37.0		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B108 B (Flush)									
Lims Reference ID:				AD22090-BK Matrix: Drinking Water				Sampled: 05/18/25 10:43:00	
Metals									
Lead	4.48		1	1.00	µg/L	06/09/25 11:30	06/09/25 22:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B108 C									
Lims Reference ID:				AD22090-BL Matrix: Drinking Water				Sampled: 05/18/25 10:43:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B108 D									
Lims Reference ID:				AD22090-BN Matrix: Drinking Water				Sampled: 05/18/25 10:44:00	
Metals									
Lead	ND		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: PVS - SO - B108 E									
Lims Reference ID:				AD22090-BP Matrix: Drinking Water				Sampled: 05/18/25 10:45:00	
Metals									
Lead	9.07		1	1.00	µg/L	06/03/25 17:02	06/05/25 21:45	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090**LIMS Reference ID:** AD22090**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]

80 Fork Bridge Road

Pittsgrove, NJ 08318

(856) 205-1077

jeberts@epicenviro.com

Project Name:

Pleasant Valley Elementary School

Customer PO:

NJ-DOE (25-1042C)

EMSL Sales Rep:

Justin Monturano

Received:

05/22/2025 09:30

Reported:

06/10/2025 13:00

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: PVS - SO - B108 F**Lims Reference ID:** AD22090-BR **Matrix:** Drinking Water**Sampled:** 05/18/25 10:46:00**Metals**

Lead	ND	1	1.00	µg/L	06/03/25 17:02	06/05/25 21:47	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: PVS - SO - B106**Lims Reference ID:** AD22090-BT **Matrix:** Drinking Water**Sampled:** 05/18/25 10:48:00**Metals**

Lead	ND	1	1.00	µg/L	06/03/25 17:02	06/05/25 21:48	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090**LIMS Reference ID:** AD22090**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Pleasant Valley Elementary School

Customer PO:

NJ-DOE (25-1042C)

EMSL Sales Rep:

Justin Monturano

Received:

05/22/2025 09:30

Reported:

06/10/2025 13:00

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012522090**LIMS Reference ID:** AD22090**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Pleasant Valley Elementary School

Customer PO:

NJ-DOE (25-1042C)

EMSL Sales Rep:

Justin Monturano

Received:

05/22/2025 09:30

Reported:

06/10/2025 13:00

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD22090

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

Report To Contact Name: James Eberts		Bill To Company: Epic Environmental Services, LLC	
Company Name: Epic Environmental Services, LLC		Attention To: James Eberts / Timothy Eberts	
Street: 80 Fork Bridge Road		Street: 80 Fork Bridge Road	
City: Pittsgrove	State/Province: NJ	City: Pittsgrove	State/Province: NJ
Zip/Postal Code: 08318	Zip/Postal Code: 08318	Phone: 856-205-1077	Phone: 856-205-1077
Project Name: Pleasant Valley Elementary School		Purchase Order: NJ-DOE (25-10426)	
U.S. State where Samples Collected: NJ		Date of Shipment:	
Number of Samples in Shipment: 146			
Sample for Compliance? Yes ☒ No ☐ If yes, NPDES? ☐ Other (Specify):			
Samples Collected by: EMSL ☐ Client ☒ check one		Samples Received Chilled (Y/N)	
Standard Turnaround Time: ☒ 2 Weeks		1 Week ☐ 4 Days ☐ 3 Days ☐ 1 Day	
Failure to complete will hinder processing of samples		List Test(s) Needed	
Client Sample ID	Collect Date/Time	Matrix	Preservative
1 PVS -FB	5/18/25	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other
2 WC-GYM 2	0830	W	2
3 WC-GYM 3	0832	W	1
4 WC-GYM 4	0833	W	
5 WC-HALL 1A	0834	W	
Released By (Signature)		Received By	
Date & Time		Date & Time	
		5/22/25 0930	
Please indicate reporting requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Disk Deliverable ☐ Other			
Instructions or Comments:			
Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.			
Analyze FIRST DRAW Samples. Analyze FLUSH samples if corresponding First Draw result is above 15.5 ppb			
Rec'd PWS.			
(Lab) Received Temperature: °C			

Page 1 of 10 pages



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD22090

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Matrix		Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8	List Test(s) Needed				Field Temp			Comments
	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O=Other			Field pH	Test pH	Deg C	Test Time				
WC-HALL 1B	☐	☐	5/18/25	W	2									
SO-KIT 1	☐	☐	0834	W										
↓ (flush)	☐	☐	0836	W										
SO-KIT 2	☐	☒	0837	W										
↓ (flush)	☐	☒	0838	W										
IM-KIT	☐	☒	0839	W										
SO-LIB	☐	☒	0840	W										
↓ (flush)	☐	☒	0842	W										
WC-HALL 2	☐	☒	0843	W										
BF-HALL 2	☐	☒	0845	W										
WC-HALL 3	☐	☒	0846	W										
BF-HALL 3	☐	☒	0846	W										
SO-BI17A	☐	☒	0850	W										
↓ (flush)	☐	☒	0851	W										
SO-BI17B	☐	☒	0851	W										
↓ (flush)	☐	☒	0852	W										
SO-BI17C	☐	☒	0853	W										

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS DIVISION

EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS DIVISION

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD22090

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Matrix	Preservative	List Test(s) Needed					Comments		
	Comp	Grab			Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O=Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8	Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time
23 SO-B17C (flush)	☐	☐	5/18/25	0854	W	2						
24 SO-B117D	☐	☐		0855	W							
25 ↓ (flush)	☐	☐		0856	W							
26 SO-B117E	☐	☒		0857	W							
27 ↓ (flush)	☐	☒		0858	W							
28 SO-B117F	☐	☒		0900	W							
29 ↓ (flush)	☐	☒		0901	W							
30 DW-B118	☐	☒		0902	W							
31 ↓ (flush)	☐	☒		0903	W							
32 DW-B127	☐	☒		0904	W							
33 ↓ (flush)	☐	☒		0905	W							
34 DW-B119	☐	☒		0906	W							
35 ↓ (flush)	☐	☒		0907	W							
36 DW-B126	☐	☒		0908	W							
37 ↓ (flush)	☐	☒		0909	W							
38 DW-B125	☐	☒		0910	W							
39 ↓ (flush)	☐	☒		0911	W							

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL INC.
LABORATORY PRODUCTS TRAINING
EMSL ANALYTICAL INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD22090

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples	Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O= Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed	Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Comments
	DW-B121	☐	☐	5/18/25	W	2	1						
	↓ (Flush)	☐	☐	0910	W								
	DW-B124	☐	☐	0911	W								
	↓ (Flush)	☐	☒	0912	W								
	DW-B123	☐	☒	0913	W								
	↓ (Flush)	☐	☒	0914	W								
	SD-C104	☐	☒	0921	W								
	↓ (Flush)	☐	☒	0922	W								
	SD-NUR	☐	☒	0922	W								
	↓ (Flush)	☐	☒	0923	W								
	SD-NUR	☐	☒	0924	W								
	↓ (Flush)	☐	☒	0925	W								
	SD-MAIN	☐	☒	0926	W								
	↓ (Flush)	☐	☒	0927	W								
	SD-FAC	☐	☒	0928	W								
	↓ (Flush)	☐	☒	0929	W								
	DW-A123	☐	☒	0931	W								

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD22090

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples			List Test(s) Needed						Comments	
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix	Preservative	EPA	Field pH	Field pH Test Time		Field Temp Deg C
DW-A123 (Flush)	☐	☐	5/18/25 0932	W	2	200.8				
DW-A117	☐	☐	0933	W						
↓ (Flush)	☐	☐	0934	W						
DW-A122	☐	☒	0935	W						
↓ (Flush)	☐	☒	0936	W						
DW-A121	☐	☒	0937	W						
↓ (Flush)	☐	☒	0938	W						
DW-A118	☐	☒	0939	W						
↓ (Flush)	☐	☒	0940	W						
DW-A120	☐	☒	0940	W						
↓ (Flush)	☐	☒	0941	W						
DW-A119	☐	☒	0942	W						
↓ (Flush)	☐	☒	0943	W						
DW-A102	☐	☒	0943	W						
↓ (Flush)	☐	☒	0944	W						
DW-A112	☐	☒	0945	W						
↓ (Flush)	☐	☒	0946	W	✓	✓				

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY/PRODUCTS TRAINING

EMSL ANALYTICAL, INC.
LABORATORY/PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD22090

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples			List Test(s) Needed					Comments		
Client Sample ID	Collect Date/Time	Matrix	Preservative	EPA 200.8	Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Comments	
WC-HALL 5A	5/18/25 0947	W	2	✓						
WC-HALL 5B	0948	W								
DW-A103	0949	W								
↓ (Flush)	0950	W								
DW-A111	0950	W								
↓ (Flush)	0951	W								
DW-A104	0952	W								
↓ (Flush)	0953	W								
DW-A110	0954	W								
↓ (Flush)	0955	W								
DW-A105	0955	W								
↓ (Flush)	0956	W								
DW-A109	0956	W								
↓ (Flush)	0958	W								
DW-A106	0959	W								
↓ (Flush)	1000	W								
SD-A108A	1003	W	✓	✓						

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS & TREATING
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS & TREATING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD22096

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				List Test(s) Needed					Comments	
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix	Preservative	EPA	Field pH	Field pH Test Time		Field Temp Deg C
91 SO-A108A (Flush)	☐	☐	5/18/25 1004	W	2	1				
92 SO-A108B	☐	☐	1004	W						
93 ↓ (Flush)	☐	☐	1005	W						
94 SO-A108C	☐	☒	1005	W						
95 ↓ (Flush)	☐	☒	1006	W						
96 SO-A108D	☐	☒	1006	W						
97 ↓ (Flush)	☐	☒	1007	W						
98 SO-A108E	☐	☒	1007	W						
99 ↓ (Flush)	☐	☒	1008	W						
100 SO-A108F	☐	☒	1008	W						
101 ↓ (Flush)	☐	☒	1009	W						
102 DW-C101H	☐	☒	1012	W						
103 ↓ (Flush)	☐	☒	1013	W						
104 DW-C101G	☐	☒	1014	W						
105 ↓ (Flush)	☐	☒	1015	W						
106 SO-B112A	☐	☒	1018	W						
107 ↓ (Flush)	☐	☒	✓ 1019	W	✓	✓				

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD22090

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples			List Test(s) Needed								
Client Sample ID	Comp	Lab	Collect Date/Time	Matrix	Preservative	EPA	Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Comments
109 SO-B112B	☐	☐	5/18/25	W	2	200.8					
109 ↓ (flush)	☐	☐	1019	W							
110 SO-B112C	☐	☐	1020	W							
111 ↓ (flush)	☒	☒	1020	W							
112 SO-B112D	☐	☒	1021	W							
113 ↓ (flush)	☐	☒	1022	W							
114 SO-B112E	☐	☒	1022	W							
115 ↓ (flush)	☒	☒	1023	W							
116 SO-B112F	☐	☒	1023	W							
117 ↓ (flush)	☐	☒	1024	W							
118 WC-HALC4B	☐	☒	1027	W							
119 DW-B102	☐	☒	1028	W							
120 ↓ (flush)	☐	☒	1029	W							
121 DW-B111	☐	☒	1030	W							
122 ↓ (flush)	☐	☒	1031	W							
123 DW-B103	☐	☒	1031	W							
124 ↓ (flush)	☐	☒	1032	W							

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD22096

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples			List Test(s) Needed					Comments		
Client Sample ID	Comp	Lab	Collect Date/Time	Matrix	Preservative	EPA	Field pH		Field pH Test Time	Field Temp Deg C
125 DW-B110	☐	☐	5/18/25	W	2	200.8				
126 DW-B104	☐	☐	1033	W						
127 DW-B104	☐	☐	1034	W						
128 DW-B104	☐	☐	1035	W						
129 DW-B109	☐	☐	1036	W						
130 DW-B109	☐	☐	1037	W						
131 DW-B105	☐	☐	1038	W						
132 DW-B105	☐	☐	1039	W						
133 DW-B108A	☐	☐	1041	W						
134 DW-B108B	☐	☐	1042	W						
135 DW-B108B	☐	☐	1042	W						
136 DW-B108B	☐	☐	1043	W						
137 DW-B108C	☐	☐	1043	W						
138 DW-B108C	☐	☐	1044	W						
139 DW-B108D	☐	☐	1044	W						
140 DW-B108D	☐	☐	1045	W						
141 DW-B108E	☐	☐	1045	W						

(Lab) Received Temperature: _____ °C

