



State Water Resources Control Board

Division of Drinking Water

Lead and Copper Tap Sample Results Reporting Form

This form must be submitted by the public water system to the regulating entity (DDW District Office or County Agency) for each round of lead and copper sampling

Report Date: (mm/dd/yyyy)	10/05/2026
Water System Name:	Rosamond School
Water System Number:	1502231
Water System Type:	☐ Community ☒ Non-Transient, Non Community
Monitoring Frequency:	☐ 6-month ☐ Annual ☒ Triennial
# of Samples Required:	20
# of Samples Reported:	20
	90th Percentile Level (mg/L)
Lead: <i>Action Level = 0.015 mg/L</i>	0.0066
Copper: <i>Action Level = 1.3 mg/L</i>	0.320

				Result	
	Sample Date	Sample Site Location/Address	Tier 1, 2, 3, or R	Lead (mg/L)	Copper (mg/L)
01	8/03/26	Room 102 Sink / 2925 Rosamond Blvd., Rosamond		ND	0.230
02	8/03/26	Room 103 Sink / Same as above		ND	0.260
03	8/03/26	Kitchen Sink / Same as above		0.001	0.370
04	8/03/26	Kitchen Pot Sink / Same as above		0.002	0.280
05	8/03/26	Boy's Locker Room Sink / Same as above		0.009	ND
06	8/03/26	Girl's Locker Room / Same as above		0.007	ND
07	8/03/26	Room 504 Sink / Same as above		0.004	ND
08	8/03/26	Room 501 / Same as above		0.099	0.012
09	8/03/26	Room 604 / Same as above		0.004	ND
10	8/03/26	Room 602 / Same as above		0.002	0.007
11	8/03/26	Custodian Room Sink / Same as above		0.002	ND
12	8/03/26	Kitchen Sink 2 / Same as above		ND	0.180
13	8/03/26	Kitchen Pot Sink 2 / Same as above		ND	0.039
14	8/03/26	Boy's Portable Restroom 1 Sink / Same as above		0.002	0.370
15	8/03/26	Girl's Portable Restroom 1 Sink / Same as above		ND	0.320
16	8/03/26	Girl's Portable Restroom 2 Sink / Same as above		ND	0.160
17	8/03/26	Boy's Portable Restroom 2 Sink / Same as above		ND	0.160
18	8/03/26	Office Unisex Restroom Sink / Same as above		ND	0.210
19	8/03/26	Boy's Restroom Sink / Same as above		ND	0.220
20	8/03/26	Girl's Restroom Sink / Same as above		ND	0.200

Division of Drinking Water
Lead and Copper Tap Sample Results Reporting Form

Sampling Site Change

Each round of sampling should be conducted at the same sampling sites. If an original sampling site is not available, you should collect a tap sample from another site meeting the same Tier criteria as the original site.

You must complete/submit the **Lead and Copper Tap Sampling Site Change** form.

Notification of Results

As required by *40 Code of Federal Regulations Section 141.85(d)*, within 30 days of learning of the tap monitoring results, I notified the participants, by mailing or by another method approved by the State, of the lead sample results from their individual taps, provided an explanation of the health effects of lead, listed steps the consumer could take to reduce exposure to lead, provided contact information for the water utility, the maximum contaminant level goal for lead, action level for lead, and any definitions.

Notification was done on October 5, 2026 by _____
(date)

- ☐ Direct Mail
☒ Posting in public area (NTNC systems only)
☐ Other (please specify below) _____
-

For general information on lead and copper tap sampling, you can refer to the **SWRCB Lead and Copper Tap Sample Results Guidance Document**. If you have any questions or comments, please contact your regulating entity (Division of Drinking Water District or County Agency).

SIGNATURE: 	DATE: October 5, 2026
NAME (Print): Barbara Gaines	TITLE: Superintendent