



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

October 06, 2026

Richard McKibben
Pine Plains Central School District
2829 Church Street
Pine Plains, NY 12567
TEL: (518) 398-7181

Work Order No: 260928035
PO#: 260144

RE:
9/26/26 Lead- Water testing SMMS

Adirondack Environmental Services, Inc received 9 samples on 9/28/2026 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

Tara Daniels
Laboratory Director

Adirondack Environmental Services, Inc

CASE NARRATIVE

Pine Plains Central School District

Date: 06-Oct-26

9/26/26 Lead- Water testing SMMS

Lab WorkOrder: 260928035

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 06-Oct-26

CLIENT: Pine Plains Central School District
Project: 9/26/26 Lead- Water testing SMMS

LabWork Order: 260928035
PO#: 260144

Lab SampleID: 260928035-001 **Collection Date:** 9/26/2026 2:23:00 PM
Client Sample ID: SMMS001 Ice Machine **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH
(Prep: - 9/28/2026 3:36:01 PM)
Lead ND 1.0 µg/L 1 10/5/2026 2:52:44 PM

Lab SampleID: 260928035-002 **Collection Date:** 9/26/2026 2:53:00 PM
Client Sample ID: SMMS002 168 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH
(Prep: - 9/28/2026 3:36:01 PM)
Lead ND 1.0 µg/L 1 10/5/2026 2:56:20 PM

Lab SampleID: 260928035-003 **Collection Date:** 9/26/2026 2:54:00 PM
Client Sample ID: SMMS003 168 Bottle F. **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH
(Prep: - 9/28/2026 3:36:01 PM)
Lead ND 1.0 µg/L 1 10/5/2026 2:59:56 PM

Lab SampleID: 260928035-004 **Collection Date:** 9/26/2026 2:58:00 PM
Client Sample ID: SMMS004 158 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH
(Prep: - 9/28/2026 3:36:01 PM)
Lead ND 1.0 µg/L 1 10/5/2026 3:03:30 PM

Lab SampleID: 260928035-005 **Collection Date:** 9/26/2026 2:59:00 PM
Client Sample ID: SMMS005 158 Bottle F. **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH
(Prep: - 9/28/2026 3:36:01 PM)
Lead ND 1.0 µg/L 1 10/5/2026 3:07:03 PM

Adirondack Environmental Services, Inc

Date: 06-Oct-26

CLIENT: Pine Plains Central School District
Project: 9/26/26 Lead- Water testing SMMS

LabWork Order: 260928035
PO#: 260144

Lab SampleID: 260928035-006 **Collection Date:** 9/26/2026 3:01:00 PM
Client Sample ID: SMMS006 FFA Classroom **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH
(Prep: - 9/28/2026 3:36:04 PM)
Lead ND 1.0 µg/L 1 10/5/2026 3:17:45 PM

Lab SampleID: 260928035-007 **Collection Date:** 9/26/2026 3:04:00 PM
Client Sample ID: SMMS007 149 Bubbler **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH
(Prep: - 9/28/2026 3:36:04 PM)
Lead ND 1.0 µg/L 1 10/5/2026 3:28:29 PM

Lab SampleID: 260928035-008 **Collection Date:** 9/26/2026 3:05:00 PM
Client Sample ID: SMMS008 149 Bubbler 2 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH
(Prep: - 9/28/2026 3:36:04 PM)
Lead ND 1.0 µg/L 1 10/5/2026 3:32:03 PM

Lab SampleID: 260928035-009 **Collection Date:** 9/26/2026 3:06:00 PM
Client Sample ID: SMMS009 Facility Lounge **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: KH
(Prep: - 9/28/2026 3:36:04 PM)
Lead 3.2 1.0 µg/L 1 10/5/2026 3:35:38 PM



CHAIN OF CUSTODY RECORD



AES Work Order#:

260928035

MR

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Pine Plains Central Schools		Address: 2829 Church St. Pine Plains, NY 12567							
Send Report to: Richard McKibben		Project Name (Location): 9/26/26 Lead - Water testing SMMS			Samplers Name: Richard McKibben				
Client Phone #: 845-706-8855		Client PO #: 260144			Samplers Signature: 				
Client Email: r.mckibben@ppcsd.org									
AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preser- vative	Analysis
				Matrix	C	G			
001	SMMS001 ICE MACHINE	9/26/26	2:43	A	P				* Lead PW PPb
002	SMMS002 168 Bubblers		2:53	A	P				
003	SMMS003 168 Bottle f.		2:54	A	P				
004	SMMS004 158 Bubblers		2:58	A	P				
005	SMMS005 158 Bottle f.		2:59	A	P				
006	SMMS006 FFA Classroom		3:01	A	P				
007	SMMS007 149 Bubblers 1		3:04	A	P				
008	SMMS008 149 Bubblers 2		3:05	A	P				
009	SMMS009 FACULTY LOUNGE	9/26/26	3:06	A	P				
				A	P				
				A	P				
				A	P				
				A	P				
				A	P				
				A	P				
				A	P				
				A	P				
				A	P				
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks: * M4 9/28					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature)				Received by: (Signature) 			Date 9/28/26	Time 10:10am	
Relinquished by: (Signature)				Received by: (Signature)			Date	Time	
Relinquished by: (Signature) 				Received for Laboratory by: M4			Date 9/28/26	Time 12:49	
Sample Temperature <u>Ambient</u> ~ Chilled ~ Chilling Begun			Properly Preserved: <u>Y</u> / N 0=None 5=NH4Cl 1=H2SO4 pH<2 6=Ascorbic Acid 2=HNO3 pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na2S2O3 9=NaOH pH>10 10=Other			Received Within Holding Times: <u>Y</u> / N			
Notes:						Notes:			
Custody Seal Intact: <u>Y</u> / N									
Bottles AES: <u>Y</u> / N									



260928035



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.