952 School Street #111
Napa, CA 94559
707-205-5706
mmichie@fitenvironmental.com

October 16, 2026

Mr. Jaime Rico
Supervisor, MOT
Cabrillo Unified School District
498 Kelly Avenue
Half Moon Bay, CA 94109

RE: Microbial Spore Trap Sampling at Cunha Intermediate School Building C with a visual inspection of the HVAC filters system, supply ductwork and return plenum for the Cabrillo Unified School District located at 600 Church Street in Half Moon Bay, California

F.I.T. Job # 26-054

Dear Mr. Rico,

F.I.T. Environmental Services (FIT) is pleased to present this letter report for the reporting of spores in air microbial sampling and visual inspection of the HVAC system in Classroom C-115 performed in Building C, at Cunha Intermediate School 600 Church Street in Half Moon Bay, California.

Overview

On October 3, 2026, F.I.T. Environmental Services (FIT) mobilized to Classroom C-115 to perform a visual inspection of the HVAC unit including the filters, the supply ductwork and return plenum. On October 10, 2026, FIT mobilized to the above-mentioned site to collect a spores-in-air comparison microbial samples from six (6) classrooms located within Building C. The inspection/sampling was at the request of the Cabrillo Unified School District following indoor air quality complaints in regard to possible elevated microbial spores. FIT collected samples from Classroom C-115, C-108, C-101, C-202, C-206, and C-211 with one (1) outside sample collected adjacent to the building for comparison purposes. The samples were submitted under chain of custody procedures to Eurofins Environment West Testing Laboratories in Burlingame, California.

Methodology

Airborne mold spore sampling was accomplished by using a spore trap method. Air-O-Cell cassettes were used to collect approximately 75 liters of air at a calibrated flow rate of 15 liters per minute. Air-O-Cell samples provide rapid collection and analysis by microscopic examination and allow identification of fungal spores, plant pollens and other particulates. Airborne particulate is collected by the spore trap cassette and analyzed by the non-viable, direct microscopic examination method. Spores are counted and identified by species type. Results are expressed in spores per cubic meter of air sampled. Samples are collected both inside the building areas to be evaluated and at one or more locations outside the building.

The inside building sample results are compared with the outside ambient air result(s) to determine if any elevated levels are present for one or more spore types in the building area of concern.
Typically, in buildings with a filtered HVAC system, interior samples in a normal non-problem building would be anticipated to be 30-80% of the outside levels. Indoor levels that are significantly higher than outdoor levels would suggest an indoor mold contamination source may be present requiring further investigation and possible remedial action.

All samples were sent to Eurofins Environment West Testing Laboratories (EEWTL) in Burlingame, California for analysis under chain of custody procedures. EEWTL specializes in air sample analysis of fungi (mold) and is a successful participant in the American Industrial Hygiene Association (AIHA) EMPAT proficiency program.

Visual Inspection

FIT performed a visual inspection of the HVAC unit filters, removed supply duct grills, and return grills to inspect the conditions from inside Classroom C-115. The filters were dry and no visible microbial growth was present. Filters were clean with normal loading from use. It appears that filters are changed on a normal rotation. The supply duct was insulated on the inside of the duct, no moisture was present, the insulation was clean with no signs of microbial growth present. There was no debris present inside the ductwork. The return plenum located immediately beneath the ductwork inside the soffit was dry and clean with no visible microbial growth present. There was no evidence of any water intrusion present. The HVAC system is a Unit Ventilator System paired with a hot water hydroponic heating system. A central boiler sends hot water to each classroom unit where a mixture of return air from the classroom and outside air is heated to each classroom desired temperature set from the thermostat in each classroom. The hot water system is a closed loop system with no water escaping. There was no evidence of any leaking water from inside the HVAC unit or from the piping coming to the unit. The system is set to always mix outdoor air and will increase the percentage of outdoor air based on the carbon dioxide (CO2) levels detected from the return air. Based on all visual inspections the HVAC system is being properly maintained and is functioning properly with no evidence of microbial growth in any part of the system.

Results of the 10/10/2026 Spore Trap Sampling

The October 10, 2026, sample results were reported by the laboratory as follows, C-115 were 160 spores/m^3, C-108 were 67 spores/m^3, C-101 were 53 Spores/m^3, C-202 were 110 spores/m^3, C-205 were 53 spores/m^3, C-211 were 490 spores/m^3, and outside the building were 3,500 spores/m^3. The C-115 spore counts were 4% of outdoor samples, C-108 spore counts were 1% of the outdoor sample, C-101 spore counts were 1% of the outdoor sample, C-202 spore counts were 3% of the outdoor sample, C-205 spore counts were 1% of the outdoor sample, C-211 spore counts were 14% of the outdoor sample. The results are summarized in Table 1 below. The certified laboratory report is attached.

Table I

Sampling Location and Date	Total Spores/m³	% of Outdoor
Building C Classroom 115 – 10/10/2026	160	4%
Building C Classroom 108 – 10/10/2026	67	1%
Building C Classroom 101 – 10/10/2026	53	1%
Building C Classroom 202 – 10/10/2026	110	3%
Building C Classroom 205 – 10/10/2026	53	1%
Building C Classroom 211 – 10/10/2026	490	14%
Outdoor Sample – 10/10/2026	3,500	N/A

All species detected in the Indoor samples were present in the Outdoor sample. There was 1 Rust spore in Classroom 108, and 1 Other Brown Spore in Classroom 211 that were not present on the outdoor sample, however since dozens of students are entering and leaving a classroom daily 1 spore does not indicate any type of microbial outbreak or elevated levels even if not present on outdoor samples.

Conclusion

Based upon the visual inspection of the C-115 HVAC system, and the 10/10/2026 certified laboratory report of the air samples conducted inside Building C at Cunha Intermediate School, F.I.T. Environmental Services has determined that the indoor air quality is that of a "normal building environment" in the areas notated above pertaining to microbial spores in accordance with industry standard indoor air quality protocols and state of the art indoor air quality assessment.

FIT Environmental Services appreciates the opportunity to provide our microbial services. Please contact Michael Michie at (707) 205-5706 if you have any questions.

Respectfully submitted,



Michael Michie, CAC (#25-7928)
Certified Commercial Mold Inspector
President/Principal Consultant

Attachments: Certified Analytical Report
Chain of Custody

eurofins | Built Environment Testing

Report for:

Michael Michie
F.I.T. Services, LLC
952 School St. #111
Napa, CA 94559

Regarding: Eurofins Built Environment Testing West, LLC
Project: 26-054; Cunha Intermediate School
EML ID: 4754592

Approved by:



Technical Manager
Murali Putty

Dates of Analysis:
Spore trap analysis: 10-12-2026

Service SOPs: Spore trap analysis (EBET-DE-SOP89537(formerly EB-MY-S-1038))
AIHA LAP, LLC accredited service, Lab ID #102856

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received and tested. Information supplied by the client which can affect the validity of results: sample air volume.

Eurofins Built Environment Testing West, LLC ("the Company"), a member of the Eurofins Built Environment Testing group of companies, shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.
Eurofins Built Environment Testing West, LLC's LabServe® reporting system includes automated fail-safes to ensure that all AIHA LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Eurofins Built Environment Testing West, LLC
111 Anza Boulevard, Suite 122, Burlingame, CA 94010
(833) 465-5857 www.eurofinsus.com/Built

Client: F.I.T. Services, LLC
C/O: Michael Michie
Re: 26-054; Cunha Intermediate School

Date of Sampling: 10-10-2026
Date of Receipt: 10-12-2026
Date of Report: 10-12-2026

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	43351209: Classroom 115		43351194: Classroom 108		43351206: Classroom 101		43351191: Classroom 202	
Comments (see below)	None		None		None		None	
Lab ID-Version‡:	24054720-1		24054721-1		24054722-1		24054723-1	
Analysis Date:	10/12/2026		10/12/2026		10/12/2026		10/12/2026	
	raw ct.	spores/m3	raw ct.	spores/m3	raw ct.	spores/m3	raw ct.	spores/m3
Ascospores	1	53						
Basidiospores								
Botrytis								
Chaetomium								
Cladosporium							1	53
Curvularia								
Epicoccum								
Fusarium								
Myrothecium								
Nigrospora								
Other brown								
Other colorless								
Penicillium/Aspergillus types†	2	110	1	53	1	53	1	53
Pithomyces								
Rusts			1	13				
Smuts, Periconia, Myxomycetes								
Stachybotrys								
Stemphylium								
Torula								
Ulocladium								
Zygomycetes								
Background debris (1-4+)	2+		2+		2+		2+	
Hyphal fragments/m3	< 13		< 13		< 13		< 13	
Pollen/m3	< 13		< 13		< 13		< 13	
Skin cells (1-4+)	< 1+		1+		1+		1+	
Sample volume (liters)	75		75		75		75	
§ TOTAL SPORES/m3		160		67		53		110

Comments:

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.
† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium, Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.
††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m^3 divided by the raw count, expressed in spores/m^3, per spore and per sample.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.
‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".
§ Total Spores/m3 has been rounded to two significant figures to reflect analytical precision.

Eurofins Built Environment Testing West, LLC
111 Anza Boulevard, Suite 122, Burlingame, CA 94010
(833) 465-5857 www.eurofinsus.com/Built

Client: F.I.T. Services, LLC
C/O: Michael Michie
Re: 26-054; Cunha Intermediate School

Date of Sampling: 10-10-2026
Date of Receipt: 10-12-2026
Date of Report: 10-12-2026

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	43351204: Classroom 205		43351190: Classroom 211		43351192: Outside Bldg.	
Comments (see below)	None		None		None	
Lab ID-Version‡:	24054724-1		24054725-1		24054726-1	
Analysis Date:	10/12/2026		10/12/2026		10/12/2026	
	raw ct.	spores/m3	raw ct.	spores/m3	raw ct.	spores/m3
Ascospores			2	110	29	770
Basidiospores			1	53	52	1,400
Botrytis						
Chaetomium						
Cladosporium			3	160	31	830
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other brown			1	13		
Other colorless						
Penicillium/Aspergillus types†	1	53	3	160	19	510
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes						
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Zygomycetes						
Background debris (1-4+)	2+		2+		3+	
Hyphal fragments/m3	< 13		< 13		7	
Pollen/m3	< 13		< 13		< 7	
Skin cells (1-4+)	1+		1+		< 1+	
Sample volume (liters)	75		75		150	
§ TOTAL SPORES/m3		53		490		3,500

Comments:

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.
† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium, Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.
††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m^3 divided by the raw count, expressed in spores/m^3, per spore and per sample.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.
‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".
§ Total Spores/m3 has been rounded to two significant figures to reflect analytical precision.

Eurofins Built Environment Testing West, LLC
111 Anza Boulevard, Suite 122, Burlingame, CA 94010
(833) 465-5857 www.eurofinsus.com/Built

Client: F.I.T. Services, LLC
C/O: Michael Michie
Re: 26-054; Cunha Intermediate School

Date of Sampling: 10-10-2026
Date of Receipt: 10-12-2026
Date of Report: 10-12-2026

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

PROJECT ANALYST AND SIGNATORY REPORT

Project Analyst



Analyst: Murali Putty

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by AIHA LAP, LLC, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Eurofins Built Environment Testing West, LLC
111 Anza Boulevard, Suite 122, Burlingame, CA 94010
(833) 465-5857 www.eurofinsus.com/Built

Client: F.I.T. Services, LLC
C/O: Michael Michie
Re: 26-054; Cunha Intermediate School

Date of Sampling: 10-10-2026
Date of Receipt: 10-12-2026
Date of Report: 10-12-2026

MoldRANGE™: Extended Outdoor Comparison

Outdoor Location: 43351192, Outside Bldg.

Fungi Identified	Outdoor data	Typical Outdoor Data for: October in California† (n‡=41297)						Typical Outdoor Data for: The entire year in California† (n‡=482575)					
	spores/m3	very low	low	med	high	very high	freq %	very low	low	med	high	very high	freq %
Generally able to grow indoors*													
Alternaria	-	13	13	27	67	110	58	13	13	27	53	100	50
Bipolaris/Drechslera group	-	10	13	13	27	53	16	8	13	13	27	53	11
Chaetomium	-	13	13	13	27	50	25	11	13	13	27	40	18
Cladosporium	830	160	320	990	2,700	4,700	98	110	210	590	1,600	2,700	96
Curvularia	-	8	13	13	40	67	13	7	13	13	33	53	6
Nigrospora	-	13	13	13	53	96	22	8	13	13	33	53	9
Other brown	-	13	13	15	40	67	39	13	13	13	40	53	34
Penicillium/Aspergillus types	510	53	110	320	910	1,600	83	53	100	230	640	1,100	76
Stachybotrys	-	8	13	13	33	67	5	8	13	13	40	67	4
Torula	-	11	13	13	40	67	11	10	13	13	40	67	10
Seldom found growing indoors**													
Ascospores	770	27	53	110	370	750	68	27	53	110	430	840	68
Basidiospores	1,400	53	67	230	960	2,300	91	53	67	230	1,000	2,600	90
Rusts	-	13	13	13	53	80	25	13	13	13	53	83	24
Smuts, Periconia, Myxomycetes	-	13	20	53	150	250	75	13	13	40	120	210	67
§ TOTAL SPORES/m3	3,500												

†The 'Typical Outdoor Data' represents the typical outdoor spore levels for the location and time frame indicated. The last column represents the frequency of occurrence. The very low, low, med, high, and very high values represent the 10, 20, 50, 80, and 90 percentile values of the spore type when it is detected. For example, if the frequency of occurrence is 63% and the low value is 53, it would mean that the given spore type is detected 63% of the time and, when detected, 20% of the time it is present in levels above the detection limit and below 53 spores/m3. These values are updated periodically, and if enough data is not available to make a statistically meaningful assessment, it is indicated with a dash.

§ Total Spores/m3 has been rounded to two significant figures to reflect analytical precision.

* The spores in this category are generally capable of growing on wet building materials in addition to growing outdoors. Building related growth is dependent upon the fungal type, moisture level, type of material, and other factors. *Cladosporium* is one of the predominant spore types worldwide and is frequently present in high numbers. *Penicillium/Aspergillus* species colonize both outdoor and indoor wet surfaces rapidly and are very easily dispersed. Other genera are usually present in lesser numbers.

** These fungi are generally not found growing on wet building materials. For example, the rusts and smuts are obligate plant pathogens. However, in each group there are notable exceptions. For example, agents of wood decay are members of the basidiomycetes and high counts of a single morphological type of basidiospore on an inside sample should be considered significant.

‡n = number of samples used to calculate data.

Interpretation of the data contained in this report is left to the client or the persons who conducted the field work. This report is provided for informational and comparative purposes only and should not be relied upon for any other purpose. "Typical outdoor data" are based on the results of the analysis of samples delivered to and analyzed by Eurofins Built Environment Testing and assumptions regarding the origins of those samples. Sampling techniques, contaminants infecting samples, unrepresentative samples and other similar or dissimilar factors may affect these results. In addition, Eurofins Built Environment Testing may not have received and tested a representative number of samples for every region or time period. Eurofins Built Environment Testing hereby disclaims any liability for any and all direct, indirect, punitive, incidental, special or consequential damages arising out of the use or interpretation of the data contained in, or any actions taken or omitted in reliance upon, this report.

Eurofins Built Environment Testing West, LLC
111 Anza Boulevard, Suite 122, Burlingame, CA 94010
(833) 465-5857 www.eurofinsus.com/Built

Client: F.I.T. Services, LLC
C/O: Michael Michie
Re: 26-054; Cunha Intermediate School

Date of Sampling: 10-10-2026
Date of Receipt: 10-12-2026
Date of Report: 10-12-2026

MoldRANGE™: Extended Outdoor Comparison

PROJECT ANALYST AND SIGNATORY REPORT

Project Analyst



Analyst: Murali Putty

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Eurofins Built Environment Testing West, LLC
111 Anza Boulevard, Suite 122, Burlingame, CA 94010
(833) 465-5857 www.eurofinsus.com/Built

Client: F.I.T. Services, LLC
C/O: Michael Michie
Re: 26-054; Cunha Intermediate School

Date of Sampling: 10-10-2026
Date of Receipt: 10-12-2026
Date of Report: 10-12-2026

MoldSTAT™: Supplementary Statistical Spore Trap Report

Outdoor Summary: 43351192: Outside Bldg.

Species detected	Outdoor sample spores/m3 (<100 / 1K / 10K / >100K)	Typical outdoor ranges (North America)	Freq. %
Ascospores	770	13 - 210 - 5,700	75
Basidiospores	1,400	13 - 370 - 23,000	88
Cladosporium	830	27 - 480 - 8,300	88
Penicillium/Aspergillus types	510	13 - 180 - 2,600	59
Smuts, Periconia, Myxomycetes	< 7	7 - 40 - 630	61
Total	3,500		

The "Typical outdoor ranges" and "Freq. %" columns show the typical low, medium, and high spore counts per cubic meter and the frequency of occurrence for the given spore type. The low, medium, and high values represent the 2.5, 50, and 97.5 percentile values when the spore type is detected. For example, if the low value is 53 and the frequency of occurence is 63%, it would mean that we typically detect the given spore type on 63 percent of all outdoor samples and, when detected, 2.5% of the time it is present in levels below 53 spores/m3.

Indoor Samples

Location: 43351209: Classroom 115

% of outdoor total spores/m3	Friedman chi-square* (indoor variation)	Agreement ratio** (indoor/outdoor)	Spearman rank correlation*** (indoor/outdoor)	MoldSCORE**** (indoor/outdoor)
Result: 4%	dF: 5 Result: 9.0952 Critical value: 11.0705 Inside Similar: Yes	Result: 0.6667	dF: 4 Result: -0.8500 Critical value: N/A Outside Similar: N/A	Score: 114 Result: Low

Species Detected	Spores/m3 (<100 / 1K / 10K / >100K)
Ascospores	53
Penicillium/Aspergillus types	110
Total	160

Location: 43351194: Classroom 108

% of outdoor total spores/m3	Friedman chi-square* (indoor variation)	Agreement ratio** (indoor/outdoor)	Spearman rank correlation*** (indoor/outdoor)	MoldSCORE**** (indoor/outdoor)
Result: 1%	dF: 5 Result: 9.0952 Critical value: 11.0705 Inside Similar: Yes	Result: 0.3333	dF: 5 Result: -0.6000 Critical value: 0.8000 Outside Similar: No	Score: 107 Result: Low

Species Detected	Spores/m3 (<100 / 1K / 10K / >100K)
Penicillium/Aspergillus types	53
Rusts	13
Total	67

Eurofins Built Environment Testing West, LLC
111 Anza Boulevard, Suite 122, Burlingame, CA 94010
(833) 465-5857 www.eurofinsus.com/Built

Client: F.I.T. Services, LLC
C/O: Michael Michie
Re: 26-054; Cunha Intermediate School

Date of Sampling: 10-10-2026
Date of Receipt: 10-12-2026
Date of Report: 10-12-2026

MoldSTAT™: Supplementary Statistical Spore Trap Report

Location: 43351206: Classroom 101

% of outdoor total spores/m3	Friedman chi-square* (indoor variation)	Agreement ratio** (indoor/outdoor)	Spearman rank correlation*** (indoor/outdoor)	MoldSCORE**** (indoor/outdoor)
Result: 1%	dF: 5 Result: 9.0952 Critical value: 11.0705 Inside Similar: Yes	Result: 0.4000	dF: 4 Result: -0.4000 Critical value: N/A Outside Similar: N/A	Score: 107 Result: Low

Species Detected	Spores/m3 <100 1K 10K >100K
Penicillium/Aspergillus types	53
Total	53

Location: 43351191: Classroom 202

% of outdoor total spores/m3	Friedman chi-square* (indoor variation)	Agreement ratio** (indoor/outdoor)	Spearman rank correlation*** (indoor/outdoor)	MoldSCORE**** (indoor/outdoor)
Result: 3%	dF: 5 Result: 9.0952 Critical value: 11.0705 Inside Similar: Yes	Result: 0.6667	dF: 4 Result: -0.3000 Critical value: N/A Outside Similar: N/A	Score: 106 Result: Low

Species Detected	Spores/m3 <100 1K 10K >100K
Cladosporium	53
Penicillium/Aspergillus types	53
Total	110

Location: 43351204: Classroom 205

% of outdoor total spores/m3	Friedman chi-square* (indoor variation)	Agreement ratio** (indoor/outdoor)	Spearman rank correlation*** (indoor/outdoor)	MoldSCORE**** (indoor/outdoor)
Result: 1%	dF: 5 Result: 9.0952 Critical value: 11.0705 Inside Similar: Yes	Result: 0.4000	dF: 4 Result: -0.4000 Critical value: N/A Outside Similar: N/A	Score: 107 Result: Low

Species Detected	Spores/m3 <100 1K 10K >100K
Penicillium/Aspergillus types	53
Total	53

Eurofins Built Environment Testing West, LLC
111 Anza Boulevard, Suite 122, Burlingame, CA 94010
(833) 465-5857 www.eurofinsus.com/Built

Client: F.I.T. Services, LLC
C/O: Michael Michie
Re: 26-054; Cunha Intermediate School

Date of Sampling: 10-10-2026
Date of Receipt: 10-12-2026
Date of Report: 10-12-2026

MoldSTAT™: Supplementary Statistical Spore Trap Report

Location: 43351190: Classroom 211

% of outdoor total spores/m3	Friedman chi-square* (indoor variation)	Agreement ratio** (indoor/outdoor)	Spearman rank correlation*** (indoor/outdoor)	MoldSCORE**** (indoor/outdoor)
Result: 14%	dF: 5 Result: 9.0952 Critical value: 11.0705 Inside Similar: Yes	Result: 0.8889	dF: 5 Result: 0.2250 Critical value: 0.8000 Outside Similar: No	Score: 114 Result: Low

Species Detected	Spores/m3 <100 1K 10K >100K	
Ascospores		110
Basidiospores		53
Cladosporium		160
Other brown		13
Penicillium/Aspergillus types		160
Total		490

* The Friedman chi-square statistic is a non-parametric test that examines variation in a set of data (in this case, all indoor spore counts). The null hypothesis (H0) being tested is that there is no meaningful difference in the data for all indoor locations. The alternative hypothesis (used if the test disproves the null hypothesis) is that there is a difference between the indoor locations. The null hypothesis is rejected when the result of the test is greater than the critical value. The critical value that is displayed is based on the degrees of freedom (dF) of the test and a significance level of 0.05.

** An agreement ratio is a simple method for assessing the similarity of two samples (in this case the indoor sample and the outdoor summary) based on the spore types present. A score of one indicates that the types detected in one location are the same as that in the other. A score of zero indicates that none of the types detected indoors are present outdoors. Typically, an agreement of 0.8 or higher is considered high.

*** The Spearman rank correlation is a non-parametric test that examines correlation between two sets of data (in this case the indoor location and the outdoor summary). The null hypothesis (H0) being tested is that the indoor and outdoor samples are unrelated. The alternative hypothesis (used if the test disproves the null hypothesis) is that the samples are similar. The null hypothesis is rejected when the result of the test is greater than the critical value. The critical value that is displayed is based on the degrees of freedom (dF) of the test and a significance level of 0.05.

**** MoldSCORE™ is a specialized method for examining air sampling data. It is a score between 100 and 300, with 100 indicating a greater likelihood that the airborne indoor spores originated from the outside, and 300 indicating a greater likelihood that they originated from an inside source. The Result displayed is based on the numeric score given and will be either Low, Medium, or High, indicating a low, medium, or high likelihood that the spores detected originated from an indoor source. Eurofins Built Environment Testingreserves the right to, and may at anytime, modify or change the MoldScore algorithm without notice.

Interpretation of the data contained in this report is left to the client or the persons who conducted the field work. This report is provided for informational and comparative purposes only and should not be relied upon for any other purpose. "Typical outdoor ranges" are based on the results of the analysis of samples delivered to and analyzed by Eurofins Built Environment Testing Testing and assumptions regarding the origins of those samples. Sampling techniques, contaminants infecting samples, unrepresentative samples and other similar or dissimilar factors may affect these results. With the statistical analysis provided, as with all statistical comparisons and analyses, false-positive and false-negative results can and do occur. Eurofins Built Environment Testing hereby disclaims any liability for any and all direct, indirect, punitive, incidental, special or consequential damages arising out of the data contained in, or any actions taken or omitted in reliance upon, this report.

Eurofins Built Environment Testing West, LLC
111 Anza Boulevard, Suite 122, Burlingame, CA 94010
(833) 465-5857 www.eurofinsus.com/Built

Client: F.I.T. Services, LLC
C/O: Michael Michie
Re: 26-054; Cunha Intermediate School

Date of Sampling: 10-10-2026
Date of Receipt: 10-12-2026
Date of Report: 10-12-2026

MoldSTAT™: Supplementary Statistical Spore Trap Report

PROJECT ANALYST AND SIGNATORY REPORT

Project Analyst



Analyst: Murali Putty

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

F.I.T. Environmental Services

☑ 952 School St. #111
Napa, CA 94559

Microbial SAMPLE DATA SHEET

004754592

PAGE 1 OF 1

Project Name/Address: Cuhna Intermediate School *Report Recipient* :

Client Name: CUSD F.I.T. Project #: 26-054 Sampled By: Michael M. Sampling Date: 10-10-2026

Sample(s) Sent To: ☐ MAL ☐ EM Lab ☐ Other:

Turnaround Time: ✓ Rush ___ Standard same DAY

Email Report To: ☐ mmichie@fitenvironmental.com ☐ pgarrett@fitenvironmental.com

Sample I.D. #	Date	Type	Sample Description: Air	Bulk	Swab	Water	Tape Lift	Sample Location	Volume Liters	Culture	Culture Screen	Direct Exam	Legionella		Analysis
4335 1209	10-10	Spore Trap	✓					Classroom 115	75						
4335 1194	10-10	Spore Trap	✓					Class room 108	75						
4335 1206	10-10	Spore Trap	✓					Class room 101	75						
4335 1191	10-10	Spore Trap	✓					Classroom 202	75						
4335 1204	10-10	Spore Trap	✓					Classroom 205	75						
4335 1190	10-10	Spore Trap	✓					Classroom 211	75						
4335 1192	10-10	Spore Trap	✓					Outside BLDG.	150						

	NAME:	SIGNATURE:	DATE:	REMARKS:
Relinquished By:	Michael Michie	[redacted]	10-10-2026	
Received By:	Ken Truong		10/10/26 1103	
Relinquished By:				
Received By:				