



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/30/2022
Received: 09/21/2022
Sampled By: Ian Barr
Work Order: 2264007

C
L
I
E
N
T
Yamhill Carlton School District
Attn: -
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :

Sampling Location: Yamhill Carlton Elementary

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2264007-01	Sample Name: 01 00 102 KF Sampled: 9/10/22 8:18					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-02	Sample Name: 01 00 103 KF Sampled: 9/10/22 8:19					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-03	Sample Name: 01 00 104 KF Sampled: 9/10/22 8:25					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-04	Sample Name: 01 00 107 CF Sampled: 9/10/22 8:29					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	09/27/22 15:41
2264007-05	Sample Name: 01 00 108 CF Sampled: 9/10/22 8:32					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-06	Sample Name: 01 00 109 BF Sampled: 9/10/22 8:34					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-07	Sample Name: 01 00 112 CF Sampled: 9/10/22 8:42					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-08	Sample Name: 01 00 113 D2 Sampled: 9/10/22 8:47					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-09	Sample Name: 01 00 114 CF Sampled: 9/10/22 8:48					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	09/27/22 15:41
2264007-10	Sample Name: 01 00 114 DW Sampled: 9/10/22 8:49					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	09/27/22 15:41



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/30/2022
Received: 09/21/2022
Sampled By: Ian Barr
Work Order: 2264007

C
L
I
E
N
T
Yamhill Carlton School District
Attn: -
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :

Sampling Location: Yamhill Carlton Elementary

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2264007-11	Sample Name: 01 00 131 CF Sampled: 9/10/22 8:55					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	09/27/22 15:41
2264007-12	Sample Name: 01 00 132 DW Sampled: 9/10/22 8:56					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	09/27/22 15:41
2264007-13	Sample Name: 01 00 116 CF Sampled: 9/10/22 9:02					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-14	Sample Name: 01 00 116 DF Sampled: 9/10/22 9:04					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	09/27/22 15:41
2264007-15	Sample Name: 01 00 118 CF Sampled: 9/10/22 9:06					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-16	Sample Name: 01 00 120 CF Sampled: 9/10/22 9:10					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-17	Sample Name: 01 00 123 CF Sampled: 9/10/22 9:15					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-18	Sample Name: 01 00 124 DW Sampled: 9/10/22 9:16					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-19	Sample Name: 01 00 126 DW Sampled: 9/10/22 9:18					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-20	Sample Name: 01 00 127 CF Sampled: 9/10/22 9:31					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/30/2022
Received: 09/21/2022
Sampled By: Ian Barr
Work Order: 2264007

C
L
I
E
N
T
Yamhill Carlton School District
Attn: -
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :

Sampling Location: Yamhill Carlton Elementary

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2264007-21	Sample Name: 01 00 128 DW Sampled: 9/10/22 9:33					Matrix: Drinking Water	
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-22	Sample Name: 01 00 129 DW Sampled: 9/10/22 9:35					Matrix: Drinking Water	
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-23	Sample Name: 01 00 130 DW Sampled: 9/10/22 9:35					Matrix: Drinking Water	
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-24	Sample Name: 01 00 105 SF Sampled: 9/10/22 9:39					Matrix: Drinking Water	
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	09/27/22 15:41
2264007-25	Sample Name: 01 00 106 DW Sampled: 9/10/22 9:39					Matrix: Drinking Water	
†Lead	1030	EPA 200.9	5	ppb	1	15 ppb	09/27/22 15:41

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/24/2022
Received: 10/12/2022
Sampled By: Ian Barr
Work Order: 2285010

C
L
I
E
N
T
Yamhill Carlton School District
Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :
PO # : 230354

Sampling Location: Yamhill Carlton Intermediate School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2285010-01	Sample Name: 0301 001BF Sampled: 10/3/22 5:45						Matrix: Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	10/17/22 16:05
2285010-02	Sample Name: 0301 002BF Sampled: 10/3/22 5:46						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285010-03	Sample Name: 0301 003BF Sampled: 10/3/22 5:47						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285010-04	Sample Name: 0301 004BF Sampled: 10/3/22 5:48						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285010-05	Sample Name: 0301 005BF Sampled: 10/3/22 5:49						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285010-06	Sample Name: 0301 006DW Sampled: 10/3/22 5:52						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285010-07	Sample Name: 0301 007DW Sampled: 10/3/22 5:52						Matrix: Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	10/17/22 16:05
2285010-08	Sample Name: 0301 008CF Sampled: 10/3/22 5:57						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285010-09	Sample Name: 0301 009BF Sampled: 10/3/22 5:58						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285010-10	Sample Name: 0301 010CF Sampled: 10/3/22 6:14						Matrix: Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	10/17/22 16:05



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/24/2022
Received: 10/12/2022
Sampled By: Ian Barr
Work Order: 2285010

C
L
I
E
N
T
Yamhill Carlton School District
Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :
PO # : 230354

Sampling Location: Yamhill Carlton Intermediate School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2285010-11	Sample Name: 0301 011CF Sampled: 10/3/22 6:15						Matrix: Water
†Lead	1030	EPA 200.9	6	ppb	1	15 ppb	10/17/22 16:05
2285010-12	Sample Name: 0301 012CF Sampled: 10/3/22 6:22						Matrix: Water
†Lead	1030	EPA 200.9	6	ppb	1	15 ppb	10/17/22 16:05
2285010-13	Sample Name: 0301 013CF Sampled: 10/3/22 6:21						Matrix: Water
†Lead	1030	EPA 200.9	8	ppb	1	15 ppb	10/17/22 16:05
2285010-14	Sample Name: 0301 014CF Sampled: 10/3/22 6:18						Matrix: Water
†Lead	1030	EPA 200.9	14	ppb	1	15 ppb	10/17/22 16:05
2285010-15	Sample Name: 0301 015CF Sampled: 10/3/22 6:24						Matrix: Water
†Lead	1030	EPA 200.9	6	ppb	1	15 ppb	10/17/22 16:05

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/24/2022
Received: 10/12/2022
Sampled By: Ian Barr
Work Order: 2285011

C
L
I
E
N
T
Yamhill Carlton School District
Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :
PO # : 230354

Sampling Location: Yamhill Carlton Elementary

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2285011-01	Sample Name: 0100 031CF Sampled: 10/3/22 6:36						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285011-02	Sample Name: 0100 032DW Sampled: 10/3/22 6:36						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285011-03	Sample Name: 0100 033CF Sampled: 10/3/22 6:42						Matrix: Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	10/17/22 16:05
2285011-04	Sample Name: 0100 034DW Sampled: 10/3/22 6:42						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285011-05	Sample Name: 0100 035CF Sampled: 10/3/22 6:45						Matrix: Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	10/17/22 16:05
2285011-06	Sample Name: 0100 036DW Sampled: 10/3/22 6:46						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285011-07	Sample Name: 0100 037CF Sampled: 10/3/22 6:51						Matrix: Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	10/17/22 16:05
2285011-08	Sample Name: 0100 038DW Sampled: 10/3/22 6:51						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285011-09	Sample Name: 0100 039CF Sampled: 10/3/22 6:54						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285011-10	Sample Name: 0100 041BF Sampled: 10/3/22 6:58						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/24/2022
Received: 10/12/2022
Sampled By: Ian Barr
Work Order: 2285011

C
L
I
E
N
T
Yamhill Carlton School District
Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :
PO # : 230354

Sampling Location: Yamhill Carlton Elementary

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2285011-11	Sample Name: 0100 042BF Sampled: 10/3/22 6:59						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285011-12	Sample Name: 0100 043CF Sampled: 10/3/22 7:01						Matrix: Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	10/17/22 16:05
2285011-13	Sample Name: 0100 044CF Sampled: 10/3/22 7:05						Matrix: Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	10/17/22 16:05
2285011-14	Sample Name: 0100 045DW Sampled: 10/3/22 7:06						Matrix: Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	10/17/22 16:05
2285011-15	Sample Name: 0100 046CF Sampled: 10/3/22 7:10						Matrix: Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	10/17/22 16:05
2285011-16	Sample Name: 0100 047DW Sampled: 10/3/22 7:12						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285011-17	Sample Name: 0100 048CF Sampled: 10/3/22 7:15						Matrix: Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	10/17/22 16:05
2285011-18	Sample Name: 0100 049DW Sampled: 10/3/22 7:17						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285011-19	Sample Name: 0100 050CF Sampled: 10/3/22 7:17						Matrix: Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	10/17/22 16:05
2285011-20	Sample Name: 0100 051DW Sampled: 10/3/22 7:18						Matrix: Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	10/17/22 16:05



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/24/2022
Received: 10/12/2022
Sampled By: Ian Barr
Work Order: 2285011

C
L
I
E
N
T
Yamhill Carlton School District
Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :
PO # : 230354

Sampling Location: Yamhill Carlton Elementary

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2285011-21	Sample Name: 0100 052BF Sampled: 10/3/22 7:20						Matrix: Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	10/17/22 16:05
2285011-22	Sample Name: 0100 053BF Sampled: 10/3/22 7:22						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/17/22 16:05
2285011-23	Sample Name: 0100 054CF Sampled: 10/3/22 7:24						Matrix: Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	10/17/22 16:05
2285011-24	Sample Name: 0100 055DW Sampled: 10/3/22 7:26						Matrix: Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	10/17/22 16:05
2285011-25	Sample Name: 0100 040DW Sampled: 10/3/22 6:56						Matrix: Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	10/17/22 16:05

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/20/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3011010

C L I E N T **Yamhill Carlton School District**

Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:

Project # : -
Sample Type :

Sampling Location: Main Campus

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3011010-01	Sample Name: 225103 02 003 SF 22A Sampled: 12/27/22 6:15						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3011010-02	Sample Name: 225103 02 012 BF 22A Sampled: 12/27/22 6:18						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3011010-03	Sample Name: 225103 02 004 KF 22A Sampled: 12/27/22 6:21						Matrix: Drinking Water
†Lead	1030	EPA 200.9	7	ppb	1	15 ppb	01/18/23 16:21
3011010-04	Sample Name: 225103 02 001 KF 22A Sampled: 12/27/22 6:30						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3011010-05	Sample Name: 225103 02 008 SF 22A Sampled: 12/27/22 6:34						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3011010-06	Sample Name: 225102 01 006 BF 22A Sampled: 12/27/22 6:37						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/18/23 16:21
3011010-07	Sample Name: 225103 02 013 BF 22A Sampled: 12/27/22 6:40						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3011010-08	Sample Name: 225102 01 007 BF 22A Sampled: 12/27/22 6:45						Matrix: Drinking Water
†Lead	1030	EPA 200.9	12	ppb	1	15 ppb	01/18/23 16:21
3011010-09	Sample Name: 225103 02 010 BF 22A Sampled: 12/27/22 6:48						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/18/23 16:21
3011010-10	Sample Name: 225102 01 004 WB 22A Sampled: 12/27/22 6:52						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/18/23 16:21



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/20/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3011010

**C
L
I
E
N
T** **Yamhill Carlton School District**
Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :

Sampling Location: Main Campus

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3011010-11	Sample Name: 225102 01 010 SF 22A Sampled: 12/27/22 6:56						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3011010-12	Sample Name: 225103 02 011 KF 22A Sampled: 12/27/22 7:01						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/18/23 16:21
3011010-13	Sample Name: 225103 02 006 BF 22A Sampled: 12/27/22 7:06						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3011010-14	Sample Name: 225102 01 002 DW 22A Sampled: 12/27/22 7:11						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/18/23 16:21
3011010-15	Sample Name: 225102 01 009 BF 22A Sampled: 12/27/22 7:15						Matrix: Drinking Water
+Lead	1030	EPA 200.9	24	ppb	2	15 ppb	01/18/23 16:21 MCLE
3011010-16	Sample Name: 225102 01 003 DW 22A Sampled: 12/27/22 7:21						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/18/23 16:21
3011010-17	Sample Name: 225103 02 007 BF 22A Sampled: 12/27/22 7:24						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3011010-18	Sample Name: 225103 02 014 BF 22A Sampled: 12/27/22 7:30						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3011010-19	Sample Name: 225103 02 005 KF 22A Sampled: 12/27/22 7:36						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/20/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3011010

C **Yamhill Carlton School District**
L Attn: Ian Barr
I 120 Larch Pl
E Yamhill OR, 97148
N Phone: (503) 852-6980
T

Project:
Project # : -
Sample Type :

Sampling Location: Main Campus

Lab Number

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/20/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012017

C L I E N T Yamhill Carlton School District

Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:

Project # : -
Sample Type :

Sampling Location: CTE

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012017-01	Sample Name: 2251 02 08 001 BF 22A Sampled: 12/12/22 6:05						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-02	Sample Name: 2251 02 08 009 CF 22A Sampled: 12/12/22 6:08						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-03	Sample Name: 2251 02 08 008 CF 22A Sampled: 12/12/22 6:11						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-04	Sample Name: 2251 02 08 005 BF 22A Sampled: 12/12/22 6:14						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-05	Sample Name: 2251 02 08 006 BF 22A Sampled: 12/12/22 6:18						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/18/23 16:21
3012017-06	Sample Name: 2551 02 08 007 BF 22A Sampled: 12/12/22 6:21						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-07	Sample Name: 2251 02 08 010 BF 22A Sampled: 12/12/22 6:25						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/18/23 16:21
3012017-08	Sample Name: 2251 02 08 011 BF 22A Sampled: 12/12/22 6:30						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-09	Sample Name: 2251 02 08 025 CF 22A Sampled: 12/12/22 6:34						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-10	Sample Name: 2251 02 08 026 CF 22A Sampled: 12/12/22 6:37						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/20/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012017

C **Yamhill Carlton School District**
L Attn: Ian Barr
I 120 Larch Pl
E Yamhill OR, 97148
N Phone: (503) 852-6980
T

Project:
Project # : -
Sample Type :

Sampling Location: CTE

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012017-11	Sample Name: 2251 02 08 013 CF 22A Sampled: 12/12/22 6:40						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-12	Sample Name: 2251 02 08 014 CF 22A Sampled: 12/12/22 6:45						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/18/23 16:21
3012017-13	Sample Name: 2251 02 08 021 CF 22A Sampled: 12/12/22 6:48						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-14	Sample Name: 2251 02 08 022 CF 22A Sampled: 12/12/22 6:51						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-15	Sample Name: 2251 02 08 018 CF 22A Sampled: 12/12/22 6:54						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/18/23 16:21
3012017-16	Sample Name: 2251 02 08 020 CF 22A Sampled: 12/12/22 6:57						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-17	Sample Name: 2251 02 08 015 CF 22A Sampled: 12/12/22 6:59						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/18/23 16:21
3012017-18	Sample Name: 2251 02 08 016 CF 22A Sampled: 12/12/22 7:02						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-19	Sample Name: 2251 02 08 017 CF 22A Sampled: 12/12/22 7:05						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-20	Sample Name: 2251 02 08 024 CF 22A Sampled: 12/12/22 7:09						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/20/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012017

C **Yamhill Carlton School District**
L Attn: Ian Barr
I 120 Larch Pl
E Yamhill OR, 97148
N Phone: (503) 852-6980
T

Project:
Project # : -
Sample Type :

Sampling Location: CTE

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012017-21	Sample Name: 2251 02 08 004 CF 22A Sampled: 12/12/22 7:12						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/18/23 16:21
3012017-22	Sample Name: 2251 02 08 023 CF 22A Sampled: 12/12/22 7:15						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-23	Sample Name: 2251 02 08 002 DW 22A Sampled: 12/12/22 7:18						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-24	Sample Name: 2251 02 08 003 DW 22A Sampled: 12/12/22 7:21						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/18/23 16:21
3012017-25	Sample Name: 2251 02 08 025 CF 22A Sampled: 12/12/22 7:25						Matrix: Drinking Water
†Lead	1030	EPA 200.9	28	ppb	2	15 ppb	01/18/23 16:21 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit

MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/24/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012027

**C
L
I
E
N
T** **Yamhill Carlton School District**
Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012027-01	Sample Name: 2251 03 00 001 DW Sampled: 10/12/22 6:08					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-02	Sample Name: 2251 03 00 002 DW Sampled: 10/12/22 6:09					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-03	Sample Name: 2251 03 00 003 DW Sampled: 10/12/22 6:10					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-04	Sample Name: 2251 03 00 004 BF Sampled: 10/12/22 6:10					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-05	Sample Name: 2251 03 00 005 BF Sampled: 10/12/22 6:11					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-06	Sample Name: 2251 03 00 006 BF Sampled: 10/12/22 6:15					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/19/23 15:04
3012027-07	Sample Name: 2251 03 00 007 KF Sampled: 10/12/22 6:18					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-08	Sample Name: 2251 03 00 008 CF Sampled: 10/12/22 6:20					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-09	Sample Name: 2251 03 00 009 CF Sampled: 10/12/22 6:22					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	17	ppb	1	15 ppb	01/19/23 15:04 MCLE
3012027-10	Sample Name: 2251 03 00 010 BF Sampled: 10/12/22 6:25					Matrix: Drinking Water	
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/24/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012027

C **Yamhill Carlton School District**
L Attn: Ian Barr
I 120 Larch Pl
E Yamhill OR, 97148
N Phone: (503) 852-6980
T

Project:
Project # : -
Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012027-11	Sample Name: 2251 03 00 012 CF Sampled: 10/12/22 6:24						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/19/23 15:04
3012027-12	Sample Name: 2251 03 00 011 DW Sampled: 10/12/22 6:28						Matrix: Drinking Water
†Lead	1030	EPA 200.9	12	ppb	1	15 ppb	01/19/23 15:04
3012027-13	Sample Name: 2251 03 00 013 CF Sampled: 10/12/22 6:33						Matrix: Drinking Water
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	01/19/23 15:04
3012027-14	Sample Name: 2251 03 00 014 CF Sampled: 10/12/22 6:38						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-15	Sample Name: 2251 03 00 015 CF Sampled: 10/12/22 6:39						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/19/23 15:04
3012027-16	Sample Name: 2251 03 00 016 CF Sampled: 10/12/22 6:39						Matrix: Drinking Water
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	01/19/23 15:04
3012027-17	Sample Name: 2251 03 00 017 CF Sampled: 10/12/22 6:41						Matrix: Drinking Water
†Lead	1030	EPA 200.9	6	ppb	1	15 ppb	01/19/23 15:04
3012027-18	Sample Name: 2251 03 00 018 CF Sampled: 10/12/22 6:42						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-19	Sample Name: 2251 03 00 019 CF Sampled: 10/12/22 6:44						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/19/23 15:04
3012027-20	Sample Name: 2251 03 00 020 CF Sampled: 10/12/22 6:46						Matrix: Drinking Water
†Lead	1030	EPA 200.9	8	ppb	1	15 ppb	01/19/23 15:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/24/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012027

C **Yamhill Carlton School District**
L Attn: Ian Barr
I 120 Larch Pl
E Yamhill OR, 97148
N Phone: (503) 852-6980
T

Project:
Project # : -
Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012027-21	Sample Name: 2251 03 00 021 CF Sampled: 10/12/22 6:46						Matrix: Drinking Water
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	01/23/23 16:21
3012027-22	Sample Name: 2251 03 00 022 BF Sampled: 10/12/22 6:50						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-23	Sample Name: 2251 03 00 023 BF Sampled: 10/12/22 6:51						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012027-24	Sample Name: 2251 03 00 024 CF Sampled: 10/12/22 6:52						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/23/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012032

**C
L
I
E
N
T** **Yamhill Carlton School District**
Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012032-01	Sample Name: 2251 02 00 203 CF 22A Sampled: 12/30/22 6:35						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-02	Sample Name: 2251 02 00 201 BF 22A Sampled: 12/30/22 6:38						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-03	Sample Name: 2251 02 00 121 KF 22A Sampled: 12/30/22 6:40						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-04	Sample Name: 2251 02 00 107 BF 22A Sampled: 12/30/22 6:45						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-05	Sample Name: 2251 02 00 205 CF 22A Sampled: 12/30/22 6:50						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-06	Sample Name: 2251 02 00 211 WB 22A Sampled: 12/30/22 6:53						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-07	Sample Name: 2251 02 00 210 DW 22A Sampled: 12/30/22 6:58						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-08	Sample Name: 2251 02 00 003 BF 22A Sampled: 12/30/22 7:01						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-09	Sample Name: 2251 02 00 207 CF 22A Sampled: 12/30/22 7:06						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-10	Sample Name: 2251 02 00 208 CF 22A Sampled: 12/30/22 7:10						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/23/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012032

C L I E N T **Yamhill Carlton School District**

Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:

Project # : -
Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012032-11	Sample Name: 2251 02 00 206 CF 22A Sampled: 12/30/22 7:12						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-12	Sample Name: 2251 02 00 204 CF 22A Sampled: 12/30/22 7:15						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-13	Sample Name: 2251 02 00 105 KF 22A Sampled: 12/30/22 7:20						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-14	Sample Name: 2251 02 00 104 SF 22A Sampled: 12/30/22 7:22						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-15	Sample Name: 2251 02 00 114 CF 22A Sampled: 12/30/22 7:25						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-16	Sample Name: 2251 02 00 108 CF 22A Sampled: 12/30/22 7:30						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-17	Sample Name: 2251 02 00 109 CF 22A Sampled: 12/30/22 7:32						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-18	Sample Name: 2251 02 00 113 CF 22A Sampled: 12/30/22 7:36						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/19/23 15:04
3012032-19	Sample Name: 2251 02 00 102 CF 22A Sampled: 12/30/22 7:38						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-20	Sample Name: 2251 02 00 007 KF 22A Sampled: 12/30/22 7:40						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/23/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012032

C L I E N T **Yamhill Carlton School District**

Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:

Project # : -
Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012032-21	Sample Name: 2251 02 00 111 CF 22A Sampled: 12/30/22 7:45						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/19/23 15:04
3012032-22	Sample Name: 2251 02 00 110 CF 22A Sampled: 12/30/22 7:48						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-23	Sample Name: 2251 02 00 002 BF 22A Sampled: 12/30/22 7:50						Matrix: Drinking Water
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	01/19/23 15:04
3012032-24	Sample Name: 2251 02 00 115 BF 22A Sampled: 12/30/22 8:00						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-25	Sample Name: 2251 02 00 212 BF 22A Sampled: 12/30/22 8:03						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-26	Sample Name: 2251 02 00 209 DW 22A Sampled: 12/30/22 6:00						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-27	Sample Name: 2251 02 00 006 CF 22A Sampled: 12/30/22 6:05						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/19/23 15:04
3012032-28	Sample Name: 2251 02 00 202 BF 22A Sampled: 12/30/22 6:10						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-29	Sample Name: 2251 02 00 005 KF 22A Sampled: 12/30/22 6:12						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-30	Sample Name: 2251 02 00 004 BF 22A Sampled: 12/30/22 6:14						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/23/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012032

C **Yamhill Carlton School District**
L Attn: Ian Barr
I 120 Larch Pl
E Yamhill OR, 97148
N Phone: (503) 852-6980
T

Project:
Project # : -
Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012032-31	Sample Name: 2251 02 00 001 CF 22A Sampled: 12/30/22 6:17						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-32	Sample Name: 2251 02 00 202 BF 22A Sampled: 12/30/22 6:20						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/19/23 15:04
3012032-33	Sample Name: 2251 02 00 106 WB 22A Sampled: 12/30/22 6:25						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-34	Sample Name: 2251 02 00 103 DW 22A Sampled: 12/30/22 6:27						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012032-35	Sample Name: 2251 02 00 202 BF 22A Sampled: 12/30/22 6:30						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/19/23 15:04

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/23/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012034

**C
L
I
E
N
T** **Yamhill Carlton School District**
Attn: Ian Barr
120 Larch Pl
Yamhill OR, 97148
Phone: (503) 852-6980

Project:
Project # : -
Sample Type :

Sampling Location: New Gym

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012034-01	Sample Name: 2251 02 10 007 BF 22A Sampled: 12/15/22 7:05						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/19/23 15:04
3012034-02	Sample Name: 2251 02 10 008 BF 22A Sampled: 12/15/22 7:09						Matrix: Drinking Water
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	01/19/23 15:04
3012034-03	Sample Name: 2251 02 10 002 BF 22A Sampled: 12/15/22 7:11						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/19/23 15:04
3012034-04	Sample Name: 2251 02 10 014 BF 22A Sampled: 12/15/22 7:15						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/19/23 15:04
3012034-05	Sample Name: 2251 02 10 010 DW 22A Sampled: 12/15/22 7:18						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012034-06	Sample Name: 2251 02 10 011 WB 22A Sampled: 12/15/22 7:21						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012034-07	Sample Name: 2251 02 10 015 DW 22A Sampled: 12/15/22 7:24						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012034-08	Sample Name: 2251 02 10 012 DW 22A Sampled: 12/15/22 7:27						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/19/23 15:04
3012034-09	Sample Name: 2251 02 10 013 DW 22A Sampled: 12/15/22 7:31						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012034-10	Sample Name: 2251 02 10 005 BF 22A Sampled: 12/15/22 7:35						Matrix: Drinking Water
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	01/19/23 15:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/23/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012034

C **Yamhill Carlton School District**
L Attn: Ian Barr
I 120 Larch Pl
E Yamhill OR, 97148
N Phone: (503) 852-6980
T

Project:
Project # : -
Sample Type :

Sampling Location: New Gym

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3012034-11	Sample Name: 2251 02 10 011 WB 22A Sampled: 12/15/22 6:35						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012034-12	Sample Name: 2251 02 10 022 DW 22A Sampled: 12/15/22 6:38						Matrix: Drinking Water
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	01/19/23 15:04
3012034-13	Sample Name: 2251 02 10 024 DW 22A Sampled: 12/15/22 6:40						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012034-14	Sample Name: 2251 02 10 003 BF 22A Sampled: 12/15/22 6:43						Matrix: Drinking Water
†Lead	1030	EPA 200.9	6	ppb	1	15 ppb	01/19/23 15:04
3012034-15	Sample Name: 2251 02 10 021 BF 22A Sampled: 12/15/22 6:47						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012034-16	Sample Name: 2251 02 10 006 BF 22A Sampled: 12/15/22 6:50						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	01/19/23 15:04
3012034-17	Sample Name: 2251 02 10 004 SF 22A Sampled: 12/15/22 6:54						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04
3012034-18	Sample Name: 2251 02 10 001 BF 22A Sampled: 12/15/22 6:56						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	01/19/23 15:04
3012034-19	Sample Name: 2251 02 10 023 WB 22A Sampled: 12/15/22 6:58						Matrix: Drinking Water
†Lead	1030	EPA 200.9	10	ppb	1	15 ppb	01/19/23 15:04
3012034-20	Sample Name: 2251 02 10 009 DW 22A Sampled: 12/15/22 7:01						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	01/19/23 15:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 01/23/2023
Received: 01/11/2023
Sampled By: Ian Barr
Work Order: 3012034

C **Yamhill Carlton School District**
L Attn: Ian Barr
I 120 Larch Pl
E Yamhill OR, 97148
N Phone: (503) 852-6980
T

Project:
Project # : -
Sample Type :

Sampling Location: New Gym

Lab Number

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____

A handwritten signature in black ink, appearing to read 'Adriana', is written over a horizontal line.

Adriana Gonzalez-Gray
Laboratory Director