

Manlio Silva Elementary School Portable Additions (Two Portables)

2026-05
10/26

LODI UNIFIED SCHOOL DISTRICT

ADDENDUM #2

FROM : ARCHITECTURICA
555 W. BENJAMIN HOLT DRIVE
SUITE 423
STOCKTON, CA 95207
(209) 952-5850 FAX (209) 952-2442

PROJECT: Manlio Silva Elementary School Relocated Portables
Lodi Unified School District

LOCATION : 6250 SCOTT CREEK DR, STOCKTON, CA 95219

REF. # : District Project No. # 0874-8874-920-78
DSA FILE # 39-50
Manlio Silva ES
Arch Project No. 2026-05
DSA App. No. 02-124197
DSA PTN: 68585-303

OPSC NO. : n/a

OWNER : Lodi Unified School District
1305 East Vine Street
Lodi, CA 95240

DATE : October 20, 2026

NOTICE TO ALL BIDDERS

IT IS THE PURPOSE AND INTENT OF THIS ADDENDUM TO MODIFY AND/OR CLARIFY THE DRAWINGS AND SPECIFICATIONS FOR THIS PROJECT AND THIS ADDENDUM SHALL BECOME A PART OF THE CONTRACT DOCUMENTS. THESE CHANGES AND/OR INTERPRETATIONS SHALL BE INCORPORATED INTO YOUR BID.

REFER TO PROJECT PLANS AND SPECIFICATIONS PREPARED BY ARCHITECTURICA, DSA APPROVED SEPTEMBER 9, 2026.

ITEM 1 **Data Cabling**

- Refer to sheet ES2.1 in the DSA approved plans.
- References to CAT 6 cabling shall mean CAT 6A. All IP based devices shall be CAT 6A.

LODI UNIFIED SCHOOL DISTRICT

ADDENDUM #2

ITEM 2 Intercom System

- Refer to sheets ES1.1 and ES2.1 in the DSA approved plans.
- The intercom work is limited to providing new devices in the portable classrooms as shown on sheet ES2.1. The new devices shall be connected to the existing intercom system. The headend equipment for the intercom is located in the main building as shown on sheet ES1.1.
- Replacement of the existing system will not be required.

END OF ADDENDUM #2

ARCHITECTURICA

By



Timothy Dearborn, AIA
Architect

Attachments:

1. None