

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level
48	10/8/2026 08:14	10/14/2026 13:07	70455392001	Lead	10.3	5
47	10/8/2026 08:13	10/14/2026 13:09	70455392002	Lead	3.8	5
42	10/8/2026 08:18	10/14/2026 13:15	70455392003	Lead	1.3	5
35	10/8/2026 08:21	10/14/2026 13:18	70455392004	Lead	3.4	5
34	10/8/2026 08:25	10/14/2026 13:22	70455392005	Lead	3.8	5
32	10/8/2026 08:25	10/14/2026 13:23	70455392006	Lead	4.3	5
30	10/8/2026 08:29	10/14/2026 13:24	70455392007	Lead	11.2	5
29	10/8/2026 08:28	10/14/2026 13:28	70455392008	Lead	3.5	5
25D	10/8/2026 08:33	10/14/2026 13:29	70455392009	Lead	3.1	5
25B	10/8/2026 08:32	10/14/2026 13:30	70455392010	Lead	4.3	5
25	10/8/2026 08:34	10/14/2026 13:31	70455392011	Lead	5.9	5
20A	10/8/2026 08:37	10/14/2026 13:33	70455392012	Lead	4.4	5
17	10/8/2026 08:40	10/14/2026 13:34	70455392013	Lead	6.2	5
15	10/8/2026 08:42	10/14/2026 13:35	70455392014	Lead	3.7	5
10	10/8/2026 08:44	10/14/2026 13:36	70455392015	Lead	1.5	5
7	10/8/2026 08:45	10/14/2026 13:38	70455392016	Lead	2.9	5
5	10/8/2026 08:47	10/14/2026 13:39	70455392017	Lead	6.8	5
4	10/8/2026 08:46	10/14/2026 13:42	70455392018	Lead	2.0	5

NYSDOH Action Level for Lead In Schools of 5 ppb

[illegible]