DODGE COUNTY
WISCONSIN

Finance Department
Trista Steinbach, Purchasing Agent
127 E. Oak St., Juneau, WI 53039
Phone: 920-386-4224
Email: tsteinbach@co.dodge.wi.us

Notice of Addendum
Addendum #1
RFB #30 2026-06 - REBID
Update HVAC Controls, Dodge County Highway Department
October 27, 2026
(Total 1 pages)

Notice to all firms:
This Addendum is issued to modify, change, delete from, add to, explain or correct the original Request for Bid and is hereby made a part of RFB #30 2026-06 - REBID. In case of conflict between the Request for Bid and this Addendum, this Addendum shall govern. It is the bidder's responsibility to pass this addendum information to all involved in the bid.

QUESTIONS AND ANSWERS

Queston 1. I was looking for some clarity on this RFB for Dodge County. In some spots it says Carrier controls (or similar) but towards the bottom it asks for Carrier iVU Front End. Is the Carrier Front End mandatory or could it be something similar for that as well?

Answer 1. It does not need to be Carrier specific and can be a different brand that is similar to what Carrier offers.

Question 2. I am curious to know what is currently being used at the other Dodge County Buildings for their front end and if there is any desire to have visibility of those buildings as well on one source.

Answer 2. This project is for the County Highway Shop only. There are two buildings (the Front Office and the VSB Office Area) at that location that will use this "front end". The other County buildings will not be part of this and there is no desire to have visibility of those buildings on this system.

Return the completed and signed acknowledgement of this addendum with your bid for this request.

Acknowledgement of Addendum was included in the bid documents.