Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

October 05, 2026

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Hedrick 1 Lead Testing Order No.: 26090966

Dear Andy Chasteen:

Neilson Research Corporation received 57 sample(s) on 9/22/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. Testing was completed in accordance with the laboratory's established quality system and standard operating procedures. For the current scope of NELAP-accredited analytes and certifications, please refer to the Certifications section at www.nrclabs.com.
If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: **26090966**
Date: **10/5/2026**

CLIENT: Medford School District
Project: Hedrick 1 Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-01** Client Sample ID: Kit Hand Wash-Sink(Serving)
Collection Date: 9/22/2026 4:00:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Kit Hand Wash-Sink(Serving)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-02** Client Sample ID: Kit Pre-Rinse Dishwasher-Sink(Single)
Collection Date: 9/22/2026 4:06:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Kit Pre-Rinse Dishwasher-Sink(Single)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.19	1	0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-03** Client Sample ID: Kit Pre-Rinse Dishwasher-Sink(Dbl)
Collection Date: 9/22/2026 4:10:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Kit Pre-Rinse Dishwasher-Sink(Dbl)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	16.3	*1	0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-04** Client Sample ID: Kit Food Prep-Sink(Dbl)
Collection Date: 9/22/2026 4:15:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Kit Food Prep-Sink(Dbl)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.547		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-05** Client Sample ID: Rm 120-DF
Collection Date: 9/22/2026 4:42:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 120-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-06** Client Sample ID: Rm 120-Sink
Collection Date: 9/22/2026 4:43:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 120-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.02		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-07** Client Sample ID: Rm 118-Ice Machine
Collection Date: 9/22/2026 4:45:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 118-Ice Machine

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-08** Client Sample ID: Hall E Side Gym By Rm 118-DF
Collection Date: 9/22/2026 4:46:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Hall E Side Gym By Rm 118-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-09** Client Sample ID: By Rm 117 Mens RR-Sink (L)
Collection Date: 9/22/2026 4:48:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: By Rm 117 Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.836		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-10** Client Sample ID: By Rm 117 Mens RR-Sink (C)
Collection Date: 9/22/2026 4:50:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: By Rm 117 Mens RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.639		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-11** Client Sample ID: By Rm 117 Mens RR-Sink (R)
Collection Date: 9/22/2026 4:50:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: By Rm 117 Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-12** Client Sample ID: By Rm 117 Womens RR-Sink (L)
Collection Date: 9/22/2026 4:52:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: By Rm 117 Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.722		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-13** Client Sample ID: By Rm 117 Womens RR-Sink (C)
Collection Date: 9/22/2026 4:52:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: By Rm 117 Womens RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.526		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-14** Client Sample ID: By Rm 117 Womens RR-Sink (R)
Collection Date: 9/22/2026 4:52:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: By Rm 117 Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-15** Client Sample ID: NE Gym Entrance Unisex RR-Sink
Collection Date: 9/22/2026 5:01:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: NE Gym Entrance Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-16** Client Sample ID: NE Gym Entrance DF-(Btl Filler)
Collection Date: 9/22/2026 5:04:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: NE Gym Entrance DF-(Btl Filler)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-17** Client Sample ID: NE Gym Entrance DF-(U)
Collection Date: 9/22/2026 5:05:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: NE Gym Entrance DF-(U)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-18** Client Sample ID: In Gym NW Corner-DF
Collection Date: 9/22/2026 5:10:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: In Gym NW Corner-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-19** Client Sample ID: In Gym SW Corner-DF
Collection Date: 9/22/2026 5:12:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: In Gym SW Corner-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-20** Client Sample ID: Rm 119(Store)-Sink(Utility)
Collection Date: 9/22/2026 5:16:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 119(Store)-Sink(Utility)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.45		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-21** Client Sample ID: Rm 122-Sink (S Wall-L)
Collection Date: 9/22/2026 5:22:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 122-Sink (S Wall-L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.872		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-22** Client Sample ID: Rm 122-Sink (S Wall-C)
Collection Date: 9/22/2026 5:23:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 122-Sink (S Wall-C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-23** Client Sample ID: Rm 122-Sink (S Wall-R)
Collection Date: 9/22/2026 5:24:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 122-Sink (S Wall-R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.14		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-24** Client Sample ID: Rm 122-Sink (E Wall-Bk Corner)
Collection Date: 9/22/2026 5:24:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 122-Sink (E Wall-Bk Corner)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.88		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-25** Client Sample ID: Rm 125-Sink (N Wall-L)
Collection Date: 9/22/2026 5:26:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 125-Sink (N Wall-L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.71		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-26** Client Sample ID: Rm 125-Sink (N Wall-R)
Collection Date: 9/22/2026 5:27:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 125-Sink (N Wall-R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.29		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-27** Client Sample ID: Rm 125-Sink (S Wall-L)
Collection Date: 9/22/2026 5:28:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 125-Sink (S Wall-L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.782		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-28** Client Sample ID: Rm 125-Sink (S Wall-R)
Collection Date: 9/22/2026 5:30:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 125-Sink (S Wall-R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-29** Client Sample ID: Rm 125-DW
Collection Date: 9/22/2026 5:31:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 125-DW

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.664		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-30** Client Sample ID: Custodial Ofc Unisex RR-Sink
Collection Date: 9/22/2026 5:34:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Custodial Ofc Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.517		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-31** Client Sample ID: Rm 121-DF
Collection Date: 9/22/2026 5:42:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 121-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-32** Client Sample ID: Rm 121-Sink
Collection Date: 9/22/2026 5:43:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 121-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.31		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-33** Client Sample ID: Rm 124 Staff Brk Rm Mens RR-Sink (L)
Collection Date: 9/22/2026 5:44:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 124 Staff Brk Rm Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.977		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-34** Client Sample ID: Rm 124 Staff Brk Rm Mens RR-Sink (R)
Collection Date: 9/22/2026 5:45:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 124 Staff Brk Rm Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.561		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-35** Client Sample ID: Rm 124 Staff Brk Rm Womens RR-Sink (L)
Collection Date: 9/22/2026 5:46:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 124 Staff Brk Rm Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.829		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-36** Client Sample ID: Rm 124 Staff Brk Rm Womens RR-Sink (R)
Collection Date: 9/22/2026 5:47:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 124 Staff Brk Rm Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.855		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-37** Client Sample ID: Rm 124 Staff Brk Rm-Sink
Collection Date: 9/22/2026 5:48:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Rm 124 Staff Brk Rm-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-38** Client Sample ID: Weight Rm-(O/S S Entrance)-Btl Filler
Collection Date: 9/22/2026 4:34:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Weight Rm-(O/S S Entrance)-Btl Filler

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-39** Client Sample ID: Weight Rm-(O/S S Entrance)-DF
Collection Date: 9/22/2026 4:35:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Weight Rm-(O/S S Entrance)-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-40** Client Sample ID: Weight Rm-(O/S S Ent)-Unisex RR-Sink (L)
Collection Date: 9/22/2026 4:37:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Weight Rm-(O/S S Ent)-Unisex RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.20		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-41** Client Sample ID: Weight Rm-(O/S S Ent)-Unisex RR-Sink (R)
Collection Date: 9/22/2026 4:40:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Weight Rm-(O/S S Ent)-Unisex RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.597		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-42** Client Sample ID: Hose Bib for Water Horse-Boys Locker O/S
Collection Date: 9/22/2026 5:55:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Hose Bib for Water Horse-Boys Locker O/S

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.24		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-43** Client Sample ID: DF O/S by Boys Locker
Collection Date: 9/22/2026 4:43:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: DF O/S by Boys Locker

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-44** Client Sample ID: Boys Locker Rm-Sink(L-Locker)
Collection Date: 9/22/2026 4:20:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Boys Locker Rm-Sink(L-Locker)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.852		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-45** Client Sample ID: Boys Locker Rm-Sink(R-Locker)
Collection Date: 9/22/2026 4:22:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Boys Locker Rm-Sink(R-Locker)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.858		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-46** Client Sample ID: Boys Locker Rm-Sink(Urinal)
Collection Date: 9/22/2026 4:23:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Boys Locker Rm-Sink(Urinal)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.23		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-47** Client Sample ID: Boys Locker Rm Coach-Sink
Collection Date: 9/22/2026 4:25:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Boys Locker Rm Coach-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.46		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-48** Client Sample ID: Boys Locker Rm Coach RR-Sink
Collection Date: 9/22/2026 4:27:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Boys Locker Rm Coach RR-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.59	1	0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-49** Client Sample ID: Girls Locker Rm-DF (L)
Collection Date: 9/22/2026 4:28:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Girls Locker Rm-DF (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.968		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-50** Client Sample ID: Girls Locker Rm-DF (R)
Collection Date: 9/22/2026 4:28:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Girls Locker Rm-DF (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.52		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-51** Client Sample ID: Girls Locker Rm-Sink (L-Locker)
Collection Date: 9/22/2026 4:29:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Girls Locker Rm-Sink (L-Locker)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.583		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-52** Client Sample ID: Girls Locker Rm-Sink (R-Locker)
Collection Date: 9/22/2026 4:29:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Girls Locker Rm-Sink (R-Locker)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.01		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-53** Client Sample ID: Girls Locker Rm-Sink (Toilet-L)
Collection Date: 9/22/2026 4:29:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Girls Locker Rm-Sink (Toilet-L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.22		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-54** Client Sample ID: Girls Locker Rm-Sink (Toilet-C)
Collection Date: 9/22/2026 4:30:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Girls Locker Rm-Sink (Toilet-C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.702		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090966**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090966
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 10:55:24 AM

Sample Information:

Lab ID: **26090966-55** Client Sample ID: Girls Locker Rm-Sink (Toilet-R)
Collection Date: 9/22/2026 4:31:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Girls Locker Rm-Sink (Toilet-R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.03		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-56** Client Sample ID: Girls Locker Rm Coach-Sink
Collection Date: 9/22/2026 4:32:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Girls Locker Rm Coach-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.77		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090966-57** Client Sample ID: NE Gym Entrance-DW Lower
Collection Date: 9/22/2026 5:03:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: NE Gym Entrance-DW Lower

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26090966**

05-Oct-26

Client: Medford School District
Project: Hedrick 1 Lead Testing

TestCode: **LEAD_SCHOOLS**

Sample ID: **MB-38508**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **PBW**	Batch ID: **38508**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215622**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38508**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **LCSW**	Batch ID: **38508**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215623**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0	104	85	115				

Sample ID: **26090966-01AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **Kit Hand Wash-Sink**	Batch ID: **38508**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215625**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	0.474	102	70	130				

Sample ID: **26090966-01AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **Kit Hand Wash-Sink**	Batch ID: **38508**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215626**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0.474	102	70	130	103	0.670	20	

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor
H	Holding times for preparation or analysis exceeded	MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
RL	Reporting Limit				

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26090966**

05-Oct-26

Client: Medford School District
Project: Hedrick 1 Lead Testing **TestCode:** **LEAD_SCHOOLS**

Sample ID: **MB-38510**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **PBW**	Batch ID: **38510**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215650**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38510**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **LCSW**	Batch ID: **38510**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215651**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0	104	85	115				

Sample ID: **26090966-21AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **Rm 122-Sink (S Wall**	Batch ID: **38510**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215653**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0.872	103	70	130				

Sample ID: **26090966-21AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **Rm 122-Sink (S Wall**	Batch ID: **38510**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215654**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	0.872	103	70	130	104	0.765	20	

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor
H	Holding times for preparation or analysis exceeded	MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
RL	Reporting Limit				

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26090966**

05-Oct-26

Client: Medford School District
Project: Hedrick 1 Lead Testing **TestCode:** **LEAD_SCHOOLS**

Sample ID: **MB-38514**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **PBW**	Batch ID: **38514**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215678**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38514**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **LCSW**	Batch ID: **38514**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215680**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0	104	85	115				

Sample ID: **26090966-41AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **Weight Rm-(O/S S E**	Batch ID: **38514**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215682**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0.597	102	70	130				

Sample ID: **26090966-41AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **Weight Rm-(O/S S E**	Batch ID: **38514**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215683**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	0.597	102	70	130	102	0.252	20	

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor
H	Holding times for preparation or analysis exceeded	MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
RL	Reporting Limit				

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: MedfordSchoolDist Work Order Number: 26090966 RcptNo: 1

Logged by:	Danielle Feagan	9/22/2026 9:15:00 AM	Danielle Feagan
Completed By:	Kyler Woolsey	9/24/2026 2:49:21 PM	Kyler Woolsey
Reviewed By:	Ashley Spiegelberg	10/5/2026 10:43:33 AM	

Chain of Custody

1. Is Chain of Custody complete? Yes ☑ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☑ NA ☐
4. Shipping container/cooler in good condition? Yes ☑ No ☐
   Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☑ NA ☐
   No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☑ NA ☐
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☑
7. Sample(s) in proper container(s)? Yes ☑ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☑ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☑ No ☐
10. Was preservative added to bottles? Yes ☐ No ☑ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☑
12. Were any sample containers received broken? Yes ☐ No ☑
13. Does paperwork match bottle labels? (Note discrepancies on chain of custody) Yes ☑ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☑ No ☐
15. Is it clear what analyses were requested? Yes ☑ No ☐
16. Were all holding times able to be met? (If no, notify customer for authorization.) Yes ☑ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☑

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp ºC	Condition	Seal Intact	Seal No	Seal Date	Signed By

NEILSON RESEARCH CORPORATION
Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: MSD 549C
Address: 900 Kenyon
Medford, OR 97501
Email: andy.chasteen@medford.k12.or.us
Phone: 541-840-4315 Fax:
Collected By (Print): SETH BARRY
Collected By (Sign):
Email Report ___ Yes ___ No Mail Report ___ Yes ___ No
Fax Report ___ Yes ___No

Section B
Required Project Information

Project Name: Hedrick 1
Project Number:
Report andy.chasteen@medford.k12.or
Copy T seth.barry@medford.k12.or.us

Section C
Invoice Information

Attention: Accounting
Company Name: Medford School District
Address: 900 Kenyon
Medford, OR 97501
P.O. #

Section D
Rush Status (Subject to Scheduling)

___ Standard 10-14 Days
___ 5 Business Days (50% surcharge)
___ 3 Business Days (75% surcharge)
___ 24 - 48 hours (100% surcharge)
___ Other _____
Authorized ____ Yes ____ No

Section E
Sample Information

NRC Workorder # (Lab Use Only) 26090966

Sample ID	Matrix*	Date Collected	Time Collect (AM)	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
Kitchen Hand Wash - Sink (Near Serving Line)	DW	9/22/2026	400	1			01
~~Kitchen Hand Wash - Sink (In Back Area That Serves Courtyard)~~	~~DW~~	~~9/22/2026~~	~~403~~	~~1~~		GONE	
Kitchen Pre-Rinse/Dishwasher - Sink (Single)	DW	9/22/2026	406	1			02
Kitchen Pre-Rinse/Dishwasher - Sink (Double)	DW	9/22/2026	410	1			03
Kitchen Food Prep - Sink (Double)	DW	9/22/2026	415	1			04
Room 120 - Drinking Fountain	DW	9/22/2026	442	1			05
Room 120 - Sink	DW	9/22/2026	443	1			06
Room 118 - Ice Machine	DW	9/22/2026	445	1			07
Hallway East Side of Gym Near Room 118 - Drinking Fountain	DW	9/22/2026	446	1			08
Next To Room 117 Men's Restroom - Sink (Left)	DW	9/22/2026	448	1			09
Next To Room 117 Men's Restroom - Sink (Center)	DW	9/22/2026	450	1			10
Next To Room 117 Men's Restroom - Sink (Right)	DW	9/22/2026	450	1			11
Next To Room 117 Women's Restroom - Sink (Left)	DW	9/22/2026	452	1			12
Next To Room 117 Women's Restroom - Sink (Center)	DW	9/22/2026	452	1			13
Next To Room 117 Women's Restroom - Sink (Right)	DW	9/22/2026	452	1			14
North East Gym Entrance Unisex Restroom - Sink	DW	9/22/2026	501	1			15
North East Gym Entrance - Drinking Fountain (Bottle Filler)	DW	9/22/2026	504	1			16
North East Gym Entrance - Drinking Fountain (Upper)	DW	9/22/2026	505	1			17
Inside Gym North West Corner - Drinking Fountain (and Old Bottle Filler?)	DW	9/22/2026	510	1			18
Inside Gym South West Corner - Drinking Fountain (and Old Bottle Filler?)	DW	9/22/26	512	1			19
Room 119 (Store) - Sink (Utility)	DW	9/22/2026	516	1			20
Room 122 - Sink (South Wall - Left) UTILITY?	DW	9/22/2026	522	1			21
Room 122 - Sink (South Wall - Center)	DW	9/22/2026	523	1			22
Room 122 - Sink (South Wall - Right)	DW	9/22/2026	524	1			23

#26090964

Room 122 - Sink (East Wall - Back Corner) UTILITY?	DW	9/22/2026	524	1													24
Room 125 - Sink (North Wall - Left)	DW	9/22/2026	526	1													25
Room 125 - Sink (North Wall - Right)	DW	9/22/2026	527	1													26
Room 125 - Sink (South Wall - Left)	DW	9/22/2026	528	1													27
Room 125 - Sink (South Wall - Right)	DW	9/22/2026	530	1													28
Room 125 DW	DW	9/22/2026	531	1													29
Custodial Office Unisex Restroom - Sink	DW	9/22/2026	534	1													30
Room 121 - Drinking Fountain	DW	9/22/2026	542	1													31
Room 121 - Sink	DW	9/22/2026	543	1													32
Room 124 (Staff Break Room) Men's Restroom - Sink (Left)	DW	9/22/2026	544	1													33
Room 124 (Staff Break Room) Men's Restroom - Sink (Right)	DW	9/22/2026	545	1													34
Room 124 (Staff Break Room) Women's Restroom - Sink (L)	DW	9/22/2026	546	1													35
Room 124 (Staff Break Room) Women's Restroom - Sink (R)	DW	9/22/2026	547	1													36
Room 124 (Staff Break Room) - Sink	DW	9/22/2026	548	1													37
	DW	9/22/2026	—	1													38
Weight Room (Outside South Entrance) - Bottle Filler	DW	9/22/2026	434	1													38
Weight Room (Outside South Entrance) - Drinking Fountain	DW	9/22/2026	435	1													39
Weight Room (Outside South Entrance) Unisex Restroom - Sink (Left)	DW	9/22/2026	437	1													40
Weight Room (Outside South Entrance) Unisex Restroom - Sink (Right)	DW	9/22/2026	440	1													41
Hose Bib Supplying Water Horse by Boys Locker Outside	DW	9/22/2026	555	1													42
Drinking Fountain Outside by Boys Locker	DW	9/22/2026	443	1													43
Boy's Locker Room - Sink (Left - Locker Area)	DW	9/22/2026	420	1													44
Boy's Locker Room - Sink (Right - Locker Area)	DW	9/22/2026	422	1													45
Boy's Locker Room - Sink (Urinal Area)	DW	9/22/2026	423	1													46
Boy's Locker Room Coach - Sink	DW	9/22/2026	425	1													47
Boy's Locker Room Coach Restroom - Sink	DW	9/22/2026	427	1													48
Girl's Locker Room - Drinking Fountain (Left)	DW	9/22/2026	428	1													49
Girl's Locker Room - Drinking Fountain (Right)	DW	9/22/2026	428	1													50
Girl's Locker Room - Sink (Left - Locker Area)	DW	9/22/2026	429	1													51
Girl's Locker Room - Sink (Right - Locker Area)	DW	9/22/2026	429	1													52
Girl's Locker Room - Sink (Toilet Area - Left)	DW	9/22/2026	429	1													53
Girl's Locker Room - Sink (Toilet Area - Center)	DW	9/22/2026	430	1													54
Girl's Locker Room - Sink (Toilet Area - Right)	DW	9/22/2026	431	1													55
Girl's Locker Room Coach - Sink	DW	9/22/2026	432	1													56
NE GYM ENTRANCE DW LOWER	DW	9/22/2026	503	1													57
~~INSIDE GYM NW CORNER DW~~	~~DW~~	~~9/22/2026~~	~~506~~	1													
	DW			1													
	DW			1													
	DW			1													
	DW			1													
	DW			1													
	DW			1													
	DW			1													
	DW			1													
	DW			1													
	DW			1													

Begin DE 9/24

#26090964

		DW			1												
		DW			1												
					1												
					1												
					1												
					1												
					1												

*Matrix: **DW** - Drinking Water **WW** - Wastewater **W** - Water **S** - Soil/Solid **SL** - Sludge **O** - Oil **WP** - Wipe **OT** - Other

Section F
Relinquish/Receive

	Sign	Print	Date	Time
Relinquished By:		SETH BAMEY	9/22/26	
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:		Dani Feagan	9/22/26	9:15

Section G
Lab Use Only

Temp: AMB
4°C +/- 2°C: Yes No
Received on Ice: ___ Yes ___ No
Number of Bottles Received:
pH Checked:
COC Seals Intact: ___ Yes ___ No ___ NA
Field Blank Included: ___ Yes ___ No
Received Via ___ UPS ___ FedEX ___ Other X Hand
Payment: X Invoice ___ Cash ___ VISA, M/C ___ Check # _____ Amount _____

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Data Flags

WO#: **26090966**
Date: **10/5/2026**

A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
B Analyte detected in the associated method blank.
C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF Results confirmed by re-analysis.
CU Cleanup performed as specified by method.
E Estimated value.
ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
HP Sample re-analysis performed outside of method specified holding time.
HR Sample received outside of method specified holding time.
HS Sample analyzed for volatile organics contained headspace.
HT At the client's request, the sample was analyzed outside of method specified holding time.
H Analysis performed outside of method specified holding time.
J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
N See Case Narrative on page 2 of report.
Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R Relative percent difference (RPD) is outside of the accepted recovery limits.
R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC Sub-contracted to another laboratory for analysis.
SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.

* Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
1 Value exceeds one half of the Maximum Contaminant Level.