Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

October 05, 2026

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Hedrick 2 Lead Testing Order No.: 26090972

Dear Andy Chasteen:

Neilson Research Corporation received 53 sample(s) on 9/22/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. Testing was completed in accordance with the laboratory's established quality system and standard operating procedures. For the current scope of NELAP-accredited analytes and certifications, please refer to the Certifications section at www.nrclabs.com.
If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: **26090972**
Date: **10/5/2026**

CLIENT: Medford School District
Project: Hedrick 2 Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-01** Client Sample ID: Health Rm-Sink
Collection Date: 9/22/2026 5:23:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Health Rm-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-02** Client Sample ID: Health Rm Unisex RR-Sink
Collection Date: 9/22/2026 5:24:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Health Rm Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.17		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-03** Client Sample ID: Main Ofc-Kitchenette
Collection Date: 9/22/2026 5:25:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Main Ofc-Kitchenette

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-04** Client Sample ID: By Ofc-DF (Btl Filler)
Collection Date: 9/22/2026 5:26:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: By Ofc-DF (Btl Filler)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-05** Client Sample ID: By Ofc-DF (Upper)
Collection Date: 9/22/2026 5:26:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: By Ofc-DF (Upper)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-06** Client Sample ID: O/S Ofc Staff Mens RR-Sink (L)
Collection Date: 9/22/2026 5:30:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: O/S Ofc Staff Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.515		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-07** Client Sample ID: O/S Ofc Staff Mens RR-Sink (R)
Collection Date: 9/22/2026 5:30:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: O/S Ofc Staff Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-08** Client Sample ID: O/S Ofc Staff Womens RR By 322-Sink (L)
Collection Date: 9/22/2026 5:32:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: O/S Ofc Staff Womens RR By 322-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.643		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-09** Client Sample ID: O/S Ofc Staff Womens RR By 322-Sink (R)
Collection Date: 9/22/2026 5:32:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: O/S Ofc Staff Womens RR By 322-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.592		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-10** Client Sample ID: Rm 322-DF
Collection Date: 9/22/2026 5:34:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 322-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-11** Client Sample ID: Rm 322-Sink
Collection Date: 9/22/2026 5:34:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 322-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-12** Client Sample ID: Rm 323-DF
Collection Date: 9/22/2026 5:35:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 323-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.
DF	Dilution Factor
H	Holding times for preparation or analysis exceeded
MI	Recovery outside comtrol limits due to Matrix Interference
R	RPD outside accepted recovery limits
C1	Sample container temperature is out of limit as specified at testcod
E	Value above quantitation range
J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit
RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-13** Client Sample ID: Rm 323-Sink
Collection Date: 9/22/2026 5:35:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 323-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.731		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-14** Client Sample ID: Rm 325-DF
Collection Date: 9/22/2026 5:37:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 325-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-15** Client Sample ID: Rm 325-Sink
Collection Date: 9/22/2026 5:37:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 325-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.85		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-16** Client Sample ID: Rm 324-DF
Collection Date: 9/22/2026 5:39:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 324-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-17** Client Sample ID: Rm 324-Sink
Collection Date: 9/22/2026 5:39:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 324-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.956		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-18** Client Sample ID: Storage By (Science)326/328-Sink
Collection Date: 9/22/2026 5:41:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Storage By (Science)326/328-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-19** Client Sample ID: Rm 327-DF
Collection Date: 9/22/2026 5:43:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 327-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-20** Client Sample ID: Rm 327-Sink
Collection Date: 9/22/2026 5:43:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 327-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-21** Client Sample ID: Rm 329-DF
Collection Date: 9/22/2026 5:45:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 329-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.
DF	Dilution Factor
H	Holding times for preparation or analysis exceeded
MI	Recovery outside comtrol limits due to Matrix Interference
R	RPD outside accepted recovery limits
C1	Sample container temperature is out of limit as specified at testcod
E	Value above quantitation range
J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit
RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-22** Client Sample ID: Rm 329-Sink
Collection Date: 9/22/2026 5:45:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 329-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.562		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-23** Client Sample ID: Rm 331-DF
Collection Date: 9/22/2026 5:46:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 331-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-24** Client Sample ID: Rm 331-Sink
Collection Date: 9/22/2026 5:46:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 331-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.593		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-25** Client Sample ID: Across Rm 331 Womens RR-Sink (L)
Collection Date: 9/22/2026 5:47:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Across Rm 331 Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.696		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-26** Client Sample ID: Across Rm 331 Womens RR-Sink (C)
Collection Date: 9/22/2026 5:47:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Across Rm 331 Womens RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.890		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-27** Client Sample ID: Across Rm 331 Womens RR-Sink (R)
Collection Date: 9/22/2026 5:47:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Across Rm 331 Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.812		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-28** Client Sample ID: Across Rm 334 Mens RR-Sink (L)
Collection Date: 9/22/2026 5:48:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Across Rm 334 Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-29** Client Sample ID: Across Rm 334 Mens RR-Sink (C)
Collection Date: 9/22/2026 5:48:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Across Rm 334 Mens RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.13		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-30** Client Sample ID: Across Rm 334 Mens RR-Sink (R)
Collection Date: 9/22/2026 5:48:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Across Rm 334 Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.02		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-31** Client Sample ID: Hall By Rms 331/334-DF
Collection Date: 9/22/2026 5:49:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Hall By Rms 331/334-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-32** Client Sample ID: Rm 334-DF
Collection Date: 9/22/2026 5:50:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 334-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-33** Client Sample ID: Rm 334-Sink
Collection Date: 9/22/2026 5:50:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 334-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.926		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-34** Client Sample ID: Rm 336-DF
Collection Date: 9/22/2026 5:51:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 336-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-35** Client Sample ID: Rm 336-Sink
Collection Date: 9/22/2026 5:51:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 336-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.615		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-36** Client Sample ID: Rm 335 (Storage)-Sink
Collection Date: 9/22/2026 5:53:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 335 (Storage)-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.48		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-37** Client Sample ID: Rm 337 Storage Rm-Sink
Collection Date: 9/22/2026 5:53:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 337 Storage Rm-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.83		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-38** Client Sample ID: Rm 338-DF
Collection Date: 9/22/2026 5:55:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 338-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-39** Client Sample ID: Rm 338-Sink
Collection Date: 9/22/2026 5:55:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 338-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.570		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-40** Client Sample ID: Wrestling Rm-DF
Collection Date: 9/22/2026 5:57:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Wrestling Rm-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.74		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-41** Client Sample ID: Fitness Rm (108)-DF
Collection Date: 9/22/2026 6:06:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Fitness Rm (108)-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.602		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-42** Client Sample ID: Room 109 (Band)-DF
Collection Date: 9/22/2026 6:02:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Room 109 (Band)-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.544		0.520	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-43** Client Sample ID: Room 109 (Band)-Sink
Collection Date: 9/22/2026 6:03:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Room 109 (Band)-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-44** Client Sample ID: Rm 107-DF
Collection Date: 9/22/2026 6:04:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 107-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-45** Client Sample ID: Rm 106B-DF-(W Wall)
Collection Date: 9/22/2026 6:04:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 106B-DF-(W Wall)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-46** Client Sample ID: Rm 106B-Sink-(W Wall)
Collection Date: 9/22/2026 6:04:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 106B-Sink-(W Wall)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.51		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-47** Client Sample ID: Rm 106A-Sink-(S Wall)
Collection Date: 9/22/2026 6:07:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 106A-Sink-(S Wall)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.746		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-48** Client Sample ID: Rm 102A-DF
Collection Date: 9/22/2026 6:08:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 102A-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-49** Client Sample ID: Rm 102B-Sink
Collection Date: 9/22/2026 6:08:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 102B-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.01		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-50** Client Sample ID: Rm 102A-Sink
Collection Date: 9/22/2026 6:08:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 102A-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-51** Client Sample ID: Rm 103-DF
Collection Date: 9/22/2026 6:08:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 103-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090972**
Date Reported: **10/5/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090972
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/5/2026 9:15:48 AM

Sample Information:

Lab ID: **26090972-52** Client Sample ID: Rm 103-Sink
Collection Date: 9/22/2026 6:08:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Rm 103-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.36		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090972-53** Client Sample ID: Office DF (Lower)
Collection Date: 9/22/2026 5:26:00 AM Collected By: Roger Maulard
Matrix: Drinking Water Sample Location: Office DF (Lower)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26090972**

05-Oct-26

Client: Medford School District
Project: Hedrick 2 Lead Testing **TestCode:** **LEAD_SCHOOLS**

Sample ID: **MB-38535**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **PBW**	Batch ID: **38535**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216265**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38535**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **LCSW**	Batch ID: **38535**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216266**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	0	103	85	115				

Sample ID: **26090972-01AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **Health Rm-Sink**	Batch ID: **38535**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216268**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0.148	102	70	130				

Sample ID: **26090972-01AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **Health Rm-Sink**	Batch ID: **38535**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216269**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0.148	102	70	130	102	0.514	20	

Qualifiers:

C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceede
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26090972**

05-Oct-26

Client: Medford School District
Project: Hedrick 2 Lead Testing **TestCode:** **LEAD_SCHOOLS**

Sample ID: **MB-38537**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **PBW**	Batch ID: **38537**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216293**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38537**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **LCSW**	Batch ID: **38537**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216294**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0	102	85	115				

Sample ID: **26090972-21AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **Rm 329-DF**	Batch ID: **38537**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216296**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	101	0.520	100	0.0917	101	70	130				

Sample ID: **26090972-21AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **Rm 329-DF**	Batch ID: **38537**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216297**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	101	0.520	100	0.0917	100	70	130	101	0.187	20	

Qualifiers:

C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceede
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26090972**

05-Oct-26

Client: Medford School District
Project: Hedrick 2 Lead Testing **TestCode:** **LEAD_SCHOOLS**

Sample ID: **MB-38538**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **PBW**	Batch ID: **38538**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216321**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38538**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **LCSW**	Batch ID: **38538**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216322**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	0	103	85	115				

Sample ID: **26090972-42AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **Room 109 (Band)-D**	Batch ID: **38538**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216325**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	99.9	0.520	100	0.544	99.3	70	130				

Sample ID: **26090972-42AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **Room 109 (Band)-D**	Batch ID: **38538**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216326**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	101	0.515	100	0.544	100	70	130	99.9	0.928	20	

Qualifiers:

C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceede
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: MedfordSchoolDist Work Order Number: 26090972 RcptNo: 1

Logged by:	Danielle Feagan	9/22/2026 9:15:00 AM	Danielle Feagan
Completed By:	Kyler Woolsey	9/24/2026 2:45:20 PM	Kyler Woolsey
Reviewed By:	Kyler Woolsey	10/5/2026 9:00:09 AM	Kyler Woolsey

Chain of Custody

1. Is Chain of Custody complete? Yes ☑ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☑
4. Shipping container/cooler in good condition? Yes ☑ No ☐
   Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☑ NA ☐
   No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☑
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☑
7. Sample(s) in proper container(s)? Yes ☑ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☑ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☑ No ☐
10. Was preservative added to bottles? Yes ☐ No ☑ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☑
12. Were any sample containers received broken? Yes ☐ No ☑
13. Does paperwork match bottle labels? (Note discrepancies on chain of custody) Yes ☑ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☑ No ☐
15. Is it clear what analyses were requested? Yes ☑ No ☐
16. Were all holding times able to be met? (If no, notify customer for authorization.) Yes ☑ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☑

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp ºC	Condition	Seal Intact	Seal No	Seal Date	Signed By

NEILSON RESEARCH CORPORATION
Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: MSD 549C
Address: 900 Kenyon
Medford, OR 97501
Email: andy.chasteen@medford.k12.or.us
Phone: 541-840-4315 Fax:
Collected By (Print): Roger Maulsby
Collected By (Sign):
Email Report ___ Yes ___ No Mail Report ___ Yes ___ No
Fax Report ___ Yes ___No

Section B
Required Project Information

Project Name: Hedrick 2
Project Number:
Report andy.chasteen@medford.k12.or
Copy T seth.barry@medford.k12.or.us

Section C
Invoice Information

Attention: Accounting
Company Name: Medford School District
Address: 900 Kenyon
Medford, OR 97501
P.O. #

Section D
Rush Status (Subject to Scheduling)

___ Standard 10-14 Days
___ 5 Business Days (50% surcharge)
___ 3 Business Days (75% surcharge)
___ 24 - 48 hours (100% surcharge)
___ Other _____
Authorized ____ Yes ____ No

Section E
Sample Information

NRC Workorder # (Lab Use Only) 26090972

Sample ID	Matrix*	Date Collected	Time Collect	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
Health Room - Sink	DW	9/22/2026	5:23	1			01
Health Room Unisex Restroom - Sink	DW	9/22/2026	5:24	1			02
Main Office - Kitchenette	DW	9/22/2026	5:25	1			03
By The Office - Drinking Fountain (Bottle Filler)	DW	9/22/2026	5:26	1			04
By The Office - Drinking Fountain (Upper)	DW	9/22/2026	5:26	1			05
Outside Office Staff Men's Restroom - Sink (Left)	DW	9/22/2026	5:30	1			06
Outside Office Staff Men's Restroom - Sink (Right)	DW	9/22/2026	5:30	1			07
Outside Office Staff Women's Restroom by 322 - Sink (Left)	DW	9/22/2026	5:32	1			08
Outside Office Staff Women's Restroom by 322 - Sink (Right)	DW	9/22/2026	5:32	1			09
Room 322 - Drinking Fountain	DW	9/22/2026	5:34	1			10
Room 322 - Sink	DW	9/22/2026	5:34	1			11
Room 323 - Drinking Fountain	DW	9/22/2026	5:35	1			12
Room 323 - Sink	DW	9/22/2026	5:35	1			13
Room 325 - Drinking Fountain	DW	9/22/2026	5:37	1			14
Room 325 - Sink	DW	9/22/2026	5:37	1			15
Room 324 - Drinking Fountain	DW	9/22/2026	5:39	1			16
Room 324 - Sink	DW	9/22/2026	5:39	1			17
Storage Room In-between (Science) 326/328 - Sink	DW	9/22/2026	5:41	1			18
Room 327 - Drinking Fountain	DW	9/22/2026	5:43	1			19
Room 327 - Sink	DW	9/22/2026	5:43	1			20
Room 329 - Drinking Fountain	DW	9/22/2026	5:45	1			21
Room 329 - Sink	DW	9/22/2026	5:45	1			22
Room 331 - Drinking Fountain	DW	9/22/2026	5:46	1			23
Room 331 - Sink	DW	9/22/2026	5:46	1			24

26090972

Across From Room 331 Women's Restroom - Sink (Left)	DW	9/22/2026	5:47	1													25
Across From Room 331 Women's Restroom - Sink (Center)	DW	9/22/2026	5:47	1													26
Across From Room 331 Women's Restroom - Sink (Right)	DW	9/22/2026	5:47	1													27
Across From Room 334 Men's Restroom - Sink (Left)	DW	9/22/2026	5:48	1													28
Across From Room 334 Men's Restroom - Sink (Center)	DW	9/22/2026	5:48	1													29
Across From Room 334 Men's Restroom - Sink (Right)	DW	9/22/2026	5:49	1													30
In Hallway Between Rooms 331/334 - Drinking Fountain	DW	9/22/2026	5:49	1													31
Room 334 - Drinking Fountain	DW	9/22/2026	5:50	1													32
Room 334 - Sink	DW	9/22/2026	5:50	1													33
Room 336 - Drinking Fountain	DW	9/22/2026	5:51	1													34
Room 336 - Sink	DW	9/22/2026	5:51	1													35
Room 335 (Storage Room) - Sink	DW	9/22/2026	5:53	1													36
Room 337 Storage Room - Sink	DW	9/22/2026	5:53	1													37
Room 338 - Drinking Fountain	DW	9/22/2026	5:55	1													38
Room 338 - Sink	DW	9/22/2026	5:55	1													39
Wrestling Room - Drinking Fountain	DW	9/22/2026	5:57	1													40
———	DW	9/22/2026	———	1													—
Fitness Room (108) - Drinking Fountain	DW	9/22/2026	6:06	1													41
Room 109 (Band Room) - Drinking Fountain	DW	9/22/2026	6:02	1													42
Room 109 (Band Room) - Sink	DW	9/22/2026	6:07	1													43
Room 107 - Drinking Fountain	DW	9/22/2026	6:03	1													44
Room 106B - Drinking Fountain (West Wall)	DW	9/22/2026	6:04	1													45
Room 106B - Sink (West Wall)	DW	9/22/2026	6:04	1													46
Room 106A - Sink (South Wall)	DW	9/22/2026	6:04	1													47
Room ~~102B~~ 102A - Drinking Fountain	DW	9/22/2026	6:07	1													48
Room 102B - Sink UTILITY?	DW	9/22/2026	6:08	1													49
Room 102A - Sink	DW	9/22/2026	6:08	1													50
Room 103 - Drinking Fountain	DW	9/22/2026	6:08	1													51
Room 103 - Sink	DW	9/22/2026	6:09	1													52
Office Drinking Fountain (Lower)	DW	9/22/2026	5:26	1													53
	DW			1													
				1													
				1													
				1													

*Matrix: **DW** - Drinking Water **WW** - Wastewater **W** - Water **S** - Soil/Solid **SL** - Sludge **O** - Oil **WP** - Wipe **OT** - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:		Roger Maitland	9.22.26	6:30
Received By:		SETH GARVY	9/22/26	6:30
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:		Dani Teagan	9/22/26	9:15

Section G
Lab Use Only

Temp: Amb	
4°C +/- 2°C:	Yes No
Received on Ice:	Yes No
Number of Bottles Received:	
pH Checked:	
COC Seals Intact:	Yes No NA
Field Blank Included:	Yes No

Received Via ___ UPS ___ FedEX ___ Other X Hand

Payment: X Invoice ___ Cash ___ VISA, M/C ___ Check # _____ Amount _____