Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

October 06, 2026

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Hedrick 3 Lead Testing Order No.: 26090981

Dear Andy Chasteen:

Neilson Research Corporation received 65 sample(s) on 9/22/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. Testing was completed in accordance with the laboratory's established quality system and standard operating procedures. For the current scope of NELAP-accredited analytes and certifications, please refer to the Certifications section at www.nrclabs.com.
If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: **26090981**
Date: **10/6/2026**

CLIENT: Medford School District
Project: Hedrick 3 Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-01** Client Sample ID: Rm 216-DF
Collection Date: 9/22/2026 5:15:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 216-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090981-02** Client Sample ID: Rm 216-Sink
Collection Date: 9/22/2026 5:16:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 216-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090981-03** Client Sample ID: Rm 215-DF
Collection Date: 9/22/2026 5:18:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 215-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-04** Client Sample ID: Rm 215-Sink
Collection Date: 9/22/2026 5:19:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 215-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090981-05** Client Sample ID: Media Center Wk Rm-DF
Collection Date: 9/22/2026 5:20:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Media Center Wk Rm-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090981-06** Client Sample ID: Media Center Wk Rm-Sink
Collection Date: 9/22/2026 5:21:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Media Center Wk Rm-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.03		0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-07** Client Sample ID: Media Center Office-DF
Collection Date: 9/22/2026 5:22:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Media Center Office-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090981-08** Client Sample ID: Media Center Office-Sink
Collection Date: 9/22/2026 5:23:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Media Center Office-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.88		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090981-09** Client Sample ID: Rm 206 A-Sink (By Washer/Dryer)
Collection Date: 9/22/2026 5:25:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 206 A-Sink (By Washer/Dryer)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	45.7	*1	0.515	ppb	1	9/30/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-10** Client Sample ID: Rm 206(Culinary)Sink(N Wall-L)Orange
Collection Date: 9/22/2026 5:26:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 206(Culinary)Sink(N Wall-L)Orange

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.44		0.515	ppb	1	9/30/2026	15.0	A

Lab ID: **26090981-11** Client Sample ID: Rm 206(Culinary)Sink(N Wall-C)
Collection Date: 9/22/2026 5:27:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 206(Culinary)Sink(N Wall-C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.62		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-12** Client Sample ID: Rm 206(Culinary)Sink(N Wall-R)
Collection Date: 9/22/2026 5:28:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 206(Culinary)Sink(N Wall-R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.790		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-13** Client Sample ID: Rm 206(Culinary)Sink(S Wall-L)
Collection Date: 9/22/2026 5:29:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 206(Culinary)Sink(S Wall-L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.21		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-14** Client Sample ID: Rm 206(Culinary)Sink(S Wall-C)
Collection Date: 9/22/2026 5:30:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 206(Culinary)Sink(S Wall-C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.567		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-15** Client Sample ID: Rm 206(Culinary)Sink(S Wall-R)
Collection Date: 9/22/2026 5:31:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 206(Culinary)Sink(S Wall-R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.01		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-16** Client Sample ID: Rm 401-DF
Collection Date: 9/22/2026 5:41:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 401-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-17** Client Sample ID: Rm 401-Sink
Collection Date: 9/22/2026 5:42:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 401-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.23		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-18** Client Sample ID: Rm 402-DF
Collection Date: 9/22/2026 5:43:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 402-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-19** Client Sample ID: Rm 402-Sink
Collection Date: 9/22/2026 5:44:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 402-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-20** Client Sample ID: Rm 404-DF
Collection Date: 9/22/2026 5:45:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 404-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.783		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-21** Client Sample ID: Rm 404-Sink
Collection Date: 9/22/2026 5:46:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 404-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.835		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-22** Client Sample ID: Between 408/404 Mens RR-Sink (L)
Collection Date: 9/22/2026 5:47:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Between 408/404 Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.74		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-23** Client Sample ID: Between 408/404 Mens RR-Sink (C)
Collection Date: 9/22/2026 5:48:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Between 408/404 Mens RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.24		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-24** Client Sample ID: Between 408/404 Mens RR-Sink (R)
Collection Date: 9/22/2026 5:49:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Between 408/404 Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-25** Client Sample ID: Between 408/404 Womens RR-Sink (L)
Collection Date: 9/22/2026 5:50:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Between 408/404 Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.11		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-26** Client Sample ID: Between 408/404 Womens RR-Sink (C)
Collection Date: 9/22/2026 5:51:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Between 408/404 Womens RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.878		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-27** Client Sample ID: Between 408/404 Womens RR-Sink (R)
Collection Date: 9/22/2026 5:52:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Between 408/404 Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.674		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-28** Client Sample ID: Rm 408-DF
Collection Date: 9/22/2026 5:53:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 408-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.991		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-29** Client Sample ID: Rm 408-Sink
Collection Date: 9/22/2026 5:54:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 408-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.798		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-30** Client Sample ID: Rm 411-DF
Collection Date: 9/22/2026 5:59:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 411-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-31** Client Sample ID: Rm 411-Sink
Collection Date: 9/22/2026 6:00:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 411-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.24		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-32** Client Sample ID: Rm 410-DF
Collection Date: 9/22/2026 5:57:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 410-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-33** Client Sample ID: Rm 410-Sink
Collection Date: 9/22/2026 5:58:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 410-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-34** Client Sample ID: Rm 409-DF (E Wall)
Collection Date: 9/22/2026 5:55:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 409-DF (E Wall)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.523		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-35** Client Sample ID: Storage between 409/403-Sink
Collection Date: 9/22/2026 5:56:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Storage between 409/403-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.41		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-36** Client Sample ID: Room 204-DF
Collection Date: 9/22/2026 5:36:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Room 204-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-37** Client Sample ID: Rm 204-Sink
Collection Date: 9/22/2026 5:37:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 204-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.39	1	0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-38** Client Sample ID: Rm 202-DF
Collection Date: 9/22/2026 5:38:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 202-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-39** Client Sample ID: Rm 202-Sink
Collection Date: 9/22/2026 5:39:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 202-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.726		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-40** Client Sample ID: Rm 303-DF
Collection Date: 9/22/2026 6:02:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 303-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.96		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-41** Client Sample ID: Rm 303-Sink
Collection Date: 9/22/2026 6:03:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 303-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.550		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-42** Client Sample ID: Across Room 303-DF
Collection Date: 9/22/2026 6:14:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Across Room 303-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-43** Client Sample ID: Across Room 303 Mens RR-Sink (L)
Collection Date: 9/22/2026 6:15:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Across Room 303 Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-44** Client Sample ID: Across Room 303 Mens RR-Sink (R)
Collection Date: 9/22/2026 6:16:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Across Room 303 Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-45** Client Sample ID: Between 304/306 Storage-Sink
Collection Date: 9/22/2026 6:17:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Between 304/306 Storage-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.05		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-46** Client Sample ID: Across 306 Womens RR-Sink (L)
Collection Date: 9/22/2026 6:18:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Across 306 Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.685		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-47** Client Sample ID: Across 306 Womens RR-Sink (C)
Collection Date: 9/22/2026 6:19:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Across 306 Womens RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.03		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-48** Client Sample ID: Across 306 Womens RR-Sink (R)
Collection Date: 9/22/2026 6:20:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Across 306 Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.817		0.515	ppb	1	10/1/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-49** Client Sample ID: Rm 309-DF
Collection Date: 9/22/2026 6:21:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 309-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.25		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-50** Client Sample ID: Rm 309-Sink
Collection Date: 9/22/2026 6:22:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 309-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.65		0.515	ppb	1	10/1/2026	15.0	A

Lab ID: **26090981-51** Client Sample ID: Rm 310-DF
Collection Date: 9/22/2026 6:24:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 310-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/2/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-52** Client Sample ID: Rm 310-Sink
Collection Date: 9/22/2026 6:25:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 310-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.38		0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26090981-53** Client Sample ID: Rm 311-DF
Collection Date: 9/22/2026 6:26:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 311-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26090981-54** Client Sample ID: Rm 311-Sink
Collection Date: 9/22/2026 6:27:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 311-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.953		0.515	ppb	1	10/2/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-55** Client Sample ID: Rm 314-DF
Collection Date: 9/22/2026 6:28:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 314-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26090981-56** Client Sample ID: Rm 314-Sink
Collection Date: 9/22/2026 6:29:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 314-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26090981-57** Client Sample ID: Rm 314 Unisex RR-Sink
Collection Date: 9/22/2026 6:30:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 314 Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/2/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-58** Client Sample ID: Rm 315-DF
Collection Date: 9/22/2026 6:31:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 315-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26090981-59** Client Sample ID: Rm 315-Sink
Collection Date: 9/22/2026 6:32:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 315-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.791		0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26090981-60** Client Sample ID: Rm 316 Staff Work Rm-DF (N Wall)
Collection Date: 9/22/2026 6:33:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 316 Staff Work Rm-DF (N Wall)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.17		0.515	ppb	1	10/2/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-61** Client Sample ID: Rm 316 Staff Work Rm-Sink (N Wall)
Collection Date: 9/22/2026 6:34:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 316 Staff Work Rm-Sink (N Wall)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.63		0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26090981-62** Client Sample ID: Rm 316 Staff Work Rm-DF (W Wall)
Collection Date: 9/22/2026 6:35:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 316 Staff Work Rm-DF (W Wall)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26090981-63** Client Sample ID: Rm 316 Staff Work Rm-Sink (W Wall)
Collection Date: 9/22/2026 6:36:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 316 Staff Work Rm-Sink (W Wall)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.877		0.515	ppb	1	10/2/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26090981**
Date Reported: **10/6/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26090981
Received Date: 9/22/2026 9:15:00 AM
Reported Date: 10/6/2026 9:16:43 AM

Sample Information:

Lab ID: **26090981-64** Client Sample ID: Rm 317-DF
Collection Date: 9/22/2026 6:37:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 317-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26090981-65** Client Sample ID: Rm 317-Sink
Collection Date: 9/22/2026 6:38:00 AM Collected By: Martin Taylor
Matrix: Drinking Water Sample Location: Rm 317-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.798		0.515	ppb	1	10/2/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26090981**

06-Oct-26

Client: Medford School District
Project: Hedrick 3 Lead Testing **TestCode:** **LEAD_SCHOOLS**

Sample ID: **MB-38515**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **PBW**	Batch ID: **38515**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215707**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38515**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **LCSW**	Batch ID: **38515**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215708**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0	104	85	115				

Sample ID: **26090964-04AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **BatchQC**	Batch ID: **38515**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215710**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	0.552	102	70	130				

Sample ID: **26090964-04AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **BatchQC**	Batch ID: **38515**	TestNo: **E200.8**	**E200.8**	Analysis Date: **9/30/2026**	SeqNo: **1215711**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0.552	101	70	130	103	0.972	20	

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor
H	Holding times for preparation or analysis exceeded	MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
RL	Reporting Limit				

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26090981**

06-Oct-26

Client: Medford School District
Project: Hedrick 3 Lead Testing

TestCode: **LEAD_SCHOOLS**

Sample ID: **MB-38516**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **PBW**	Batch ID: **38516**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1215735**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38516**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **LCSW**	Batch ID: **38516**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1215736**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0	104	85	115				

Sample ID: **26090981-11AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **Rm 206(Culinary)Si**	Batch ID: **38516**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1215738**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	3.62	101	70	130				

Sample ID: **26090981-11AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **9/30/2026**	RunNo: **73227**
Client ID: **Rm 206(Culinary)Si**	Batch ID: **38516**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1215739**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	105	0.520	100	3.62	101	70	130	104	0.607	20	

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor
H	Holding times for preparation or analysis exceeded	MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
RL	Reporting Limit				

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26090981**

06-Oct-26

Client: Medford School District
Project: Hedrick 3 Lead Testing **TestCode:** **LEAD_SCHOOLS**

Sample ID: **MB-38525**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **PBW**	Batch ID: **38525**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216232**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38525**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **LCSW**	Batch ID: **38525**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216234**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0	104	85	115				

Sample ID: **26090981-31AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **Rm 411-Sink**	Batch ID: **38525**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216238**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	2.24	101	70	130				

Sample ID: **26090981-31AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/1/2026**	RunNo: **73267**
Client ID: **Rm 411-Sink**	Batch ID: **38525**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/1/2026**	SeqNo: **1216240**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	2.24	101	70	130	103	0.0947	20	

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor
H	Holding times for preparation or analysis exceeded	MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
RL	Reporting Limit				

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26090981**

06-Oct-26

Client: Medford School District
Project: Hedrick 3 Lead Testing

TestCode: **LEAD_SCHOOLS**

Sample ID: **MB-38553**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/2/2026**	RunNo: **73295**
Client ID: **PBW**	Batch ID: **38553**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/2/2026**	SeqNo: **1216757**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38553**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/2/2026**	RunNo: **73295**
Client ID: **LCSW**	Batch ID: **38553**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/2/2026**	SeqNo: **1216758**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	105	0.520	100	0	105	85	115				

Sample ID: **26090981-51AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/2/2026**	RunNo: **73295**
Client ID: **Rm 310-DF**	Batch ID: **38553**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/2/2026**	SeqNo: **1216760**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0.427	104	70	130				

Sample ID: **26090981-51AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/2/2026**	RunNo: **73295**
Client ID: **Rm 310-DF**	Batch ID: **38553**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/2/2026**	SeqNo: **1216761**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0.427	104	70	130	104	0.0947	20	

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor
H	Holding times for preparation or analysis exceeded	MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
RL	Reporting Limit				

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: MedfordSchoolDist Work Order Number: 26090981 RcptNo: 1

Logged by:	Danielle Feagan	9/22/2026 9:15:00 AM	Danielle Feagan
Completed By:	Kyler Woolsey	9/24/2026 2:44:54 PM	Kyler Woolsey
Reviewed By:	Ashley Spiegelberg	10/6/2026 9:02:27 AM	

Chain of Custody

1. Is Chain of Custody complete? Yes ☑ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☑
4. Shipping container/cooler in good condition? Yes ☑ No ☐
   Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☑ NA ☐
   No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☑ NA ☐
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☑
7. Sample(s) in proper container(s)? Yes ☑ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☑ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☑ No ☐
10. Was preservative added to bottles? Yes ☐ No ☑ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☑
12. Were any sample containers received broken? Yes ☐ No ☑
13. Does paperwork match bottle labels? (Note discrepancies on chain of custody) Yes ☑ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☑ No ☐
15. Is it clear what analyses were requested? Yes ☑ No ☐
16. Were all holding times able to be met? (If no, notify customer for authorization.) Yes ☑ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☑

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp ºC	Condition	Seal Intact	Seal No	Seal Date	Signed By

Rick & Marlon

NEILSON RESEARCH CORPORATION
Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: MSD 549C
Address: 900 Kenyon
Medford, OR 97501
Email: andy.chasteen@medford.k12.or.us
Phone: 541-840-4315 Fax:
Collected By (Print): Marlon Taylor
Collected By (Sign): Marlon Taylor
Email Report ___ Yes ___ No Mail Report ___ Yes ___ No
Fax Report ___ Yes ___No

Section B
Required Project Information

Project Name: Hedrick 3
Project Number:
Report andy.chasteen@medford.k12.or
Copy T seth.barry@medford.k12.or.us

Section C
Invoice Information

Attention: Accounting
Company Name: Medford School District
Address: 900 Kenyon
Medford, OR 97501
P.O. #

Section D
Rush Status (Subject to Scheduling)

___ Standard 10-14 Days
___ 5 Business Days (50% surcharge)
___ 3 Business Days (75% surcharge)
___ 24 - 48 hours (100% surcharge)
___ Other _____
Authorized ____ Yes ____ No

Section E
Sample Information

NRC Workorder # (Lab Use Only) 26090981

Sample ID	Matrix*	Date Collected	Time Collect	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
Room 216 - Drinking Fountain	DW	9/22/2026	5:15 am	1			01
Room 216 - Sink	DW	9/22/2026	5:16 am	1			02
Room 215 - Drinking Fountain	DW	9/22/2026	5:18 am	1			03
Room 215 - Sink	DW	9/22/2026	5:19 am	1			04
Media Center Work Room - Drinking Fountain	DW	9/22/2026	5:20 am	1			05
Media Center Work Room - Sink	DW	9/22/2026	5:24 am	1			06
Media Center Office - Drinking Fountain	DW	9/22/2026	5:22 am	1			07
Media Center Office - Sink	DW	9/22/2026	5:23 am	1			08
Room 206 A - Sink (Near Washer/Dryer)	DW	9/22/2026	5:25 am	1			09
Room 206 (Culinary) - Sink (North Wall - Left) Orange	DW	9/22/2026	5:26 am	1			10
Room 206 (Culinary) - Sink (North Wall - Center)	DW	9/22/2026	5:27 am	1			11
Room 206 (Culinary) - Sink (North Wall - Right)	DW	9/22/2026	5:28 am	1			12
Room 206 (Culinary) - Sink (South Wall - Left)	DW	9/22/2026	5:29 am	1			13
Room 206 (Culinary) - Sink (South Wall - Center)	DW	9/22/2026	5:30 am	1			14
Room 206 (Culinary) - Sink (South Wall - Right)	DW	9/22/2026	5:31 am	1			15
Room 401 - Drinking Fountain	DW	9/22/2026	5:41 am	1			16
Room 401 - Sink	DW	9/22/2026	5:42 am	1			17
Room 402 - Drinking Fountain	DW	9/22/2026	5:43 am	1			18
Room 402 - Sink	DW	9/22/2026	5:44 am	1			19
Room 404 - Drinking Fountain	DW	9/22/2026	5:45 am	1			20
Room 404 - Sink	DW	9/22/2026	5:46 am	1			21
In-between Room 408/404 Men's Restroom - Sink (Left)	DW	9/22/2026	5:47 am	1			22
In-between Room 408/404 Men's Restroom - Sink (Center)	DW	9/22/2026	5:48 am	1			23
In-between Room 408/404 Men's Restroom - Sink (Right)	DW	9/22/2026	5:49 am	1			24

2609098l

In-between Room 408/404 Women's Restroom - Sink (Left)	DW	9/22/2026	5:50	1												25
In-between Room 408/404 Women's Restroom - Sink (Center)	DW	9/22/2026	5:51	1												26
In-between Room 408/404 Women's Restroom - Sink (Right)	DW	9/22/2026	5:52	1												27
Room 408 - Drinking Fountain	DW	9/22/2026	5:53	1												28
Room 408 - Sink	DW	9/22/2026	5:54	1												29
Room 411 - Drinking Fountain	DW	9/22/2026	5:59	1												30
Room 411 - Sink	DW	9/22/2026	6:00	1												31
Room 410 - Drinking Fountain	DW	9/22/2026	5:57	1												32
Room 410 - Sink	DW	9/22/2026	5:58	1												33
Room 409 - Drinking Fountain (East Wall)	DW	9/22/2026	5:55	1												34
Storage Room In-between 409/403 - Sink	DW	9/22/2026	5:56	1												35
	DW	9/22/2026		1												-
Room 204 - Drinking Fountain	DW	9/22/2026	5:36	1												36
Room 204 - Sink	DW	9/22/2026	5:37	1												37
Room 202 - Drinking Fountain	DW	9/22/2026	5:38	1												38
Room 202 - Sink	DW	9/22/2026	5:39	1												39
Room 303 - Drinking Fountain	DW	9/22/2026	6:02	1												40
Room 303 - Sink	DW	9/22/2026	6:03	1												41
Across From Room 303 - Drinking Fountain	DW	9/22/2026	6:14	1												42
Across From Room 303 Men's Restroom - Sink (Left)	DW	9/22/2026	6:15	1												43
Across From Room 303 Men's Restroom - Sink (Right)	DW	9/22/2026	6:16	1												44
Room In-between 304/306 Storage Room - Sink	DW	9/22/2026	6:17	1												45
Across From Room 306 Women's Restroom - Sink (Left)	DW	9/22/2026	6:18	1												46
Across From Room 306 Women's Restroom - Sink (Center)	DW	9/22/2026	6:19	1												47
Across From Room 306 Women's Restroom - Sink (Right)	DW	9/22/2026	6:20	1												48
Room 309 - Drinking Fountain	DW	9/22/2026	6:21	1												49
Room 309 - Sink	DW	9/22/2026	6:22	1												50
Room 310 - Drinking Fountain	DW	9/22/2026	6:24	1												51
Room 310 - Sink	DW	9/22/2026	6:25	1												52
Room 311 - Drinking Fountain	DW	9/22/2026	6:26	1												53
Room 311 - Sink	DW	9/22/2026	6:27	1												54
Room 314 - Drinking Fountain	DW	9/22/2026	6:28	1												55
Room 314 - Sink	DW	9/22/2026	6:29	1												56
Room 314 Unisex Restroom - Sink	DW	9/22/2026	6:30	1												57
Room 315 - Drinking Fountain	DW	9/22/2026	6:31	1												58
Room 315 - Sink	DW	9/22/2026	6:32	1												59
Room 316 Staff Work Room - Drinking Fountain (North Wall)	DW	9/22/2026	6:33	1												60
Room 316 Staff Work Room - Sink (North Wall)	DW	9/22/2026	6:34	1												61
Room 316 Staff Work Room - Drinking Fountain (West Wall)	DW	9/22/2026	6:35	1												62
Room 316 Staff Work Room - Sink (West Wall)	DW	9/22/2026	6:36	1												63
Room 317 - Drinking Fountain	DW	9/22/2026	6:37	1												64
Room 317 - Sink	DW	9/22/2026	6:38	1												65
	DW			1												
				1												
				1												
				1												

*Matrix: **DW** - Drinking Water **WW** - Wastewater **W** - Water **S** - Soil/Solid **SL** - Sludge **O** - Oil **WP** - Wipe **OT** - Other

26090981

Section F
Relinquish/Receive

	Sign	Print	Date	Time
Relinquished By:		Marlen Taylor	9-22-26	6:38am
Received By:		SETH BARRY	9/22/26	6:38
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:		Dani Feagan	9/22/26	9:15

Section G
Lab Use Only

Temp:	Amb
4°C +/- 2°C:	Yes No
Received on Ice:	Yes No
Number of Bottles Received:	
pH Checked:	
COC Seals Intact:	Yes No NA
Field Blank Included:	Yes No

Received Via ___ UPS ___ FedEX ___ Other X Hand

Payment: X Invoice ___ Cash ___ VISA, M/C ___ Check # _____ Amount _____

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Data Flags

WO#: **26090981**
Date: **10/6/2026**

A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
B Analyte detected in the associated method blank.
C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF Results confirmed by re-analysis.
CU Cleanup performed as specified by method.
E Estimated value.
ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
HP Sample re-analysis performed outside of method specified holding time.
HR Sample received outside of method specified holding time.
HS Sample analyzed for volatile organics contained headspace.
HT At the client's request, the sample was analyzed outside of method specified holding time.
H Analysis performed outside of method specified holding time.
J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
N See Case Narrative on page 2 of report.
Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R Relative percent difference (RPD) is outside of the accepted recovery limits.
R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC Sub-contracted to another laboratory for analysis.
SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.

* Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
1 Value exceeds one half of the Maximum Contaminant Level.