Lead Tests - Bartlett Building - 20481900											
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Filtering For	Date Filter Installed	Date of Last Filter Change	Filter Type	Supplier	Remarks
1	20481900-001BF	20481900-001BF21A	1st Floor Men's Restroom - Sink (Left)	09/22/26	1.0	Lead	11/12/24	11/12/24	3US-MAX-F01H	Lowes	
2	20481900-002BF	20481900-002BF21A	1st Floor Men's Restroom - Sink (Right)	09/22/26	1.2	Lead	11/20/24	11/20/24	3US-MAX-F01H	Lowes	
3	20481900-003BF	20481900-003BF21A	1st Floor Women's Restroom - Sink (Left)	09/22/26	0.8	Lead	11/12/24	11/12/24	3US-MAX-F01H	Lowes	
4	20481900-004BF	20481900-004BF21A	1st Floor Women's Restroom - Sink (Right)	09/22/26	0.6	Lead	11/12/24	11/12/24	3US-MAX-F01H	Lowes	
5	20481900-005WB	20481900-005WB21A	1st Floor In Between Restrooms - Bottle Filler (Upper)	09/22/26	ND	Sediment	01/15/23	01/15/23	Elkay	Ferguson	Upper and Lower Share Filter.
6	20481900-013DW	20481900-013DW21A	1st Floor In Between Restrooms - Drinking Fountain (Lower)	09/22/26	ND	Sediment	01/15/23	01/15/23	Elkay	Ferguson	Upper and Lower Share Filter.
7	20481900-006BF	20481900-006BF21A	2nd Floor Men's Restroom - Sink (Left)	09/22/26	1.0	Lead	11/20/24	11/20/24	3US-MAX-F01H	Lowes	
8	20481900-007BF	20481900-007BF21A	2nd Floor Men's Restroom - Sink (Right)	09/22/26	1.7	Lead	12/09/24	12/09/24	3US-MAX-F01H	Lowes	
9	20481900-008BF	20481900-008BF21A	2nd Floor Woman's Restroom - Sink (Left)	09/22/26	2.5	Lead	12/09/24	12/09/24	3US-MAX-F01H	Lowes	
10	20481900-009BF	20481900-009BF21A	2nd Floor Woman's Restroom - Sink (Right)	09/22/26	1.6	Lead	11/20/24	11/20/24	3US-MAX-F01H	Lowes	
11	20481900-010DW	20481900-010DW21A	2nd Floor In Between Restrooms - Drinking Fountain	09/22/26	ND						
12	20481900-011SF	20481900-011SF21A	2nd Floor Staff Breakroom - Sink (Left)	09/22/26	0.9						
13	20481900-012SF	20481900-012SF21A	2nd Floor Staff Breakroom - Sink (Right)	09/22/26	0.9						

*None Detected (ND) = 0.10 Or Less PPB

[ ] = Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

*The E.P.A. action level for lead in schools is 20 PPB. Oregon's action level for schools is 15 PPB (Changed in 2019 in accordance with OAR 333-061-0400).

*The E.P.A. action level for copper is 1.30

*Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.