Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

October 09, 2026

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Ruch 2 Lead Testing Order No.: 26091052

Dear Andy Chasteen:

Neilson Research Corporation received 34 sample(s) on 9/23/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. Testing was completed in accordance with the laboratory's established quality system and standard operating procedures. For the current scope of NELAP-accredited analytes and certifications, please refer to the Certifications section at www.nrclabs.com.
If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: **26091052**
Date: **10/9/2026**

CLIENT: Medford School District
Project: Ruch 2 Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analytical Comments for LEAD_SCHOOLS, Sample 26091052-19A thru 26091052-34A, Batch ID 38577 : The samples required a dilution due to matrix interference associated with elevated copper and zinc responses observed during analysis. As a result, the lead reporting limit is elevated.

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-01** Client Sample ID: Rm 7-DF
Collection Date: 9/23/2026 5:36:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 7-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	11.9	1	0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26091052-02** Client Sample ID: Rm 7-Sink
Collection Date: 9/23/2026 5:37:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 7-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.70		0.515	ppb	1	10/2/2026	15.0	A

Lab ID: **26091052-03** Client Sample ID: Rm 8-DF
Collection Date: 9/23/2026 5:39:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 8-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.75		0.515	ppb	1	10/3/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-04** Client Sample ID: Rm 8-Sink
Collection Date: 9/23/2026 5:40:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 8-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.71	1	0.515	ppb	1	10/3/2026	15.0	A

Lab ID: **26091052-05** Client Sample ID: Rm 9-DF
Collection Date: 9/23/2026 5:41:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 9-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.54		0.515	ppb	1	10/3/2026	15.0	A

Lab ID: **26091052-06** Client Sample ID: Rm 9-Sink
Collection Date: 9/23/2026 5:42:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 9-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	9.92	1	0.515	ppb	1	10/3/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-07** Client Sample ID: Boys RR O/S Rm 9-Sink
Collection Date: 9/23/2026 5:43:00 AM Collected By:
Matrix: Drinking Water Sample Location: Boys RR O/S Rm 9-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.99		0.515	ppb	1	10/3/2026	15.0	A

Lab ID: **26091052-08** Client Sample ID: Girls RR O/S Rm 9-Sink
Collection Date: 9/23/2026 5:44:00 AM Collected By:
Matrix: Drinking Water Sample Location: Girls RR O/S Rm 9-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.7	1	0.515	ppb	1	10/3/2026	15.0	A

Lab ID: **26091052-09** Client Sample ID: Staff RR O/S Main Ofc-Sink
Collection Date: 9/23/2026 5:45:00 AM Collected By:
Matrix: Drinking Water Sample Location: Staff RR O/S Main Ofc-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.21		0.515	ppb	1	10/3/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-10** Client Sample ID: Rm 2-DF
Collection Date: 9/23/2026 5:50:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 2-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.61		0.515	ppb	1	10/3/2026	15.0	A

Lab ID: **26091052-11** Client Sample ID: Rm 2-Sink
Collection Date: 9/23/2026 5:51:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 2-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.685		0.515	ppb	1	10/3/2026	15.0	A

Lab ID: **26091052-12** Client Sample ID: Rm 3-DF
Collection Date: 9/23/2026 5:52:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 3-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.7	1	0.515	ppb	1	10/3/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-13** Client Sample ID: Rm 3-Sink
Collection Date: 9/23/2026 5:53:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 3-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.72		0.515	ppb	1	10/3/2026	15.0	A

Lab ID: **26091052-14** Client Sample ID: Rm 4-DF
Collection Date: 9/23/2026 5:54:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 4-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.42		0.515	ppb	1	10/3/2026	15.0	A

Lab ID: **26091052-15** Client Sample ID: Rm 4-Sink
Collection Date: 9/23/2026 5:55:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 4-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.36		0.515	ppb	1	10/3/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-16** Client Sample ID: Health Rm-Sink
Collection Date: 9/23/2026 5:09:00 AM Collected By:
Matrix: Drinking Water Sample Location: Health Rm-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.47		0.515	ppb	1	10/3/2026	15.0	A

Lab ID: **26091052-17** Client Sample ID: Health Rm RR-Sink
Collection Date: 9/23/2026 5:10:00 AM Collected By:
Matrix: Drinking Water Sample Location: Health Rm RR-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.04		0.515	ppb	1	10/3/2026	15.0	A

Lab ID: **26091052-18** Client Sample ID: Sports Field-DF (Wellhouse)
Collection Date: 9/23/2026 5:11:00 AM Collected By:
Matrix: Drinking Water Sample Location: Sports Field-DF (Wellhouse)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.69		0.515	ppb	1	10/3/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-19** Client Sample ID: O/S Main Ofc-DF (L)
Collection Date: 9/23/2026 4:54:00 AM Collected By:
Matrix: Drinking Water Sample Location: O/S Main Ofc-DF (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND	ER N	2.50	ppb	5	10/8/2026	15.0	A

Lab ID: **26091052-20** Client Sample ID: O/S Main Ofc-DF (R)
Collection Date: 9/23/2026 4:55:00 AM Collected By:
Matrix: Drinking Water Sample Location: O/S Main Ofc-DF (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND	ER N	2.50	ppb	5	10/8/2026	15.0	A

Lab ID: **26091052-21** Client Sample ID: Boys RR by Main Ofc-Sink (L)
Collection Date: 9/23/2026 5:13:00 AM Collected By:
Matrix: Drinking Water Sample Location: Boys RR by Main Ofc-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.68	ER N	2.50	ppb	5	10/8/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-22** Client Sample ID: Boys RR by Main Ofc-Sink (R)
Collection Date: 9/23/2026 5:14:00 AM Collected By:
Matrix: Drinking Water Sample Location: Boys RR by Main Ofc-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.86	ER N	2.50	ppb	5	10/8/2026	15.0	A

Lab ID: **26091052-23** Client Sample ID: Boys RR by Main Ofc-Sink (C)
Collection Date: 9/23/2026 5:15:00 AM Collected By:
Matrix: Drinking Water Sample Location: Boys RR by Main Ofc-Sink (C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND	ER N	2.50	ppb	5	10/8/2026	15.0	A

Lab ID: **26091052-24** Client Sample ID: Boys RR (Unisex)by Main Ofc-Sink
Collection Date: 9/23/2026 5:16:00 AM Collected By:
Matrix: Drinking Water Sample Location: Boys RR (Unisex)by Main Ofc-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	21.8	*ER N1	2.50	ppb	5	10/8/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-25** Client Sample ID: Girls RR by Main Ofc-Sink (L)
Collection Date: 9/23/2026 5:17:00 AM Collected By:
Matrix: Drinking Water Sample Location: Girls RR by Main Ofc-Sink (L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.14	ER N	2.50	ppb	5	10/8/2026	15.0	A

Lab ID: **26091052-26** Client Sample ID: Girls RR by Main Ofc-Sink (R)
Collection Date: 9/23/2026 5:18:00 AM Collected By:
Matrix: Drinking Water Sample Location: Girls RR by Main Ofc-Sink (R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.56	ER N	2.50	ppb	5	10/8/2026	15.0	A

Lab ID: **26091052-27** Client Sample ID: Girls RR by Main Ofc-Sink (C)
Collection Date: 9/23/2026 5:19:00 AM Collected By:
Matrix: Drinking Water Sample Location: Girls RR by Main Ofc-Sink (C)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND	ER N	2.50	ppb	5	10/8/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-28** Client Sample ID: Girls RR (Unisex) by Main Ofc-Sink
Collection Date: 9/23/2026 5:20:00 AM Collected By:
Matrix: Drinking Water Sample Location: Girls RR (Unisex) by Main Ofc-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	18.7	*ER N1	2.50	ppb	5	10/8/2026	15.0	A

Lab ID: **26091052-29** Client Sample ID: Staff Brk Rm-Sink
Collection Date: 9/23/2026 5:22:00 AM Collected By:
Matrix: Drinking Water Sample Location: Staff Brk Rm-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND	ER N	2.50	ppb	5	10/8/2026	15.0	A

Lab ID: **26091052-30** Client Sample ID: Rm by Staff Brk Rm-Sink
Collection Date: 9/23/2026 5:23:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm by Staff Brk Rm-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.44	ER N	2.50	ppb	5	10/8/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-31** Client Sample ID: Rm 15-DF
Collection Date: 9/23/2026 5:29:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 15-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	14.5	ER N1	2.50	ppb	5	10/8/2026	15.0	A

Lab ID: **26091052-32** Client Sample ID: Rm 15-Sink
Collection Date: 9/23/2026 5:30:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 15-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.63	ER N	2.50	ppb	5	10/9/2026	15.0	A

Lab ID: **26091052-33** Client Sample ID: Rm 14-DF
Collection Date: 9/23/2026 5:31:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 14-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.95	ER N	2.50	ppb	5	10/9/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: **26091052**
Date Reported: **10/9/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

Lab Order: 26091052
Received Date: 9/23/2026 10:36:00 AM
Reported Date: 10/9/2026 1:16:47 PM

Sample Information:

Lab ID: **26091052-34** Client Sample ID: Rm 14-Sink
Collection Date: 9/23/2026 5:32:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 14-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	9.36	ER N1	2.50	ppb	5	10/9/2026	15.0	A

QUALIFIERS

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
DF	Dilution Factor	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26091052**

09-Oct-26

Client: Medford School District
Project: Ruch 2 Lead Testing

TestCode: **LEAD_SCHOOLS**

Sample ID: **MB-38557**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/2/2026**	RunNo: **73295**
Client ID: **PBW**	Batch ID: **38557**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/2/2026**	SeqNo: **1216813**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: **LCS-38557**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/2/2026**	RunNo: **73295**
Client ID: **LCSW**	Batch ID: **38557**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/2/2026**	SeqNo: **1216814**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	99.4	0.520	100	0	99.4	85	115				

Sample ID: **26091048-26AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/2/2026**	RunNo: **73295**
Client ID: **BatchQC**	Batch ID: **38557**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/2/2026**	SeqNo: **1216816**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	108	0.520	100	12.5	95.7	70	130				

Sample ID: **26091048-26AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/2/2026**	RunNo: **73295**
Client ID: **BatchQC**	Batch ID: **38557**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/2/2026**	SeqNo: **1216817**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	109	0.520	100	12.5	96.3	70	130	108	0.545	20	

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor
H	Holding times for preparation or analysis exceeded	MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
RL	Reporting Limit				

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: **26091052**

09-Oct-26

Client: Medford School District
Project: Ruch 2 Lead Testing

TestCode: **LEAD_SCHOOLS**

Sample ID: **MB-38577**	SampType: **MBLK**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/5/2026**	RunNo: **73409**
Client ID: **PBW**	Batch ID: **38577**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/8/2026**	SeqNo: **1219334**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.500									

Sample ID: **LCS-38577**	SampType: **LCS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/5/2026**	RunNo: **73409**
Client ID: **LCSW**	Batch ID: **38577**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/8/2026**	SeqNo: **1219335**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	97.5	0.500	100	0	97.5	85	115				

Sample ID: **26091052-19AMS**	SampType: **MS**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/5/2026**	RunNo: **73409**
Client ID: **O/S Main Ofc-DF (L)**	Batch ID: **38577**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/8/2026**	SeqNo: **1219337**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.9	2.50	100	0.830	98.1	70	130				

Sample ID: **26091052-19AMSD**	SampType: **MSD**	TestCode: **LEAD_SCHO**	Units: **ppb**	Prep Date: **10/5/2026**	RunNo: **73409**
Client ID: **O/S Main Ofc-DF (L)**	Batch ID: **38577**	TestNo: **E200.8**	**E200.8**	Analysis Date: **10/8/2026**	SeqNo: **1219338**

Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.5	2.50	100	0.830	97.7	70	130	98.9	0.415	20	

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor
H	Holding times for preparation or analysis exceeded	MI	Recovery outside comtrol limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
RL	Reporting Limit				

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: MedfordSchoolDist Work Order Number: 26091052 RcptNo: 1

Logged by:	Ashley Spiegelberg	9/23/2026 10:36:00 AM
Completed By:	Kyler Woolsey	9/25/2026 12:13:46 PM
Reviewed By:	Dorie Evans	10/9/2026 1:13:57 PM

Chain of Custody

1. Is Chain of Custody complete? Yes ☑ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☑
4. Shipping container/cooler in good condition? Yes ☑ No ☐
   Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☑ NA ☐
   No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☑
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☑
7. Sample(s) in proper container(s)? Yes ☑ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☑ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☑ No ☐
10. Was preservative added to bottles? Yes ☐ No ☑ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☑
12. Were any sample containers received broken? Yes ☐ No ☑
13. Does paperwork match bottle labels? (Note discrepancies on chain of custody) Yes ☑ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☑ No ☐
15. Is it clear what analyses were requested? Yes ☑ No ☐
16. Were all holding times able to be met? (If no, notify customer for authorization.) Yes ☑ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☑

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp ºC	Condition	Seal Intact	Seal No	Seal Date	Signed By

NEILSON RESEARCH CORPORATION
Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: MSD 549C
Address: 900 Kenyon
Medford, OR 97501
Email: andy.chasteen@medford.k12.or.us
Phone: 541-840-4315 Fax:

Section B
Required Project Information

Project Name: Ruch 2
Project Number:
Report andy.chasteen@medford.k12.or
Copy T seth.barry@medford.k12.or.us

Section C
Invoice Information

Attention: Accounting
Company Name: Medford School District
Address: 900 Kenyon
Medford, OR 97501
P.O. #

Section D
Rush Status (Subject to Scheduling)

____ Standard 10-14 Days
____ 5 Business Days (50% surcharge)
____ 3 Business Days (75% surcharge)
____ 24 - 48 hours (100% surcharge)
____ Other _____

Authorized ____ Yes ____ No

Collected By (Print):
Collected By (Sign):

Email Report ___ Yes ___ No Mail Report ___ Yes ___ No
Fax Report ___ Yes ___No

Section E
Sample Information

NRC Workorder # (Lab Use Only) 26091052

Sample ID	Matrix*	Date Collected	Time Collect AM	No. of Containers	Analysis Requested										Remarks/Field Data	NRC Sample # (Lab Use Only)
Room 7 - Drinking Fountain	DW	9/23/2026	536	1												01
Room 7 - Sink	DW	9/23/2026	537	1												02
Room 8 - Drinking Fountain	DW	9/23/2026	539	1												03
Room 8 - Sink	DW	9/23/2026	540	1												04
Room 9 - Drinking Fountain	DW	9/23/2026	541	1												05
Room 9 - Sink	DW	9/23/2026	542	1												06
Boy's Restroom Outside Room 9 - Sink	DW	9/23/2026	543	1												07
Girl's Restroom Outside Room 9 - Sink	DW	9/23/2026	544	1												08
Staff Restroom Outside The Main Office - Sink	DW	9/23/2026	545	1												09
Room 2 - Drinking Fountain	DW	9/23/2026	550	1												10
Room 2 - Sink	DW	9/23/2026	551	1												11
Room 3 - Drinking Fountain	DW	9/23/2026	552	1												12
Room 3 - Sink	DW	9/23/2026	553	1												13
Room 4 - Drinking Fountain	DW	9/23/2026	554	1												14
Room 4 - Sink	DW	9/23/2026	555	1												15
Health Room - Sink	DW	9/23/2026	509	1												16
Health Room Restroom - Sink	DW	9/23/2026	510	1												17
Sports Field - Drinking Fountain (On Wellhouse)	DW	9/23/2026	511	1												18
Outside Main Office - Drinking Fountain (Left)	DW	9/23/2026	454	1												19
Outside Main Office - Drinking Fountain (Right)	DW	9/23/2026	455	1												20
Boy's Restroom Adjacent To Main Office - Sink (Left)	DW	9/23/2026	513	1												21
Boy's Restroom Adjacent To Main Office - Sink (Right)	DW	9/23/2026	514	1												22
Boy's Restroom Adjacent To Main Office - Sink (Center)	DW	9/23/2026	515	1												23
Boy's Restroom (Unisex Area) Adjacent To Main Office - Sink	DW	9/23/2026	516	1												24

Girl's Restroom Adjacent To Main Office - Sink (Left)	DW	9/23/2026	517	1												25
Girl's Restroom Adjacent To Main Office - Sink (Right)	DW	9/23/2026	518	1												26
Girl's Restroom Adjacent To Main Office - Sink (Center)	DW	9/23/2026	519	1												27
Girl's Restroom (Unisex Area) Adjacent To Main Office - Sink	DW	9/23/2026	520	1												28
Staff Break Room - Sink	DW	9/23/2026	522	1												29
Room Adjacent To Staff Break Room - Sink	DW	9/23/2026	523	1												30
Room 15 - Drinking Fountain	DW	9/23/2026	529	1												31
Room 15 - Sink	DW	9/23/2026	530	1												32
Room 14 - Drinking Fountain	DW	9/23/2026	531	1												33
RM 14 SINK	DW	9/23/26	532	1												34

*Matrix: **DW** - Drinking Water **WW** - Wastewater **W** - Water **S** - Soil/Solid **SL** - Sludge **O** - Oil **WP** - Wipe **OT** - Other

Section F
Relinquish/Receive

	Sign	Print	Date	Time
Relinquished By:		SETH BARDY	9/23/26	
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:		Ashley Spiegelberg	9/23/26	10:36

Section G
Lab Use Only

Temp: Amb
4°C +/- 2°C: Yes No N/A
Received on Ice: ___ Yes ___ No
Number of Bottles Received:
pH Checked:
COC Seals Intact: ___ Yes ___ No ___ NA
Field Blank Included: ___ Yes ___ No
Received Via ___ UPS ___ FedEX ___ Other ___ Hand
Payment: ___ Invoice ___ Cash ___ VISA, M/C ___ Check # _____ Amount _____

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Data Flags

WO#: **26091052**
Date: **10/9/2026**

A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
B Analyte detected in the associated method blank.
C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF Results confirmed by re-analysis.
CU Cleanup performed as specified by method.
E Estimated value.
ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
HP Sample re-analysis performed outside of method specified holding time.
HR Sample received outside of method specified holding time.
HS Sample analyzed for volatile organics contained headspace.
HT At the client's request, the sample was analyzed outside of method specified holding time.
H Analysis performed outside of method specified holding time.
J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
N See Case Narrative on page 2 of report.
Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R Relative percent difference (RPD) is outside of the accepted recovery limits.
R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC Sub-contracted to another laboratory for analysis.
SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.

* Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
1 Value exceeds one half of the Maximum Contaminant Level.