Pasadena Unified School District

Sierra Madre Middle

2017 Drinking Water Lead Testing Records

This packet includes state published sample results and district sampling records. The original laboratory report was not located. The state data extract is clearly labeled.

Documents included

State published results - Sierra Madre Middle | page 2

Sierra Madre Middle School | page 3

Sampling location photographs | pages 4-5

Select a document above to jump to it. Original reports are reproduced in full; Word and Excel supporting records have been converted to PDF.

Historical records only. These documents describe the samples and conditions recorded in 2017, not every outlet or current water conditions. Separate 2023 preschool testing is not included.

Sierra Madre Middle

2017 lead testing - state published results

Sample date: 2017-11-01

Extracted from the California State Water Resources Control Board K-12 school lead sampling dataset. This is a data extract, not an original laboratory certificate.

Sample ID	Location / site identifier	Lead (ug/L)
1910148-AAC-A	F-Building 1st Outside Boy's and Girl's Restroom 1st Floor Next to Library Drinking Fountain	< 5
1910148-AAC-B	F-Building 1st Teacher's Lounge F-122A Sink Faucet	< 5
1910148-AAC-C	E-Building 1st Basketball Court North Side of E- building Ouside of Roomo E108 Drinking Fountain	< 5
1910148-AAC-D	C- Building 1st Lunch Area Outside Cafe C-122 Drinking Fountain	< 5
1910148-AAC-E	C-Building 1st Kitchen Food Prep Sink Faucet Sink Faucet	< 5

All five entries are reported as less than 5 ug/L. In water, ug/L is equivalent to parts per billion (ppb). Less than 5 does not mean zero lead.

Water system: SIERRA MADRE-CITY, WATER DEPT. (CA1910148).

School address in source: 160 North Canon Avenue Sierra Madre CA 91024-2004.

Source: State Water Board school lead sampling dataset (Excel)

Historical records only. These results do not describe current water conditions.

Pasadena Unified School District
Lead Sampling Plan

School Site: **Sierra Madre Middle School**

Address **160 N. Canon Ave., Sierra Madre 91024**

No.	**Building** (Letter/ Name)	**Floor No.**	**Location Description** (Hallway/Kitchen/Café/ Classroom)	**Proximity to** (Room number or next to)	**Type of faucet** (Drinking Fountain/Sink)	**Photo**
1	F- Building	1st	OUTSIDE BOY'S AND GIRLS' RESTROOM-1ST FLOOR	NEXT TO LIBRARY	DINKING FOUNTAIN	**SEE ATTACHED PAGE**
2	F- Building	1st	TEACHER'S LOUNGE	F-122 A	SINK FAUCET	**SEE ATTACHED PAGE**
3	E- Building	1st	BASKETBALL COURT	NORTH SIDE OF E-BUILDING OUTSIDE OF RM. E108	DRINKING FOUNTAIN	**SEE ATTACHED PAGE**
4	C- Building	1st	LUNCH AREA	OUTSIDE OF CAFÉ C-112	DRINKING FOUNTAIN	**SEE ATTACHED PAGE**
5	C-Building	1st	KITCHEN	FOOD PRE SINK FAUCET	SINK FAUCET	**SEE ATTACHED PAGE**

SCHOOL NAME: SM MIDD

SAMPLE #1



SAMPLE#2



SAMPLE# 3



SAMPLE# 4



SAMPLE# 5

