Pasadena Unified School District

Sierra Madre Elementary

2017 Drinking Water Lead Testing Records

This packet includes state published sample results and district sampling records. The original laboratory report was not located. The state data extract is clearly labeled.

Documents included

State published results - Sierra Madre Elementary | page 2

Sierra Madre Elementary School | page 3

Sampling location photographs | pages 4-5

Select a document above to jump to it. Original reports are reproduced in full; Word and Excel supporting records have been converted to PDF.

Historical records only. These documents describe the samples and conditions recorded in 2017, not every outlet or current water conditions. Separate 2023 preschool testing is not included.

Sierra Madre Elementary

2017 lead testing - state published results

Sample date: 2017-11-15

Extracted from the California State Water Resources Control Board K-12 school lead sampling dataset. This is a data extract, not an original laboratory certificate.

Sample ID	Location / site identifier	Lead (ug/L)
1910148-AAB-A	A-blg 1st Room 110 Teachers Workroom Next to Mail Box Sink Faucet	< 5
1910148-AAB-B	A-blg- 1st Outside Cafe North Side of Girls Restroom, Drinking Fountain	< 5
1910148-AAB-C	A-blg 1st Kitchen North side of Kitchen Next to Oven Inside Cafe Sink Faucet	< 5
1910148-AAB-D	A-blg 1st Teachers Lounge Inside Cafe Sink Faucet	< 5
1910148-AAB-E	Playground 2nd Level South of Garden Next to Handicamp Ramp Drinking Fountain	< 5

All five entries are reported as less than 5 ug/L. In water, ug/L is equivalent to parts per billion (ppb). Less than 5 does not mean zero lead.

Water system: SIERRA MADRE-CITY, WATER DEPT. (CA1910148).

School address in source: 141 West Highland Avenue Sierra Madre CA 91024-1810.

Source: State Water Board school lead sampling dataset (Excel)

Historical records only. These results do not describe current water conditions.

Pasadena Unified School District
Lead Sampling Plan

School Site**: Sierra Madre Elem School**

Address **141 W. Highland Ave., Sierra Madre 91024**

No.	**BUILDING** (Letter/ Name)	**Floor No.**	**Location Description** (Hallway/Kitchen/Café/ Classroom)	**Proximity to** (Room number or next to)	**Type of faucet** (Drinking Fountain/Sink)	**Photo**
1	A-BUILDING	1st	RM. 110 TEACHER'S WORKROOM	NEXT TO MAILBOX	SINK FAUCET	**SEE ATTACHED PAGE**
2	A-BUILDING	1st	OUTSIDE CAFETERIA	NORTHSIDE OF GIRL'S RESTROOM	DRINKING FOUNTAIN	**SEE ATTACHED PAGE**
3	A-BUILDING	1st	KITCHEN	NORTHSIDE OF KITCHEN NEXT TO OVEN	SINK FAUCET	**SEE ATTACHED PAGE**
4	A-BUILDING	1st	TEACHER LOUNGE	INSIDE CAFETERIA	SINK FAUCET	**SEE ATTACHED PAGE**
5	PLAYGROUND	2nd	SOUTH OF GARDEN	NEXT TO HANDICAP RAMP	DRINKING FOUNTAIN	**SEE ATTACHED PAGE**

SCHOOL NAME: SM ELEM

SAMPLE #1



SAMPLE#2



SAMPLE# 3



SAMPLE# 4



SAMPLE# 5

