DOMINION
Environmental Consultants

AHERA 6-Month Surveillance Inspection Form

(As Required by AHERA – 40 CFR Part 763 Subpart E)

I. Facility Information

School/Building Name: Kyrene Traditional Academy

LEA (Local Education Agency): Kyrene Elementary School District No. 28

Building Address: 3375 West Galveston Street

City/State/Zip: Chandler, AZ 85226

Last Reinspection Date (3-Year): August 18, 2025

II. Surveillance Information

Date of Surveillance: October 19, 2026

Inspector Name: Nick Marcos

Inspector Accreditation # / Expiration: ON-188748-8873-031326 Exp. 3.13.27

Management Planner Accreditation # / Expiration: 4612-8873-102425 Exp. 10.24.26

Inspector Company: Dominion Environmental Consultants, Inc.

Phone: (623) 516-1415

III. Review of Asbestos Management Plan

✓ Asbestos Management Plan reviewed prior to inspection
✓ Most recent inspection/reinspection report available
✓ Previous response actions reviewed
✓ O&M; program documentation reviewed
✓ Training records reviewed by LEA

Comments:

_____

_____

_____

IV. O & M Areas with ACBM in need of repair

Based on the findings of the inspection, appropriate response actions must be selected in accordance with AHERA guidelines. If ACBM is in good condition and unlikely to be disturbed, it may be managed in place through an operations and maintenance (O&M) program, including periodic surveillance and worker training. However, if the material is damaged or poses a risk of fiber release, response actions such as repair (e.g., encapsulation or enclosure) or removal may be required. Repairs are typically used when damage is limited, and the material can be stabilized, while removal is often necessary when ACBM is significantly damaged, cannot be effectively repaired, or will be impacted by renovation or demolition activities. All such actions must be performed using accredited personnel and appropriate work practices to prevent asbestos fiber release and protect building occupants. Under 40 CFR 61 Subpart M, projects involving regulated asbestos-containing material (RACM) above threshold amounts (160 sq ft, 260 linear ft, or 35 cubic ft) must follow full NESHAP requirements, regardless of how the waste is packaged.

In the event of a fiber release episode, 40 CFR 763.90 requires prompt action to control the hazard. The affected area must be immediately isolated, appropriate personnel notified, and cleanup performed by trained professionals using HEPA vacuums and wet methods. The damaged ACBM must then be repaired, encapsulated, or removed, followed by a visual inspection and, if necessary, air clearance testing before the space can be safely reoccupied.

Room/ Area	HM #	Material Description	Friable? (Y/N)	Damage Observed	Action Needed
Main Building Room 13, 16, 18, 24, 35	20	Tackboard	No	Some Tearing	Remove/Replace or Enclose/Encapsulate
Main Building Electrical Room (near Room 9)	88-89	Pipe Wrap & Insulation	No	Tearing	Remove/Replace or Enclose/Encapsulate
Main Building Art Room, Room 15, 36/37	29/30	Tan Speckled 12” x 12” VCT & Mastic	No	Broken/Cracking	Remove/Replace or Enclose/Encapsulate
Main Building Boys Restroom 44	60-62	Blue 2” x 2” Ceramic Floor Tile, Grout, Thinset	No	Broken/Cracking	Remove/Replace or Enclose/Encapsulate
Main Building Girls Restroom 42 & 43	72	Peach 2” x 2” Ceramic Floor Tile	No	Broken/Cracking	Remove/Replace or Enclose/Encapsulate
Building 200 2nd Floor Lab Area & Classroom 1-251	14	Polished Concrete	No	Cracking/Chipped	Repair/Enclose
Building 300 Kitchen	10	Polished Concrete	No	Cracking/Chipped	Repair/Enclose

*L-Wing has sealed rooms, which were no longer in use

V. Classification, Condition, Response Action of All Remaining ACBM

100 BUILDING: Main Building

Material Description	Assessment Classification	Material Condition	Changes Since Last Inspection		Response Action Recommendations	Accessibility & Potential for Disturbance
Dark Blue Entry Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated

Mastic for Dark Blue Entry Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Interior Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Exterior Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black Window Glazing	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
White Glass Block Mortar	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Tackboard	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Tackboard	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black Vinyl Flooring	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Black Vinyl Flooring	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Blue Floor Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Tan 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for Tan 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Tan 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Fixture Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Tan Speckled 12" x 12" Vinyl Floor Tile (VCT)	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Tan Speckled 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Red Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Red Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
White 8" x 8" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for White 8" x 8" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for White 8" x 8" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Gray Floor Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black Sink Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
White w/Gray Specks 12" x 12" Vinyl Floor Tile (VCT)	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for White w/Gray Specks 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
White Sink Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Divider Wall	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Beige 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for Beige 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Thinset for Beige 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Pink 4" x 6" Ceramic Cove Base Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for Pink 4" x 6"	1 2 3 4	G MD SD	Y	N	O&M Repair	Inaccessible Accessible

Ceramic Cove Base Tile	5 6 7	DA R E			Enclose/Encaps Remove	V/D W/D Renovated
Mastic for Pink 4" x 6" Ceramic Cove Base Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Gray Floor Paint	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black/Gray Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Black/Gray Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Black Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Gray/Black Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Skip Trowel Drywall System	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Exterior Plaster	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Brick	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mortar for Brick	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Fiberglass Reinforced Plastic (FRP)	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for FRP	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Blue 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for Blue 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Thinset for Blue 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Blue 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for Blue 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Blue 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for Black 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Black 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Off-White 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for Off-White 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Off-White 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Peach 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Peach 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
White 4" x 4" Replacement Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
White 2" x 2" Replacement Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Box Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Gray Flex Duct Wrap	1 2 3 4	G MD SD	Y	N	O&M Repair	Inaccessible Accessible

	5 6 7	DA R E			Enclose/Encaps Remove	V/D W/D Renovated
Skylight Insulation Panel	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Insulation for Skylight Insulation Panel	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Duct Tape	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Ceiling Insulation	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Ceiling Insulation Backing for Ceiling Insulation	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black Pipe Foam	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Unfinished Drywall System	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Gray Duct Mastic	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Large Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Large Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Small Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Small Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Flex Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Brown Fire Stop Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated

200 BUILDING

Material Description	Assessment Classification	Material Condition	Changes Since Last Inspection		Response Action Recommendations	Accessibility & Potential for Disturbance
Dark Blue Entry Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Dark Blue Entry Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Interior Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Exterior Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Polished Concrete	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Floor Expansion Joint	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Tackboard	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Tackboard	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black Countertops	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Smooth Drywall System	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Tan 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for 4" x 4" Ceramic Wall Tiles	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for 4" x 4" Ceramic Wall Tiles	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Blue 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Red 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Expansion Joint for Blocks	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Blue Floor Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Fixture Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Exterior Plaster	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Red Fire Stop Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Large Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Large Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Small Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Small Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Flex Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Duct Tape	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Gray Duct Mastic	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Unfinished Drywall System	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black Pipe Foam	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated

300 BUILDING: Multipurpose Room

Material Description	Assessment Classification	Material Condition	Changes Since Last Inspection		Response Action Recommendations	Accessibility & Potential for Disturbance
Expansion Joint	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Polished Concrete	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Floor Expansion Joint for Polished Concrete	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Gray Soundboard Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Gray Soundboard Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Blue Soundboard Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Blue Soundboard Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Red Soundboard Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Red Soundboard Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Gray Floor Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Tan 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for Tan 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Tan 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Blue 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for Blue 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Blue 4"x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Red 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Grout for Red 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Red 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Fixture Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Blue Stair Tread	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Stair Tread	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Interior Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Exterior Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Dark Blue Entry Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Entry Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Gray Sink Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Tackboard	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Tackboard	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated

Fiberglass Reinforced Plastic (FRP)	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for FRP	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
2' x 4' Drywall Ceiling Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black Vinyl Flooring	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Vinyl Flooring	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Dark Gray Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Dark Gray Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Divider Wall	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black L-Shaped Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Black L-Shaped Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Flex Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Gray Duct Mastic	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black Pipe Foam Insulation	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Unfinished Drywall	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Large Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Large Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Small Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Small Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Duct Tape	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated

*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

*ACBM Condition:

G	Good
MD	Minor Damage
SD	Significant Damage
DA	Damaged & Accessible
R	Removed
E	Enclosed or Encapsulated

VI. Notifications

☐ Custodial/Maintenance staff informed by _____ on Date: _____
☐ Response action timeline established by_____ on Date: _____

VII. Photographic Documentation of Damaged Areas

☑ Photo Log of Damaged ACBM Attached

☐ No Damages Observed

VIII. Inspector Certification




I certify that this surveillance was conducted in accordance with 40 CFR §763.92 and applicable state regulations.


Inspector Signature: _____
Date: 10/19/26

IX. LEA Acknowledgment

LEA Representative Name: _____
Title: _____
Signature: _____
Date: _____

DOMINION

Kyrene Traditional Academy – 6 Month Surveillance March 20, 2026 & October 19, 2026	
Main Building	
Tackboard	
	
White Pipe Wrap & Insulation	
	
Tan Speckled 12" x 12" VCT & Mastic	
	
Peach 2" x 2" Ceramic Floor Tile	Blue 2" x 2" Ceramic Floor Tile, Grout, Thinset
	

200 Building	
Polished Conrete	
	
300 Building	
Polished Conrete	
	