Jackson County ISD
an Educational Service Agency

Columbia Network Cabinet Upgrade - Addendum 1

Question: The RFP specifies replacing the existing wall-mounted cabinets with floor-mounted 2-post racks, but the rack dimensions and other specifications are not provided. Could you please confirm the required rack height, depth, width, and any other specific requirements?
Answer: 45U, Steel, 6 inch Channel Depth, 20" wide