J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing

1775 Expressway Drive North
Hauppauge, NY 11788
631.584.5492
Fax: 631.584.3395
www.jcbroderick.com

November 12, 2026

Mr. Miguel Cruz
Brentwood Union Free School District
52 Third Avenue
Brentwood, New York 11717

Re: Update 3 to Lead Testing in School Drinking Water
Remedial Action Plan
2023-2025 Compliance 10 NYCRR Subpart 67-4
Initial Report Date: August 11, 2025

JCB#: 23-53744

Dear Mr. Cruz:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 5 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

Attachment 1: Lead in Water Remediation Plan
Attachment 2: Outlet Inventory and Lead Testing Results
Attachment 3: Laboratory Analytical Reports
Attachment 4: Laboratory Certifications

If you have any questions, or if more information is needed, please contact our office.

Sincerely,

Danielle Bolognini

Danielle Bolognini
J C Broderick & Associates, Inc.

Attachment 1:

Lead in Water Remediation Plan



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Lead in Water Remediation Plan

Section 67-4.4 Response of the New York State Department of Health (NYS DOH) Title 10 of the Official Compilation of the Codes, Rules and Regulations of the State of New York requires:

If the lead concentration of water at an outlet exceeds the action level, the school shall:
(a) prohibit use of the outlet until:
(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
(2) test results indicate that the lead levels are at or below the action level;

As historical sampling results have indicated, the concentrations of lead are more likely attributable to the individual fixtures and/or their immediately adjoining plumbing, and not with the building-wide plumbing. Based upon this information, the following remedial steps are recommended:

Step 1A: Potable Outlets (Outlets intended to be used for drinking/cooking)

Immediately remove the fixture from service. If necessary, provide an adequate supply of potable water for drinking/cooking to this location at no cost to the occupants. If an outlet is seldomly used or is unnecessary, the district may consider permanent removal of the outlet and capping of its supply line.

Step 1B: Non-Potable Outlets (Outlets not intended for drinking/cooking)


See Step 1A OR Placard the outlet for non-drinking use. Signs must be clearly visible and in close proximity to the affected outlet. Example signage is provided at: https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns_lead .pdf.



Do not use for drinking



Hand washing only





Step 2: Service & Repair or Outlet Replacement

The school district's plumber should evaluate the outlet to determine if any components require service or repair. Depending on the extent of service/repair necessary, age of the fixture, and or overall costs, the district may consider replacing the outlet entirely. Any newly installed components shall be certified lead free. (i.e. NSF/ANSI 61, NSF/ANSI-273). If servicing involves installing/replacing a point-of-use filtration system, this filter shall be certified for its lead reduction capability (i.e. NSF/ANSI 53). Follow all manufacturer's instructions for all component installations. OUTLET RESTRICTIONS MUST REMAIN IN PLACE UNTIL SATISFACTORY TEST RESULTS ARE RECEIVED. See Step 3.

Step 3: Retesting & Return to Service

Schedule a retest of the outlet. Outlet restrictions must remain in place until lead testing results at or below the action level are received. Once satisfactory results are received, the outlet may be returned to normal service. Note: It is recommended that "Do Not Drink" signage remain in place for all non-potable and non-applicable outlet types.

Attachment 2:

Outlet Inventory and Lead Testing Results



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Brentwood Union Free School District

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0001	**Kitchen**	1031	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**OOS**	10/2/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-0002	**Kitchen**	1031	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**OOS**	10/2/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-0003	**Kitchen**	1031	Hand Wash Only	Applicable	**6/7/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-0005	**Kitchen**	1031	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0006	**Kitchen**	1031	Spray Nozzle	Applicable					Result Below Action Level, Continue O&M
BRTWD-0007	**Kitchen**	1031	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-0008	**Kitchen**	1031	Hand Wash Only	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0009	**Kitchen Storage Room**	1031F	Kitchen Non Potable	Applicable	**6/7/2025**	**OOS**	12/23/2025	18.0	Placarded for Non-Drinking Use Until Remediated
BRTWD-0010	**Kitchen Locker Room**	1031C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0015	**New Construction Hallway Near East Exit**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0016	**New Construction Hallway Near East Exit**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0017	**Womens Faculty Bathroom (Near Special Education Room**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0018	**Mens Faculty Bathroom (Near Special Education Room 144)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0019	**Asst. Principal's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0024	**Corridor Near Bathrooms**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0025	**Corridor Near Bathrooms**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service RFI = Removed from Inventory

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0030	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0031	**Girls Bathroom (Across Room 111)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0032	**Girls Bathroom (Across Room 111)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0033	**Boys Bathroom (Across Room 111)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0034	**Boys Bathroom (Across Room 111)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0035	**Corridor Near Exit Vestibule 106**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0036	**Corridor Near Exit Vestibule 106**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0037	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0038	**Room 1831 Home Economics**	N/A	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0039	**Cafeteria Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0040	**Cafeteria Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0041	**Cafeteria Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0042	**Cafeteria Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0043	**Kitchen (New Construction)**	N/A	Hand Wash Only	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0044	**Kitchen (New Construction)**	N/A	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0045	**Kitchen (New Construction)**	N/A	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0046	**Kitchen (New Construction)**	N/A	Hand Wash Only	Applicable	**6/7/2025**	**9.5**	12/30/2025	42.1	Placarded for Non-Drinking Use Until Remediated
BRTWD-0047	**Kitchen (New Construction)**	N/A	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0049	**Kitchen (New Construction)**	N/A	Pasta Pot/Steam Kettle	Applicable	**6/7/2025**	**2.9**			Result Below Action Level, Continue O&M
BRTWD-0050	**Kitchen (New Construction)**	N/A	Hand Wash Only	Applicable	**6/7/2025**	**14.5**	12/30/2025	9.0	Placarded for Non-Drinking Use Until Remediated

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0051	**Kitchen (New Construction)**	N/A	Hand Wash Only	Applicable	**6/7/2025**	**3.0**			Result Below Action Level, Continue O&M
BRTWD-0052	**Kitchen Slop Sink Room**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0053	**Kitchen Slop Sink Room**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0054	**Kitchen Slop Sink Room**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0055	**Kitchen Girls Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0056	**Kitchen Boys Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0057	**Mens Bathroom (Adjacent to Room 428)**	1010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0058	**Mens Bathroom (Adjacent to Room 428)**	1010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0059	**Mens Bathroom (Adjacent to Room 428)**	1010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0060	**Custodial Closet**	1012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0061	**Women's Bathroom (Adjacent to Room 428)**	1013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0062	**Women's Bathroom (Adjacent to Room 428)**	1013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0063	**Women's Bathroom (Adjacent to Room 428)**	1013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0064	**Nurse's Office**	1022	Nurse's Office Sink	Applicable	**6/7/2025**	**1.7**			Result Below Action Level, Continue O&M
BRTWD-0065	**Nurse's Office Bathroom**	1022A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0069	**Boiler Room**	0001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0070	**Corridor Near Closet (1027A)**	1027	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0071	**Closet in Corridor Outside Boiler Room**	1027A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0072	**Closet in Corridor Outside Boiler Room**	1027A	Ice Machine	Applicable	**6/7/2025**	**OOS**	1/23/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-0073	**Girls Coach's Office Bathroom**	1021E1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0074	**Girls Locker Room**	1021E2	Water Fountain-No Chiller	Applicable	**6/7/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-0078	**Gym Vestibule to Aux. Gym & Girls Locker Room**	1021B	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0079	**Gym Vestibule to Aux. Gym & Girls Locker Room**	1021B	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0082	**Gym Coach's Office Bathroom**	1019A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0083	**Corridor Near Custodial Room (1017A)**	1017	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0084	**Custodial Room Outside Boys Team Locker Room**	1017A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0085	**Team Locker Room Bathroom**	1018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0086	**Team Locker Room Bathroom**	1018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0088	**Custodial Closet**	1029	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0091	**Corridor Near Guidance Office (1040)**	1067	Water Fountain-No Chiller	Applicable	**6/7/2025**	**3.6**			Result Below Action Level, Continue O&M
BRTWD-0092	**Custodial Closet**	1044	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0093	**Mens Faculty Bathroom (Across Custodial Receving)**	1045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0094	**Corridor Near Men's Faculty Bathroom (1045)**	1051	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0095	**Corridor Near Men's Faculty Bathroom (1045)**	1051	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0096	**Womens Faculty Bathroom (Across Custodial Receiving)**	1047	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0099	**Faculty Lounge**	1053	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**3.5**			Result Below Action Level, Continue O&M
BRTWD-0103	**Room 1410 Home Economics**	1054	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-0104	**Room 1410 Home Economics**	1054	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-0105	**Room 1410 Home Economics**	1054	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0106	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0107	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0108	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0109	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0110	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0111	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0112	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0113	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0114	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0115	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0116	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0117	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0118	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0119	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0120	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0121	**Room 1406**	1058	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0125	**Corridor Near Men's Bathroom (1060)**	1067	Water Fountain-No Chiller	Applicable	**6/7/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-0126	**Custodial Closet**	1061	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0127	**Womens Bathroom (Across Room 1405)**	1062	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0129	**Womens Bathroom (Across Room 1405)**	1062	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0130	**Corridor Near Principal's Office (1065B)**	1067	Water Fountain-No Chiller	Applicable	**6/7/2025**	**1.7**			Result Below Action Level, Continue O&M

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0131	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0132	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0133	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0134	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0135	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0136	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0137	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0138	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0139	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0140	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0141	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0142	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0143	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0144	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0145	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0146	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0147	**Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0148	**2805/2809 Prep Room**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0149	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0150	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0151	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0152	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0153	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0154	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0155	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0156	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0157	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0158	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0159	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0160	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0161	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0162	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0163	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0164	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0165	**Room 2809**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0166	**Handicap Bathroom (Across Rooms 2809 & 2805)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0167	**Library Workroom**	N/A	Office Faucet	Applicable	**6/7/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-0168	**Ladies Faculty Bathroom (Near Library)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0169	**Ladies Faculty Bathroom (Near Library)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0170	**Ladies Faculty Bathroom (Near Library)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0171	**Ladies Faculty Bathroom (Near Library)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0172	**Corridor Near Faculty Bathrooms**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0173	**Corridor Near Faculty Bathrooms**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0174	**Storage (Former Bathroom)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0175	**Storage (Former Bathroom)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0176	**Storage (Former Bathroom)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0177	**Storage (Former Bathroom)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0178	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0179	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0180	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0181	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0182	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0183	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0184	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0185	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0186	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0187	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0188	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0189	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0190	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0191	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0192	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0193	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0194	**Room 2819**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0195	**Room 2819/2823 Prep Room**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0196	**Room 2819/2823 Prep Room**	N/A	Water Cooler	Applicable	**6/7/2025**	**2.2**			Result Below Action Level, Continue O&M
BRTWD-0197	**Room 2823**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0198	**Room 2823**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0199	**Room 2823**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0200	**Room 2823**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0201	**Room 2823**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0202	**Room 2823**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0203	**Room 2823**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0204	**Room 2823**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0205	**Room 2823**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0206	**Room 2823**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0207	**Mens Faculty Bathroom (Across Rooms 2823 & 2819)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0208	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0209	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0210	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0211	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0212	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0213	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0214	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0215	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0216	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0217	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0218	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0219	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0220	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0221	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0222	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0223	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0224	**Room 2826**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0225	**Corridor Near Room 2537 (2001)**	2054	Water Fountain-No Chiller	Applicable	**6/7/2025**	**OOS**	9/28/2026	4.5	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-0229	**Corridor Near Men's Bathroom (2010)**	2054	Water Fountain-No Chiller	Applicable	**6/7/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-0230	**Custodial Closet**	2012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0232	**Womens Bathroom (Across AV Room)**	2013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0233	**Womens Bathroom (Across AV Room)**	2013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0234	**Corridor Near Room 2520 Book Room (2023)**	2054	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0238	**Corridor Room 2500 To Room 2537**	2054	Water Fountain-No Chiller	Applicable	**6/7/2025**	**9.4**			Removed From Service, Pending Remediation
BRTWD-0239	**Room 2512**	2037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0240	**Room 2512**	2037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0241	**Room 2512**	2037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0242	**Room 2512**	2037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0243	**Room 2512**	2037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0248	**Room 2510 Prep Room**	2039A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0268	**Room 2507**	2042	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0269	**Room 2507**	2042	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0270	**Room 2507**	2042	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0271	**Room 2507**	2042	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0272	**Room 2507**	2042	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0273	**Room 2507**	2042	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0274	**Room 2507**	2042	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0275	**Room 2507**	2042	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0276	**Room 2507**	2042	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0277	**Room 2507 Prep Room**	2042A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0278	**Room 2506**	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0279	**Room 2506**	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0280	**Room 2506**	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0281	**Room 2506**	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0282	**Room 2506**	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0283	**Room 2506**	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0287	**Corridor Near Men's Bathroom (2045)**	2054	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0288	**Custodial Closet**	2046	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0289	**Womens Bathroom (Across Room 2505)**	2047	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0290	**Womens Bathroom (Across Room 2505)**	2047	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0291	**Womens Bathroom (Across Room 2505)**	2047	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0292	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0293	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0294	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0295	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0296	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0297	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0298	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0299	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0300	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0301	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0302	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0303	**Room 2503**	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0304	**Room 2504**	2050	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0305	**Room 2502**	2052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0306	**Room 2501**	2051	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0307	**Room 2501**	2051	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0308	**Room 2501**	2051	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0309	**Science Prep Room 2500 Growing Room**	2053A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0310	**Science Prep Room 2500**	2053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0311	**Corridor Near Science Prep Room 2500 (2053)**	2054	Water Fountain-No Chiller	RFI	**6/7/2025**	**OOS**			Replaced by Outlets 4272/4273
BRTWD-0312	**Room 2505**	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0313	**Room 2505**	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0314	**Room 2505**	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0315	**Room 2505**	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0316	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0317	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0318	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0319	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0320	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0321	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0322	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0323	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0324	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0325	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0326	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0327	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0328	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0329	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0330	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0331	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0332	**Room 2825**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0371	**Boys Locker Room Bathroom**	1080A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0373	**Wood Shop**	1078	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0374	**Wood Shop**	1078	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0375	**Wood Shop**	1078	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0376	**Girls Locker Room Bathroom**	1079A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0377	**Girls Locker Room Bathroom**	1079A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0378	**Auxilary Gym Vestibule**	1081A	Water Cooler	Applicable	**6/7/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-0379	**Room 1612**	1076	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0382	**Room 1608 Art Room**	1074	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0383	**Room 1608 Art Room**	1074	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0384	**Room 1608 Art Room**	1074	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0385	**Room 1608 Art Room**	1074	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0386	**Room 1608 Art Room**	1074	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0387	**Room 1608 Art Room**	1074	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0388	**Room 1606 Art Room**	1071	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0389	**Room 1606 Art Room**	1071	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0390	**Room 1606 Art Room**	1071	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0391	**Room 1606 Art Room**	1071	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0392	**Room 1606 Art Room**	1071	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0393	**Room 1606 Art Room**	1071	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0394	**Room 1607/1605 Art Room**	1072	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0395	**Room 1607/1605 Art Room**	1072	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0396	**Room 1607/1605 Art Room**	1072	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0397	**Room 1607/1605 Art Room**	1072	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0398	**Room 1607/1605 Art Room**	1072	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0399	**Room 1607/1605 Art Room**	1072	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0400	**Room 1607/1605 Dark Room**	1072B1	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0401	**Room 1607/1605 Dark Room**	1072B1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0408	**Library Annex Break Room**	1089B6	Office Faucet	Applicable	**6/7/2025**	**OOS**	6/26/2026	2.6	Result Below Action Level, Continue O&M
BRTWD-0698	**Exterior of Main Entrance (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0699	**Exterior of Lobby by Cafeteria (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0700	**Exterior of Kitchen (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0701	**Exterior of Stairwell Adj. to Room 1433 (1000)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0702	**Exterior of Bathrooms (1010/1013)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0703	**Exterior of Boys Locker Room (1020)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0704	**Exterior of Girls Locker Room Shower (1021E2A)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3166	**Cafeteria A**	1030A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3167	**Cafeteria A**	1030A	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3168	**Cafeteria B**	1030B	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3169	**Cafeteria B**	1030B	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3692	**Corridor Boiler Room to Girls Locker Room**	1027	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3693	**Corridor Boiler Room to Girls Locker Room**	1027	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3694	**Girls Locker Room Bathroom**	1021E2B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3695	**Girls Locker Room Bathroom**	1021E2B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3696	**Girls Locker Room Bathroom**	1021E2B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3697	**Girls Locker Room Bathroom**	1021E2B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3698	**Boys Locker Room Bathroom**	1020C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3699	**Boys Locker Room Bathroom**	1020C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3700	**Boys Locker Room Bathroom**	1020C	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3701	**Faculty Men's Bathroom**	1035	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3702	**Faculty Men's Bathroom**	1035	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3703	**Faculty Women's Bathroom**	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3704	**Faculty Women's Bathroom**	1036	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3705	**Faculty Lounge Women's Bathroom**	1053B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3706	**Faculty Lounge Women's Bathroom**	1053B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3707	**Faculty Lounge Women's Bathroom**	1053B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3708	**Faculty Lounge Men's Bathroom**	1053A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3709	**Faculty Lounge Men's Bathroom**	1053A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3710	**Room 1410**	1054	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3711	**Room 1410**	1054	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3712	**Room 1406**	1058	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3713	**Room 1406**	1058	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3714	**Boys Bathroom**	1060	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3715	**Boys Bathroom**	1060	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3716	**Boys Bathroom**	1060	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3717	**Girls Bathroom**	1062	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3718	**Room 2805 Room 2805**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3719	**Room 2805**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3720	**Room 2805**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3721	**Room 2809**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3722	**Room 2809**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3723	**Room 2819**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3724	**Room 2819**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3725	**Room 2823**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3726	**Room 2823**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3727	**Room 2826**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3728	**Room 2826**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3729	**Room 2825**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3730	**Room 2825**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3731	**Room 2825 Prep Room**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3732	**Room 2825 Prep Room Back Storage**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3733	**Men's Bathroom**	2010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3734	**Men's Bathroom**	2010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3735	**Men's Bathroom**	2010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3736	**Women's Bathroom**	2013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3737	**Women's Bathroom**	2026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3738	**Women's Bathroom**	2026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3739	**Women's Bathroom**	2026	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3740	**Men's Bathroom**	2027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3741	**Men's Bathroom**	2027	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3742	**Room 2510**	2039	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3743	**Room 2510**	2039	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3744	**Room 2510**	2039	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3745	**Room 2510**	2039	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3746	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3747	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3748	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3749	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3750	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3751	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3752	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3753	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3754	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3755	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3756	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3757	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3758	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3759	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3760	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3761	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3762	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3763	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3764	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3765	**Room 2508**	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3766	**Room 2508**	2040	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3767	**Room 2508**	2040	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3768	**Room 2508 Chemistry Prep Room**	2040A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3769	**Room 2507**	2042	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3770	**Room 2507**	2042	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3771	**Boys Bathroom**	2045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3772	**Boys Bathroom**	2045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3773	**Boys Bathroom**	2045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3774	**Room 2503**	2049	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3775	**Room 2501**	2051	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3776	**Custodial Closet**	1094A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3777	**1607/1605 Dark Room**	1072B1	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3778	**Art/Cosmetics Room**	1073	Hair Wash Station	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3779	**Art/Cosmetics Room**	1073	Hair Wash Station	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3780	**Art/Cosmetics Room**	1073	Hair Wash Station	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3781	**Ladies Restroom**	1085	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3782	**Ladies Restroom**	1085	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3783	**Ladies Restroom**	1085	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3784	**Men's Restroom**	1087	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3785	**Men's Restroom**	1087	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3786	**Kitchen**	1031	Pasta Pot/Steam Kettle	Applicable	**6/7/2025**	**2.8**			Result Below Action Level, Continue O&M
BRTWD-3787	**Kitchen Storage Room**	1031D	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3788	**Kitchen Storage Room**	1031D	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3789	**Kitchen Storage Room**	1031D	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3790	**Nurses Office**	1022A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3791	**Men's Bathroom near Room 125**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3792	**Men's Bathroom near Room 125**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3793	**Men's Bathroom near Room 125**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3794	**Men's Bathroom near Room 125**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3795	**Men's Bathroom near Room 125**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3796	**Women's Bathroom near Room 125**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3797	**Women's Bathroom near Room 125**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3798	**Women's Bathroom near Room 125**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3799	**Women's Bathroom near Room 125**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3800	**Women's Bathroom near Room 125**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3801	**Men's Bathroom near Room 144**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3802	**Women's Bathroom near Room 144**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3803	**Boy's Bathroom across Room 1824**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3804	**Girl's Bathroom across Room 1824**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3805	**New Kitchen**	N/A	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3806	**New Kitchen**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3807	**New Cafeteria Girls Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3808	**New Cafeteria Boys Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3809	**New Cafeteria Boys Bathroom Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3810	**Wood Shop Storage**	1078A	Bottled Water Dispenser (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3811	**Wood Shop Storage**	1078A	Bottled Water Dispenser (Hot)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3812	**Exterior o/s Cafeteria**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3813	**Exterior o/s Girls Locker Room**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3814	**Exterior o/s Boys Locker Room**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3815	**Exterior o/s Bathrooms (1010/1013)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3816	**Exterior o/s Corridor (1000)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3817	**Exterior o/s New Cafeteria Lobby**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3818	**Exterior o/s Main Entrance**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3819	**Exterior o/s Library Annex Break Room (1089B6)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3820	**Exterior o/s Room 1404 (1063)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3828	**Exterior o/s Bathrooms (1060/1062)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3945	**Room 1401 Storage**	1065A	Bottled Water Dispenser (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Sonderling High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3946	**Room 1401 Storage**	1065A	Bottled Water Dispenser (Hot)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3953	**Corridor Outside Team Locker Room**	1017	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3954	**Corridor Outside Team Locker Room**	1017	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-4272	**Corridor Room 2500 To Room 2537**	2054	Bottle Fill Station	Applicable	**1/9/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4273	**Corridor Room 2500 To Room 2537**	2054	Water Cooler	Applicable	**1/9/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4276	**Corridor Room 2500 To Room 2537**	2054	Bottle Fill Station	Applicable	**1/23/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4277	**Corridor Room 2500 To Room 2537**	2054	Water Cooler	Applicable	**1/23/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4312	**Mens Bathroom (Near Room 125)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4313	**Mens Bathroom (Near Room 125)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4314	**Mens Bathroom (Near Room 125)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4315	**Mens Bathroom (Near Room 125)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4316	**Mens Bathroom (Near Room 125)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4317	**Womens Bathroom (Near Room 125)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4318	**Womens Bathroom (Near Room 125)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4319	**Womens Bathroom (Near Room 125)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4320	**Womens Bathroom (Near Room 125)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4321	**Womens Bathroom (Near Room 125)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4322	**Boy Bathroom (Across Room 1824)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Southeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0333	**Room 8**	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0334	**Kitchen**	1029	Pasta Pot/Steam Kettle	Applicable	**6/5/2025**	**3.3**			Result Below Action Level, Continue O&M
BRTWD-0335	**Boys Bathroom**	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0336	**Boys Bathroom**	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0337	**Boys Bathroom**	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0338	**Custodial Closet**	1038	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0339	**Girls Bathroom**	1039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0340	**Girls Bathroom**	1039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0341	**Girls Bathroom**	1039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0342	**Room 23**	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0343	**Room 26**	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0344	**Coach's Office**	1025A1	Bottled Water Dispenser (Hot)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0345	**Exterior o/s Room 102 (1002)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0346	**Exterior o/s Room 6 (1011)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0347	**Exterior o/s Room 2 (1015)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0348	**Exterior o/s Bathrooms (1036/1039)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0349	**Exterior o/s Room 15 (1043)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0350	**Exterior o/s Room 23 (1053)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0351	**Exterior o/s Room 26 (1055)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0352	**Exterior o/s Custodial Office (1030)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Southeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2664	**Room 101**	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2665	**Room 101**	1001	Water Fountain-No Chiller	Applicable	**6/5/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2666	**Room 101 Bathroom**	1001B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2667	**Room 102**	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2668	**Room 102**	1002	Water Fountain-No Chiller	Applicable	**6/5/2025**	**5.1**	1/9/2026	4.1	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2669	**Room 102 Bathroom**	1002B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2670	**Room 11**	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2671	**Room 11**	1004	Water Fountain-No Chiller	Applicable	**6/5/2025**	**3.3**			Result Below Action Level, Continue O&M
BRTWD-2672	**Room 12**	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2673	**Room 12**	1005	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.2**	5/1/2026	1.5	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2674	**Room 9**	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2675	**Room 9**	1006	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2676	**Room 10**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2677	**Room 10**	1007	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-2678	**Room 7**	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2679	**Room 7**	1008	Water Fountain-No Chiller	Applicable	**6/5/2025**	**2.0**			Result Below Action Level, Continue O&M
BRTWD-2681	**Room 8**	1009	Water Fountain-No Chiller	Applicable	**6/5/2025**	**3.9**			Result Below Action Level, Continue O&M
BRTWD-2682	**Room 5**	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2683	**Room 5**	1010	Water Fountain-No Chiller	Applicable	**6/5/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2684	**Room 6**	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Southeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2685	**Room 6**	1011	Water Fountain-No Chiller	Applicable	**6/5/2025**	**2.1**			Result Below Action Level, Continue O&M
BRTWD-2686	**Room 3**	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2687	**Room 3**	1012	Water Fountain-No Chiller	Applicable	**6/5/2025**	**14.9**	1/9/2026	4.3	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2688	**Room 4**	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2689	**Room 4**	1013	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-2690	**Room 1**	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2691	**Room 1**	1014	Water Fountain-No Chiller	Applicable	**6/5/2025**	**6.4**	1/9/2026	1.5	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2692	**Mens Bathroom (Near Gym)**	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2693	**Custodial Closet**	1019	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2694	**Womens Bathroom (Near Gym)**	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2695	**Nurse's Office**	1000	Nurse's Office Sink	Applicable	**6/5/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-2696	**Nurse's Office Bathroom**	1000B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2698	**Coach's Office**	1025A1	Bottled Water Dispenser	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2700	**Kitchen**	1029	Hand Wash Only	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2702	**Kitchen**	1029	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2703	**Kitchen**	1029	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2704	**Kitchen**	1029	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2705	**Kitchen**	1029	Hand Wash Only	Applicable	**6/5/2025**	**32.5**	12/30/2025	32.9	Placarded for Non-Drinking Use Until Remediated
BRTWD-2706	**Kitchen Can Wash Room**	1029B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2707	**Custodial Office Bathroom**	1030A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Southeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2708	**Faculty Room**	1035	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2712	**Custodial Closet**	1038	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2716	**Room 16**	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2717	**Room 16**	1040	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2718	**Room 13**	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2719	**Room 13**	1041	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.7**			Result Below Action Level, Continue O&M
BRTWD-2720	**Room 18**	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2721	**Room 18**	1042	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2722	**Room 15**	1043	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2723	**Room 15**	1043	Water Fountain-No Chiller	Applicable	**6/5/2025**	**7.8**	5/7/2026	4.4	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2724	**Room 20**	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2725	**Room 20**	1044	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2726	**Room 17**	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2727	**Room 17**	1045	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-2728	**Room 22**	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2729	**Room 22**	1046	Water Fountain-No Chiller	Applicable	**6/5/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2730	**Room 19**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2731	**Room 19**	1047	Water Fountain-No Chiller	Applicable	**6/5/2025**	**16.7**	1/9/2026	16.5	Removed From Service, Pending Remediation
BRTWD-2732	**Room 24**	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2733	**Room 24**	1048	Water Fountain-No Chiller	Applicable	**6/5/2025**	**2.2**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Southeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2734	**Room 25**	1054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2736	**Room 26**	1055	Water Fountain-No Chiller	Applicable	**6/5/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2737	**Room 27 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2738	**Room 28 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2739	**Room 29 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2740	**Room 30 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2741	**Exterior of Main Office (1024)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2742	**Exterior of Room 3 (1012)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2743	**Exterior of Room 101 (1001)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2744	**Exterior of Room 101 (1001)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2751	**Exterior of Room 18 (1042)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2988	**Kitchen**	1029	Hand Wash Only	Applicable	**6/5/2025**	**3.0**			Result Below Action Level, Continue O&M
BRTWD-3067	**Corridor Near Cafeteria (1028)**	1032	Water Cooler	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3068	**Corridor Near Cafeteria (1028)**	1032	Bottle Fill Station	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3069	**Corridor Near Gymnasium (1025)**	1032	Water Cooler	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3070	**Corridor Near Gymnasium (1025)**	1032	Bottle Fill Station	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-4288	**Gym Corridor**	1032	Bottle Fill Station	Applicable	**3/4/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4289	**Gym Corridor**	1032	Water Cooler	Applicable	**3/4/2026**	**<1.0**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0356	**Room 1170**	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0357	**Corridor Near Shop Storage Room (1004)**	1025	Water Fountain-No Chiller	RFI	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0360	**Girls Bathroom**	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0361	**Girls Bathroom**	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0362	**Girls Bathroom**	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0363	**Girls Bathroom**	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0364	**Custodial Closet**	1010	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0365	**Men's Bathroom**	1011	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0366	**Men's Bathroom**	1011	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0367	**Men's Bathroom**	1011	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0368	**Men's Bathroom**	1011	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0369	**Room 1160**	1017	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0370	**Corridor Near Room 1157 (1018)**	1025	Water Fountain-No Chiller	Applicable	**6/7/2025**	**OOS**	5/1/2026	1.7	Result Below Action Level, Continue O&M
BRTWD-0403	**Music Hallway**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0404	**Music Hallway**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0407	**Chorus Office**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0414	**Corridor Near Room 1103 (1060)**	1064	Water Fountain-No Chiller	Applicable	**6/7/2025**	**7.4**			Removed From Service, Pending Remediation
BRTWD-0415	**Corridor Near Room 1110 (1057)**	1064	Water Fountain-No Chiller	Applicable	**6/7/2025**	**6.6**			Removed From Service, Pending Remediation
BRTWD-0416	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0417	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0418	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0419	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0420	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0421	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0422	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0423	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0424	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0425	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0426	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0427	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0428	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0429	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0430	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0431	**Room 1116**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0432	**1116/1117 Prep Room**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0433	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0434	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0435	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0436	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0437	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0438	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0439	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0440	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0441	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0442	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0443	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0444	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0445	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0446	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0447	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0448	**Room 1117**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0449	**Corridor Near Room 1117**	N/A	Water Cooler	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlets 4293, 4294
BRTWD-0450	**Corridor Near Room 1117**	N/A	Water Cooler	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlets 4293, 4294
BRTWD-0451	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0452	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0453	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0454	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0455	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0456	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0457	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0458	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0459	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0460	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0461	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0462	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0463	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0464	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0465	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0466	**Room 1118**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0467	**1118/1119 Prep Room**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0468	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0469	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0470	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0471	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0472	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0473	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0474	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0475	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0476	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0477	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0478	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0479	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0480	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0481	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0482	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0483	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0484	**Room 1119**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0485	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0486	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0487	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0488	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0489	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0490	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0491	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0492	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0493	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0494	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0495	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0496	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0497	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0498	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0499	**Room 1120**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0500	**1120/1121 Prep Room**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0501	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0502	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0503	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0504	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0505	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0506	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0507	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0508	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0509	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0510	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0511	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0512	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0513	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0514	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0515	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0516	**Room 1121**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0517	**Custodial Closet**	1088	Ice Machine	Applicable	**6/7/2025**	**1.7**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0518	**Custodial Closet**	1088	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0519	**Team Locker Room Bathroom**	1087A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0524	**Girls Locker Room Custodial Closet**	1081A4	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0530	**Storage Room**	1080	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0531	**Custodial Office Bathroom**	1076A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0540	**Health Office Suite Nurse's Office**	1066B	Nurse's Office Sink	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0541	**Health Office Suite Nurse's Office Bathroom**	1066B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0542	**Corridor Near Room 1125 (1033)**	1037	Water Fountain-No Chiller	Applicable	**6/7/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-0547	**Faculty Bathroom Near Faculty Room**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0548	**Faculty Bathroom Near Faculty Room**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0549	**Faculty Bathroom Near Faculty Room**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0550	**Corridor Near Room 1142 (1029)**	1031	Water Fountain-No Chiller	Applicable	**6/7/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-0551	**Science Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0552	**Science Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0553	**Science Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0554	**Science Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0555	**Science Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0556	**Science Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0557	**Science Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0558	**Science Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0559	**Science Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0562	**Boys Bathroom Near Room 1708**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0563	**Boys Bathroom Near Room 1708**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0564	**Boys Bathroom Near Room 1708**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0565	**Boys Bathroom Near Room 1708**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0566	**Gender-Neutral Bathroom Adjacent to Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0567	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0568	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0569	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0570	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0571	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0572	**Girls Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0573	**Boys Bathroom Near Room 1708**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0574	**Corridor Near Girls Bathroom**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0575	**Corridor Near Girls Bathroom**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0576	**Boys Bathroom**	1042	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0577	**Boys Bathroom**	1042	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0578	**Boys Bathroom**	1042	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0579	**Boys Bathroom**	1042	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0580	**Custodial Closet**	1043	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0582	**Corridor Near Faculty Lounge**	1049	Water Fountain-No Chiller	RFI	**6/7/2025**	**OOS**			Replaced by Outlet 4328
BRTWD-0583	**Girls Bathroom**	1045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0584	**Girls Bathroom**	1045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0585	**Girls Bathroom**	1045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0586	**Girls Bathroom**	1045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0587	**Kitchen**	1074	Hand Wash Only	Applicable	**6/7/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-0588	**Kitchen**	1074	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0589	**Kitchen**	1074	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0590	**Kitchen**	1074	Pasta Pot/Steam Kettle	Applicable	**6/7/2025**	**16.1**	3/3/2026	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-0591	**Kitchen**	1074	Hand Wash Only	Applicable	**6/7/2025**	**3.1**			Result Below Action Level, Continue O&M
BRTWD-0592	**Kitchen**	1074	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**2.7**			Result Below Action Level, Continue O&M
BRTWD-0593	**Kitchen**	N/A	Hand Wash Only	Applicable	**6/7/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-0594	**Kitchen**	N/A	Hand Wash Only	Applicable	**6/12/2025**	**32.6**	2/18/2026	13.6	Placarded for Non-Drinking Use Until Remediated
BRTWD-0595	**Kitchen Women's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0596	**Kitchen Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0597	**Kitchen Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0598	**Kitchen**	1074	Hand Wash Only	Applicable	**6/7/2025**	**2.7**			Result Below Action Level, Continue O&M
BRTWD-0599	**Kitchen**	1074	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**2.0**			Result Below Action Level, Continue O&M
BRTWD-0600	**Kitchen**	1074	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0601	**Kitchen**	1074	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0602	**Kitchen**	1074	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**20.7**	12/23/2025	3.7	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-0603	**Boiler Room**	0002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0604	**Pool Girls Locker Room Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0606	**Pool Pump Room**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0607	**Pool Boys Locker Room Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0615	**Custodial Closet**	2007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0636	**Lab Prep Office**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0637	**Lab Prep Room Closet**	2011A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0638	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0639	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0640	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0641	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0642	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0643	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0644	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0645	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0646	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0647	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0648	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0649	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0650	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0651	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0652	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0653	**Room 2208**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0654	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0655	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0656	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0657	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0658	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0659	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0660	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0661	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0662	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0663	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0664	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0665	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0666	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0667	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0668	**Room 2213**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0669	**Room 2210 Growing Room**	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0670	**Room 2210 Growing Room**	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0671	**Room 2210 Growing Room**	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0675	**Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0676	**Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0677	**Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0678	**Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0679	**Faculty Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0680	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0681	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0682	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0683	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0684	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0687	**Room 2301**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0688	**Room 2301**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0689	**Exterior of Room 1111 (1052)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0690	**Exterior of Room 1101 & 1103 (1062/1060)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0691	**Exterior of Room 810A (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0692	**Exterior of Girls Locker Room Shower (1081A2)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0693	**Exterior of Pool (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0694	**Exterior of Boys Locker Room (1084)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0695	**Exterior of Room 1108 (1057)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0696	**Exterior of Room 1102 (1063)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0697	**Exterior of Library (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0705	**Exterior of Kitchen (1031)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0706	**Exterior of Bathrooms (1060/1062)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0707	**Exterior of Room 1159 (1016)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0708	**Exterior of Room 1170 (1002)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0709	**Exterior of Room 1168 (1001)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0710	**Exterior of Room 1140 (1030)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0711	**Exterior of Kitchen (1074)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2989	**Industrial Arts Room**	1001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3100	**Corridor to Locker Room**	1086	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3101	**Corridor to Locker Room**	1086	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3102	**Corridor Outside Library Near Stairwell**	N/A	Water Cooler	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlet 4250/4251
BRTWD-3103	**Corridor Outside Library Near Stairwell**	N/A	Bottle Fill Station	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlet 4250/4251
BRTWD-3104	**Vestibule Near Storage Room**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3105	**Vestibule Near Storage Room**	N/A	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3164	**Cafeteria**	1075	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3165	**Cafeteria**	1075	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3614	**Industrial Arts Room - Auto Shop**	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3615	**Industrial Arts Room - Auto Shop**	1001	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3616	**Room 1170 Storage**	1002A	Bottled Water Dispenser (Cold)	Applicable	**6/13/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3617	**Room 1170 Storage**	1002A	Bottled Water Dispenser (Hot)	Applicable	**6/13/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3618	**Room 1165**	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3619	**Room 1116**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3620	**Room 1116**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3621	**Room 1117**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3622	**Room 1117**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3623	**Room 1118**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3624	**Room 1118**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3625	**Room 1119**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3626	**Room 1119**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3627	**Room 1120**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3628	**Room 1120**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3629	**Room 1121**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3630	**Room 1121**	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3631	**2nd Floor Girl's Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3632	**2nd Floor Boy's Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3633	**Room 2204**	2003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3634	**Room 2204**	2003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3635	**Room 2204**	2003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3636	**Room 2204**	2003	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3637	**Girls Bathroom**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3638	**Girls Bathroom**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3639	**Girls Bathroom**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3640	**Girls Bathroom**	2005	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3641	**Boys Bathroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3642	**Boys Bathroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3643	**Boys Bathroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3644	**Boys Bathroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3645	**Boys Bathroom**	2008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3646	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3647	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3648	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3649	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3650	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3651	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3652	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3653	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3654	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3655	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3656	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3657	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3658	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3659	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3660	**Room 2206**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3661	**Room 2206**	2010	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3662	**Room 2206**	2010	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3663	**Room 2208**	2012	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3664	**Room 2210**	2014	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3665	**Room 2215**	2016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3666	**Room 2215**	2016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3667	**Room 2215**	2016	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3668	**Girls Locker Room Bathroom**	1081A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3669	**Girls Locker Room Bathroom**	1081A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3670	**Girls Locker Room Bathroom**	1081A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3671	**Girls Locker Room**	1081A	Water Cooler	Applicable	**6/7/2025**	**2.6**			Result Below Action Level, Continue O&M
BRTWD-3672	**Girls Locker Room**	1081A	Bottle Fill Station	Applicable	**6/7/2025**	**3.2**			Result Below Action Level, Continue O&M
BRTWD-3673	**Boys Locker Room**	1084	Water Cooler	Applicable	**6/7/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-3674	**Boys Locker Room**	1084	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3675	**Women's Bathroom**	1070	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3676	**Women's Bathroom**	1070	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3677	**Women's Bathroom**	1070	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3678	**Women's Bathroom**	1070	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3679	**Men's Bathroom**	1071	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3680	**Men's Bathroom**	1071	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3681	**Nurses Office**	1066B	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3682	**Room 1127**	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3683	**Room 1127**	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3684	**Room 1127**	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3685	**Room 1127**	1032	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3686	**Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3687	**Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3688	**Room 1133**	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3689	**Room 1133**	1028	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3690	**Room 1133**	1028	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3691	**Room 1128 Faculty Lounge**	1044	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3821	**Exterior o/s Room 1108 (1057)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3822	**Exterior o/s Boys Locker Room (1084)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3823	**Exterior o/s Room 1101 (1062)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3824	**Exterior (confirm location)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3825	**Exterior o/s Room 1170 (1002)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3826	**Exterior o/s Men's Bathroom (1011)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3827	**Exterior o/s Room 1159 (1016)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3947	**Corridor 1171 to Boys Coach Office**	1099	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3948	**Corridor 1171 to Boys Coach Office**	1099	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3949	**Pool**	1101	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3950	**Pool**	1101	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3955	**Corridor Room 2202 to Room 2215**	2017	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**	9/28/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-3956	**Corridor Room 2202 to Room 2215**	2017	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**	9/28/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-3963	**Corridor Room 2202 to Room 2215**	2017	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3964	**Industrial Arts Room Storage**	1001A	Bottled Water Dispenser (Hot)	Applicable	**6/12/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3968	**Industrial Arts Room Storage**	1001A	Bottled Water Dispenser	Applicable	**6/12/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3969	**Industrial Arts Room Storage**	1001A	Bottled Water Dispenser	Applicable	**6/13/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3970	**Room 1170 Storage**	1002A	Bottled Water Dispenser	Applicable	**6/13/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-4237	**Corridor 1171 to Boys Coach Office**	1099	Bottle Fill Station	Applicable	**10/2/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4238	**Corridor 1171 to Boys Coach Office**	1099	Water Cooler	Applicable	**10/2/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4250	**Corridor Outside Library Near Stairwell**	N/A	Bottle Fill Station	Applicable	**10/23/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4251	**Corridor Outside Library Near Stairwell**	N/A	Water Cooler	Applicable	**10/23/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4267	**Corridor Near Room 2215**	2017	Water Cooler	Applicable	**1/6/2026**	**<1.0**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Brentwood Ross High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4290	**Corridor Room 1152 to Industrial Arts Room**	1025	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Previously Outlet 357, Result Below Action Level, Continue O&M
BRTWD-4293	**Corridor Near Room 1117**	N/A	Bottle Fill Station	Applicable	**5/1/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4294	**Corridor Near Room 1117**	N/A	Water Cooler	Applicable	**5/1/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4328	**Corridor Assistant Principal Office to Room 1115**	1049	Bottle Fill Station	Applicable	**9/4/2026**	**<1.0**			Result Below Action Level, Continue O&M

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0712	**Custodial Closet**	1004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0713	**Kindergarten Room 2A**	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0714	**Kindergarten Room 2A**	1005	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-0715	**Kindergarten Room 2A Bathroom**	1005A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0716	**Kindergarten Room 1A**	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0717	**Kindergarten Room 1A**	1006	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0718	**Kindergarten Room 1A Bathroom**	1006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0719	**Room 3A**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0720	**Room 3A**	1007	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-0721	**Room 4A**	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0722	**Room 4A**	1008	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0723	**Room 5A**	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0724	**Room 5A**	1009	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.9**			Result Below Action Level, Continue O&M
BRTWD-0725	**Room 6A**	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0726	**Room 6A**	1010	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-0727	**Room 7A**	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0728	**Room 7A**	1011	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-0729	**Room 8A**	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0730	**Room 8A**	1012	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-0731	**Room 9A**	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0732	**Room 9A**	1013	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0733	**Room 10A**	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0734	**Room 10A**	1014	Water Fountain-No Chiller	Applicable	**6/5/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-0735	**Room 11A**	1016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0736	**Room 11A**	1016	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0737	**Men's Bathroom across Main Office**	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0738	**Women's Bathroom across Main Office**	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0740	**Cafeteria Nurse's Office**	1022B	Nurse's Office Sink	Applicable	**6/5/2025**	**2.7**			Result Below Action Level, Continue O&M
BRTWD-0741	**Cafeteria Nurse's Office Bathroom**	1022B2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0742	**Gym Activities Room Bathroom**	1022A2B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0743	**Kitchen**	1022D	Hand Wash Only	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0744	**Kitchen**	1022D	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0745	**Kitchen**	1022D	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0746	**Kitchen Can Wash Room**	1022D2	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0747	**Exterior of Room 2 (1025)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0749	**Math Lab (Room 2)**	1025	Water Fountain-No Chiller	RFI	**6/5/2025**	**<1.00 ND**			Replaced by Outlet 4154
BRTWD-0750	**Library**	1026	Office Faucet	RFI	**6/5/2025**	**1.1**			Replaced by Outlet 4155/4156
BRTWD-0752	**Room 4**	1027	Water Fountain-No Chiller	RFI	**6/5/2025**	**2.5**			Replaced by Outlet 4158
BRTWD-0753	**Speech Room 6 Work Room 2**	1029B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0754	**Speech Room 6 Work Room 2**	1029B	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.2**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0759	**Room 31**	1041	Water Fountain-No Chiller	RFI	**6/5/2025**	**<1.00 ND**			Replaced by Outlet 4128
BRTWD-0761	**Room 33**	1042	Water Fountain-No Chiller	RFI	**6/5/2025**	**<1.00 ND**			Replaced by Outlet 4132
BRTWD-0763	**Room 35**	1043	Water Fountain-No Chiller	RFI	**6/5/2025**	**<1.00 ND**			Replaced by Outlet 4136
BRTWD-0765	**Room 34**	1045	Water Fountain-No Chiller	RFI	**6/5/2025**	**45.0**			Replaced by Outlet 4138
BRTWD-0767	**Room 32**	1046	Water Fountain-No Chiller	RFI	**6/5/2025**	**<1.00 ND**			Replaced by Outlet 4134
BRTWD-0769	**Room 30**	1047	Water Fountain-No Chiller	RFI	**6/5/2025**	**2.2**			Replaced by Outlet 4130
BRTWD-0770	**Women's Bathroom**	1048	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0771	**Custodial Closet 51H**	1050	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0772	**Men's Bathroom**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0773	**Cafeteria**	1058	Water Cooler	RFI	**6/5/2025**	**OOS**			Replaced by Outlets 4239/4240
BRTWD-0774	**Custodial Closet**	1059	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0777	**Faculty Room**	1063	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-0778	**Faculty Room**	1063	Bottled Water Dispenser	Applicable	**6/5/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-0779	**Nurse's Office**	1065	Nurse's Office Sink	Applicable	**6/5/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-0780	**Nurse's Office Bathroom**	1065A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0783	**Custodial Closet 13D**	1069	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0785	**Girls Bathroom**	1070	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0787	**Room 15**	1071	Water Fountain-No Chiller	RFI	**6/5/2025**	**3.0**			Replaced by Outlet 4166
BRTWD-0789	**Room 16**	1072	Water Fountain-No Chiller	RFI	**6/5/2025**	**1.9**			Replaced by Outlet 4168
BRTWD-0791	**Room 17**	1073	Water Fountain-No Chiller	RFI	**6/5/2025**	**<1.00 ND**			Replaced by Outlet 4170

OOS= Out of Service **RFI = Removed from Inventory**

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0793	**Room 18**	1074	Water Fountain-No Chiller	RFI	**6/5/2025**	**71.2**			Replaced by Outlet 4172
BRTWD-0795	**Room 19**	1075	Water Fountain-No Chiller	RFI	**6/5/2025**	**<1.00 ND**			Replaced by Outlet 4249
BRTWD-0797	**Room 20**	1076	Water Fountain-No Chiller	RFI	**6/5/2025**	**75.3**			Replaced by Outlet 4174
BRTWD-0798	**Room 20X Bathroom**	1077A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0799	**Room 20X Psychologist Office**	1077A3	Bottled Water Dispenser (Cold)	Applicable	**6/5/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-0801	**Room 21**	1079	Water Fountain-No Chiller	RFI	**6/5/2025**	**11.3**			Replaced by Outlet 4176
BRTWD-0803	**Room 22**	1080	Water Fountain-No Chiller	RFI	**6/5/2025**	**<1.00 ND**			Replaced by Outlet 4178
BRTWD-0805	**Room 23**	1081	Water Fountain-No Chiller	RFI	**6/5/2025**	**1.8**			Replaced by Outlet 4180
BRTWD-0807	**Room 24**	1082	Water Fountain-No Chiller	RFI	**6/5/2025**	**1.8**			Replaced by Outlet 4182
BRTWD-0809	**Room 25**	1083	Water Fountain-No Chiller	RFI	**6/5/2025**	**1.3**			Replaced by Outlet 4184
BRTWD-0811	**Room 26**	1084	Water Fountain-No Chiller	RFI	**6/5/2025**	**1.6**			Replaced by Outlet 4186
BRTWD-0814	**Custodial Closet**	3002	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0818	**Room 36**	3004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0819	**Room36**	3004	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0820	**Room38**	3006	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0821	**Room38**	3006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0822	**Room37**	3005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0823	**Room37**	3005	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0824	**Room39**	3007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0825	**Room 39**	3007	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0826	**Room 13A**	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0827	**Room 13A**	2003	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-0828	**Room 12A**	2004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0829	**Room 12A**	2004	Water Fountain-No Chiller	Applicable	**6/5/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-0830	**Room 15A**	2005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0831	**Room 15A**	2005	Water Fountain-No Chiller	Applicable	**6/5/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-0832	**Room 14A**	2006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0833	**Room 14A**	2006	Water Fountain-No Chiller	Applicable	**6/5/2025**	**2.7**			Result Below Action Level, Continue O&M
BRTWD-0834	**Room 17A**	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0835	**Room 17A**	2007	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0836	**Room 16A**	2008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0837	**Room 16A**	2008	Water Fountain-No Chiller	Applicable	**6/5/2025**	**4.5**			Result Below Action Level, Continue O&M
BRTWD-0838	**Room 19A**	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0839	**Room 19A**	2009	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0840	**Room 18A**	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0841	**Room 18A**	2010	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0842	**Room 21A**	2011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0843	**Room 21A**	2011	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0844	**Room 20A**	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0845	**Room 20A**	2012	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.5**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0846	**Room 22A**	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0847	**Room 22A**	2014	Water Fountain-No Chiller	Applicable	**6/5/2025**	**2.2**			Result Below Action Level, Continue O&M
BRTWD-0848	**ESL Room 23A Bathroom**	2015B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0849	**ESL Room 23A Bathroom**	2015C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0850	**Corridor Near Custodial Closet (2016)**	2018	Water Cooler	Applicable	**6/5/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-0852	**Room 46**	2021	Water Fountain-No Chiller	RFI	**6/5/2025**	**2.0**			Replaced by Outlet 4140
BRTWD-0854	**Room 45**	2022	Water Fountain-No Chiller	RFI	**6/5/2025**	**2.2**			Replaced by Outlet 4142
BRTWD-0856	**Room 44**	2023	Water Fountain-No Chiller	RFI	**6/5/2025**	**6.3**			Replaced by Outlet 4144
BRTWD-0858	**Room 43**	2024	Water Fountain-No Chiller	RFI	**6/5/2025**	**2.0**			Replaced by Outlet 4146
BRTWD-0860	**Room 42**	2025	Water Fountain-No Chiller	RFI	**6/5/2025**	**2.7**			Replaced by Outlet 4148
BRTWD-0862	**Room 41**	2026	Water Fountain-No Chiller	RFI	**6/5/2025**	**3.8**			Replaced by Outlet 4150
BRTWD-0863	**Boys Bathroom**	2027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0864	**Boys Bathroom**	2027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0865	**Boys Bathroom**	2027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0866	**Custodial Closet 56M**	2029	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0867	**Girls Bathroom**	2030	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0868	**Girls Bathroom**	2030	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0869	**Girls Bathroom**	2030	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0871	**Room 40**	2028	Water Fountain-No Chiller	RFI	**6/5/2025**	**1.6**			Replaced by Outlet 4152
BRTWD-0872	**Kitchen**	1058A	Hand Wash Only	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0873	**Kitchen**	1058A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0874	**Kitchen**	1058A	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0876	**Kitchen**	1058A	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0877	**Kitchen**	1058A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0878	**Kitchen**	1058A	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0879	**Kitchen**	1058A	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0880	**Kitchen**	1058A	Hand Wash Only	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0881	**Kitchen Can Wash Room**	1058E	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0884	**Kitchen Bathroom**	1058F	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0886	**Room 5**	1028	Water Fountain-No Chiller	RFI	**6/5/2025**	**6.3**			Replaced by Outlet 4160
BRTWD-0887	**Custodial Closet**	2016	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3075	**Corridor Near Custodial Closet (1059)**	1066	Water Cooler	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3076	**Corridor Near Custodial Closet (1059)**	1066	Bottle Fill Station	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3077	**Corridor Near Main Office (1020)**	1021	Water Cooler	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3078	**Corridor Near Main Office (1020)**	1021	Bottle Fill Station	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3172	**Corridor Near Room 32**	3008	Water Cooler	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3173	**Men's Bathroom**	1034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3174	**Men's Bathroom**	1034	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3175	**Women's Bathroom**	1060	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3176	**Women's Bathroom**	1060	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3582	**Cafeteria Nurse's Office**	1022B	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3583	**Speech Room 6 Work Room 2 (Interior Wall Removed)**	1029B	Bottled Water Dispenser (Cold)	Applicable	**6/5/2025**	**32.0**			Removed From Service, Pending Remediation
BRTWD-3584	**Speech Room 6 Work Room 2 (Interior Wall Removed)**	1029B	Bottled Water Dispenser (Hot)	Applicable	**6/5/2025**	**3.4**			Result Below Action Level, Continue O&M
BRTWD-3585	**Math Lab Room 7**	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3586	**Math Lab Room 7**	1030	Water Fountain-No Chiller	Applicable	**6/5/2025**	**4.7**			Result Below Action Level, Continue O&M
BRTWD-3587	**Math Lab Room 7**	1030	Home Economics Faucet (Cold)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3588	**Kitchen**	1058A	Pasta Pot/Steam Kettle	Applicable	**6/5/2025**	**1.7**			Result Below Action Level, Continue O&M
BRTWD-3589	**Kitchen Can Wash Room**	1058E	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3591	**Kitchen Can Wash Room**	1058E	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3592	**Nurses Office**	1065	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3593	**Boy's Bathroom near Boiler Room**	1067	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3594	**Boy's Bathroom near Boiler Room**	1067	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3595	**Girl's Bathroom near Boiler Room**	1070	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3596	**Room 20X Inner Classroom 2**	1077A3	Bottled Water Dispenser (Hot)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3597	**Girl's Bathroom**	3001	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3598	**Girl's Bathroom**	3001	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3599	**Exterior of Kitchen (1058A)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3600	**Exterior of Room 19 (1075)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3601	**Exterior of Room 25 (1083)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3602	**Exterior of New Construction Bathrooms**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3603	**Exterior of Room 26 (1084)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3604	**Exterior of Room 20 (1076)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3605		N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3606	**Exterior of Room 8A (1012)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3607	**Exterior of Room 9A (1013)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3608	**Exterior of Library**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3609	**Exterior of Room 7 (1030)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3610	**Exterior of Stairwell (1039)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3611	**Exterior of Stairwell (1039)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3612	**Exterior of Room 35 (1043)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3613	**Exterior of Room 32 (1046)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4127	**Room 31**	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4128	**Room 31**	1041	Water Fountain-No Chiller	Applicable	**8/28/2025**	**2.7**			Result Below Action Level, Continue O&M
BRTWD-4129	**Room 30**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4130	**Room 30**	1047	Water Fountain-No Chiller	Applicable	**8/28/2025**	**3.5**			Result Below Action Level, Continue O&M
BRTWD-4131	**Room 33**	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4132	**Room 33**	1042	Water Fountain-No Chiller	Applicable	**8/28/2025**	**3.3**			Result Below Action Level, Continue O&M
BRTWD-4133	**Room 32**	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4134	**Room 32**	1046	Water Fountain-No Chiller	Applicable	**8/28/2025**	**4.1**			Result Below Action Level, Continue O&M
BRTWD-4135	**Room 35**	1043	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4136	**Room 35**	1043	Water Fountain-No Chiller	Applicable	**8/28/2025**	**2.0**			Result Below Action Level, Continue O&M
BRTWD-4137	**Room 34**	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4138	**Room 34**	1045	Water Fountain-No Chiller	Applicable	**8/28/2025**	**3.0**			Result Below Action Level, Continue O&M
BRTWD-4139	**Room 46**	2021	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4140	**Room 46**	2021	Water Fountain-No Chiller	Applicable	**8/28/2025**	**2.5**			Result Below Action Level, Continue O&M
BRTWD-4141	**Room 45**	2022	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4142	**Room 45**	2022	Water Fountain-No Chiller	Applicable	**8/28/2025**	**4.8**			Result Below Action Level, Continue O&M
BRTWD-4143	**Room 44**	2023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4144	**Room 44**	2023	Water Fountain-No Chiller	Applicable	**8/28/2025**	**3.7**			Result Below Action Level, Continue O&M
BRTWD-4145	**Room 43**	2024	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4146	**Room 43**	2024	Water Fountain-No Chiller	Applicable	**8/28/2025**	**3.1**			Result Below Action Level, Continue O&M
BRTWD-4147	**Room 42**	2025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4148	**Room 42**	2025	Water Fountain-No Chiller	Applicable	**8/28/2025**	**3.5**			Result Below Action Level, Continue O&M
BRTWD-4149	**Room 41**	2026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4150	**Room 41**	2026	Water Fountain-No Chiller	Applicable	**8/28/2025**	**5.5**	9/18/2025	1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4151	**Room 40**	2028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4152	**Room 40**	2028	Water Fountain-No Chiller	Applicable	**8/28/2025**	**6.8**	9/18/2025	1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4153	**Math Lab (Room 2)**	1025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4154	**Math Lab (Room 2)**	1025	Water Fountain-No Chiller	Applicable	**8/28/2025**	**6.8**	10/2/2025	1.5	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4155	**Library (1)**	1026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4156	**Library (1)**	1026	Water Fountain-No Chiller	Applicable	**8/28/2025**	**9.3**	9/18/2025	3.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4157	**Room 4**	1027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4158	**Room 4**	1027	Water Fountain-No Chiller	Applicable	**8/28/2025**	**13.6**	9/18/2025	4.7	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4159	**Computer Room 5**	1028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4160	**Computer Room 5**	1028	Water Fountain-No Chiller	Applicable	**8/28/2025**	**25.4**	9/18/2025	2.6	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4161	**Speech Room 6**	1029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4162	**Speech Room 6**	1029	Water Fountain-No Chiller	Applicable	**8/28/2025**	**5.5**	9/18/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4163	**Room 8**	1031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4164	**Room 8**	1031	Water Fountain-No Chiller	Applicable	**8/28/2025**	**9.3**	9/18/2025	1.9	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4165	**Music Room 15**	1071	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4166	**Music Room 15**	1071	Water Fountain-No Chiller	Applicable	**8/28/2025**	**6.8**	9/18/2025	1.9	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4167	**Art Room 16**	1072	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4168	**Art Room 16**	1072	Water Fountain-No Chiller	Applicable	**8/28/2025**	**40.9**	9/18/2025	1.2	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4169	**Room 17**	1073	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4170	**Room 17**	1073	Water Fountain-No Chiller	Applicable	**8/28/2025**	**27.5**	9/18/2025	1.6	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4171	**Room 18**	1074	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4172	**Room 18**	1074	Water Fountain-No Chiller	Applicable	**8/28/2025**	**56.5**	10/2/2025	2.8	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4173	**Room 20**	1076	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4174	**Room 20**	1076	Water Fountain-No Chiller	Applicable	**8/28/2025**	**8.5**	9/18/2025	4.1	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4175	**Room 21**	1079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Southwest Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4176	**Room 21**	1079	Water Fountain-No Chiller	Applicable	**8/28/2025**	**4.5**			Result Below Action Level, Continue O&M
BRTWD-4177	**Room 22**	1080	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4178	**Room 22**	1080	Water Fountain-No Chiller	Applicable	**8/28/2025**	**4.4**			Result Below Action Level, Continue O&M
BRTWD-4179	**Room 23**	1081	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4180	**Room 23**	1081	Water Fountain-No Chiller	Applicable	**8/28/2025**	**4.3**			Result Below Action Level, Continue O&M
BRTWD-4181	**Room 24**	1082	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4182	**Room 24**	1082	Water Fountain-No Chiller	Applicable	**8/28/2025**	**4.5**			Result Below Action Level, Continue O&M
BRTWD-4183	**Room 25**	1083	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4184	**Room 25**	1083	Water Fountain-No Chiller	Applicable	**8/28/2025**	**5.3**	9/18/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4185	**Room 26**	1084	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4186	**Room 26**	1084	Water Fountain-No Chiller	Applicable	**8/28/2025**	**36.8**	10/2/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4239	**Cafeteria**	1058	Bottle Fill Station	Applicable	**10/2/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4240	**Cafeteria**	1058	Water Cooler	Applicable	**10/2/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4248	**Room 19**	1075	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4249	**Room 19**	1075	Water Fountain-No Chiller	Applicable	**9/18/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-4258	**New Construction Corridor Outside Bathrooms**	N/A	Bottle Fill Station	Applicable	**11/25/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4259	**New Construction Corridor Outside Bathrooms**	N/A	Water Cooler	Applicable	**11/25/2025**	**<1.0**			Result Below Action Level, Continue O&M

Twin Pines Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0903	**Room 1A**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0904	**Room 2A**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0905	**Room 2A**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0906	**Kindergarten Room 2**	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0907	**Kindergarten Room 2**	1001	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0908	**Room 1**	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0909	**Room 1**	1000	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-0910	**Custodial Closet**	1002	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0911	**Room 3**	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0912	**Room 3**	1003	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-0913	**Room 4**	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0914	**Room 4**	1004	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-0915	**Room 4 Bathroom**	1004C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0916	**Room 5**	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0917	**Room 5**	1005	Water Fountain-No Chiller	Applicable	**6/6/2025**	**4.2**			Result Below Action Level, Continue O&M
BRTWD-0918	**Kindergarten Room 6**	1007	Bottled Water Dispenser	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0919	**Kindergarten Room 6**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0920	**Kindergarten Room 6**	1007	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0921	**Kindergarten Room 6 Bathroom**	1007C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0922	**Room 7**	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Twin Pines Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0923	**Room 7**	1008	Water Fountain-No Chiller	Applicable	**6/6/2025**	**2.8**			Result Below Action Level, Continue O&M
BRTWD-0924	**Room 8**	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0925	**Room 8**	1009	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0926	**Room 9**	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0927	**Room 9**	1010	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-0928	**Room 10**	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0929	**Room 10**	1011	Water Fountain-No Chiller	Applicable	**6/6/2025**	**2.7**			Result Below Action Level, Continue O&M
BRTWD-0930	**Room 11**	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0931	**Room 11**	1012	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0932	**Room 12**	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0933	**Room 12**	1013	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-0934	**Room 13**	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0935	**Room 13**	1014	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0936	**Room 15A**	1016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0937	**Room 15A**	1016	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0938	**Computer Room 14**	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0939	**Computer Room 14**	1015	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0940	**Room 16**	1019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0941	**Room 16**	1019	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-0944	**Custodial Closet**	1028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Twin Pines Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0947	**Nurse's Office**	1036	Nurse's Office Sink	Applicable	**6/6/2025**	**2.9**			Result Below Action Level, Continue O&M
BRTWD-0949	**Nurse Office Bathroom**	1036A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0950	**Girls Locker Room Bathroom**	1032A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0952	**Boys Locker Room Bathroom**	1034A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0955	**Faculty Room**	1048	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**3.6**			Result Below Action Level, Continue O&M
BRTWD-0963	**Room 18**	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0964	**Room 18**	1052	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0965	**Room 17**	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0966	**Room 17**	1053	Water Fountain-No Chiller	Applicable	**6/6/2025**	**5.3**	2/19/2026	1.4	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-0967	**Room 20**	1054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0968	**Room 20**	1054	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0969	**Room 19**	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0970	**Room 19**	1055	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0971	**Room 22**	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0972	**Room 22**	1056	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0973	**Room 21**	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0974	**Room 21**	1057	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-0975	**Room 24**	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0976	**Room 24**	1058	Water Fountain-No Chiller	Applicable	**6/6/2025**	**2.7**			Result Below Action Level, Continue O&M
BRTWD-0977	**Room 23**	1059	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Twin Pines Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-0978	**Room 23**	1059	Water Fountain-No Chiller	Applicable	**6/6/2025**	**12.8**	8/19/2026	2.8	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-0979	**Room 26**	1060	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0980	**Room 26**	1060	Water Fountain-No Chiller	Applicable	**6/6/2025**	**2.5**			Result Below Action Level, Continue O&M
BRTWD-0981	**Room 25**	1061	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0982	**Room 25**	1061	Water Fountain-No Chiller	Applicable	**6/6/2025**	**OOS**	8/19/2026	1.6	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-0983	**Room 28**	1062	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0984	**Room 28**	1062	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0985	**Room 27**	1063	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0986	**Room 27**	1063	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-0987	**Room 30**	1064	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0988	**Room 30**	1064	Water Fountain-No Chiller	Applicable	**6/6/2025**	**3.8**			Result Below Action Level, Continue O&M
BRTWD-0989	**Room 30**	1064	Bottled Water Dispenser	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0990	**Room 29**	1065	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0991	**Room 29**	1065	Water Fountain-No Chiller	Applicable	**6/6/2025**	**2.6**			Result Below Action Level, Continue O&M
BRTWD-0995	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-0996	**Corridor Near Bathrooms**	N/A	Water Cooler	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-0997	**Unisex Bathroom (Near Room 31)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1000	**Room 31**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1001	**Room 31**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1002	**Room 32**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Twin Pines Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1003	**Room 32**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1004	**Room 33**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1005	**Room 33**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1006	**Room 34**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1007	**Room 34**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1008	**Room 35**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1009	**Room 35**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-1010	**Room 36**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1011	**Room 36**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1012	**Kitchen**	1043	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**4.4**			Result Below Action Level, Continue O&M
BRTWD-1013	**Kitchen**	1043	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**2.2**			Result Below Action Level, Continue O&M
BRTWD-1015	**Kitchen**	1043	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**7.9**	12/23/2025	3.1	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1016	**Kitchen**	1043	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1017	**Kitchen**	1043	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**5.1**	12/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1018	**Kitchen**	1043	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**41.5**	2/19/2026	4.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1019	**Kitchen**	1043	Hand Wash Only	Applicable	**6/6/2025**	**2.3**			Result Below Action Level, Continue O&M
BRTWD-1020	**Kitchen**	1043	Hand Wash Only	Applicable	**6/6/2025**	**5.0**			Result Below Action Level, Continue O&M
BRTWD-1021	**Kitchen Locker Room**	1043A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1022	**Kitchen Slop Sink**	1043B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1023	**Music Room Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Twin Pines Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1024	**Art Room Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1025	**Exterior of Room 22 (1056)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1026	**Exterior of Room 35/36 (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1027	**Exterior of Room 33 (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1028	**Exterior of New Construction Bathrooms**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1032	**Exterior of Room 3 (1003)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2999	**Nurse's Office Back Office**	1038	Nurse's Office Sink	Applicable	**6/6/2025**	**13.5**	12/30/2025	3.3	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3043	**Corridor Kitchen to Faculty Bathrooms**	1044	Water Cooler	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3044	**Corridor Kitchen to Faculty Bathrooms**	1044	Bottle Fill Station	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3045	**Corridor Kitchen to Faculty Bathrooms**	1044	Water Cooler	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3046	**Corridor Kitchen to Faculty Bathrooms**	1044	Bottle Fill Station	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3315	**Room 1A**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3316	**Room 6**	1007	Bottled Water Dispenser (Hot)	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3317	**Gender Neutral Bathroom 1**	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3318	**Gender Neutral Bathroom 2**	1027	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3319	**Custodial Closet**	1028	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3320	**Gender Neutral Bathroom 2**	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3321	**Gender Neutral Bathroom 2**	1029	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3322	**Nurses Office**	1036	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3323	**Kitchen**	1043	Pasta Pot/Steam Kettle	Applicable	**6/6/2025**	**2.8**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Twin Pines Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3324	**Girls Bathroom (Across Boiler Room)**	1049	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3325	**Girls Bathroom (Across Boiler Room)**	1049	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3326	**Girls Bathroom (Across Boiler Room)**	1049	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3327	**Boys Bathroom (Across Boiler Room)**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3328	**Boys Bathroom (Across Boiler Room)**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3329	**Boys Bathroom (Across Boiler Room)**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3330	**Room 30**	1064	Bottled Water Dispenser (Hot)	Applicable	**6/6/2025**	**OOS**	8/4/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-3331	**Girl's Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3332	**Girl's Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3333	**Girl's Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3334	**Boy's Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3335	**Boy's Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3336	**Exterior of Kitchen (1043)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3337	**Exterior of Room 16 (1019)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3338	**Exterior of Room 16 (1019)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3339	**Exterior of Room 6 (1007)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3340	**Exterior of Room 11 (1012)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3341	**Exterior of Bathrooms (1049, 1051)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3342	**Exterior of Room 27 (1063)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1038	**Room A-11**	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1039	**Room A-11**	1004	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1041	**Room A-10**	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1042	**Room A-10**	1005	Water Fountain-No Chiller	Applicable	**6/4/2025**	**3.7**			Result Below Action Level, Continue O&M
BRTWD-1043	**Room A-10 Bathroom**	1005A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1044	**Room A-9**	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1045	**Room A-9**	1006	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1046	**Room A-8**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1047	**Room A-8**	1007	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1048	**Room A-7**	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1049	**Room A-7**	1008	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1050	**Room A-6**	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1051	**Room A-6**	1009	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1052	**Room A-5**	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1053	**Room A-5**	1010	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1054	**Room A-4**	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1055	**Room A-4**	1011	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1056	**Room A-3**	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1057	**Room A-3**	1012	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1058	**Room A-2**	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

North Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1059	**Room A-2**	1013	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1060	**Room A-1**	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1061	**Room A-1**	1015	Water Fountain-No Chiller	Applicable	**6/4/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-1062	**Womens Bathroom (Near Room A1)**	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1066	**Corridor Near Stairwell (2001)**	2019	Water Fountain-No Chiller	Applicable	**6/4/2025**	**2.4**			Result Below Action Level, Continue O&M
BRTWD-1067	**Ladies Bathroom (Near Faculty Lounge)**	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1068	**Mens Bathroom (Near Falculty Room)**	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1069	**Room A-12**	2005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1070	**Room A-12**	2005	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1071	**Room A-13**	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1073	**Room A-14**	2008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1074	**Room A-14**	2008	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1075	**Room A-15**	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1076	**Room A-15**	2009	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1077	**Room A-16**	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1078	**Room A-16**	2010	Water Fountain-No Chiller	Applicable	**6/4/2025**	**3.1**			Result Below Action Level, Continue O&M
BRTWD-1080	**Room A-17**	2011	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1081	**Room A-18**	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1082	**Room A-18**	2012	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1083	**Room A-19**	2013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

North Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1084	**Room A-19**	2013	Water Fountain-No Chiller	Applicable	**6/4/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-1085	**Room A-20**	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1086	**Room A-20**	2014	Water Fountain-No Chiller	Applicable	**6/4/2025**	**5.2**	2/19/2026	2.8	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1087	**Room A-21**	2015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1088	**Room A-21**	2015	Water Fountain-No Chiller	Applicable	**6/4/2025**	**6.6**	2/19/2026	2.2	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1089	**Room A-22**	2016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1090	**Room A-22**	2016	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1091	**All Purpose Room Storage 2 Bathroom**	1023B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1092	**All Purpose Room Reading Office Bathroom**	1023C2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1093	**Kitchen (Annex)**	1026	Hand Wash Only	Applicable	**6/4/2025**	**3.8**			Result Below Action Level, Continue O&M
BRTWD-1094	**Kitchen (Annex)**	1026	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1095	**Kitchen (Annex)**	1026	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**28.0**	3/26/2026	3.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1096	**Kitchen Custodial Closet**	1026A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1098	**Room 1**	1031	Water Fountain-No Chiller	RFI	**6/4/2025**	**4.3**			Replaced by Outlet 4188
BRTWD-1099	**Room 1 Bathroom**	1031B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1100	**Library Bathroom**	1033A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1102	**Room 3**	1035	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4190
BRTWD-1104	**Room 5**	1036	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4192
BRTWD-1106	**Room 6**	1037	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4194
BRTWD-1108	**Room 7**	1038	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4196

OOS= Out of Service **RFI = Removed from Inventory**

North Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1110	**Room 8**	1039	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.3**			Replaced by Outlet 4198
BRTWD-1112	**Room 9**	1040	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4200
BRTWD-1113	**Room 10**	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1114	**Room 10**	1041	Water Fountain-No Chiller	Applicable	**6/4/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-1116	**Room 11**	1042	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.2**			Replaced by Outlet 4204
BRTWD-1118	**Room 12**	1043	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4206
BRTWD-1120	**Room 13**	1044	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4208
BRTWD-1122	**Room 14**	1045	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4210
BRTWD-1124	**Room 15**	1047	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4212
BRTWD-1128	**Nurse's Office**	1056	Nurse's Office Sink	Applicable	**6/4/2025**	**8.3**	3/20/2026	4.9	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1129	**Nurse's Office**	1056	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1131	**Custodial Closet**	1055B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1132	**Faculty Room**	1057A	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1134	**Kitchen**	1065	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1136	**Kitchen**	1065	Hand Wash Only	Applicable	**6/4/2025**	**OOS**	12/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1137	**Kitchen**	1065	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**4.0**			Result Below Action Level, Continue O&M
BRTWD-1138	**Kitchen**	1065	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1139	**Kitchen**	1065	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**1.7**			Result Below Action Level, Continue O&M
BRTWD-1140	**Kitchen Bathroom**	1065C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1141	**Kitchen Custodial Area**	1065B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1145	**Custodial Closet**	1070	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1150	**Room 16**	1073	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4214
BRTWD-1152	**Room 17**	1074	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.8**			Replaced by Outlet 4216
BRTWD-1154	**Room 18**	1075	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4218
BRTWD-1156	**Room 19**	1076	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4220
BRTWD-1158	**Room 20**	1077	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.3**			Replaced by Outlet 4222
BRTWD-1160	**Room 21**	1078	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.0**			Replaced by Outlet 4224
BRTWD-1162	**Room 22**	1079	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4226
BRTWD-1164	**Room 23**	1080	Water Fountain-No Chiller	RFI	**6/4/2025**	**5.0**			Replaced by Outlet 4228
BRTWD-1166	**Room 24**	1081	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4230
BRTWD-1168	**Room 25**	1082	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.4**			Replaced by Outlet 4232
BRTWD-1170	**Room 26**	1083	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4236
BRTWD-1172	**Room 27**	1084	Water Fountain-No Chiller	RFI	**6/4/2025**	**2.3**			Replaced by Outlet 4234
BRTWD-1173	**Exterior of Room 24 (1081)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1174	**Exterior of Room 26 (1083)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1175	**Exterior of Room 23 (1080)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1176	**Exterior of Bathrooms (1069/1072)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1177	**Exterior of Room 8 (1039)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1178	**Exterior of Room 1 (1031)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1179	**Exterior of Room A4 (1011)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1180	**Exterior of Custodial Closet (1003)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1181	**Exterior of Room A5 (1010)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1183	**Exterior of Room 13 (1044)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1186	**Exterior of Boiler Room (1067)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3051	**Main Corridor Near Cafeteria (1063)**	1086	Water Cooler	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3052	**Main Corridor Near Cafeteria (1063)**	1086	Bottle Fill Station	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3053	**Corridor Near Annex Office (1021)**	1017	Water Cooler	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3054	**Corridor Near Annex Office (1021)**	1017	Bottle Fill Station	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3882	**Custodial Closet**	1003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3883	**Room A11 Bathroom**	1004B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3884	**Men's Bathroom**	1019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3885	**Custodial Closet**	2000	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3886	**Room A13**	2007	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3887	**Room A17**	2011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3888	**Women's Bathroom**	1052	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3889	**Women's Bathroom**	1052	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3890	**Men's Bathroom**	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3891	**Men's Bathroom**	1053	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3892	**Gym Custodial Closet (In Corridor)**	1055B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3893	**Kitchen**	1065	Pasta Pot/Steam Kettle	Applicable	**6/4/2025**	**OOS**	12/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

North Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3894	**Girls Bathroom**	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3895	**Girls Bathroom**	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3896	**Girls Bathroom**	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3897	**Girls Bathroom**	1069	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3898	**Boys Bathroom**	1072	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3899	**Boys Bathroom**	1072	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3900	**Boys Bathroom**	1072	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3901	**Boys Bathroom**	1072	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3902	**Nurse's Bathroom**	1056A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3903	**Nurse's Office**	1056	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3904	**Main Office Copy Room**	1050C	Bottled Water Dispenser (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3905	**Main Office Copy Room**	1050C	Bottled Water Dispenser (Hot)	Applicable	**6/4/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-3906	**Exterior of Cafeteria (1063)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3907	**Exterior of Main Office (1050)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3908	**Exterior of Math/Reading Lab 3 (1035)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3909	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3910	**Exterior of Kitchen (1065)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4187	**Music Room 1**	1031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4188	**Music Room 1**	1031	Water Fountain-No Chiller	Applicable	**8/29/2025**	**3.8**			Result Below Action Level, Continue O&M
BRTWD-4189	**Math/Reading Lab 3**	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4190	**Math/Reading Lab 3**	1035	Water Fountain-No Chiller	Applicable	**8/29/2025**	**2.5**			Result Below Action Level, Continue O&M
BRTWD-4191	**Computer Room 5**	1036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4192	**Computer Room 5**	1036	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-4193	**Room 6**	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4194	**Room 6**	1037	Water Fountain-No Chiller	Applicable	**8/29/2025**	**2.1**			Result Below Action Level, Continue O&M
BRTWD-4195	**Room 7**	1038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4196	**Room 7**	1038	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-4197	**Room 8**	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4198	**Room 8**	1039	Water Fountain-No Chiller	Applicable	**8/29/2025**	**2.3**			Result Below Action Level, Continue O&M
BRTWD-4199	**Room 9**	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4200	**Room 9**	1040	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-4201	**Room 10**	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4202	**Room 10**	1041	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-4203	**Room 11**	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4204	**Room 11**	1042	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-4205	**Room 12**	1043	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4206	**Room 12**	1043	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-4207	**Room 13**	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4208	**Room 13**	1044	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.9**			Result Below Action Level, Continue O&M
BRTWD-4209	**Room 14**	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

North Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4210	**Room 14**	1045	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.9**			Result Below Action Level, Continue O&M
BRTWD-4211	**Room 15**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4212	**Room 15**	1047	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-4213	**Room 16**	1073	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4214	**Room 16**	1073	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-4215	**Room 17**	1074	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4216	**Room 17**	1074	Water Fountain-No Chiller	Applicable	**8/29/2025**	**5.5**	9/19/2025	1.3	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4217	**Room 18**	1075	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4218	**Room 18**	1075	Water Fountain-No Chiller	Applicable	**8/29/2025**	**7.9**	9/19/2025	3.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4219	**Room 19**	1076	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4220	**Room 19**	1076	Water Fountain-No Chiller	Applicable	**8/29/2025**	**4.3**			Result Below Action Level, Continue O&M
BRTWD-4221	**Room 20**	1077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4222	**Room 20**	1077	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-4223	**Room 21**	1078	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4224	**Room 21**	1078	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.9**			Result Below Action Level, Continue O&M
BRTWD-4225	**Room 22**	1079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4226	**Room 22**	1079	Water Fountain-No Chiller	Applicable	**8/29/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-4227	**Room 23**	1080	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4228	**Room 23**	1080	Water Fountain-No Chiller	Applicable	**8/29/2025**	**6.8**	9/19/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4229	**Room 24**	1081	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

North Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4230	**Room 24**	1081	Water Fountain-No Chiller	Applicable	**8/29/2025**	**7.3**	9/19/2025	1.2	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4231	**Room 25**	1082	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4232	**Room 25**	1082	Water Fountain-No Chiller	Applicable	**8/29/2025**	**14.7**	9/19/2025	1.4	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4233	**Room 27**	1084	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4234	**Room 27**	1084	Water Fountain-No Chiller	Applicable	**8/29/2025**	**2.6**			Result Below Action Level, Continue O&M
BRTWD-4235	**Room 26**	1083	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4236	**Room 26**	1083	Water Fountain-No Chiller	Applicable	**8/29/2025**	**3.0**			Result Below Action Level, Continue O&M

Northeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1187	**Room 32**	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1188	**Room 32**	1001	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1189	**Room 33**	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1196	**Room 28**	1005	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1197	**Room 29**	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1199	**Room 27**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1202	**Student Bathroom (Near Gym)**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1203	**Custodial Closet**	1011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1204	**Gym Locker Room Bathroom**	1030C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1207	**Custodial Closet 10A**	1027	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1210	**Nurse's Office**	1031	Nurse's Office Sink	Applicable	**6/4/2025**	**2.9**			Result Below Action Level, Continue O&M
BRTWD-1214	**Custodial Closet 13D**	1035	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1220	**Room 16**	1038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1221	**Room 16**	1038	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1222	**Room 17**	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1223	**Room 17**	1039	Water Fountain-No Chiller	Applicable	**6/4/2025**	**4.8**			Result Below Action Level, Continue O&M
BRTWD-1224	**Room 18**	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1225	**Room 18**	1040	Water Fountain-No Chiller	Applicable	**6/4/2025**	**OOS**	1/23/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-1226	**Room 19**	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1227	**Room 19**	1041	Water Fountain-No Chiller	Applicable	**6/4/2025**	**1.8**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Northeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1228	**Room 20**	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1229	**Room 20**	1042	Water Fountain-No Chiller	Applicable	**6/4/2025**	**3.7**			Result Below Action Level, Continue O&M
BRTWD-1230	**Room 20A Bathroom**	1045A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1231	**Room 21**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1232	**Room 21**	1047	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1233	**Room 22**	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1234	**Room 22**	1048	Water Fountain-No Chiller	Applicable	**6/4/2025**	**OOS**	1/23/2026	1.4	Result Below Action Level, Continue O&M
BRTWD-1235	**Room 23**	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1236	**Room 23**	1049	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1237	**Room 24**	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1238	**Room 24**	1050	Water Fountain-No Chiller	Applicable	**6/4/2025**	**7.7**	1/23/2026	3.8	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1239	**Room 25**	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1240	**Room 25**	1051	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1241	**Room 26**	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1242	**Room 26**	1052	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1243	**Room 410**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1244	**Room 410**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1245	**Room 412**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1246	**Room 412**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1247	**Girls Bathroom (Near Faculty Room)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Northeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1250	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1252	**Faculty Bathroom (Near Faculty Room)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1255	**Room 414**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1256	**Room 414**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1257	**Room 416**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1258	**Room 416**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1260	**Faculty Room 8**	1055	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-1262	**Room 6**	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1263	**Room 5**	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1264	**Room 5**	1057	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1267	**Room 1**	1060	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1268	**Room 1**	1060	Water Fountain-No Chiller	Applicable	**6/4/2025**	**3.5**			Result Below Action Level, Continue O&M
BRTWD-1269	**Room 2**	1061	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1270	**Room 2**	1061	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1271	**Annex Kitchen**	1067	Hand Wash Only	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1272	**Annex Kitchen**	1067	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**7.0**	12/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1273	**Annex Kitchen**	1067	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1274	**Annex Kitchen**	1067	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1275	**Annex Student Bathroom (Across Copy Room)**	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1276	**Annex Faculty Bathroom (Across Copy Room)**	1066	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Northeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1277	**Custodial Closet**	1069	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1278	**Corridor Near Speech Room (1070)**	1085	Water Cooler	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1279	**Room 9A**	1071	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1280	**Room 9A**	1071	Water Fountain-No Chiller	Applicable	**6/4/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-1281	**Room 12A**	1072	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1282	**Room 12A**	1072	Water Fountain-No Chiller	Applicable	**6/4/2025**	**OOS**	3/4/2026	1.1	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1283	**Room 7A**	1073	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1284	**Room 7A**	1073	Water Fountain-No Chiller	Applicable	**6/4/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-1285	**Room 10A**	1074	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1286	**Room 10A**	1074	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1287	**Room 5A**	1075	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1288	**Room 5A**	1075	Water Fountain-No Chiller	Applicable	**6/4/2025**	**2.6**			Result Below Action Level, Continue O&M
BRTWD-1289	**Room 5A Bathroom**	1075B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1290	**Room 8A**	1077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1291	**Room 8A**	1077	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1292	**Room 6A**	1078	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1293	**Room 6A**	1078	Water Fountain-No Chiller	Applicable	**6/4/2025**	**OOS**	1/23/2026	1.6	Result Below Action Level, Continue O&M
BRTWD-1294	**Room 3A**	1079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1295	**Room 3A**	1079	Water Fountain-No Chiller	Applicable	**6/4/2025**	**3.6**			Result Below Action Level, Continue O&M
BRTWD-1296	**Room 3A Bathroom**	1079A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Northeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1297	**Custodial Closet**	1080	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1300	**Room 2A**	1082	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1301	**Room 2A**	1082	Water Fountain-No Chiller	Applicable	**6/4/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-1302	**Room 1A**	1083	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1303	**Room 1A**	1083	Water Fountain-No Chiller	Applicable	**6/4/2025**	**2.1**			Result Below Action Level, Continue O&M
BRTWD-1304	**Room 1A Bathroom**	1083B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1305	**Cafeteria**	1018	Water Cooler	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1306	**Kitchen**	1018B	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1307	**Kitchen**	1018B	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1308	**Kitchen**	1018B	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**4.1**			Result Below Action Level, Continue O&M
BRTWD-1309	**Kitchen**	1018B	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1310	**Kitchen**	1018B	Hand Wash Only	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1312	**Kitchen**	1018B	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1313	**Kitchen Bathroom**	1018B2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1314	**Kitchen Custodial Closet**	1018B3	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1315	**Kitchen Custodial Closet**	1018B3	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1316	**Kitchen Custodial Closet**	1018B3	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1317	**Room 34**	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1318	**Room 34**	2009	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1319	**Room 35**	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Northeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1320	**Room 35**	2010	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1321	**Room 37**	2008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1322	**Room 37**	2008	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1325	**Room 39**	2006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1326	**Room 39**	2006	Water Fountain-No Chiller	Applicable	**6/4/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-1327	**Room 38**	2005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1328	**Room 38**	2005	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1329	**Room 40**	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1330	**Room 40**	2003	Water Fountain-No Chiller	Applicable	**6/4/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-1334	**Custodial Closet**	2001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1342	**Exterior of Room 25 (1051)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1343	**Exterior of Room 416 (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1344	**Exterior of Room 410 (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1345	**Exterior of Room 26 (1052)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3055	**Corridor Near Bathrooms (New Construction)**	N/A	Water Cooler	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3056	**Corridor Near Bathrooms (New Construction)**	N/A	Bottle Fill Station	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3057	**Corridor Between Gym & Library**	1032	Water Cooler	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3058	**Corridor Between Gym & Library**	1032	Bottle Fill Station	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3109	**Room 4A**	1081	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3177	**Art Room 4**	1058	Water Fountain-No Chiller	Applicable	**6/4/2025**	**2.8**			Result Below Action Level, Continue O&M

Northeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3178	**Room 15**	1037	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3444	**Room 33**	1002	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3445	**Room 30**	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3446	**Room 31**	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3447	**Room 28**	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3448	**Room 29**	1006	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3450	**Faculty Bathroom**	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3451	**Kitchen**	1018B	Pasta Pot/Steam Kettle	Applicable	**6/4/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-3452	**Main Office**	1024	Bottled Water Dispenser (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3453	**Main Office**	1024	Bottled Water Dispenser (Hot)	Applicable	**6/4/2025**	**OOS**	1/23/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-3454	**Women's Bathroom**	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3455	**Women's Bathroom**	1028	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3456	**Men's Bathroom**	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3457	**Men's Bathroom**	1025	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3458	**Nurses Office Bathroom**	1031A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3460	**Boys Bathroom**	1034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3461	**Boys Bathroom**	1034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3462	**Boys Bathroom**	1034	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3463	**Girls Bathroom**	1036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3464	**Girls Bathroom**	1036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Northeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3465	**Girls Bathroom**	1036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3466	**Girls Bathroom**	1036	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3467	**Room 15**	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3468	**Girls Bathroom (near Faculty)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3469	**Girls Bathroom (near Faculty)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3470	**Boys Bathroom (near Faculty)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3471	**Boys Bathroom (near Faculty)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3473	**Faculty Room 8**	1055	Bottled Water Dispenser (Hot)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3475	**Room 4**	1058	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3476	**Room 4A**	1081	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3477	**Girls Bathroom**	2000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3478	**Girls Bathroom**	2000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3479	**Girls Bathroom**	2000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3480	**Girls Bathroom**	2000	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3481	**Boys Bathroom**	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3482	**Boys Bathroom**	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3483	**Boys Bathroom**	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3484	**Boys Bathroom**	2002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3485	**Room 36**	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3486	**Room 36**	2007	Water Fountain-No Chiller	Applicable	**6/4/2025**	**1.8**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Northeast Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3487	**Exterior of Room 31 (1004)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3488	**Exterior of Cafeteria (1018)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3489	**Exterior of Kitchen (1018B)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3490	**Exterior of Main Office (1024)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3491	**Exterior of Room 1 (1060)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3492	**Exterior of Room 6A (1078)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3493	**Exterior of Room 1A (1083)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3494	**Exterior of Room 3A (1079)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3495	**Exterior of Annex Kitchen (1067)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3496	**Exterior of Room 2 (1061)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3497	**Exterior of Room 19 (1041)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3957	**Room 6**	1056	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3958	**Faculty Room 8**	1055	Bottled Water Dispenser (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3959	**Faculty Room 8**	1055	Bottled Water Dispenser (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3960	**Room 27**	1007	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

East Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1354	**Auditorium Lobby Men's Bathroom**	1006A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1357	**Auditorium Lobby Women's Bathroom**	1006A2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1358	**Custodial Closet**	1010	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1359	**Science Room 123**	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1360	**Science Room 123**	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1363	**Science Room 124**	1014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1364	**Science Room 124**	1014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1365	**Room 121**	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1367	**Boutique (Former Bathroom)**	1009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1368	**Boutique (Former Bathroom)**	1009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1369	**Boys Bathroom (Near Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1370	**Boys Bathroom (Near Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1372	**Girls Bathroom (Near Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1373	**Girls Bathroom (Near Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1374	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1375	**Room 143**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1376	**Room 142**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1377	**Corridor Near Basement Stairwell**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1378	**Corridor Near Basement Stairwell**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1379	**Basement Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1380	**Basement Womens Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1381	**Basement Womens Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1382	**Basement Womens Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1383	**Basement Womens Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1384	**Corridor Near Bathrooms**	N/A	Water Cooler	Applicable	**6/7/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-1385	**Corridor Near Bathrooms**	N/A	Water Cooler	Applicable	**6/7/2025**	**2.3**			Result Below Action Level, Continue O&M
BRTWD-1386	**Basement Mens Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1387	**Basement Mens Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1388	**Basement Mens Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1389	**Basement Mens Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1393	**Corridor Near Faculty Room (1026A)**	1056	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1394	**Corridor Near Faculty Room (1026A)**	1056	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1396	**Nurse's Office**	1029	Nurse's Office Sink	Applicable	**6/7/2025**	**4.4**			Result Below Action Level, Continue O&M
BRTWD-1397	**Nurse's Office Bathroom**	1029C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1400	**Corridor Near Girls Locker Room (1033A)**	1056	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1401	**Girls Coach's Office Bathroom**	1033B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1402	**Girls Locker Room Bathroom**	1033A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1403	**Girls Locker Room Bathroom**	1033A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1404	**Girls Locker Room**	1033A	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1407	**Boys Coach's Office Bathroom**	1042A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1408	**Boys Locker Room**	1042B	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1409	**Boys Locker Room Bathroom**	1042B2	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1410	**Boys Locker Room Bathroom**	1042B2	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1411	**Corridor Near Room 110 (1044)**	1056	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1412	**Room 108**	1046	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1413	**Room 108**	1046	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1418	**Custodial Closet**	1050	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1423	**Storage (Former Boys Bathroom)**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1424	**Storage (Former Boys Bathroom)**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1425	**Storage (Former Boys Bathroom)**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1426	**Corridor Near Room 104 (1052)**	1056	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1427	**Room 102 Technology Room**	1054	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1428	**Room 102 Technology Room**	1054	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1429	**Room 101 Technology Room**	1055	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1430	**Room 101 Technology Room**	1055	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1431	**Boys Bathroom (Across Art Room 202)**	2000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1432	**Boys Bathroom (Across Art Room 202)**	2000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1433	**Custodial Closet**	2001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1434	**Corridor Near Room 202 (2002)**	2021	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1435	**Girls Bathroom (Across Art Room 202)**	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1436	**Girls Bathroom (Across Art Room 202)**	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1437	**Room 202 Art Room**	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1438	**Room 202 Art Room**	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1439	**Room 204 Art Room**	2004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1440	**Room 204 Art Room**	2004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1446	**Library Work Room**	2017A	Office Faucet	Applicable	**6/7/2025**	**4.5**			Result Below Action Level, Continue O&M
BRTWD-1448	**Mens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1449	**Mens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1450	**Corridor Near Faculty Bathrooms**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1451	**Womens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1452	**Womens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1453	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1454	**Corridor Near Room 246**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1455	**Corridor Near Room 246**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1456	**Corridor Near Room 218 (2024)**	2041	Water Fountain-No Chiller	Applicable	**6/7/2025**	**2.1**			Result Below Action Level, Continue O&M
BRTWD-1457	**Room 221**	2030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1458	**Room 223**	2032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1462	**Corridor Near Room 226 (2033)**	2041	Water Fountain-No Chiller	Applicable	**6/7/2025**	**4.4**			Result Below Action Level, Continue O&M
BRTWD-1463	**Corridor Near Room 226 (2033)**	2041	Bottle Fill Station	Applicable	**6/7/2025**	**4.0**			Result Below Action Level, Continue O&M
BRTWD-1467	**Boys Bathroom (Across Room 228)**	2035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1468	**Boys Bathroom (Across Room 228)**	2035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1470	**Custodial Closet**	2036	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1471	**Girls Bathroom (Across Room 228)**	2037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1472	**Girls Bathroom (Across Room 228)**	2037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1473	**Girls Bathroom (Across Room 228)**	2037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1474	**Basement Technology Suite Break Room**	N/A	Bottled Water Dispenser	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1475	**Basement Technology Suite Break Room**	N/A	Water Cooler	Applicable	**6/7/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-1476	**Kitchen**	1036	Hand Wash Only	Applicable	**6/7/2025**	**11.7**	12/30/2025	2.1	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1477	**Kitchen**	1036	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**2.4**			Result Below Action Level, Continue O&M
BRTWD-1478	**Kitchen**	1036	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1479	**Kitchen**	1036	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**1.7**			Result Below Action Level, Continue O&M
BRTWD-1480	**Kitchen**	1036	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1481	**Kitchen**	1036	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-1482	**Kitchen**	1036	Hand Wash Only	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1484	**Kitchen**	1036	Hand Wash Only	Applicable	**6/7/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-1485	**Kitchen Can Wash Room**	1036C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1486	**Kitchen Bathroom**	1036D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1487	**Exterior of Main Office**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1488	**Exterior of Bathrooms (1009/1011)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2986	**Auditorium Lobby**	1006A	Water Fountain-No Chiller	RFI	**6/7/2025**	**OOS**			Replaced by Outlet 3107

OOS= Out of Service **RFI = Removed from Inventory**

East Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3013	**Auditorium Lobby Women's Bathroom**	1006A2	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3014	**Corridor Near Boiler Room (1001)**	1056	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3015	**Corridor Near Boiler Room (1001)**	1056	Bottle Fill Station	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlet 3096
BRTWD-3016	**Corridor Near Room 124 (1014)**	1023	Water Cooler	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlet 3097
BRTWD-3017	**Corridor Near Room 124 (1014)**	1023	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3018	**Corridor Near Bathrooms (New Construction)**	N/A	Water Cooler	Applicable	**6/7/2025**	**OOS**	2/19/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-3019	**Corridor Near Bathrooms (New Construction)**	N/A	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3020	**Corridor Near Room 216 (2019)**	2021	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3021	**Corridor Near Room 216 (2019)**	2021	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3106	**Corridor Near Room 210 (2010)**	2021	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3107	**Auditorium Lobby**	1006A	Water Cooler	Applicable	**6/7/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-3226	**Auditorium Lobby Men's Bathroom**	1006A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3227	**Girl's Bathroom (Across Faculty Lounge)**	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3228	**Room 123**	1013	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3229	**Faculty Lounge Room 114 Women's Bathroom**	1026B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3230	**Faculty Lounge Room 114**	1026A	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-3231	**Faculty Lounge Room 114 Men's Bathroom**	1027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3232	**Nurse's Office**	1029	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3233	**Kitchen**	1036	Pasta Pot/Steam Kettle	Applicable	**6/7/2025**	**2.2**			Result Below Action Level, Continue O&M
BRTWD-3234	**Girl's Bathroom (Across Faculty Lounge)**	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3235	**Boys Bathroom**	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3236	**Custodial Office Bathroom**	1041A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3237	**Room 106**	1048	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3238	**Room 106**	1048	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-3239	**Room 106**	1048	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3240	**Room 106 Laundry Room**	1048A	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**15.5**	12/30/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3241	**Room 104**	1052	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3242	**Room 104**	1052	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3243	**Room 104**	1052	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3244	**Room 104**	1052	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3245	**Room 101**	1055	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3246	**Room 102**	1054	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3247	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3248	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3249	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3250	**Room 226**	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3251	**Room 226**	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3252	**Room 226**	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3253	**Room 225**	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3254	**Room 225**	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

East Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3255	**Room 225**	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3256	**Boys Bathroom (Across Room 28)**	2035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3257	**Basement Technology Suite Break Room**	N/A	Bottled Water Dispenser (Hot)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3258	**Exterior of Auditorium Lobby Bathrooms (1006A1/1006A2)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3259	**Exterior of Assistant Principal's Office (1022C)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3260	**Exterior of Girls Locker Room (1033A)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3261	**Exterior of Room 104 (1052)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3262	**Exterior of Room 102 (1054)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3263	**Exterior of Bathrooms (1049/1051)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4296	**Cafeteria Corridor**	1056	Bottle Fill Station	Applicable	**6/26/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4297	**Cafeteria Corridor**	1056	Water Cooler	Applicable	**6/26/2026**	**<1.0**			Result Below Action Level, Continue O&M

Freshman Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1495	**Room 11 Art Room**	1000	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1496	**Room 11 Art Room**	1000	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1497	**Room 11 Art Room**	1000	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1498	**Room 10 Sink Area**	1002A	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1499	**Room 10 Sink Area**	1002A	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1500	**Room 10 Sink Area**	1002A	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1501	**Health Suite**	1010	Nurse's Office Sink	Applicable	**6/7/2025**	**6.3**	1/9/2026	3.7	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1503	**Health Suite Bathroom**	1010C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1507	**Custodial Closet A**	1026	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1516	**Corridor Near Room 48 (1034)**	1042	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1517	**Cafeteria (Area Reconstructed)**	1036	Hand Wash Only	Applicable	**6/7/2025**	**16.8**	12/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1518	**Cafeteria (Area Reconstructed)**	1036	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**12.1**	9/4/2026	2.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1519	**Cafeteria (Area Reconstructed)**	1036	Hand Wash Only	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1520	**Kitchen**	1038	Hand Wash Only	Applicable	**6/7/2025**	**10.2**	12/23/2025	1.8	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1521	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-1522	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1523	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-1524	**Kitchen**	1038	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1526	**Kitchen**	1038	Hand Wash Only	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1527	**Kitchen Bathroom**	1039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Freshman Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1528	**Kitchen Slop Sink Room**	1038A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1529	**Girls Bathroom (Across Boiler Room)**	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1530	**Girls Bathroom (Across Boiler Room)**	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1532	**Custodial Closet B**	1045	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1539	**Custodial Closet**	1074A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1540	**Girls Coach's Office Bathroom**	1073B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1541	**Girls Locker Room**	1073	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1543	**Gymnasium**	1075	Water Fountain-No Chiller	RFI	**6/7/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-1544	**Gymnasium**	1075	Water Fountain-No Chiller	RFI	**6/7/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-1545	**Boys Coach's Office Bathroom**	1071A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1546	**Boys Locker Room**	1071	Water Fountain-No Chiller	Applicable	**6/7/2025**	**20.2**	9/4/2026	20.7	Removed From Service, Pending Remediation
BRTWD-1548	**Library Work Room**	1068C	Office Faucet	Applicable	**6/7/2025**	**OOS**	8/19/2026	2.1	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1549	**Library Work Room**	1068C	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1552	**Girls Bathroom (Near Gym)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1553	**Girls Bathroom (Near Gym)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1554	**Corridor Near Bathrooms**	N/A	Water Cooler	RFI	**6/7/2025**	**OOS**			Replaced by Outlets 4244/4245
BRTWD-1555	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1556	**Boys Bathroom (Near Gym)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1560	**Custodial Closet**	1082	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1564	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Freshman Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1566	**Womens Faculty Bathroom (Near Room 214)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1567	**Womens Faculty Bathroom (Near Room 214)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1568	**Room 214**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1569	**Room 214**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1570	**Room 211**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1571	**Room 211**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1572	**Room 212**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1573	**Room 212**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1574	**Boys Bathroom (Near Science Room 200)**	2017	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1575	**Room 200**	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1576	**Room 200**	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1577	**Room 200**	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1578	**Room 200**	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1579	**Room 200**	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1580	**Room 200**	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1581	**Room 200**	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1582	**Room 201**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1583	**Room 201**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1584	**Room 201**	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1585	**Room 202**	2002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Freshman Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1586	**Room 202**	2002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1587	**Room 202**	2002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1588	**Room 202**	2002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1589	**Room 202**	2002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1590	**Room 202**	2002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1591	**Room 202**	2002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1592	**Room 200/202 Prep Room**	2001A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1593	**Room 200/202 Prep Room**	2001A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1594	**Room 204**	2003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1595	**Room 204**	2003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1596	**Room 204**	2003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1597	**Room 204**	2003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1598	**Room 204**	2003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1599	**Room 204**	2003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1600	**Room 204**	2003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1601	**Room 204 Prep Room**	2003A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1603	**Room 204 Prep Room**	2003A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1604	**Room 206**	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1605	**Room 206**	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1606	**Room 206**	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Freshman Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1607	**Room 206**	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1608	**Room 206**	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1609	**Room 206**	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1610	**Room 206**	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1611	**Room 206 Prep Room**	2004A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1612	**Room 206 Prep Room**	2004A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1613	**Custodial Closet**	2005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1614	**Corridor Near Room 209 (2008)**	2014	Water Fountain-No Chiller	RFI	**6/7/2025**	**13.8**			Replaced by Outlets 4304, 4305
BRTWD-1615	**Room 209**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1616	**Room 209**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1617	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1618	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1619	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1620	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1621	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1622	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1623	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1624	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1625	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1626	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Freshman Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1627	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1628	**Room 207**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1629	**Girls Bathroom (Near Room 204)**	2010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1630	**Faculty Bathroom (Near Room 209)**	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1631	**Room 203**	2013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1632	**Room 203**	2013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1633	**Room 203**	2013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1634	**Room 203**	2013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1635	**Room 203**	2013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1636	**Room 203**	2013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1637	**Room 203**	2013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1638	**Room 203**	2013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1639	**Room 203**	2013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1640	**Exterior of Room 32 (1054)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1641	**Exterior of Bathrooms (1044/1046)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1642	**Exterior of Bathrooms (1044/1046)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1643	**Exterior of Room 8 (1007)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1659	**Exterior of Orchestra Room (1063)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1660	**Exterior of Gymnasium (1075)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2993	**Cafeteria (Expanded in 2012)**	1036	Bottle Fill Station	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlet 4265

OOS= Out of Service **RFI = Removed from Inventory**

Freshman Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2994	**Corridor Between Library & Gym**	1076	Bottle Fill Station	Applicable	**6/7/2025**	**1.7**			Result Below Action Level, Continue O&M
BRTWD-3094	**Corridor Across From Room 217**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3095	**Corridor Across From Room 217**	N/A	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3096	**Mens Faculty Bathroom (Near Room 214)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3108	**Boys Locker Room**	1071	Water Fountain-No Chiller	Applicable	**6/7/2025**	**19.6**	9/4/2026	6.9	Removed From Service, Pending Remediation
BRTWD-3343	**Boys Bathroom (near Gym)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3344	**Boys Bathroom (near Gym)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3345	**Girls Bathroom (near Gym)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3346	**Men's Bathroom**	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3347	**Men's Bathroom**	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3348	**Men's Bathroom**	1065	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3349	**Girls Locker Room Bathroom**	1073A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3350	**Girls Locker Room Bathroom**	1073A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3351	**Girls Locker Room Bathroom**	1073A1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3352	**Boys Locker Room Bathroom**	1071B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3353	**Boys Locker Room Bathroom**	1071B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3354	**Boys Locker Room Bathroom**	1071B1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3355	**Women's Faculty Bathroom**	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3356	**Women's Faculty Bathroom**	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3357	**Women's Faculty Bathroom**	1069	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Freshman Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3358	**Storage (Former Bathroom)**	1081	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3359	**Storage (Former Bathroom)**	1081	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3360	**Faculty Women's Bathroom**	1083	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3361	**Health Suite**	1010	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3362	**Gender Neutral Bathroom 1**	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3363	**Gender Neutral Bathroom 1**	1020	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3364	**Gender Neutral Bathroom 2**	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3365	**Gender Neutral Bathroom 2**	1021	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3366	**Home Ec. Kitchen**	1028A	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**40.9**	1/14/2026	3.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3367	**Home Ec. Kitchen**	1028A	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**119**	1/14/2026	3.7	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3368	**Home Ec. Kitchen**	1028A	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**2.5**			Result Below Action Level, Continue O&M
BRTWD-3369	**Faculty Room**	1034	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**2.9**			Result Below Action Level, Continue O&M
BRTWD-3370	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3371	**Kitchen**	1038	Pasta Pot/Steam Kettle	Applicable	**6/7/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-3372	**Girls Bathroom**	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3373	**Men's Bathroom**	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3374	**Men's Bathroom**	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3375	**Men's Bathroom**	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3376	**Exterior of Main Office (1017)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3377	**Exterior of Room 11 (1000)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Freshman Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3378	**Exterior of Gymnasium (1075)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3379	**Exterior of Room 29 (1058)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3380	**Exterior of Boiler Room (1047)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4244	**New Construction Corridor Near Room 14**	N/A	Bottle Fill Station	Applicable	**10/2/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4245	**New Construction Corridor Near Room 14**	N/A	Water Cooler	Applicable	**10/2/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4252	**Girls Bathroom (near Gym)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4253	**Boys Bathroom (near Gym)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4254	**Mens Faculty Bathroom (Near Room 214)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4255	**Mens Faculty Bathroom (Near Room 214)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4256	**Womens Faculty Bathroom (Near Room 214)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4257	**Womens Faculty Bathroom (Near Room 214)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4265	**Cafeteria (Expanded in 2012)**	1036	Bottle Fill Station	Applicable	**12/18/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4266	**Cafeteria (Expanded in 2012)**	1036		Applicable	**12/18/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4304	**Corridor Room 203 to 209**	2014	Bottle Fill Station	Applicable	**8/4/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4305	**Corridor Room 203 to 209**	2014	Water Cooler	Applicable	**8/4/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4324	**Gym**	1075	Bottle Fill Station	Applicable	**8/19/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4325	**Gym**	1075	Bottle Fill Station	Applicable	**8/19/2026**	**<1.0**			Result Below Action Level, Continue O&M

Instructional Media Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1644	**Room 41 Wood Shop**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1645	**Room 41 Wood Shop**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1646	**Room 41 Wood Shop**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1647	**Room 41 Wood Shop**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1648	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1649	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1650	**Faculty Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1651	**Faculty Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1652	**Corridor Near Room 43**	N/A	Water Cooler	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlets 4306, 4307
BRTWD-1653	**Room 45 Art Room**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1654	**Room 45 Art Room**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1655	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1656	**Exterior of Room 45**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4306	**Corridor Near Room 43**	N/A	Bottle Fill Station	Applicable	**8/4/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4307	**Corridor Near Room 43**	N/A	Water Cooler	Applicable	**8/4/2026**	**<1.0**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

North Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1664	**Auditorium Lobby Men's Bathroom**	1008A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1665	**Auditorium Lobby Men's Bathroom**	1008A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1667	**Auditorium Lobby Women's Bathroom**	1008B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1669	**Custodial Closet**	1010	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1671	**Corridor Near Room 123 (1013)**	1023	Water Fountain-No Chiller	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1672	**Room 124**	1014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1673	**Room 124**	1014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1674	**Room 124**	1014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1675	**Room 121**	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1676	**Room 122**	1016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1677	**Corridor Near Room 116 (1021)**	1023	Water Fountain-No Chiller	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1679	**Boys Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1680	**Boys Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1681	**Boys Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1682	**Boys Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1684	**Girls Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1685	**Girls Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1686	**Girls Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1687	**Girls Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1688	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1689	**Room 143**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1690	**Room 142**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1694	**Faculty Room**	1026	Kitchen Faucet (Cold)	Applicable	**6/11/2025**	**2.0**			Result Below Action Level, Continue O&M
BRTWD-1700	**Nurse's Office**	1029	Nurse's Office Sink	Applicable	**6/11/2025**	**2.2**			Result Below Action Level, Continue O&M
BRTWD-1705	**Girls Locker Room Bathroom**	1033B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1706	**Girls Locker Room Bathroom**	1033B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1707	**Girls Locker Room**	1033	Water Fountain-No Chiller	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1708	**Girls Coach's Office Bathroom**	1033A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1709	**Kitchen**	1034	Kitchen Faucet (Cold)	Applicable	**6/11/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-1710	**Kitchen**	1034	Kitchen Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1711	**Kitchen**	1034	Kitchen Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1712	**Kitchen**	1034	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1713	**Kitchen**	1034	Kitchen Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1715	**Kitchen**	1034	Hand Wash Only	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1716	**Kitchen Can Wash Room**	1034A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1717	**Kitchen Can Wash Room**	1034A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1718	**Kitchen Bathroom**	1034B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1720	**Custodial Office Bathroom**	1039A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1721	**Boys Locker Room**	1041	Water Fountain-No Chiller	RFI	**6/11/2025**	**OOS**			Replaced by Outlet 4295
BRTWD-1722	**Boys Locker Room Bathroom**	1041B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1723	**Boys Locker Room Bathroom**	1041B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1724	**Boys Coach's Office Bathroom**	1041A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1725	**Corridor Near Room 110 (1044)**	1057	Water Fountain-No Chiller	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1726	**Room 108**	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1732	**Girls Bathroom (Across Room 104)**	1049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1733	**Custodial Closet**	1050	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1739	**Corridor Near Room 104 (1051)**	1057	Water Fountain-No Chiller	Applicable	**6/11/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-1743	**Shop Room 102**	1056	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1744	**Shop Room 102**	1056	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1745	**Shop Room 101**	1055	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1746	**Shop Room 101**	1055	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1747	**Shop Room 101**	1055	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1748	**Girls Bathroom (Across Room 230)**	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1749	**Girls Bathroom (Across Room 230)**	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1750	**Girls Bathroom (Across Room 230)**	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1751	**Custodial Closet**	2004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1752	**Boys Bathroom (Across Room 230)**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1753	**Boys Bathroom (Across Room 230)**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1754	**Boys Bathroom (Across Room 230)**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1756	**Corridor Near Room 228 (2008)**	2018	Water Fountain-No Chiller	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

North Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1758	**Room 223**	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1759	**Room 226**	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1761	**Corridor Near Room 220 (2016)**	2018	Water Fountain-No Chiller	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1762	**Mens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1763	**Mens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1764	**Mens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1765	**Mens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1768	**Womens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1769	**Womens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1770	**Womens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1771	**Womens Faculty Bathroom (Near Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1772	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1773	**Corridor Near Room 246**	N/A	Water Cooler	RFI	**6/11/2025**	**OOS**			Replaced by Outlet 4243
BRTWD-1774	**Corridor Near Room 246**	N/A	Water Cooler	RFI	**6/11/2025**	**OOS**			Replaced by Outlet 4242
BRTWD-1776	**Library Work Room**	2023A	Office Faucet	Applicable	**6/11/2025**	**10.0**	3/26/2026	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-1777	**Corridor Near Stairwell (2030)**	2043	Water Fountain-No Chiller	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1781	**Art Room 204**	2037	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1782	**Art Room 204**	2037	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1783	**Womens Faculty Bathroom (Across Room 202)**	2038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1784	**Womens Faculty Bathroom (Across Room 202)**	2038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1785	**Custodial Closet**	2039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1786	**Art Room 202**	2041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1787	**Art Room 202**	2041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1788	**Corridor Near Art Room 202 (2041)**	2043	Water Fountain-No Chiller	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1793	**Exterior of New Construction Faculty Bathrooms**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1797	**Exterior of Bathrooms (1049/1052)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3005	**Room 218 Life Skills**	2019	Home Economics Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3011	**Auditorium Lobby Women's Bathroom**	1008B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3028	**Corridor Near Elevator**	1057	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3029	**Corridor Near Elevator**	1057	Bottle Fill Station	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3030	**Corridor Near Bathrooms (New Construction)**	N/A	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3031	**Corridor Near Bathrooms (New Construction)**	N/A	Bottle Fill Station	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3032	**Corridor Near Auditorium (1005)**	1008	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3033	**Corridor Near Auditorium (1005)**	1008	Bottle Fill Station	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3034	**Corridor Near Room 216 (2021)**	2043	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3035	**Corridor Near Room 216 (2021)**	2043	Bottle Fill Station	RFI	**6/11/2025**	**<1.00 ND**			Replaced by Outlet 4241
BRTWD-3036	**Corridor Near Faculty Bathrooms (New**	N/A	Water Cooler	RFI	**6/11/2025**	**OOS**			Replaced By Outlet 4274
BRTWD-3037	**Corridor Near Faculty Bathrooms (New**	N/A	Bottle Fill Station	RFI	**6/11/2025**	**OOS**			Replaced By Outlet 4275
BRTWD-3090	**Corridor Near Faculty Room (1026)**	1058	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3091	**Corridor Near Faculty Room (1026)**	1058	Bottle Fill Station	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

North Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3092	**Corridor Near Room 146**	N/A	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3093	**Corridor Near Room 146**	N/A	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3381	**Room 123**	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3382	**Room 114**	1024	Bottled Water Dispenser (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3383	**Room 114**	1024	Bottled Water Dispenser (Hot)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3384	**Women's Faculty Bathroom**	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3385	**Women's Faculty Bathroom**	1025	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3386	**Men's Faculty Bathroom**	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3387	**Men's Faculty Bathroom**	1027	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3388	**Boy's Bathroom**	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3389	**Boy's Bathroom**	1028	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3390	**Girls Bathroom**	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3391	**Girls Bathroom**	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3392	**Girls Bathroom**	1030	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3393	**Nurses Office Bathroom**	1029A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3394	**Nurses Office**	1029	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3395	**Nurses Office Inner Room 2**	1029C	Nurse's Office Sink	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3396	**Kitchen**	1034	Pasta Pot/Steam Kettle	Applicable	**6/11/2025**	**3.1**			Result Below Action Level, Continue O&M
BRTWD-3397	**Room 106**	1048	Home Economics Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3398	**Room 106**	1048	Home Economics Faucet (Cold)	Applicable	**6/11/2025**	**1.3**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

North Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3399	**Room 106**	1048	Home Economics Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3400	**Girls Bathroom**	1049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3401	**Girls Bathroom**	1049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3402	**Room 104**	1051	Home Economics Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3403	**Room 104**	1051	Home Economics Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3404	**Room 104**	1051	Home Economics Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3405	**Room 104**	1051	Home Economics Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3406	**Room 104 Storage**	1051A	Home Economics Faucet (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3407	**Boys Bathroom**	1052	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3408	**Boys Bathroom**	1052	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3409	**Boys Bathroom**	1052	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3410	**Room 101**	1055	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3411	**Room 102**	1056	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3412	**Teacher Center Kitchen (exterior access)**	N/A	Kitchen Faucet (Cold)	Applicable	**6/11/2025**	**18.1**	3/20/2026	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3413	**Teacher Center Kitchen (exterior access)**	N/A	Bottled Water Dispenser (Cold)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3414	**Teacher Center Kitchen (exterior access)**	N/A	Bottled Water Dispenser (Hot)	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3415	**Teacher Center Kitchen Bathroom (exterior access)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3416	**Corridor Main Lobby to Receiving**	1058	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3417	**Corridor Main Lobby to Receiving**	1058	Bottle Fill Station	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3418	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3419	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3420	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3421	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3422	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3423	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3424	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3425	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3426	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3427	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3428	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3429	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3430	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3431	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3432	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3433	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3434	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3435	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3436	**Exterior of Main Office (1022)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3437	**Exterior of Room 123 (1013)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3438	**Exterior of Auditorium Lobby Bathrooms (1008A/1008B)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

North Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3439	**Exterior of Bathrooms (1021, 1024)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3440	**Exterior of Gymnasium (1038)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3441	**Exterior of Boys Locker Room (1041)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3442	**Exterior of Shop Room 102 (1056)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3443	**Exterior of Cafeteria 2 (1035)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4241	**Corridor Near Room 216 (2021)**	2043	Bottle Fill Station	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M (Previously Outlet 3035)
BRTWD-4242	**New Construction Corridor Near Room 246**	N/A	Water Cooler	Applicable	**10/23/2025**	**<1.0**			Result Below Action Level, Continue O&M (Previously Outlet 3035)
BRTWD-4243	**New COnstructionCorridor Near Room 246**	N/A	Water Cooler	Applicable	**10/23/2025**	**<1.0**			Result Below Action Level, Continue O&M (Previously Outlet 3035)
BRTWD-4274	**Corridor Near Faculty Bathrooms (New**	N/A	Water Cooler	Applicable	**1/14/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4275	**Corridor Near Faculty Bathrooms (New**	N/A	Bottle Fill Station	Applicable	**1/14/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4295	**Boys Locker Room**	1041	Water Fountain-No Chiller	Applicable	**5/7/2026**	**2.8**			Result Below Action Level, Continue O&M

South Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1800	**Womens Faculty Bathroom (Adjacent to Auditorium)**	1046	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1801	**Womens Faculty Bathroom (Adjacent to Auditorium)**	1046	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1802	**Womens Faculty Bathroom (Adjacent to Auditorium)**	1046	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1803	**Custodial Closet**	1045	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1805	**Mens Faculty Bathroom (Adjacent to Auditorium)**	1044	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1806	**Mens Faculty Bathroom (Adjacent to Auditorium)**	1044	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1809	**Corridor Near Room 123 (1042)**	1047	Water Fountain-No Chiller	Applicable	**6/7/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-1810	**Room 124**	1041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1812	**Guidance Office Storage**	1032A	Bottled Water Dispenser (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1813	**Corridor Near Room 116 (1036)**	1047	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1814	**Boys Bathroom (Across Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1815	**Boys Bathroom (Across Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1816	**Boys Bathroom (Across Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1817	**Boys Bathroom (Across Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1819	**Girls Bathroom (Across Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1820	**Girls Bathroom (Across Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1821	**Girls Bathroom (Across Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1822	**Girls Bathroom (Across Room 109)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1823	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1824	**Room 143**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

South Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1825	**Room 142**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1826	**Room 142**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1827	**Corridor Near Room 146**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1828	**Corridor Near Room 146**	N/A	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1830	**Faculty Room**	1028	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**2.9**			Result Below Action Level, Continue O&M
BRTWD-1832	**Corridor Near Faculty Room (1028)**	1029	Water Fountain-No Chiller	Applicable	**6/7/2025**	**1.9**			Result Below Action Level, Continue O&M
BRTWD-1834	**Nurse's Office**	1025	Nurse's Office Sink	Applicable	**6/7/2025**	**8.8**	9/4/2026	30.4	Removed From Service, Pending Remediation
BRTWD-1835	**Nurse's Office Bathroom**	1025B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1838	**Corridor Near Girls Locker Room (1022)**	1029	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1839	**Corridor Near Girls Locker Room (1022)**	1029	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1840	**Girls Locker Room Bathroom**	1022B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1841	**Girls Locker Room Bathroom**	1022B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1842	**Girls Locker Room**	1022	Water Fountain-No Chiller	Applicable	**6/7/2025**	**4.4**			Result Below Action Level, Continue O&M
BRTWD-1846	**Kitchen**	1021	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**1.7**			Result Below Action Level, Continue O&M
BRTWD-1848	**Kitchen**	1021	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1849	**Kitchen**	1021	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1850	**Kitchen**	1021	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1853	**Kitchen Locker Room**	1021A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1855	**Custodial Office Bathroom**	1015A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1856	**Weight Room**	1014	Water Fountain-No Chiller	Applicable	**6/7/2025**	**3.5**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

South Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1857	**Weight Room Bathroom**	1014E	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1858	**Weight Room Bathroom**	1014E	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1860	**Corridor Near Room 110 (1011)**	1029	Water Fountain-No Chiller	Applicable	**6/7/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-1864	**Womens Bathroom (Across Room 104)**	1006	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1865	**Womens Bathroom (Across Room 104)**	1006	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1866	**Womens Bathroom (Across Room 104)**	1006	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1867	**Custodial Closet**	1005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1873	**Corridor Near Room 104 (1004)**	1029	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1874	**Mens Faculty Bathroom (Across Room 104)**	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1875	**Mens Faculty Bathroom (Across Room 104)**	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1876	**Mens Faculty Bathroom (Across Room 104)**	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1877	**Technology Lab Room 102**	1000	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1878	**Technology Lab Room 102**	1000	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1879	**Shop Room 101**	1001	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1880	**Shop Room 101**	1001	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1881	**Mens Faculty Bathroom (Across Room 202)**	2040	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1882	**Mens Faculty Bathroom (Across Room 202)**	2040	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1883	**Corridor Near Room 202 (2038)**	2042	Water Fountain-No Chiller	Applicable	**6/7/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-1884	**Custodial Closet**	2039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1885	**Art Room 202**	2038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

South Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1886	**Art Room 202**	2038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1889	**Womens Faculty Bathroom (Across Room 202)**	2037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1890	**Art Room 204**	2036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1891	**Art Room 204**	2036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1895	**Corridor Near Stairwell (2029)**	2042	Water Fountain-No Chiller	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1896	**Library Work Room**	2021A	Office Faucet	Applicable	**6/7/2025**	**8.8**	5/7/2026	6.0	Removed From Service, Pending Remediation
BRTWD-1897	**Corridor Near Room 216 (2020)**	2042	Water Cooler	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlets 4278/4279
BRTWD-1898	**Corridor Near Room 216 (2020)**	2042	Bottle Fill Station	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlets 4278/4279
BRTWD-1899	**Boys Bathroom (Across Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1900	**Boys Bathroom (Across Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1901	**Boys Bathroom (Across Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1902	**Boys Bathroom (Across Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1903	**Corridor Near Bathrooms**	N/A	Water Cooler	RFI	**6/7/2025**	**OOS**			Replaced by Outlet 4284
BRTWD-1904	**Corridor Near Bathrooms**	N/A	Water Cooler	RFI	**6/7/2025**	**<1.00 ND**			Replaced by Outlet 4285
BRTWD-1905	**Girls Bathroom (Across Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1906	**Girls Bathroom (Across Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1907	**Girls Bathroom (Across Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1908	**Girls Bathroom (Across Room 207)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1909	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1910	**Corridor Near Room 248**	N/A	Water Cooler	RFI	**6/7/2025**	**OOS**			Replaced by Outlet 4286

OOS= Out of Service **RFI = Removed from Inventory**

South Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1911	**Corridor Near Room 248**	N/A	Water Cooler	RFI	**6/7/2025**	**OOS**			Replaced by Outlet 4287
BRTWD-1912	**Corridor Near Room 218 (2016)**	2025	Water Fountain-No Chiller	Applicable	**6/7/2025**	**2.6**			Result Below Action Level, Continue O&M
BRTWD-1920	**Mens Faculty Bathroom (Across Room 228)**	2005	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1921	**Mens Faculty Bathroom (Across Room 228)**	2005	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1922	**Mens Faculty Bathroom (Across Room 228)**	2005	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1923	**Custodial Closet**	2004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1924	**Womens Faculty Bathroom (Across Room 228)**	2003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1925	**Womens Faculty Bathroom (Across Room 228)**	2003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1926	**Womens Faculty Bathroom (Across Room 228)**	2003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1927	**Exterior of Main Office (1031)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1928	**Exterior of Bathrooms (1044/1046)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1930	**Exterior of Room 116 (1036)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1931	**Exterior of New Construction Bathrooms**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3002	**Room 123 Life Skills**	1042	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**3.2**			Result Below Action Level, Continue O&M
BRTWD-3012	**Weight Room Office Bathroom**	1014A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3022	**Auditorium Lobby**	1050	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3023	**Auditorium Lobby**	1050	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3024	**Corridor Near Room 226 (2008)**	2025	Water Cooler	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3025	**Corridor Near Room 226 (2008)**	2025	Bottle Fill Station	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3026	**Corridor Near Cafeteria A (1020)**	1029	Water Cooler	RFI	**6/7/2025**	**OOS**			Replaced by Outlet 4246

OOS= Out of Service **RFI = Removed from Inventory**

South Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3027	**Corridor Near Cafeteria A (1020)**	1029	Bottle Fill Station	RFI	**6/7/2025**	**OOS**			Replaced by Outlet 4247
BRTWD-3829	**Faculty Men's Bathroom**	1044	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3830	**Room 124**	1041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3831	**Student Management Office Conference Room**	1032A	Bottled Water Dispenser (Hot)	Applicable	**6/7/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-3832	**Boy's Bathroom (across Room 109)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3833	**Corridor (near Bathrooms)**	N/A	Water Fountain-No Chiller	Applicable	**6/7/2025**	**1.7**			Result Below Action Level, Continue O&M
BRTWD-3834	**Girl's Bathroom (across Rom 109)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3835	**Faculty Lounge Women's Bathroom**	1028B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3836	**Faculty Lounge Women's Bathroom**	1028B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3837	**Faculty Lounge Men's Bathroom**	1028A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3838	**Faculty Lounge Men's Bathroom**	1028A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3839	**Boys Bathroom (near Cafeteria)**	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3840	**Boys Bathroom (near Cafeteria)**	1027	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3841	**Nurses Office**	1025	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3842	**Girls Bathroom (near Cafeteria)**	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3843	**Girls Bathroom (near Cafeteria)**	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3844	**Girls Bathroom (near Cafeteria)**	1026	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3845	**Kitchen**	1021	Kitchen Faucet (Cold)	Applicable	**6/7/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-3846	**Kitchen**	1021	Hand Wash Only	Applicable	**6/7/2025**	**9.6**	12/23/2025	2.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3847	**Kitchen**	1021	Pasta Pot/Steam Kettle	Applicable	**6/7/2025**	**2.8**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

South Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3848	**Kitchen Can Wash**	1021C	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3849	**Kitchen Can Wash**	1021C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3850	**Room 106**	1007	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-3851	**Room 106**	1007	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3852	**Room 106**	1007	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3853	**Room 104**	1004	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**4.0**			Result Below Action Level, Continue O&M
BRTWD-3854	**Room 104**	1004	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-3855	**Room 104**	1004	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3856	**Room 104**	1004	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-3857	**Room 104 Closet**	1004A	Home Economics Faucet (Cold)	Applicable	**6/7/2025**	**2.3**			Result Below Action Level, Continue O&M
BRTWD-3858	**Technology Lab Room 102**	1000	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3859	**Shop Room 101**	1001	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3860	**Faculty Women's Bathroom**	2037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3861	**Faculty Women's Bathroom**	2037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3862	**Room 210**	2030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3863	**Room 210**	2030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3864	**Room 210**	2030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3865	**Boys Bathroom (across Room 207)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3866	**Girls Bathroom (across Room 207)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3867	**Room 226**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

South Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3868	**Room 226**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3869	**Room 226**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3870	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3871	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3872	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3873	**Girls Locker Room Office Bathroom**	1022A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3874	**Exterior of Bathrooms (1048/1049)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3875	**Exterior of Girls Locker Room (1022)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3876	**Exterior of Weight Room (1014)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3877	**Exterior of Room 104 (1004)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3878	**Exterior of Room 102/101 (1000/1001)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3879	**Exterior of Bathrooms (1003/1006)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3880	**Exterior of Receiving Room 109 (1015)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3881	**Exterior of Kitchen (1021)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4246	**Corridor Near Cafeteria A (1020)**	1029	Bottle Fill Station	Applicable	**10/2/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4247	**Corridor Near Cafeteria A (1020)**	1029	Water Cooler	Applicable	**10/2/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4278	**Corridor Near Room 216 (2020)**	2042	Bottle Fill Station	Applicable	**2/11/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4279	**Corridor Near Room 216 (2020)**	2042	Water Cooler	Applicable	**2/11/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4284	**2nd Floor New Wing by Gang Bathrooms**	N/A	Water Cooler	Applicable	**3/3/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4285	**2nd Floor New Wing by Gang Bathrooms**	N/A	Water Cooler	Applicable	**3/3/2026**	**<1.0**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

South Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4286	**2nd Floor New Wing by Room 248**	N/A	Water Cooler	Applicable	**3/3/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4287	**2nd Floor New Wing by Room 248**	N/A	Water Cooler	Applicable	**3/3/2026**	**<1.0**			Result Below Action Level, Continue O&M

West Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1938	**Auditorium Lobby Mens Bathroom**	1000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1939	**Auditorium Lobby Mens Bathroom**	1000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1940	**Auditorium Lobby Womens Bathroom**	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1941	**Auditorium Lobby Womens Bathroom**	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1942	**Corridor Near Auditorium**	1002	Water Fountain-No Chiller	Applicable	**6/10/2025**	**11.3**			Removed From Service, Pending Remediation
BRTWD-1943	**Custodial Closet**	1012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1944	**Room 123**	1015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1945	**Room 123**	1015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1946	**Room 123**	1015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1948	**Old Boys Bathroom/Storage**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1949	**Old Boys Bathroom/Storage**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1950	**Room 124**	1016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1951	**Room 124**	1016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1952	**Room 124**	1016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1953	**Room 121**	1017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1954	**Room 122**	1018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1957	**Boys Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1958	**Boys Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1959	**Boys Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1960	**Boys Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

West Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1963	**Girls Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1964	**Girls Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1965	**Girls Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1966	**Girls Bathroom (Near Room 143)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1967	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1968	**Room 143**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1969	**Room 142**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1970	**Corridor Near Room 148**	N/A	Water Cooler	RFI	**6/10/2025**	**OOS**			Replaced by Outlet 4123
BRTWD-1971	**Corridor Near Room 148**	N/A	Water Cooler	RFI	**6/10/2025**	**OOS**			Replaced by Outlet 4124
BRTWD-1973	**Faculty Room**	1027	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1975	**Corridor Near Faculty Room (1027)**	1050	Water Fountain-No Chiller	Applicable	**6/10/2025**	**5.1**			Removed From Service, Pending Remediation
BRTWD-1977	**Nurse's Office**	1029	Nurse's Office Sink	Applicable	**6/10/2025**	**2.2**			Result Below Action Level, Continue O&M
BRTWD-1978	**Nurse's Office - Inner Office**	1029C	Nurse's Office Sink	Applicable	**6/10/2025**	**19.0**	12/30/2025	36.3	Removed From Service, Pending Remediation
BRTWD-1979	**Nurse's Bathroom**	1029A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1982	**Corridor Near Girls Locker Room (1030)**	1050	Water Fountain-No Chiller	Applicable	**6/10/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-1983	**Girls Locker Room Bathroom**	1035B3	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1984	**Girls Locker Room Bathroom**	1035B3	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1985	**Girls Locker Room**	1035B	Water Fountain-No Chiller	RFI	**6/10/2025**	**1.1**			Replaced by Outlet 4323
BRTWD-1986	**Girls Coach's Office Bathroom**	1035B1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1987	**Kitchen**	1033	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**6.2**	12/30/2025	15.9	Removed From Service, Pending Remediation

OOS= Out of Service **RFI = Removed from Inventory**

West Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-1988	**Kitchen**	1033	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1989	**Kitchen**	1033	Hand Wash Only	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1990	**Kitchen**	1033	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1991	**Kitchen**	1033	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1992	**Kitchen**	1033	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1994	**Kitchen**	1033	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-1995	**Kitchen**	1033	Hand Wash Only	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-1996	**Kitchen Can Wash Room**	1033C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1997	**Kitchen Bathroom**	1033B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-1999	**Custodial Office Bathroom**	1036A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2000	**Boys Locker Room**	1035A	Water Fountain-No Chiller	Applicable	**6/10/2025**	**2.5**			Result Below Action Level, Continue O&M
BRTWD-2001	**Boys Locker Room Bathroom**	1035A3	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2002	**Boys Locker Room Bathroom**	1035A3	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2003	**Boys Coach's Office Bathroom**	1035A4A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2004	**Corridor Near Room 110 (1039)**	1050	Water Fountain-No Chiller	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2008	**Girls Bathroom (Near Room 101)**	1044	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2009	**Girls Bathroom (Near Room 101)**	1044	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2010	**Girls Bathroom (Near Room 101)**	1044	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2011	**Custodial Closet**	1045	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2017	**Corridor Near Room 104 (1047)**	1050	Water Fountain-No Chiller	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

West Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2018	**Boys Bathroom (Near Room 101)**	1046	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2019	**Boys Bathroom (Near Room 101)**	1046	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2020	**Boys Bathroom (Near Room 101)**	1046	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2021	**Room 102 Technology**	1048	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2022	**Room 102 Technology**	1048	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2023	**Room 101 Technology**	1049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2024	**Room 101 Technology**	1049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2025	**Room 101 Technology**	1049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2027	**Mens Bathroom (Across Room 202)**	2040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2028	**Corridor Near Room 202 (2041)**	2043	Water Fountain-No Chiller	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2029	**Custodial Closet**	2039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2030	**Art Room 202**	2041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2031	**Art Room 202**	2041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2032	**Womens Bathroom (Across Room 202)**	2038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2033	**Womens Bathroom (Across Room 202)**	2038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2034	**Art Room 204**	2037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2035	**Art Room 204**	2037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2039	**Corridor Near Room 210 (2031)**	2043	Water Fountain-No Chiller	Applicable	**6/10/2025**	**99.7**			Removed From Service, Pending Remediation
BRTWD-2040	**Library Work Room**	2022A	Office Faucet	Applicable	**6/10/2025**	**3.3**			Result Below Action Level, Continue O&M
BRTWD-2042	**Corridor Near Room 220 (2016)**	2019	Water Fountain-No Chiller	Applicable	**6/10/2025**	**14.5**			Removed From Service, Pending Remediation

OOS= Out of Service **RFI = Removed from Inventory**

West Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2043	**Room 226**	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2044	**Room 223**	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2050	**Boys Bathroom (Across Room 230)**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2051	**Boys Bathroom (Across Room 230)**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2052	**Custodial Closet**	2004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2053	**Girls Bathroom (Across Room 230)**	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2054	**Girls Bathroom (Across Room 230)**	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2055	**Girls Bathroom (Across Room 230)**	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2056	**Mens Faculty Bathroom (Near Room 243)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2057	**Mens Faculty Bathroom (Near Room 243)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2058	**Mens Faculty Bathroom (Near Room 243)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2059	**Mens Faculty Bathroom (Near Room 243)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2060	**Corridor Near Bathrooms**	N/A	Water Cooler	RFI	**6/10/2025**	**OOS**			Replaced by Outlet 4125
BRTWD-2061	**Corridor Near Bathrooms**	N/A	Water Cooler	RFI	**6/10/2025**	**OOS**			Replaced by Outlet 4126
BRTWD-2062	**Womens Faculty Bathroom (Near Room 243)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2063	**Womens Faculty Bathroom (Near Room 243)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2064	**Womens Faculty Bathroom (Near Room 243)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2065	**Womens Faculty Bathroom (Near Room 243)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2066	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2069	**Exterior of Main Office (1024)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

West Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2070	**Exterior of Storage Bathrooms (1011/1013)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2072	**Exterior of Student Mgmt Office 116**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2073	**Exterior of New Construction Bathrooms**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2075	**Exterior of Boys Locker Room (1035A)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2078	**Exterior of Room 101 (1049)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2082	**Wrestling Room Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2083	**Basement Corridor**	0001	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2084	**Boiler Room**	0003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3001	**Mens Bathroom (Across Room 202)**	2040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3008	**Corridor Near Student Management Office (1023)**	1026	Bottle Fill Station	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3009	**Corridor Near Room 124 (1016)**	1026	Bottle Fill Station	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3010	**Corridor Near Room 124 (1016)**	1026	Water Cooler	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3038	**Corridor Near Cafeteria (1034)**	1050	Water Cooler	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3039	**Corridor Near Cafeteria (1034)**	1050	Bottle Fill Station	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3040	**Corridor Near Room 216 (2021)**	2043	Bottle Fill Station	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3041	**Corridor Near Room 228 (2008)**	2019	Water Cooler	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3042	**Corridor Near Room 228 (2008)**	2019	Bottle Fill Station	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3087	**Corridor Near Bathrooms**	N/A	Water Cooler	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3088	**Corridor Near Bathrooms**	N/A	Bottle Fill Station	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3097	**Corridor Near Room 248**	N/A	Water Cooler	Applicable	**6/10/2025**	**OOS**	2/18/2026	<1.0	Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

West Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3098	**Corridor Near Room 248**	N/A	Water Cooler	Applicable	**6/10/2025**	**OOS**	2/18/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-3099	**Wrestling Room**	N/A	Water Cooler	RFI	**6/10/2025**	**OOS**	2/18/2026	<1.0	Replaced by Outlets 4302/4303
BRTWD-3498	**Kitchen**	1033	Pasta Pot/Steam Kettle	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3499	**Auditorium Lobby Women's Bathroom**	1001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3500	**Room 124**	1016	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3501	**Boy's Bathroom (Near Room 143)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3502	**Girl's Bathroom (Near Room 143)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3503	**Faculty Lounge Women's Bathroom**	1027B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3504	**Faculty Lounge Men's Bathroom**	1027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3505	**Faculty Lounge Men's Bathroom**	1027A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3506	**Boys Bathroom (Outside Faculty Lounge)**	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3507	**Boys Bathroom (Outside Faculty Lounge)**	1028	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3508	**Girls Bathroom (Outside Faculty Lounge)**	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3509	**Girls Bathroom (Outside Faculty Lounge)**	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3510	**Girls Bathroom (Outside Faculty Lounge)**	1030	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3511	**Room 106**	1043	Home Economics Faucet (Cold)	Applicable	**6/10/2025**	**3.8**			Result Below Action Level, Continue O&M
BRTWD-3512	**Room 106**	1043	Home Economics Faucet (Cold)	Applicable	**6/10/2025**	**5.2**	12/30/2025	1.3	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3513	**Room 106**	1043	Home Economics Faucet (Cold)	Applicable	**6/10/2025**	**6.3**	12/30/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3514	**Custodial Closet**	1045	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3515	**Room 104**	1047	Home Economics Faucet (Cold)	Applicable	**6/10/2025**	**19.8**	12/30/2025	1.2	Outlet Remediated Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

West Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3516	**Room 104**	1047	Home Economics Faucet (Cold)	Applicable	**6/10/2025**	**52.8**	12/30/2025	2.3	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3517	**Room 104**	1047	Home Economics Faucet (Cold)	Applicable	**6/10/2025**	**28.5**	12/30/2025	1.1	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3518	**Room 104**	1047	Home Economics Faucet (Cold)	Applicable	**6/10/2025**	**12.4**	12/30/2025	2.6	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3519	**Room 104 Laundry Room**	1047A	Home Economics Faucet (Cold)	Applicable	**6/10/2025**	**7.4**	12/30/2025	3.6	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3520	**Room 102**	1048	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3521	**Room 101**	1049	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3522	**Women's Bathroom (Across Room 202)**	2038	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3523	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3524	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3525	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3526	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3527	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3528	**Room 210**	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3529	**Room 214 Life Skills**	2023	Home Economics Faucet (Cold)	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3530	**Women's Bathroom (Near Room 243)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3531	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3532	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3533	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3534	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3535	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

West Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3536	**Room 228**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3537	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3538	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3539	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3540	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3541	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3542	**Room 225**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3543	**Boy's Bathroom (Across Room 230)**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3544	**Men's Bathroom (Near Room 243)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3545	**Auditorium Lobby Men's Bathroom**	1000	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3546	**Exterior of Auditorium Lobby Bathrooms (1000/1001)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3547	**Exterior of Girls Locker Room (1035B)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3548	**Exterior of Room 104 (1047)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3549	**Exterior of Room 102 (1048)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3550	**Exterior of Bathrooms (1044/1046)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3551	**Exterior of Custodial Office (1036)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4123	**Corridor Near Room 148**	N/A	Water Cooler	Applicable	**8/27/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4124	**Corridor Near Room 148**	N/A	Water Cooler	Applicable	**8/26/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4125	**Corridor Near Room 243**	N/A	Water Cooler	Applicable	**8/26/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4126	**Corridor Near Room 243**	N/A	Water Cooler	Applicable	**8/26/2025**	**<1.0**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

West Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4291	**Corridor 101 to Main Lobby**	1050	Bottle Fill Station	Applicable	**3/26/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4292	**Corridor 101 to Main Lobby**	1050	Water Cooler	Applicable	**3/26/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4302	**Wrestling Room**	1052	Bottle Fill Station	Applicable	**8/4/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4303	**Wrestling Room**	1052	Water Cooler	Applicable	**8/4/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4323	**Girls Locker Room**	1035B	Water Fountain-No Chiller	Applicable	**8/19/2026**	**12.6**	9/4/2026	2.5	Outlet Remediated Result Below Action Level, Continue O&M

Pine Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2085	**Room 33**	2000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2086	**Room 33**	2000	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2087	**Room 33 Bathroom**	2000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2088	**Faculty Room Bathroom**	2001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2089	**Room 35**	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2090	**Room35**	2002	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2091	**Room 35 Bathroom**	2002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2092	**Room 36Room 36**	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2093	**Room 36**	2003	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2094	**Room 36 Bathroom**	2003A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2095	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2096	**Room 34**	2004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2097	**Room 34**	2004	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2098	**Room 34 Bathroom**	2004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2099	**Room 32**	2005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2100	**Room 32**	2005	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2101	**Room 32 Bathroom**	2005A	Bathroom Faucet	Non-Applicable	**6/6/2025**	**5.9**			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
BRTWD-2102	**Room 1**	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2103	**Room 1**	1001	Water Fountain-No Chiller	Applicable	**6/6/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2105	**Room 2**	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Pine Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2106	**Room 2**	1003	Water Fountain-No Chiller	Applicable	**6/6/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2108	**Room 3**	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2109	**Room 3**	1004	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2110	**Room 4**	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2111	**Room 4**	1005	Water Fountain-No Chiller	Applicable	**6/6/2025**	**3.0**			Result Below Action Level, Continue O&M
BRTWD-2112	**Room 5**	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2113	**Room 5**	1006	Water Fountain-No Chiller	Applicable	**6/6/2025**	**2.2**			Result Below Action Level, Continue O&M
BRTWD-2114	**Room 6**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2115	**Room 6**	1007	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2116	**Room 7**	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2120	**Room 9**	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2121	**Room 9**	1010	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2122	**Room 10**	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2123	**Room 10**	1011	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2124	**Room 11**	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2125	**Room 11**	1012	Water Fountain-No Chiller	Applicable	**6/6/2025**	**7.0**	8/19/2026	2.5	Result Below Action Level, Continue O&M
BRTWD-2126	**Room 12**	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2128	**Room 13**	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2129	**Room 13**	1014	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2130	**Room 14**	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Pine Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2131	**Room 14**	1015	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2132	**Room 15**	1016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2133	**Room 15**	1016	Water Fountain-No Chiller	Applicable	**6/6/2025**	**11.2**			Removed From Service, Pending Remediation
BRTWD-2134	**Gender Neutral Faculty Bathroom 1**	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2136	**Gender Neutral Faculty Bathroom 2**	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2137	**Rear Psychologist Office**	1024B	Office Faucet	Applicable	**6/6/2025**	**2.0**			Result Below Action Level, Continue O&M
BRTWD-2138	**Nurse's Office Bathroom**	1025A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2139	**Nurse's Office**	1025	Nurse's Office Sink	Applicable	**6/6/2025**	**3.9**			Result Below Action Level, Continue O&M
BRTWD-2140	**Custodial Closet A**	1027	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2141	**Faculty Room**	1033	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2144	**Kitchen**	1036	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**19.5**	12/30/2025	1.2	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2145	**Kitchen**	1036	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-2146	**Kitchen**	1036	Hand Wash Only	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2148	**Kitchen**	1036	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2149	**Kitchen**	1036	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2150	**Kitchen**	1036	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**4.9**			Result Below Action Level, Continue O&M
BRTWD-2151	**Kitchen**	1036	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**2.9**			Result Below Action Level, Continue O&M
BRTWD-2152	**Kitchen**	1036	Hand Wash Only	Applicable	**6/6/2025**	**12.7**	12/23/2025	4.3	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2153	**Kitchen Bathroom**	1036A3	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2154	**Kitchen Can Wash Room**	1036A2	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Pine Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2155	**Girls Bathroom**	1040	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2156	**Girls Bathroom**	1040	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2157	**Girls Bathroom**	1040	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2158	**Custodial Closet B**	1041	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2159	**Boys Bathroom**	1043	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2160	**Boys Bathroom**	1043	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2161	**Boys Bathroom**	1043	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2162	**Room 16**	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2163	**Room 16**	1044	Water Fountain-No Chiller	Applicable	**6/6/2025**	**2.1**			Result Below Action Level, Continue O&M
BRTWD-2164	**Room 17**	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2165	**Room 17**	1045	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-2166	**Room 18**	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2167	**Room 18**	1046	Water Fountain-No Chiller	Applicable	**6/6/2025**	**3.5**			Result Below Action Level, Continue O&M
BRTWD-2168	**Room 19**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2169	**Room 19**	1047	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2170	**Room 20**	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2171	**Room 20**	1048	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2172	**Room 21**	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2173	**Room 21**	1049	Water Fountain-No Chiller	Applicable	**6/6/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2174	**Room 22**	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Pine Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2175	**Room 22**	1050	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2176	**Room 24**	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2177	**Room 24**	1052	Water Fountain-No Chiller	Applicable	**6/6/2025**	**16.3**			Removed From Service, Pending Remediation
BRTWD-2178	**Room 25**	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2179	**Room 25**	1053	Water Fountain-No Chiller	Applicable	**6/6/2025**	**7.4**	9/4/2026	8.4	Removed From Service, Pending Remediation
BRTWD-2180	**Room 27**	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2181	**Room 27**	1055	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-2182	**Room 26**	1054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2183	**Room 26**	1054	Water Fountain-No Chiller	Applicable	**6/6/2025**	**6.2**	2/19/2026	8.3	Removed From Service, Pending Remediation
BRTWD-2186	**Room 28**	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2187	**Room 28**	1056	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2189	**Room 30 Bathroom**	1058	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2192	**Exterior of Main Office (1019)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2195	**Exterior of Room 33A**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2196	**Exterior of Room 36**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2197	**Exterior of Main Office (1019)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2203	**Exterior of Room 26 (1054)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2985	**Main Office Copy Room**	1019A	Bottled Water Dispenser	Applicable	**6/6/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-3047	**Corridor Near Faculty Room (1033)**	1061	Water Cooler	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3048	**Corridor Near Faculty Room (1033)**	1061	Bottle Fill Station	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Pine Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3049	**Corridor Adjacent Gender Neutral Bathroom (1022)**	1061	Water Cooler	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3050	**Corridor Adjacent Gender Neutral Bathroom (1022)**	1061	Bottle Fill Station	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3292	**Room 1 Bathroom**	1001B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3293	**Room 2 Bathroom**	1003A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3294	**Room 7**	1008	Water Fountain-No Chiller	Applicable	**6/6/2025**	**2.0**			Result Below Action Level, Continue O&M
BRTWD-3295	**Room 8**	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3296	**Room 8**	1009	Water Fountain-No Chiller	Applicable	**6/6/2025**	**4.0**			Result Below Action Level, Continue O&M
BRTWD-3297	**Room 12**	1013	Water Fountain-No Chiller	Applicable	**6/6/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-3298	**Nurse's Office**	1025	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3299	**Custodial Closet A**	1027	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3300	**Faculty Room**	1033	Bottled Water Dispenser (Cold)	Applicable	**6/6/2025**	**OOS**	8/19/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-3301	**Faculty Room**	1033	Bottled Water Dispenser (Hot)	Applicable	**6/6/2025**	**OOS**	8/19/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-3302	**Main Office Copy Room**	1019A	Bottled Water Dispenser (Hot)	Applicable	**6/6/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-3303	**Kitchen**	1036	Pasta Pot/Steam Kettle	Applicable	**6/6/2025**	**3.3**			Result Below Action Level, Continue O&M
BRTWD-3304	**Room 29**	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3305	**Room 31 Bathroom**	1059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3306	**Exterior of Kitchen (1036)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3307	**Exterior of Stage (1032B)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3308	**Exterior of Room 5 (1006)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3309	**Exterior of Room 13 (1014)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Pine Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3310	**Exterior of Room 1 (1001)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3311	**Exterior of Room 4 (1005)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3312	**Exterior of Room 10 (1011)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3313	**Exterior of Bathrooms (1040/1043)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3314	**Exterior of Room 28 (1056)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3962	**Room 12**	1013	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

Hemlock Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2204	**Room 2**	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2205	**Room 2**	1001	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2206	**Room 2 Bathroom**	1001C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2207	**Room 1**	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2208	**Room 1**	1000	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2209	**Custodial Closet**	1002	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2210	**Room 3**	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2212	**Room 4**	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2213	**Room 4**	1004	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2214	**Room 4 Bathroom**	1004B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2215	**Room 5**	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2216	**Room 5**	1005	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2217	**Room 6**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2218	**Room 6**	1007	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2219	**Room 6 Bathroom**	1007B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2220	**Room 7**	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2221	**Room 7**	1008	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2224	**Room 9**	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2225	**Room 9**	1010	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2227	**Room 10**	1011	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Hemlock Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2228	**Room 11**	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2229	**Room 11**	1012	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2230	**Room 12**	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2231	**Room 12**	1013	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2232	**Room 13**	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2233	**Room 13**	1014	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2234	**Room 14**	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2235	**Room 14**	1015	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2236	**Room 15**	1016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2237	**Room 15**	1016	Water Fountain-No Chiller	Applicable	**6/5/2025**	**OOS**	1/9/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-2238	**Room 16**	1017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2239	**Room 16**	1017	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2240	**Gender Neutral Bathroom 1**	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2241	**Custodial Closet**	1022	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2242	**Gender Neutral Bathroom 2**	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2243	**Girls Locker Room Toilet**	1024D1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2244	**Nurse's Office**	1025	Nurse's Office Sink	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2246	**Nurse Sick Room**	1025A	Nurse's Office Sink	Applicable	**6/5/2025**	**79.8**	12/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2248	**Faculty Room**	1030	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-2250	**Music Room**	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Hemlock Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2254	**Custodial Closet**	1037	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2258	**Room 18**	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2259	**Room 18**	1040	Water Fountain-No Chiller	Applicable	**6/5/2025**	**34.5**	1/9/2026	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2260	**Room 17**	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2261	**Room 17**	1041	Water Fountain-No Chiller	Applicable	**6/5/2025**	**7.3**	1/9/2026	1.3	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2262	**Room 19**	1043	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2263	**Room 19**	1043	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-2264	**Room 21**	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2266	**Room 24**	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2267	**Room 24**	1045	Water Fountain-No Chiller	Applicable	**6/5/2025**	**7.0**	1/9/2026	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2268	**Room 23**	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2269	**Room 23**	1046	Water Fountain-No Chiller	Applicable	**6/5/2025**	**7.5**	1/9/2026	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2270	**Room 26**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2271	**Room 26**	1047	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.9**			Result Below Action Level, Continue O&M
BRTWD-2272	**Room 25**	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2273	**Room 25**	1048	Water Fountain-No Chiller	Applicable	**6/5/2025**	**4.5**			Result Below Action Level, Continue O&M
BRTWD-2274	**Room 28**	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2275	**Room 28**	1049	Water Fountain-No Chiller	Applicable	**6/5/2025**	**23.5**	1/9/2026	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2276	**Room 27**	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2277	**Room 27**	1050	Water Fountain-No Chiller	Applicable	**6/5/2025**	**4.4**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Hemlock Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2278	**Room 29**	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2279	**Room 29**	1052	Water Fountain-No Chiller	Applicable	**6/5/2025**	**3.1**			Result Below Action Level, Continue O&M
BRTWD-2280	**Room 30**	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2281	**Room 30**	1051	Water Fountain-No Chiller	Applicable	**6/5/2025**	**3.6**			Result Below Action Level, Continue O&M
BRTWD-2282	**Room 31**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2283	**Room 31**	N/A	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2284	**Room 32**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2285	**Room 32**	N/A	Water Fountain-No Chiller	Applicable	**6/5/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-2289	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2291	**Faculty Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2294	**Room 33**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2296	**Room 35**	N/A	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2297	**Room 35**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2298	**Room 34**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2299	**Room 34**	N/A	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2300	**Room 37**	N/A	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2301	**Room 37**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2302	**Room 36**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2303	**Room 36**	N/A	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2304	**Room 39**	N/A	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Hemlock Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2305	**Room 39**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2306	**Room 38**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2307	**Room 38**	N/A	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2308	**Kitchen**	1033	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-2309	**Kitchen**	1033	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**1.8**			Result Below Action Level, Continue O&M
BRTWD-2310	**Kitchen**	1033	Hand Wash Only	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2312	**Kitchen**	1033	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2313	**Kitchen**	1033	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-2314	**Kitchen**	1033	Kitchen Faucet (Cold)	Applicable	**6/5/2025**	**2.6**			Result Below Action Level, Continue O&M
BRTWD-2315	**Kitchen**	1033	Hand Wash Only	Applicable	**6/5/2025**	**4.2**			Result Below Action Level, Continue O&M
BRTWD-2316	**Kitchen Bathroom**	1033A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2317	**Kitchen Can Wash Room**	1033B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2325	**Exterior of Room 35**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2326	**Exterior of Room 36**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2327	**Exterior of Room 28**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2992	**Boys Locker Room**	1029B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3079	**Corridor Near Custodial Office (1034A)**	1054	Water Cooler	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3080	**Corridor Near Custodial Office (1034A)**	1054	Bottle Fill Station	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3081	**Corridor Near Gym (1024)**	1054	Water Cooler	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3082	**Corridor Near Gym (1024)**	1054	Bottle Fill Station	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Hemlock Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3552	**Room 3**	1003	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3553	**Room 8**	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3554	**Room 8**	1009	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3555	**Room 10**	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3556	**Custodial Closet**	1022	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3557	**Nurses Bathroom**	1025B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3558	**Kitchen**	1033	Pasta Pot/Steam Kettle	Applicable	**6/5/2025**	**31.6**	12/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3559	**Room 21**	1044	Water Fountain-No Chiller	Applicable	**6/5/2025**	**3.2**			Result Below Action Level, Continue O&M
BRTWD-3560	**Girls Bathroom (New Construction)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3561	**Girls Bathroom (New Construction)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3562	**Girls Bathroom (New Construction)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3563	**Corridor near Bathrooms**	N/A	Water Cooler	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3564	**Boys Bathroom (New Construction)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3565	**Boys Bathroom (New Construction)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3566	**Room 33**	N/A	Water Fountain-No Chiller	Applicable	**6/5/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3567	**Girls Bathroom (Across Boiler Room)**	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3568	**Girls Bathroom (Across Boiler Room)**	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3569	**Girls Bathroom (Across Boiler Room)**	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3570	**Girls Bathroom (Across Boiler Room)**	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3571	**Men's Bathroom (Across Boiler Room)**	1038	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Hemlock Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3572	**Men's Bathroom (Across Boiler Room)**	1038	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3573	**Men's Bathroom (Across Boiler Room)**	1038	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3574	**Men's Bathroom (Across Boiler Room)**	1038	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3575	**Exterior of Kitchen (1033)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3576	**Exterior of Room 14 (1015)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3577	**Exterior of Room 6 (1007)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3578	**Exterior of Room 1 (1000)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3579	**Exterior of Room 3 (1003)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3580	**Exterior of Bathrooms (1036/1038)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3581	**Exterior of Room 25 (1048)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Loretta Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2328	**Room 5A**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2329	**Room 5A**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2330	**Room 6A**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2331	**Room 6A**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2332	**Room 4A**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2333	**Room 4A**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2334	**Room 3A**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2335	**Room 3A**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2336	**Room 2A**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2337	**Room 2A**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2338	**Room 1A**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2339	**Room 1A**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2341	**Girls Bathroom (Near Room 1)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2342	**Girls Bathroom (Near Room 1)**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2343	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2344	**Corridor Near Faculty Bathroom**	N/A	Water Cooler	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2345	**Faculty Bathroom (Near Room 1)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2349	**Room 1**	1000	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4076
BRTWD-2350	**Room 1 Bathroom**	1000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2352	**Room 2**	1001	Water Fountain-No Chiller	RFI	**6/4/2025**	**9.3**			Replaced by Outlet 4074

OOS= Out of Service **RFI = Removed from Inventory**

Loretta Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2353	**Room 2 Bathroom**	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2359	**Room 5**	1004	Water Fountain-No Chiller	RFI	**6/4/2025**	**10.9**			Replaced by Outlet 4068
BRTWD-2361	**Room 6**	1005	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4066
BRTWD-2363	**Room 7**	1006	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4064
BRTWD-2365	**Room 8**	1007	Water Fountain-No Chiller	RFI	**6/4/2025**	**13.2**			Replaced by Outlet 4062
BRTWD-2367	**Room 9**	1008	Water Fountain-No Chiller	RFI	**6/4/2025**	**4.1**			Replaced by Outlet 4060
BRTWD-2369	**Room 10**	1009	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4058
BRTWD-2371	**Room 11**	1010	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.4**			Replaced by Outlet 4056
BRTWD-2373	**Room 12**	1011	Water Fountain-No Chiller	RFI	**6/4/2025**	**6.5**			Replaced by Outlet 4054
BRTWD-2375	**Room 14**	1013	Water Fountain-No Chiller	RFI	**6/4/2025**	**9.5**			Replaced by Outlet 4052
BRTWD-2376	**Faculty Room**	1014	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**6.6**	12/23/2025	1.3	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2377	**Womens Bathroom (Across Main Office)**	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2379	**Mens Bathroom (Across Main Office)**	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2380	**Nurse's Office**	1022	Nurse's Office Sink	Applicable	**6/4/2025**	**OOS**	12/23/2025	1.6	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2381	**Nurse's Office Bathroom**	1022C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2382	**Custodial Closet**	1024	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2384	**Kitchen**	1035	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**9.4**	12/23/2025	2.4	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2385	**Kitchen**	1035	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**3.2**			Result Below Action Level, Continue O&M
BRTWD-2386	**Kitchen**	1035	Hand Wash Only	Applicable	**6/4/2025**	**OOS**	12/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2388	**Kitchen**	1035	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Loretta Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2389	**Kitchen**	1035	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2390	**Kitchen**	1035	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**2.2**			Result Below Action Level, Continue O&M
BRTWD-2391	**Kitchen**	1035	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**5.9**	12/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2392	**Kitchen**	1035	Hand Wash Only	Applicable	**6/4/2025**	**OOS**	1/7/2026	31.9	Placarded for Non-Drinking Use Until Remediated
BRTWD-2393	**Kitchen Bathroom**	1035A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2394	**Kitchen Can Wash Room**	1035A2	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2398	**Custodial Closet B**	1041	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2403	**Room 16**	1045	Water Fountain-No Chiller	RFI	**6/4/2025**	**4.3**			Replaced by Outlet 4050
BRTWD-2405	**Room 18**	1047	Water Fountain-No Chiller	RFI	**6/4/2025**	**3.4**			Replaced by Outlet 4048
BRTWD-2407	**Room 20**	1048	Water Fountain-No Chiller	RFI	**6/4/2025**	**3.1**			Replaced by Outlet 4046
BRTWD-2413	**Room 23**	1051	Water Fountain-No Chiller	RFI	**6/4/2025**	**3.1**			Replaced by Outlet 4040
BRTWD-2415	**Room 24**	1052	Water Fountain-No Chiller	RFI	**6/4/2025**	**26.3**			Replaced by Outlet 4038
BRTWD-2417	**Room 25**	1053	Water Fountain-No Chiller	RFI	**6/4/2025**	**9.4**			Replaced by Outlet 4036
BRTWD-2419	**Room 26**	1054	Water Fountain-No Chiller	RFI	**6/4/2025**	**5.0**			Replaced by Outlet 4034
BRTWD-2423	**Room 28**	1056	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.5**			Replaced by Outlet 4030
BRTWD-2425	**Room 29**	1057	Water Fountain-No Chiller	RFI	**6/4/2025**	**2.7**			Replaced by Outlet 4028
BRTWD-2429	**Exterior of Room 13 (1012)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2431	**Exterior of Room 5A**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2432	**Exterior of Room 4A**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3063	**Corridor Near Room 17 (1026)**	1038	Water Cooler	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4229

OOS= Out of Service **RFI = Removed from Inventory**

Loretta Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3064	**Corridor Near Room 17 (1026)**	1038	Bottle Fill Station	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4230
BRTWD-3065	**Corridor Near Men's Bathroom (1020)**	1038	Water Cooler	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3066	**Corridor Near Men's Bathroom (1020)**	1038	Bottle Fill Station	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3199	**Girl's Bathroom (near Room 1)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3200	**Boy's Bathroom (near Room 1)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3201	**Boy's Bathroom (near Room 1)**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3202	**Room 3**	1002	Water Fountain-No Chiller	RFI	**6/4/2025**	**7.3**			Replaced by Outlet 4072
BRTWD-3203	**Room 4**	1003	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4070
BRTWD-3204	**Kitchen**	1035	Pasta Pot/Steam Kettle	Applicable	**6/4/2025**	**11.4**	12/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3205	**Girl's Bathroom (across Boiler Room)**	1040	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3206	**Girl's Bathroom (across Boiler Room)**	1040	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3207	**Girl's Bathroom (across Boiler Room)**	1040	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3208	**Boy's Bathroom (across Boiler Room)**	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3209	**Boy's Bathroom (across Boiler Room)**	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3210	**Boy's Bathroom (across Boiler Room)**	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3211	**Room 22**	1050	Water Fountain-No Chiller	RFI	**6/4/2025**	**6.9**			Replaced by Outlet 4042
BRTWD-3212	**Room 27**	1055	Water Fountain-No Chiller	RFI	**6/4/2025**	**30.6**			Replaced by Outlet 4032
BRTWD-3213	**Exterior o/s Custodial Office (1036)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3214	**Exterior o/s Kitchen (1035)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3215	**Exterior o/s Stage (1031)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Loretta Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3216	**Exterior o/s Main Office (1018)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3217	**Exterior o/s Room 5 (1004)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3218	**Exterior o/s Room 1 (1000)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3219	**Exterior o/s Room 4 (1003)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3220	**Exterior o/s Room 12 (1011)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3221	**Exterior o/s Bathrooms (1040/1043)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3222	**Exterior o/s Room 25 (1053)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3223	**Exterior o/s Room 28 (1056)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3224	**Exterior o/s Room 26 (1054)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3961	**Room 21**	1049	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.1**			Replaced by Outlet 4044
BRTWD-4027	**Room 29**	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4028	**Room 29**	1057	Water Fountain-No Chiller	Applicable	**8/20/2025**	**OOS**	5/1/2026	1.7	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4029	**Room 28**	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4030	**Room 28**	1056	Water Fountain-No Chiller	Applicable	**8/20/2025**	**2.8**			Result Below Action Level, Continue O&M
BRTWD-4031	**Room 27**	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4032	**Room 27**	1055	Water Fountain-No Chiller	Applicable	**8/20/2025**	**2.4**			Result Below Action Level, Continue O&M
BRTWD-4033	**Room 26**	1054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4034	**Room 26**	1054	Water Fountain-No Chiller	Applicable	**8/20/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-4035	**Room 25**	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4036	**Room 25**	1053	Water Fountain-No Chiller	Applicable	**8/20/2025**	**1.1**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Loretta Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4037	**Room 24**	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4038	**Room 24**	1052	Water Fountain-No Chiller	Applicable	**8/20/2025**	**2.1**			Result Below Action Level, Continue O&M
BRTWD-4039	**Room 23**	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4040	**Room 23**	1051	Water Fountain-No Chiller	Applicable	**8/20/2025**	**2.0**			Result Below Action Level, Continue O&M
BRTWD-4041	**Room 22**	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4042	**Room 22**	1050	Water Fountain-No Chiller	Applicable	**8/20/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-4043	**Room 21**	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4044	**Room 21**	1049	Water Fountain-No Chiller	Applicable	**8/20/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-4045	**Room 20**	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4046	**Room 20**	1048	Water Fountain-No Chiller	Applicable	**8/20/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-4047	**Room 18**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4048	**Room 18**	1047	Water Fountain-No Chiller	Applicable	**8/20/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-4049	**Room 16**	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4050	**Room 16**	1045	Water Fountain-No Chiller	Applicable	**8/20/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-4051	**Room 14**	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4052	**Room 14**	1013	Water Fountain-No Chiller	Applicable	**8/20/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-4053	**Room 12**	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4054	**Room 12**	1011	Water Fountain-No Chiller	Applicable	**8/20/2025**	**1.7**			Result Below Action Level, Continue O&M
BRTWD-4055	**Room 11**	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4056	**Room 11**	1010	Water Fountain-No Chiller	Applicable	**8/20/2025**	**3.4**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Loretta Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4057	**Room 10**	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4058	**Room 10**	1009	Water Fountain-No Chiller	Applicable	**8/20/2025**	**2.3**			Result Below Action Level, Continue O&M
BRTWD-4059	**Room 9**	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4060	**Room 9**	1008	Water Fountain-No Chiller	Applicable	**8/20/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-4061	**Room 8**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4062	**Room 8**	1007	Water Fountain-No Chiller	Applicable	**8/20/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-4063	**Room 7**	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4064	**Room 7**	1006	Water Fountain-No Chiller	Applicable	**8/20/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-4065	**Room 6**	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4066	**Room 6**	1005	Water Fountain-No Chiller	Applicable	**8/20/2025**	**1.9**			Result Below Action Level, Continue O&M
BRTWD-4067	**Room 5**	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4068	**Room 5**	1004	Water Fountain-No Chiller	Applicable	**8/20/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-4069	**Room 4**	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4070	**Room 4**	1003	Water Fountain-No Chiller	Applicable	**8/20/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-4071	**Room 3**	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4072	**Room 3**	1002	Water Fountain-No Chiller	Applicable	**8/20/2025**	**2.3**			Result Below Action Level, Continue O&M
BRTWD-4073	**Room 2**	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4074	**Room 2**	1001	Water Fountain-No Chiller	Applicable	**8/20/2025**	**3.5**			Result Below Action Level, Continue O&M
BRTWD-4075	**Room 1**	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4076	**Room 1**	1000	Water Fountain-No Chiller	Applicable	**8/20/2025**	**1.4**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Loretta Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4329	**Corridor Main Office To Maintenance**	1038	Bottle Fill Station	Applicable	**10/19/2026**	**<1.0**			
BRTWD-4330	**Corridor Main Office To Maintenance**	1038	Water Cooler	Applicable	**10/19/2026**	**<1.0**			

Laurel Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2441	**Room 1A Bathroom**	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2444	**Room 1**	1003	Water Fountain-No Chiller	RFI	**6/4/2025**	**OOS**			Replaced by Outlet 4002
BRTWD-2445	**Room 1 Bathroom**	1003B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2447	**Room 2**	1004	Water Fountain-No Chiller	RFI	**6/4/2025**	**6.2**			Replaced by Outlet 4000
BRTWD-2448	**Custodial Closet**	1005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2450	**Room 4**	1006	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 3998
BRTWD-2452	**Room 3**	1007	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.9**			Replaced by Outlet 3996
BRTWD-2455	**Room 6**	1008	Water Fountain-No Chiller	RFI	**6/4/2025**	**OOS**			Replaced by Outlet 3994
BRTWD-2457	**Room 5**	1010	Water Fountain-No Chiller	RFI	**6/4/2025**	**3.9**			Replaced by Outlet 3992
BRTWD-2458	**Room 5 Bathroom**	1010B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2460	**Room 8**	1011	Water Fountain-No Chiller	RFI	**6/4/2025**	**4.9**			Replaced by Outlet 3990
BRTWD-2462	**Room 7**	1012	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.7**			Replaced by Outlet 3988
BRTWD-2464	**Room 10**	1013	Water Fountain-No Chiller	RFI	**6/4/2025**	**4.4**			Replaced by Outlet 3986
BRTWD-2466	**Room 9**	1014	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 3984
BRTWD-2468	**Room 12**	1015	Water Fountain-No Chiller	RFI	**6/4/2025**	**3.0**			Replaced by Outlet 3982
BRTWD-2470	**Room 11**	1016	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.1**			Replaced by Outlet 3980
BRTWD-2472	**Room 14**	1017	Water Fountain-No Chiller	RFI	**6/4/2025**	**9.0**			Replaced by Outlet 3978
BRTWD-2474	**Room 13**	1018	Water Fountain-No Chiller	RFI	**6/4/2025**	**3.7**			Replaced by Outlet 3976
BRTWD-2476	**Room 16**	1019	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 3974
BRTWD-2478	**Room 15**	1020	Water Fountain-No Chiller	RFI	**6/4/2025**	**6.9**			Replaced by Outlet 3972

OOS= Out of Service **RFI = Removed from Inventory**

Laurel Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2479	**Mens Bathroom (Near Gym)**	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2480	**Mens Bathroom (Near Gym)**	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2481	**Custodial Closet**	1027	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2482	**Womens Bathroom (Near Gym)**	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2484	**Girls Locker Room Bathroom**	1031C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2485	**Nurse's Office**	1029	Nurse's Office Sink	Applicable	**6/4/2025**	**1.9**			Result Below Action Level, Continue O&M
BRTWD-2486	**Nurse's Office Bathroom**	1029A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2487	**Speech Therapist Office**	1030A	Office Faucet	Applicable	**6/4/2025**	**5.9**	12/23/2025	58.4	Placarded for Non-Drinking Use Until Remediated
BRTWD-2489	**Faculty Room**	1035	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2490	**Faculty Room**	1035	Bottled Water Dispenser	Applicable	**6/4/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2493	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**4.6**			Result Below Action Level, Continue O&M
BRTWD-2494	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-2496	**Kitchen**	1038	Hand Wash Only	Applicable	**6/4/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-2497	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2498	**Kitchen**	1038	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2499	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2500	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/4/2025**	**1.7**			Result Below Action Level, Continue O&M
BRTWD-2501	**Kitchen**	1038	Hand Wash Only	Applicable	**6/4/2025**	**15.3**	2/18/2026	23.2	Placarded for Non-Drinking Use Until Remediated
BRTWD-2502	**Kitchen Bathroom**	1038A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2503	**Kitchen Can Wash Room**	1038A2	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Laurel Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2504	**Room 20**	1041	Classroom Faucet	RFI					Replaced by Outlet 4270
BRTWD-2505	**Room 20**	1041	Water Fountain-No Chiller	RFI	**6/4/2025**	**8.7**			Replaced by Outlet 4271
BRTWD-2506	**Womens Bathroom (Across Boiler Room)**	1042	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2509	**Custodial Closet**	1043	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2514	**Room 17**	1047	Water Fountain-No Chiller	RFI	**6/4/2025**	**6.2**			Replaced by Outlet 4004
BRTWD-2516	**Room 19**	1048	Water Fountain-No Chiller	RFI	**6/4/2025**	**17.3**			Replaced by Outlet 4006
BRTWD-2518	**Room 22**	1049	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.8**			Replaced by Outlet 4008
BRTWD-2520	**Room 24**	1051	Water Fountain-No Chiller	RFI	**6/4/2025**	**3.8**			Replaced by Outlet 4012
BRTWD-2522	**Room 23**	1052	Water Fountain-No Chiller	RFI	**6/4/2025**	**3.5**			Replaced by Outlet 4014
BRTWD-2524	**Room 26**	1053	Water Fountain-No Chiller	RFI	**6/4/2025**	**3.0**			Replaced by Outlet 4016
BRTWD-2526	**Room 25**	1054	Water Fountain-No Chiller	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4018
BRTWD-2528	**Room 28**	1055	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.5**			Replaced by Outlet 4020
BRTWD-2530	**Room 27**	1056	Water Fountain-No Chiller	RFI	**6/4/2025**	**1.5**			Replaced by Outlet 4022
BRTWD-2532	**Room 30**	1057	Water Fountain-No Chiller	RFI	**6/4/2025**	**15.1**			Replaced by Outlet 4026
BRTWD-2534	**Room 29**	1058	Water Fountain-No Chiller	RFI	**6/4/2025**	**6.2**			Replaced by Outlet 4024
BRTWD-2536	**Room 31**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2537	**Room 34**	N/A	Water Fountain-No Chiller	Applicable	**6/4/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2538	**Room 34**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2987	**Stage Boys Locker Room Bathroom**	1034A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3059	**Corridor Near Kitchen (1038)**	1040	Water Cooler	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4309

OOS= Out of Service **RFI = Removed from Inventory**

Laurel Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3060	**Corridor Near Kitchen (1038)**	1040	Bottle Fill Station	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4308
BRTWD-3061	**Corridor Near Gymnasium (1031B)**	1040	Water Cooler	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4326
BRTWD-3062	**Corridor Near Gymnasium (1031B)**	1040	Bottle Fill Station	RFI	**6/4/2025**	**<1.00 ND**			Replaced by Outlet 4327
BRTWD-3179	**Room 2A Bathroom**	1002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3180	**Room 3 Bathroom**	1007B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3181	**Custodial Closet**	1027	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3182	**Women's Bathroom (near Gym)**	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3183	**Kitchen**	1038	Pasta Pot/Steam Kettle	Applicable	**6/4/2025**	**7.9**	12/23/2025	2.8	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3184	**Women's Bathroom (across Boiler Room)**	1042	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3185	**Women's Bathroom (across Boiler Room)**	1042	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3186	**Men's Bathroom (across Boiler Room)**	1045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3187	**Men's Bathroom (across Boiler Room)**	1045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3188	**Men's Bathroom (across Boiler Room)**	1045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3189	**Room 31**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3190	**Exterior o/s Kitchen (1038)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3191	**Exterior o/s Room 13 (1018)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3192	**Exterior o/s Room 5 (1010)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3193	**Exterior o/s Room 4 (1006)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3194	**Exterior o/s Room 10 (1013)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3195	**Exterior o/s Bathrooms (1042/1045)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Laurel Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3196	**Exterior o/s Room 25 (1054)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3197	**Exterior o/s Room 28 (1055)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3198	**Exterior o/s Library (1046)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3971	**Room 15**	1020	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3972	**Room 15**	1020	Water Fountain-No Chiller	Applicable	**8/20/2025**	**3.5**			Result Below Action Level, Continue O&M
BRTWD-3973	**Room 16**	1019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3974	**Room 16**	1019	Water Fountain-No Chiller	Applicable	**8/20/2025**	**4.0**			Result Below Action Level, Continue O&M
BRTWD-3975	**Room 13**	1018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3976	**Room 13**	1018	Water Fountain-No Chiller	Applicable	**8/20/2025**	**2.6**			Result Below Action Level, Continue O&M
BRTWD-3977	**Room 14**	1017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3978	**Room 14**	1017	Water Fountain-No Chiller	Applicable	**8/20/2025**	**4.2**			Result Below Action Level, Continue O&M
BRTWD-3979	**Room 11**	1016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3980	**Room 11**	1016	Water Fountain-No Chiller	Applicable	**8/20/2025**	**4.4**			Result Below Action Level, Continue O&M
BRTWD-3981	**Room 12**	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3982	**Room 12**	1015	Water Fountain-No Chiller	Applicable	**8/20/2025**	**3.9**			Result Below Action Level, Continue O&M
BRTWD-3983	**Room 9**	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3984	**Room 9**	1014	Water Fountain-No Chiller	Applicable	**8/20/2025**	**4.4**			Result Below Action Level, Continue O&M
BRTWD-3985	**Room 10**	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3986	**Room 10**	1013	Water Fountain-No Chiller	Applicable	**8/20/2025**	**6.9**	8/29/2025	2.6	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3987	**Room 7**	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Laurel Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3988	**Room 7**	1012	Water Fountain-No Chiller	Applicable	**8/20/2025**	**5.3**	8/29/2025	1.5	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3989	**Room 8**	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3990	**Room 8**	1011	Water Fountain-No Chiller	Applicable	**8/20/2025**	**3.9**			Result Below Action Level, Continue O&M
BRTWD-3991	**Room 5**	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3992	**Room 5**	1010	Water Fountain-No Chiller	Applicable	**8/20/2025**	**5.9**	8/29/2025	1.8	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3993	**Room 6**	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3994	**Room 6**	1008	Water Fountain-No Chiller	Applicable	**8/20/2025**	**5.9**	8/29/2025	2.6	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3995	**Room 3**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3996	**Room 3**	1007	Water Fountain-No Chiller	Applicable	**8/20/2025**	**13.7**	8/29/2025	2.8	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3997	**Room 4**	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3998	**Room 4**	1006	Water Fountain-No Chiller	Applicable	**8/20/2025**	**4.1**			Result Below Action Level, Continue O&M
BRTWD-3999	**Kindergarten Room 2**	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4000	**Kindergarten Room 2**	1004	Water Fountain-No Chiller	Applicable	**8/20/2025**	**18.8**	9/17/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4001	**Kindergarten Room 1**	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4002	**Kindergarten Room 1**	1003	Water Fountain-No Chiller	Applicable	**8/20/2025**	**5.1**	8/29/2025	2.5	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4003	**Room 17**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4004	**Room 17**	1047	Water Fountain-No Chiller	Applicable	**8/20/2025**	**15.9**	8/29/2025	3.2	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4005	**Room 19**	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4006	**Room 19**	1048	Water Fountain-No Chiller	Applicable	**8/20/2025**	**9.0**	8/29/2025	2.3	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4007	**Room 22**	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Laurel Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4008	**Room 22**	1049	Water Fountain-No Chiller	Applicable	**8/20/2025**	**6.6**	9/17/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4009	**Computer Lab Room 21**	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4010	**Computer Lab Room 21**	1050	Water Fountain-No Chiller	Applicable	**8/20/2025**	**7.9**	8/29/2025	4.5	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4011	**Room 24**	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4012	**Room 24**	1051	Water Fountain-No Chiller	Applicable	**8/20/2025**	**9.4**	9/17/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4013	**Room 23**	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4014	**Room 23**	1052	Water Fountain-No Chiller	Applicable	**8/20/2025**	**4.7**			Result Below Action Level, Continue O&M
BRTWD-4015	**Room 26**	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4016	**Room 26**	1053	Water Fountain-No Chiller	Applicable	**8/20/2025**	**35.9**	10/23/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4017	**Room 25**	1054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4018	**Room 25**	1054	Water Fountain-No Chiller	Applicable	**8/20/2025**	**6.6**	8/29/2025	2.4	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4019	**Room 28**	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4020	**Room 28**	1055	Water Fountain-No Chiller	Applicable	**8/20/2025**	**6.0**	8/29/2025	4.7	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4021	**Room 27**	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4022	**Room 27**	1056	Water Fountain-No Chiller	Applicable	**8/20/2025**	**9.7**	8/29/2025	3.6	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4023	**Room 29**	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4024	**Room 29**	1058	Water Fountain-No Chiller	Applicable	**8/20/2025**	**5.6**	8/29/2025	3.8	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4025	**Room 30**	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4026	**Room 30**	1057	Water Fountain-No Chiller	Applicable	**8/20/2025**	**6.4**	8/29/2025	2.5	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4270	**Room 20**	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Laurel Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4271	**Room 20**	1041	Water Fountain-No Chiller	Applicable	**1/7/2026**	**3.7**			Result Below Action Level, Continue O&M
BRTWD-4308	**Corridor Near Kitchen (1038)**	1040	Bottle Fill Station	Applicable	**8/4/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4309	**Corridor Near Kitchen (1038)**	1040	Water Cooler	Applicable	**8/4/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4326	**Corridor Main Office To Receiving Room**	1040	Bottle Fill Station	Applicable	**9/4/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4327	**Corridor Main Office To Receiving Room**	1040	Water Cooler	Applicable	**9/4/2026**	**<1.0**			Result Below Action Level, Continue O&M

East Kindergarten Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2549	**Room 1**	N/A	Water Fountain-No Chiller	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2551	**Room 1 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2552	**Room 2**	N/A	Water Fountain-No Chiller	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2554	**Room 2 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2555	**Room 3**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2556	**Room 3**	N/A	Water Fountain-No Chiller	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2557	**Room 3 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2558	**Room 4**	N/A	Water Fountain-No Chiller	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2560	**Room 4 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2562	**Room 5**	N/A	Water Fountain-No Chiller	Applicable	**6/10/2025**	**2.5**			Result Below Action Level, Continue O&M
BRTWD-2564	**Room 6**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2565	**Room 6**	N/A	Water Fountain-No Chiller	Applicable	**6/10/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-2566	**Room 6 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2567	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2568	**Corridor Near Faculty Bathroom**	N/A	Water Cooler	RFI	**6/10/2025**	**OOS**			Replaced by Outlets 4298/4299
BRTWD-2569	**Faculty Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2571	**Room 7**	1001	Water Fountain-No Chiller	RFI	**6/10/2025**	**OOS**			Replaced by Outlet 4120
BRTWD-2573	**Room 8**	1003	Water Fountain-No Chiller	RFI	**6/10/2025**	**<1.00 ND**			Replaced by Outlet 4118
BRTWD-2575	**Room 9**	1004	Water Fountain-No Chiller	RFI	**6/10/2025**	**4.4**			Replaced by Outlet 4116
BRTWD-2577	**Room 10**	1005	Water Fountain-No Chiller	RFI	**6/10/2025**	**14.1**			Replaced by Outlet 4114

OOS= Out of Service **RFI = Removed from Inventory**

East Kindergarten Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2579	**Room 11**	1006	Water Fountain-No Chiller	RFI	**6/10/2025**	**7.2**			Replaced by Outlet 4112
BRTWD-2581	**Room 12**	1007	Water Fountain-No Chiller	RFI	**6/10/2025**	**<1.00 ND**			Replaced by Outlet 4110
BRTWD-2583	**Room 13**	1008	Water Fountain-No Chiller	RFI	**6/10/2025**	**3.5**			Replaced by Outlet 4108
BRTWD-2585	**Room 15**	1011	Water Fountain-No Chiller	RFI	**6/10/2025**	**3.9**			Replaced by Outlet 4106
BRTWD-2587	**Room 17**	1014	Water Fountain-No Chiller	RFI	**6/10/2025**	**<1.00 ND**			Replaced by Outlet 4104
BRTWD-2589	**Room 20**	1015	Water Fountain-No Chiller	RFI	**6/10/2025**	**12.1**			Replaced by Outlet 4102
BRTWD-2592	**Room 22**	1018	Water Fountain-No Chiller	RFI	**6/10/2025**	**2.0**			Replaced by Outlet 4100
BRTWD-2597	**Nurse's Office**	1031	Nurse's Office Sink	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2598	**Nurse's Office Bathroom**	1031A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2599	**Custodial Closet**	1033	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2600	**Faculty Room**	1037	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2602	**Kitchen**	1041	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-2603	**Kitchen**	1041	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2604	**Kitchen**	1041	Hand Wash Only	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2606	**Kitchen**	1041	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2607	**Kitchen**	1041	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**2.2**			Result Below Action Level, Continue O&M
BRTWD-2608	**Kitchen**	1041	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2609	**Kitchen**	1041	Kitchen Faucet (Cold)	Applicable	**6/10/2025**	**2.9**			Result Below Action Level, Continue O&M
BRTWD-2610	**Kitchen Bathroom**	1041A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2611	**Kitchen Can Wash Room**	1041A2	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Kindergarten Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2616	**Custodial Closet**	1048	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2624	**Room 31**	1053	Water Fountain-No Chiller	RFI	**6/10/2025**	**<1.00 ND**			Replaced by Outlet 4096
BRTWD-2626	**Room 34**	1054	Water Fountain-No Chiller	RFI	**6/10/2025**	**1.6**			Replaced by Outlet 4094
BRTWD-2628	**Room 33**	1055	Water Fountain-No Chiller	RFI	**6/10/2025**	**13.5**			Replaced by Outlet 4092
BRTWD-2630	**Room 36**	1056	Water Fountain-No Chiller	RFI	**6/10/2025**	**<1.00 ND**			Replaced by Outlet 4090
BRTWD-2634	**Room 38**	1058	Water Fountain-No Chiller	RFI	**6/10/2025**	**OOS**			Replaced by Outlet 4086
BRTWD-2636	**Room 40**	1060	Water Fountain-No Chiller	RFI	**6/10/2025**	**1.8**			Replaced by Outlet 4084
BRTWD-2638	**Room 39**	1061	Water Fountain-No Chiller	RFI	**6/10/2025**	**6.3**			Replaced by Outlet 4082
BRTWD-2640	**Room 42**	1062	Water Fountain-No Chiller	RFI	**6/10/2025**	**5.1**			Replaced by Outlet 4080
BRTWD-2642	**Room 44**	1064	Water Fountain-No Chiller	RFI	**6/10/2025**	**OOS**			Replaced by Outlet 4078
BRTWD-2643	**Room 41**	1065	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2644	**Room 41**	1065	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2645	**Room 41**	1065	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2646	**Room 46**	N/A	Water Fountain-No Chiller	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2647	**Room 46**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2648	**Room 46 Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2649	**Room 47**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2650	**Room 47**	N/A	Water Fountain-No Chiller	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2651	**Room 47 Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2655	**Exterior of Room 4**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Kindergarten Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2656	**Exterior of Room 1**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2657	**Exterior of Room 5**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3071	**Corridor Near Faculty Room (1037)**	1044	Water Cooler	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3072	**Corridor Near Faculty Room (1037)**	1044	Bottle Fill Station	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3073	**Corridor Near Room 19 (1016)**	1025	Water Cooler	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3074	**Corridor Near Room 19 (1016)**	1025	Bottle Fill Station	Applicable	**6/10/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3264	**Room 1**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3265	**Room 2**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3266	**Room 4**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3267	**Room 5**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3268	**Room 5 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3269	**Faculty Women's Bathroom**	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3270	**Nurses Office**	1031	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3271	**Kitchen**	1041	Pasta Pot/Steam Kettle	Applicable	**6/10/2025**	**7.0**	12/23/2025	3.4	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-3272	**Girls Bathroom (Acoss Boiler Room)**	1047	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3273	**Girls Bathroom (Acoss Boiler Room)**	1047	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3274	**Girls Bathroom (Acoss Boiler Room)**	1047	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3275	**Boys Bathroom (Acoss Boiler Room)**	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3276	**Boys Bathroom (Acoss Boiler Room)**	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3277	**Boys Bathroom (Acoss Boiler Room)**	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Kindergarten Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3279	**Room 32**	1052	Water Fountain-No Chiller	RFI	**6/10/2025**	**OOS**			Replaced by Outlet 4098
BRTWD-3280	**Room 35**	1057	Water Fountain-No Chiller	RFI	**6/10/2025**	**2.4**			Replaced by Outlet 4088
BRTWD-3281	**Faculty Men's Bathroom**	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3282	**Women's Bathroom**	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3283	**Exterior of Kitchen (1041)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3284	**Exterior of Main Office (1024)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3285	**Exterior of Room 17 (1014)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3286	**Exterior of Room 7 (1001)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3287	**Exterior of Room 16 (1010)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3288	**Exterior of Bathrooms (1047/1050)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3289	**Exterior of Room 38 (1058)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3290	**Exterior of Room 39 (1061)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3291	**Exterior of Boiler Room (0001)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4077	**Room 44**	1064	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4078	**Room 44**	1064	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-4079	**Room 42**	1062	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4080	**Room 42**	1062	Water Fountain-No Chiller	Applicable	**8/26/2025**	**17.3**	9/17/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4081	**Room 39**	1061	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4082	**Room 39**	1061	Water Fountain-No Chiller	Applicable	**8/26/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4083	**Room 40**	1060	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Kindergarten Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4084	**Room 40**	1060	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-4085	**Room 38**	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4086	**Room 38**	1058	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-4087	**Room 35**	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4088	**Room 35**	1057	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-4089	**Room 36**	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4090	**Room 36**	1056	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.0**			Result Below Action Level, Continue O&M
BRTWD-4091	**Room 33**	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4092	**Room 33**	1055	Water Fountain-No Chiller	Applicable	**8/26/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4093	**Room 34**	1054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4094	**Room 34**	1054	Water Fountain-No Chiller	Applicable	**8/26/2025**	**13.9**	9/17/2025	1.1	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4095	**Room 31**	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4096	**Room 31**	1053	Water Fountain-No Chiller	Applicable	**8/26/2025**	**4.5**			Result Below Action Level, Continue O&M
BRTWD-4097	**Room 32**	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4098	**Room 32**	1052	Water Fountain-No Chiller	Applicable	**8/26/2025**	**21.0**	9/17/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4099	**Room 22**	1018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4100	**Room 22**	1018	Water Fountain-No Chiller	Applicable	**8/26/2025**	**2.7**			Result Below Action Level, Continue O&M
BRTWD-4101	**Room 20**	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4102	**Room 20**	1015	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-4103	**Room 17**	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Kindergarten Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4104	**Room 17**	1014	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-4105	**Room 15**	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4106	**Room 15**	1011	Water Fountain-No Chiller	Applicable	**8/26/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4107	**Room 13**	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4108	**Room 13**	1008	Water Fountain-No Chiller	Applicable	**8/26/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4109	**Room 12**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4110	**Room 12**	1007	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-4111	**Room 11**	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4112	**Room 11**	1006	Water Fountain-No Chiller	Applicable	**8/26/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4113	**Room 10**	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4114	**Room 10**	1005	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-4115	**Room 9**	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4116	**Room 9**	1004	Water Fountain-No Chiller	Applicable	**8/26/2025**	**6.1**	9/17/2025	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4117	**Room 8**	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4118	**Room 8**	1003	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-4119	**Room 7**	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4120	**Room 7**	1001	Water Fountain-No Chiller	Applicable	**8/26/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-4263	**Room 43**	1065	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4280	**Room 43**	1065	Water Fountain-No Chiller	Applicable	**2/19/2026**	**7.3**	3/11/2026	<1.0	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4281	**Room 43**	1065	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

East Kindergarten Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4282	**Room 41**	1063	Water Fountain-No Chiller	Applicable	**2/19/2026**	**7.9**	3/11/2026	1.3	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-4283	**Room 41**	1063	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4298	**Corridor Near Faculty Bathroom**	N/A	Bottle Fill Station	Applicable	**6/26/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4299	**Corridor Near Faculty Bathroom**	N/A	Water Cooler	Applicable	**6/26/2026**	**<1.0**			Result Below Action Level, Continue O&M

Oak Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2757	**Room 2 Bathroom**	1003B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2758	**Room 1 Bathroom**	1001B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2786	**Custodial Closet A**	1028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2787	**Nurse's Office**	1026	Nurse's Office Sink	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2788	**Nurse's Office Bathroom**	1026B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2789	**Nurse's Office Exam Room**	1026A	Nurse's Office Sink	Applicable	**6/6/2025**	**171**	12/30/2025	13.0	Removed From Service, Pending Remediation
BRTWD-2793	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**5.2**	12/23/2025	4.5	Outlet Remediated Result Below Action Level, Continue O&M
BRTWD-2794	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2795	**Kitchen**	1038	Hand Wash Only	Applicable	**6/6/2025**	**10.6**	12/30/2025	10.9	Placarded for Non-Drinking Use Until Remediated
BRTWD-2797	**Kitchen**	1038	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2798	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2799	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2800	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2801	**Kitchen**	1038	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-2802	**Kitchen**	1038	Hand Wash Only	Applicable	**6/6/2025**	**3.7**			Result Below Action Level, Continue O&M
BRTWD-2803	**Kitchen Bathroom**	1038A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2804	**Kitchen Can Wash Room**	1038B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2808	**Custodial Closet B**	1044	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2836	**Room 52**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2837	**Room 52**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Oak Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2838	**Room 53**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2839	**Room 53**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2840	**Room 54**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2841	**Room 54**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.3**			Result Below Action Level, Continue O&M
BRTWD-2842	**Room 55**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2843	**Room 55**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2844	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2845	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2848	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2850	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2851	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2852	**Corridor Near Bathrooms**	N/A	Water Cooler	RFI	**6/6/2025**	**<1.00 ND**			Replaced by Outlets 4300/4301
BRTWD-2853	**Faculty Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2856	**Room 56**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2857	**Room 56**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2858	**Room 57**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2859	**Room 57**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2860	**Room 58**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2861	**Room 58**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2862	**Room 59**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Oak Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2863	**Room 59**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2864	**Room 60**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2865	**Room 60**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2866	**Room 61**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2867	**Room 61**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2868	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2869	**Faculty Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2871	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2873	**Corridor Near Bathrooms**	N/A	Water Cooler	RFI	**6/6/2025**	**<1.00 ND**			Replaced by Outlets 4268/4269
BRTWD-2874	**Corridor Near Bathrooms**	N/A	Water Cooler	RFI	**6/6/2025**	**<1.00 ND**			Replaced by Outlets 4268/4269
BRTWD-2875	**Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2877	**Room 66**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2878	**Room 66**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2879	**Room 67**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-2880	**Room 67**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2881	**Room 68**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.6**			Result Below Action Level, Continue O&M
BRTWD-2882	**Room 68**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2883	**Room 69**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2884	**Room 69**	N/A	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2896	**Exterior of Bathrooms (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Oak Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2897	**Exterior of Room 58 (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2898	**Exterior of Room 60 (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2899	**Exterior of Room 68 (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2900	**Exterior of Room 69 (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2901	**Exterior of Room 67 (New Construction)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2902	**Exterior of Room 26 (1056)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3083	**Corridor Near Cafeteria (1036)**	1040	Water Cooler	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3084	**Corridor Near Cafeteria (1036)**	1040	Bottle Fill Station	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3085	**Corridor Outside Bathrooms (1023/1024)**	1040	Water Cooler	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3086	**Corridor Outside Bathrooms (1023/1024)**	1040	Bottle Fill Station	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3110	**Room 1**	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3111	**Room 1**	1001	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3112	**Room 2**	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3113	**Room 2**	1003	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-3114	**Room 3**	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3115	**Room 3**	1004	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3116	**Room 4**	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3117	**Room 4**	1005	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3118	**Room 5**	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3119	**Room 5**	1006	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Oak Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3120	**Room 6**	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3121	**Room 6**	1007	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-3122	**Room 7**	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3123	**Room 7**	1008	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-3124	**Room 8**	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3125	**Room 8**	1009	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3126	**Room 9**	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3127	**Room 9**	1010	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3128	**Room 10**	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3129	**Room 10**	1011	Water Fountain-No Chiller	Applicable	**6/6/2025**	**2.1**			Result Below Action Level, Continue O&M
BRTWD-3130	**Room 11**	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3131	**Room 11**	1012	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-3132	**Room 12**	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3133	**Room 12**	1013	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-3134	**Computer Lab Room 13**	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3135	**Computer Lab Room 13**	1014	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.4**			Result Below Action Level, Continue O&M
BRTWD-3136	**Room 14**	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3137	**Room 14**	1015	Water Fountain-No Chiller	Applicable	**6/6/2025**	**6.7**	12/24/2025	1.8	Result Below Action Level, Continue O&M
BRTWD-3138	**Room 15**	1017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3139	**Room 15**	1017	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Oak Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3140	**Room 16**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3141	**Room 16**	1047	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3142	**Room 18**	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3143	**Room 18**	1049	Water Fountain-No Chiller	Applicable	**6/6/2025**	**2.1**			Result Below Action Level, Continue O&M
BRTWD-3144	**Room 20**	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3145	**Room 20**	1050	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3146	**Room 21**	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3147	**Room 21**	1051	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3148	**Room 22**	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3149	**Room 22**	1052	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3150	**Room 23**	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3151	**Room 23**	1053	Water Fountain-No Chiller	Applicable	**6/6/2025**	**OOS**	12/24/2025	1.1	Result Below Action Level, Continue O&M
BRTWD-3152	**Room 24**	1054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3153	**Room 24**	1054	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3154	**Room 25**	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3155	**Room 25**	1055	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3156	**Room 26**	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3157	**Room 26**	1056	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3158	**Room 27**	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3159	**Room 27**	1057	Water Fountain-No Chiller	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Oak Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3161	**Room 28**	1058	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-3162	**Room 29**	1059	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3163	**Room 29**	1059	Water Fountain-No Chiller	Applicable	**6/6/2025**	**1.5**			Result Below Action Level, Continue O&M
BRTWD-3911	**Gender Neutral Bathroom 1**	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3912	**Gender Neutral Bathroom 1**	1023	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3913	**Gender Neutral Bathroom 2**	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3914	**Gender Neutral Bathroom 2**	1024	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3915	**Nurse's Office**	1026	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3916	**Kitchen**	1038	Pasta Pot/Steam Kettle	Applicable	**6/6/2025**	**2.3**			Result Below Action Level, Continue O&M
BRTWD-3917	**Girls Bathroom (across Boiler Room)**	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3918	**Girls Bathroom (across Boiler Room)**	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3919	**Girls Bathroom (across Boiler Room)**	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3920	**Girls Bathroom (across Boiler Room)**	1043	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3921	**Boys Bathroom (across Boiler Room)**	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3922	**Boys Bathroom (across Boiler Room)**	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3923	**Boys Bathroom (across Boiler Room)**	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3924	**Boys Bathroom (across Boiler Room)**	1046	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3925	**Room 28**	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3926	**Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3927	**Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Oak Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3928	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3929	**Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3930	**Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3931	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3932	**Girls Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3933	**Boys Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3934	**Exterior of Custodial Office (1039)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3935	**Exterior of Kitchen (1038)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3936	**Exterior of Stage (1034B)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3937	**Exterior of Principal's Office (1019C)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3938	**Exterior of Room 13 (1014)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3939	**Exterior of Room 5 (1006)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3940	**Exterior of Room 1 (1001)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3941	**Exterior of Room 4 (1005)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3942	**Exterior of Room 12 (1013)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3943	**Exterior of Bathrooms (1043/1046)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3944	**Exterior of Room 25 (1055)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-4268	**5th Grade Corridor by Gang Bathrooms**	N/A	Bottle Fill Station	Applicable	**1/6/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4269	**5th Grade Corridor by Gang Bathrooms**	N/A	Water Cooler	Applicable	**1/6/2026**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4300	**Corridor Near Bathrooms**	N/A	Bottle Fill Station	Applicable	**7/9/2026**	**<1.0**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Oak Park Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-4301	**Corridor Near Bathrooms**	N/A	Water Cooler	Applicable	**7/9/2026**	**<1.0**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Anthony Felicio Administration Building

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2905	**Men's Bathroom**	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2906	**Men's Bathroom**	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2907	**Custodial Closet**	1012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2908	**Faculty Room**	1004	Kitchen Faucet (Cold)	Applicable	**6/11/2025**	**1.1**			Result Below Action Level, Continue O&M
BRTWD-2909	**Custodial Office Bathroom**	1002D1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2911	**Women's Bathroom**	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2912	**Women's Bathroom**	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2913	**Printing Room**	1020	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2914	**Men's Bathroom**	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2915	**Men's Bathroom**	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2917	**Custodial Closet**	1031	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2918	**Women's Bathroom**	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2919	**Women's Bathroom**	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2920	**Women's Bathroom**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2921	**Women's Bathroom**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2922	**Custodial Closet**	2006	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2923	**2nd Floor Corridor**	2010	Water Cooler	RFI	**6/11/2025**	**OOS**			Replaced by Outlets 4121/4122
BRTWD-2924	**Men's Bathroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2925	**Men's Bathroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2931	**Women's Bathroom**	3002J	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Anthony Felicio Administration Building

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2932	**Women's Bathroom**	3002J	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2933	**Women's Bathroom**	3002J	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2934	**Men's Bathroom**	3002I	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2936	**Maureen Belanger Board Room Kitchen**	1007C	Office Faucet	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2937	**Exterior of Custodial Office (1002)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2938	**Exterior of Men's Bathroom (1005)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2939	**Exterior of Maureen Belanger Board Room (1007)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2940	**Exterior of Purchasing Department (1011)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2941	**Exterior of Transportation Department Office (1024)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2942	**Exterior of Women's Bathroom (1030)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2943	**Exterior of Book Storage/Basement Stairwell**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2944	**Exterior of Book Storage/Basement Stairwell**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2995	**East Wing Conference Room Bathroom**	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3006	**West Corridor**	1033	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3007	**West Corridor**	1033	Bottle Fill Station	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3170	**Main Corridor**	1039	Bottle Fill Station	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3171	**Main Corridor**	1039	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3951	**East Corridor**	1013	Water Cooler	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3952	**East Corridor**	1013	Bottle Fill Station	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3965	**Health Benefits Suite Kitchen Area**	2009D	Bottle Fill Station	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Anthony Felicio Administration Building

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-3966	**Health Benefits Suite Kitchen Area**	2009D	Bottled Water Dispenser	Applicable	**6/11/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-3967	**Health Benefits Suite Kitchen Area**	2009D	Kitchen Faucet (Cold)	Applicable	**6/11/2025**	**1.2**			Result Below Action Level, Continue O&M
BRTWD-4121	**2nd Floor Corridor**	2010	Bottle Fill Station	Applicable	**8/26/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4122	**2nd Floor Corridor**	2010	Water Cooler	Applicable	**8/26/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4260	**Main Office Suite Kitchen**	3002M	Kitchen Faucet (Cold)	Applicable	**12/4/2025**	**OOS**	1/7/2026	<1.0	Result Below Action Level, Continue O&M
BRTWD-4261	**Main Office Suite Kitchen**	3002M	Bottled Water Dispenser	Applicable	**12/4/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4262	**Main Office Suite Kitchen**	3002M	Bottled Water Dispenser	Applicable	**12/4/2025**	**<1.0**			Result Below Action Level, Continue O&M
BRTWD-4264	**Main Office Suite Kitchen**	3002M	Ice Machine	Applicable	**12/4/2025**	**<1.0**			Result Below Action Level, Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Special Services Building

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2945	**Offices Bathroom**	1021A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2946	**Women's Bathroom**	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2947	**Unisex Bathroom**	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2949	**Faculty Room**	1011	Water Cooler	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M
BRTWD-2951	**Exterior of Faculty Lounge (1011)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-3003	**Faculty Room**	1011	Kitchen Faucet (Cold)	Applicable	**6/6/2025**	**<1.00 ND**			Result Below Action Level, Continue O&M

Buildings & Grounds Building

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2952	**Stairwell Vestibule Bathroom**	1008A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2953	**Custodial Closet**	1007A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2954	**Vestibule Bathroom**	1006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2955	**Faculty Room**	1005	Water Cooler	Applicable	**6/11/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2956	**Faculty Room**	1005	Kitchen Faucet (Cold)	Applicable	**6/11/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2957	**Women's Bathroom**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2958	**Corridor Near Custodial Closet (2004)**	2007	Water Cooler	Applicable	**6/11/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2959	**Men's Bathroom**	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2960	**Faculty Room**	2002	Kitchen Faucet (Cold)	Applicable	**6/11/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2961	**Warehouse**	1010	Water Cooler	Applicable	**6/11/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2962	**Auto Shop**	1011	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2963	**Auto Shop**	1011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2964	**Auto Shop**	1011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2965	**Auto Shop Bathroom**	1011A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2966	**Glazier/Locksmith Shop Vestibule Bathroom**	1014A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2967	**Exterior of Plumber Workshop (1002)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2968	**Exterior of Warehouse (1010)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2969	**Exterior of Auto Shop (1011)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2970	**Exterior of Glazier Shop (1014B)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2971	**Exterior of Glazier Shop (1014B)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Loretta Park Warehouse

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2972	**Warehouse Garage**	1001	Water Cooler	Applicable	**6/4/2025**	**OOS**			Testing Required Before Return to Service
BRTWD-2973	**Warehouse Garage**	1001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2974	**Warehouse Bathroom**	1001B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2975	**Warehouse Garage**	1001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

East Kindergarten Warehouse

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2976	**Custodial Office**	1000	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2977	**Locker Area Bathroom**	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2978	**Warehouse Bathroom**	1002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2979	**Locker Area**	1001	Water Cooler	Applicable	**6/10/2025**	**OOS**			Testing Required Before Return to Service

OOS= Out of Service **RFI = Removed from Inventory**

Pine Park Warehouse

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
BRTWD-2980	**Men's Bathroom**	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2981	**Women's Bathroom**	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2982	**Exterior of Warehouse (1005)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
BRTWD-2983	**Exterior of Office (1001)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Attachment 3:

Laboratory Analytical Reports



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Lead in Water: Chain of Custody for ED53701

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0003	KI	1031	Kitchen	HW	6/7/2025	7:13:00 AM
BRTWD-0005	KI	1031	Kitchen	KC	6/7/2025	7:10:00 AM
BRTWD-0007	KI	1031	Kitchen	KC	6/7/2025	7:08:00 AM
BRTWD-0008	KI	1031	Kitchen	HW	6/7/2025	7:09:00 AM
BRTWD-0015	HA	N/A	New Construction Hallway Near East Exit	WC	6/7/2025	7:43:00 AM
BRTWD-0016	HA	N/A	New Construction Hallway Near East Exit	WC	6/7/2025	7:43:00 AM
BRTWD-0024	HA	N/A	Corridor Near Bathrooms	WC	6/7/2025	6:23:00 AM
BRTWD-0025	HA	N/A	Corridor Near Bathrooms	WC	6/7/2025	6:23:00 AM
BRTWD-0035	HA	N/A	Corridor Near Exit Vestibule 106	WC	6/7/2025	6:15:00 AM
BRTWD-0036	HA	N/A	Corridor Near Exit Vestibule 106	WC	6/7/2025	6:15:00 AM
BRTWD-0038	HE	N/A	Room 1831 Home Economics	EC	6/7/2025	6:27:00 AM
BRTWD-0043	KI	N/A	Kitchen (New Construction)	HW	6/7/2025	6:39:00 AM
BRTWD-0044	KI	N/A	Kitchen (New Construction)	KC	6/7/2025	6:35:00 AM
BRTWD-0045	KI	N/A	Kitchen (New Construction)	KC	6/7/2025	6:36:00 AM
BRTWD-0046	KI	N/A	Kitchen (New Construction)	HW	6/7/2025	6:38:00 AM
BRTWD-0047	KI	N/A	Kitchen (New Construction)	KC	6/7/2025	6:32:00 AM
BRTWD-0049	KI	N/A	Kitchen (New Construction)	PK	6/7/2025	6:30:00 AM
BRTWD-0050	KI	N/A	Kitchen (New Construction)	HW	6/7/2025	6:29:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM09:00

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: 06/13/25 21:00

Signature:

Samplers Name: Frank Ulloa

Samplers Signature:

JCB Project Manager: Meghan Gruyon

Lead in Water: Chain of Custody for ED533 01

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: (Normal) 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0051	KI	N/A	Kitchen (New Construction)	HW	6/7/2025	6:34:00 AM
BRTWD-0064	NO	1022	Nurse's Office	NS	6/7/2025	6:50:00 AM
BRTWD-0070	HA	1027	Corridor Near Closet (1027A)	WC	6/7/2025	6:55:00 AM
BRTWD-0078	HA	1021B	Gym Vestibule to Aux. Gym & Girls Locker Room	WC	6/7/2025	6:59:00 AM
BRTWD-0079	HA	1021B	Gym Vestibule to Aux. Gym & Girls Locker Room	WC	6/7/2025	6:59:00 AM
BRTWD-0083	HA	1017	Corridor Near Custodial Room (1017A)	DW	6/7/2025	6:43:00 AM
BRTWD-0091	HA	1067	Corridor Near Guidance Office (1040)	DW	6/7/2025	7:23:00 AM
BRTWD-0094	HA	1051	Corridor Near Men's Faculty Bathroom (1045)	WC	6/7/2025	7:14:00 AM
BRTWD-0095	HA	1051	Corridor Near Men's Faculty Bathroom (1045)	WF	6/7/2025	7:14:00 AM
BRTWD-0099	FL	1053	Faculty Lounge	KC	6/7/2025	7:31:00 AM
BRTWD-0103	HE	1054	Room 1410 Home Economics	EC	6/7/2025	7:30:00 AM
BRTWD-0104	HE	1054	Room 1410 Home Economics	EC	6/7/2025	7:29:00 AM
BRTWD-0105	HE	1054	Room 1410 Home Economics	EC	6/7/2025	7:26:00 AM
BRTWD-0125	HA	1067	Corridor Near Men's Bathroom (1060)	DW	6/7/2025	7:33:00 AM
BRTWD-0130	HA	1067	Corridor Near Principal's Office (1065B)	DW	6/7/2025	7:37:00 AM
BRTWD-0167	OF	N/A	Library Workroom	OF	6/7/2025	7:53:00 AM
BRTWD-0172	HA	N/A	Corridor Near Faculty Bathrooms	WC	6/7/2025	7:49:00 AM
BRTWD-0173	HA	N/A	Corridor Near Faculty Bathrooms	WC	6/7/2025	7:49:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM02:01

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 22:00

Signature:

Samplers Name: Erika Wilson

Samplers Signature:

JCB Project Manager: Meghan Grugan

Lead in Water: Chain of Custody for EDS 3301

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0196	SC	N/A	Room 2819/2823 Prep Room	WC	6/7/2025	7:52:00 AM
BRTWD-0229	HA	2054	Corridor Near Men's Bathroom (2010)	DW	6/7/2025	7:56:00 AM
BRTWD-0234	HA	2054	Corridor Near Room 2520 Book Room (2023)	DW	6/7/2025	7:58:00 AM
BRTWD-0238	HA	2054	Corridor Room 2500 To Room 2537	DW	6/7/2025	8:00:00 AM
BRTWD-0287	HA	2054	Corridor Near Men's Bathroom (2045)	DW	6/7/2025	8:02:00 AM
BRTWD-0378	HA	1081A	Auxilary Gym Vestibule	WC	6/7/2025	7:00:00 AM
BRTWD-3166	CA	1030A	Cafeteria A	WC	6/7/2025	7:03:00 AM
BRTWD-3167	CA	1030A	Cafeteria A	WF	6/7/2025	7:03:00 AM
BRTWD-3168	CA	1030B	Cafeteria B	WC	6/7/2025	7:05:00 AM
BRTWD-3169	CA	1030B	Cafeteria B	WF	6/7/2025	7:05:00 AM
BRTWD-3692	HA	1027	Corridor Boiler Room to Girls Locker Room	WC	6/7/2025	6:53:00 AM
BRTWD-3693	HA	1027	Corridor Boiler Room to Girls Locker Room	WF	6/7/2025	6:53:00 AM
BRTWD-3710	HE	1054	Room 1410	EC	6/7/2025	7:28:00 AM
BRTWD-3711	HE	1054	Room 1410	EC	6/7/2025	7:25:00 AM
BRTWD-3786	KI	1031	Kitchen	PK	6/7/2025	7:12:00 AM
BRTWD-3805	KI	N/A	New Kitchen	KC	6/7/2025	6:31:00 AM
BRTWD-3810	SP	1078A	Wood Shop Storage	BWC	6/7/2025	8:10:00 AM
BRTWD-3811	SP	1078A	Wood Shop Storage	BWH	6/7/2025	8:10:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM 07:01

Building Address

2 Sixth Avenue

Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 2100

Signature:

Samplers Name:

Samplers Signature:

JCB Project Manager: Megan Grayson

Lead in Water: Chain of Custody for ED53301

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3945	OF	1065A	Room 1401 Storage	BWC	6/7/2025	7:35:00 AM
BRTWD-3946	OF	1065A	Room 1401 Storage	BWH	6/7/2025	7:35:00 AM
BRTWD-3953	HA	1017	Corridor Outside Team Locker Room	WC	6/7/2025	6:44:00 AM
BRTWD-3954	HA	1017	Corridor Outside Team Locker Room	WF	6/7/2025	6:44:00 AM

Samples Submitted 58

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:01

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:00

Signature:

Samplers Name: Erika Wilson

Samplers Signature:

JCB Project Manager: Meghan Grayson

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553301
LIMS Reference ID: ED53301
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sisth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0003			**Lims Reference ID:**	**ED53301-01**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**1.2**		1	1.0	µg/L	06/24/25 10:20	06/24/25 10:20	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0005			**Lims Reference ID:**	**ED53301-02**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 10:21	06/24/25 10:21	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0007			**Lims Reference ID:**	**ED53301-03**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	06/24/25 10:23	06/24/25 10:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0008			**Lims Reference ID:**	**ED53301-04**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 10:24	06/24/25 10:24	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0015			**Lims Reference ID:**	**ED53301-05**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 10:25	06/24/25 10:25	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0016			**Lims Reference ID:**	**ED53301-06**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 10:27	06/24/25 10:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0024			**Lims Reference ID:**	**ED53301-07**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 10:30	06/24/25 10:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0025			**Lims Reference ID:**	**ED53301-08**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 10:32	06/24/25 10:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0035			**Lims Reference ID:**	**ED53301-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553301
LIMS Reference ID: ED53301
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sisth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0035 (Continued)		**Lims Reference ID:**		**ED53301-09**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 10:36	06/24/25 10:36	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0036		**Lims Reference ID:**		**ED53301-10**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 10:37	06/24/25 10:37	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0038		**Lims Reference ID:**		**ED53301-11**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 10:38	06/24/25 10:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0043		**Lims Reference ID:**		**ED53301-12**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 10:40	06/24/25 10:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0044		**Lims Reference ID:**		**ED53301-13**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 10:41	06/24/25 10:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0045		**Lims Reference ID:**		**ED53301-14**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 10:42	06/24/25 10:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0046		**Lims Reference ID:**		**ED53301-15**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	9.5		1	1.0	µg/L	06/24/25 10:44	06/24/25 10:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0047		**Lims Reference ID:**		**ED53301-16**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 10:55	06/24/25 10:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0049		**Lims Reference ID:**		**ED53301-17**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553301
LIMS Reference ID: ED53301
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sisth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0049 (Continued)		**Lims Reference ID:**		**ED53301-17**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	2.9		1	1.0	µg/L	06/24/25 10:59	06/24/25 10:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0050		**Lims Reference ID:**		**ED53301-18**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	14.5		1	1.0	µg/L	06/24/25 11:01	06/24/25 11:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0051		**Lims Reference ID:**		**ED53301-19**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	3.0		1	1.0	µg/L	06/24/25 11:02	06/24/25 11:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0064		**Lims Reference ID:**		**ED53301-20**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.7		1	1.0	µg/L	06/24/25 11:03	06/24/25 11:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0070		**Lims Reference ID:**		**ED53301-21**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:07	06/24/25 11:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0078		**Lims Reference ID:**		**ED53301-22**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:09	06/24/25 11:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0079		**Lims Reference ID:**		**ED53301-23**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:10	06/24/25 11:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0083		**Lims Reference ID:**		**ED53301-24**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:11	06/24/25 11:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0091		**Lims Reference ID:**		**ED53301-25**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553301
LIMS Reference ID: ED53301
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sisth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0091 (Continued)		**Lims Reference ID:**		**ED53301-25**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	3.6		1	1.0	µg/L	06/24/25 11:12	06/24/25 11:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0094		**Lims Reference ID:**		**ED53301-26**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:14	06/24/25 11:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0095		**Lims Reference ID:**		**ED53301-27**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:18	06/24/25 11:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0099		**Lims Reference ID:**		**ED53301-28**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	3.5		1	1.0	µg/L	06/24/25 11:19	06/24/25 11:19	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0103		**Lims Reference ID:**		**ED53301-29**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/24/25 11:23	06/24/25 11:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0104		**Lims Reference ID:**		**ED53301-30**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/24/25 11:24	06/24/25 11:24	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0105		**Lims Reference ID:**		**ED53301-31**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:26	06/24/25 11:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0125		**Lims Reference ID:**		**ED53301-32**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/24/25 11:27	06/24/25 11:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0130		**Lims Reference ID:**		**ED53301-33**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553301
LIMS Reference ID: ED53301
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sisth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0130 (Continued)			**Lims Reference ID:**	**ED53301-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	**1.7**		1	1.0	µg/L	06/24/25 11:28	06/24/25 11:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0167			**Lims Reference ID:**	**ED53301-34**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	06/24/25 11:30	06/24/25 11:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0172			**Lims Reference ID:**	**ED53301-35**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 11:31	06/24/25 11:31	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0173			**Lims Reference ID:**	**ED53301-36**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 18:52	06/23/25 18:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0196			**Lims Reference ID:**	**ED53301-37**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**2.2**		1	1.0	µg/L	06/23/25 18:53	06/23/25 18:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0229			**Lims Reference ID:**	**ED53301-38**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**1.8**		1	1.0	µg/L	06/23/25 18:55	06/23/25 18:55	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0234			**Lims Reference ID:**	**ED53301-39**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 18:56	06/23/25 18:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0238			**Lims Reference ID:**	**ED53301-40**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**9.4**		1	1.0	µg/L	06/23/25 18:57	06/23/25 18:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0287			**Lims Reference ID:**	**ED53301-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553301
LIMS Reference ID: ED53301
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sisth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0287 (Continued)		**Lims Reference ID:**		**ED53301-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:11	06/23/25 19:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0378		**Lims Reference ID:**		**ED53301-42**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/23/25 19:15	06/23/25 19:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3166		**Lims Reference ID:**		**ED53301-43**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:16	06/23/25 19:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3167		**Lims Reference ID:**		**ED53301-44**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:18	06/23/25 19:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3168		**Lims Reference ID:**		**ED53301-45**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:19	06/23/25 19:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3169		**Lims Reference ID:**		**ED53301-46**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:23	06/23/25 19:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3692		**Lims Reference ID:**		**ED53301-47**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:24	06/23/25 19:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3693		**Lims Reference ID:**		**ED53301-48**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:26	06/23/25 19:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3710		**Lims Reference ID:**		**ED53301-49**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553301
LIMS Reference ID: ED53301
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sisth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3710 (Continued)		**Lims Reference ID:**		**ED53301-49**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:27	06/23/25 19:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3711		**Lims Reference ID:**		**ED53301-50**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:28	06/23/25 19:28	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3786		**Lims Reference ID:**		**ED53301-51**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.8		1	1.0	µg/L	06/23/25 19:30	06/23/25 19:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3805		**Lims Reference ID:**		**ED53301-52**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:34	06/23/25 19:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3810		**Lims Reference ID:**		**ED53301-53**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:35	06/23/25 19:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3811		**Lims Reference ID:**		**ED53301-54**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:39	06/23/25 19:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3945		**Lims Reference ID:**		**ED53301-55**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:40	06/23/25 19:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3946		**Lims Reference ID:**		**ED53301-56**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 19:41	06/23/25 19:41	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3953		**Lims Reference ID:**		**ED53301-57**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553301
LIMS Reference ID: ED53301
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sisth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3953 (Continued)			**Lims Reference ID:**	**ED53301-57**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 19:43	06/23/25 19:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3954			**Lims Reference ID:**	**ED53301-58**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 19:44	06/23/25 19:44	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553301
LIMS Reference ID: ED53301
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sisth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553301
LIMS Reference ID: ED53301
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sisth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED55459

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48 hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0001	KI	1031	Kitchen	KC	8/26/2025	8:42:00 AM
BRTWD-0002	KI	1031	Kitchen	KC	8/26/2025	8:42:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 26 25, PM03:42

PB2008 Kathleen Jones 8/28/25

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/26/25 3:42 pm

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555459

LIMS Reference ID: ED55459

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Brentwood Sonderling High School SON, 2 Sixth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/26/2025 15:42

Reported: 08/28/2025 21:39

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0001		**Lims Reference ID:**		**ED55459-01**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**43.6**		1	1.0	µg/L	08/28/25 19:11	08/28/25 19:11	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-0002		**Lims Reference ID:**		**ED55459-02**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**65.0**		1	1.0	µg/L	08/28/25 19:12	08/28/25 19:12	KT1	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555459
LIMS Reference ID: ED55459
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Brentwood Sonderling High School SON, 2 Sixth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/26/2025 15:42
Reported: 08/28/2025 21:39

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555459

LIMS Reference ID: ED55459

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Brentwood Sonderling High School SON, 2 Sixth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/26/2025 15:42

Reported: 08/28/2025 21:39

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED56327

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Sonderling High School
SON

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0001	KI	1031	Kitchen	KC	10/2/2025	8:09:00 AM
BRTWD-0002	KI	1031	Kitchen	KC	10/2/2025	8:09:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 02 25, PM03:09

NB 200.8 Billing 10/3/25

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/2/25 3:09 PM

Signature: David Wharton

Samplers Name: Meghan Guygnn

Samplers Signature: Meghan Guy

JCB Project Manager: Meghan Guy

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556327

LIMS Reference ID: ED56327

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Brentwood Sonderling High School (SON), 2 Sixth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/02/2025 15:09

Reported: 10/04/2025 09:43

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0001		**Lims Reference ID:**		**ED56327-01**	**Matrix: Drinking Water**			**Sampled:**	**10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 13:19	10/03/25 13:19	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0002		**Lims Reference ID:**		**ED56327-02**	**Matrix: Drinking Water**			**Sampled:**	**10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 13:20	10/03/25 13:20	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556327
LIMS Reference ID: ED56327
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Brentwood Sonderling High School (SON), 2 Sixth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/02/2025 15:09
Reported: 10/04/2025 09:43

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556327
LIMS Reference ID: ED56327
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Brentwood Sonderling High School (SON), 2 Sixth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/02/2025 15:09
Reported: 10/04/2025 09:43

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57894

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest / New Install [ ]

Turn Around: Normal 1 wk **Rush** 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0009	ST	1031F	Kitchen Storage Room	KC	12/23/2025	6:07:00 AM

Samples Submitted 1

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:11

12/24/25

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 12/23/25 14:11

Signature: Kay Hausner

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557894

LIMS Reference ID: ED57894

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Brentwood Sonderling High School: 2 Sixth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 14:11
Reported:	12/24/2025 17:03

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0009			**Lims Reference ID:**	**ED57894-01**	**Matrix: Drinking Water**			**Sampled:**	**12/23/25 14:11:00**
Metals									
Lead	**18.0**		1	1.0	µg/L	12/24/25 13:38	12/24/25 13:38	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557894

LIMS Reference ID: ED57894

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Brentwood Sonderling High School: 2 Sixth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 14:11
Reported:	12/24/2025 17:03

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557894

LIMS Reference ID: ED57894

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School: 2 Sixth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:11

Reported: 12/24/2025 17:03

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57967

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0046	KI	N/A	Kitchen (New Construction)	HW	12/30/2025	7:06:00 AM
BRTWD-0050	KI	N/A	Kitchen (New Construction)	HW	12/30/2025	7:07:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:36

PB 200.8 Kathleen Lyn 12/31/25

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/30/25 4:36 PM

Signature:

Samplers Name: Jordan Miglino

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557967

LIMS Reference ID: ED57967

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Brentwood Sonderling High School SON / 2 Sixth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:36

Reported: 12/31/2025 15:31

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0046		**Lims Reference ID:**		**ED57967-01**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 00:00:00**
Metals									
Lead	**42.1**		1	1.0	µg/L	12/31/25 13:50	12/31/25 13:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0050		**Lims Reference ID:**		**ED57967-02**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 00:00:00**
Metals									
Lead	**9.0**		1	1.0	µg/L	12/31/25 13:52	12/31/25 13:52	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557967

LIMS Reference ID: ED57967

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Brentwood Sonderling High School SON / 2 Sixth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:36

Reported: 12/31/2025 15:31

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557967
LIMS Reference ID: ED57967
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Brentwood Sonderling High School SON / 2 Sixth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:36
Reported: 12/31/2025 15:31

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50115

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4272	HA	2054	Corridor Room 2500 To Room 2537	WF	1/9/2026	7:03:00 AM
BRTWD-4273	HA	2054	Corridor Room 2500 To Room 2537	WC	1/9/2026	7:02:00 AM

Samples Submitted 2

Walk In

1/10/26 200.8 Pb

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 09 26, PM02:55

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 1/9/26 2:55 pm

Signature:

Samplers Name: Derick Colagiovi

Samplers Signature:

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650115
LIMS Reference ID: EE50115
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Brentwood Sonderling High School SON / 2 Sixth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:55
Reported: 01/10/2026 14:20

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4272		**Lims Reference ID:**		**EE50115-01**	**Matrix: Drinking Water**				**Sampled: 01/09/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/10/26 13:51	01/10/26 13:51	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4273		**Lims Reference ID:**		**EE50115-02**	**Matrix: Drinking Water**				**Sampled: 01/09/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/10/26 13:52	01/10/26 13:52	JH	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650115
LIMS Reference ID: EE50115
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Brentwood Sonderling High School SON / 2 Sixth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:55
Reported: 01/10/2026 14:20

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650115
LIMS Reference ID: EE50115
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Brentwood Sonderling High School SON / 2 Sixth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:55
Reported: 01/10/2026 14:20

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE 50421

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush** 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0072	CC	1027A	Closet in Corridor Outside Boiler Room	IM	1/23/2026	6:45:00 AM
BRTWD-4276	HA	2054	Corridor Room 2500 To Room 2537	WF	1/23/2026	6:48:00 AM
BRTWD-4277	HA	2054	Corridor Room 2500 To Room 2537	WC	1/23/2026	6:48:00 AM

Samples Submitted 3

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 23 26, PM01:44

Courier

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: _____

Signature: _____

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650421
LIMS Reference ID: EE50421
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School, 2 Sixth Avenue Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/23/2026 13:44
Reported: 01/26/2026 13:19

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0072		**Lims Reference ID:**		**EE50421-01**	**Matrix: Drinking Water**				**Sampled: 01/23/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/24/26 17:09	01/24/26 17:09	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4276		**Lims Reference ID:**		**EE50421-02**	**Matrix: Drinking Water**				**Sampled: 01/23/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/24/26 17:10	01/24/26 17:10	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4277		**Lims Reference ID:**		**EE50421-03**	**Matrix: Drinking Water**				**Sampled: 01/23/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/24/26 17:12	01/24/26 17:12	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650421

LIMS Reference ID: EE50421

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Sonderling High School, 2 Sixth Avenue Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 01/23/2026 13:44

Reported: 01/26/2026 13:19

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650421
LIMS Reference ID: EE50421
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Brentwood Sonderling High School, 2 Sixth Avenue Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	01/23/2026 13:44
Reported:	01/26/2026 13:19

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE53369

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest/New Install N

Turn Around: Normal 1 wk **Rush** 48hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0408	OF	1089B6	Library Annex Break Room	OF	6/26/2026	6:31:00 AM

Samples Submitted 1

Pb 200.8 Billing 6/29/26

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 26 26, PM01:00

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 6/26/26 1:00 PM

Signature:

Samplers Name: Danielle Belegnini

Samplers Signature:

JCB Project Manager: Danielle Belegnini

ND Drinking Water 6/27/26

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653369

LIMS Reference ID: EE53369

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Sonderling High School SON, 2 Sixth Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/26/2026 13:00

Reported: 06/29/2026 15:48

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0408			**Lims Reference ID:**	**EE53369-01**	**Matrix: Drinking Water**			**Sampled:**	**06/26/26 00:00:00**
Metals									
Lead	**2.6**		1	1.0	µg/L	06/29/26 14:13	06/29/26 14:13	BP	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653369
LIMS Reference ID: EE53369
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Sonderling High School SON, 2 Sixth Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/26/2026 13:00
Reported: 06/29/2026 15:48

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	05/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653369
LIMS Reference ID: EE53369
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Sonderling High School SON, 2 Sixth Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/26/2026 13:00
Reported: 06/29/2026 15:48

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE54665

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

Courier

JCB #: 26-64123

Building: Brentwood Sonderling High School

SON

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0225	HA	2054	Corridor Near Room 2537 (2001)	DW	9/28/2026	6:48:00 AM

Samples Submitted 1

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
SEP 29 26, PM01:02

Building Address
2 Sixth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved:

Signature: 9/29/66 1:02 pm

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654665
LIMS Reference ID: EE54665
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Sonderling High School, Brentwood Union Free School District, 26-64123, 2 Sixth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/29/2026 13:02
Reported: 10/01/2026 17:57

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0225			**Lims Reference ID:**	**EE54665-01**	**Matrix: Drinking Water**			**Sampled:**	**09/28/26 00:00:00**
Metals									
Lead	**4.5**		1	1.0	µg/L	10/01/26 17:05	10/01/26 17:05	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654665
LIMS Reference ID: EE54665
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Sonderling High School, Brentwood Union Free School District, 26-64123, 2 Sixth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/29/2026 13:02
Reported: 10/01/2026 17:57

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP ELLAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	11/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654665
LIMS Reference ID: EE54665
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Sonderling High School, Brentwood Union Free School District, 26-64123, 2 Sixth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/29/2026 13:02
Reported: 10/01/2026 17:57

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for E053309

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southeast Elementary School

SES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0334	KI	1029	Kitchen	PK	6/5/2025	6:06:00 AM
BRTWD-0344	OF	1025A1	Coach's Office	BWH	6/5/2025	7:15:00 AM
BRTWD-2668	CR	1002	Room 102	DW	6/5/2025	6:38:00 AM
BRTWD-2671	CR	1004	Room 11	DW	6/5/2025	6:34:00 AM
BRTWD-2673	CR	1005	Room 12	DW	6/5/2025	6:32:00 AM
BRTWD-2675	CR	1006	Room 9	DW	6/5/2025	6:30:00 AM
BRTWD-2677	CR	1007	Room 10	DW	6/5/2025	6:29:00 AM
BRTWD-2679	CR	1008	Room 7	DW	6/5/2025	6:27:00 AM
BRTWD-2681	CR	1009	Room 8	DW	6/5/2025	6:26:00 AM
BRTWD-2685	CR	1011	Room 6	DW	6/5/2025	6:22:00 AM
BRTWD-2687	OF	1012	Room 3	DW	6/5/2025	6:20:00 AM
BRTWD-2689	CR	1013	Room 4	DW	6/5/2025	6:19:00 AM
BRTWD-2691	CR	1014	Room 1	DW	6/5/2025	6:17:00 AM
BRTWD-2695	NO	1000	Nurse's Office	NS	6/5/2025	6:14:00 AM
BRTWD-2698	OF	1025A1	Coach's Office	BW	6/5/2025	7:10:00 AM
BRTWD-2700	KI	1029	Kitchen	HW	6/5/2025	6:05:00 AM
BRTWD-2702	KI	1029	Kitchen	KC	6/5/2025	6:01:00 AM
BRTWD-2704	KI	1029	Kitchen	KC	6/5/2025	6:02:00 AM

RECEIVED
EMSL ANALYTICAL INC.
Carle Place, NY
JUN 13 25, PM09:04

Building Address
1 Melody Lane
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:04

Signature: Ivan Warner

Samplers Name: Tiffany Chen

Samplers Signature:

JCB Project Manager: Meghan Grogan

Lead in Water: Chain of Custody for EDS 3309

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southeast Elementary School

SES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2705	KI	1029	Kitchen	HW	6/5/2025	6:03:00 AM
BRTWD-2708	FL	1035	Faculty Room	KC	6/5/2025	6:45:00 AM
BRTWD-2717	CR	1040	Room 16	DW	6/5/2025	6:46:00 AM
BRTWD-2719	CR	1041	Room 13	DW	6/5/2025	6:48:00 AM
BRTWD-2721	CR	1042	Room 18	DW	6/5/2025	6:50:00 AM
BRTWD-2723	CR	1043	Room 15	DW	6/5/2025	6:51:00 AM
BRTWD-2725	CR	1044	Room 20	DW	6/5/2025	6:53:00 AM
BRTWD-2727	CR	1045	Room 17	DW	6/5/2025	6:55:00 AM
BRTWD-2731	CR	1047	Room 19	DW	6/5/2025	6:58:00 AM
BRTWD-2733	CR	1048	Room 24	DW	6/5/2025	6:59:00 AM
BRTWD-2988	KI	1029	Kitchen	HW	6/5/2025	6:04:00 AM
BRTWD-3067	HA	1032	Corridor Near Cafeteria (1028)	WC	6/5/2025	6:09:00 AM
BRTWD-3068	HA	1032	Corridor Near Cafeteria (1028)	WF	6/5/2025	6:08:00 AM
BRTWD-3069	HA	1032	Corridor Near Gymnasium (1025)	WC	6/5/2025	6:11:00 AM
BRTWD-3070	HA	1032	Corridor Near Gymnasium (1025)	WF	6/5/2025	6:12:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:04

Building Address
1 Melody Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 11:04

Signature: [signature] / KAY WORCESTER

Samplers Name:_____

Samplers Signature:_____

JCB Project Manager: Meghan Grayson

Lead in Water: Chain of Custody for E053309

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southeast Elementary School

SES

Client: Brentwood Union Free School District

Retest/New Install | |

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time

Samples Submitted 33

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:04

Building Address
1 Melody Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 06/13/25 21:04

Signature: [signature] / RAY WARNER

Samplers Name:_____

Samplers Signature:_____

JCB Project Manager: Meghan Emerson

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553309
LIMS Reference ID: ED53309
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School: 1 Melody Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:04
Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0334		**Lims Reference ID:**		**ED53309-01**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.3		1	1.0	µg/L	06/17/25 14:30	06/17/25 14:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0344		**Lims Reference ID:**		**ED53309-02**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 14:32	06/17/25 14:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2668		**Lims Reference ID:**		**ED53309-03**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	5.1		1	1.0	µg/L	06/17/25 14:33	06/17/25 14:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2671		**Lims Reference ID:**		**ED53309-04**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.3		1	1.0	µg/L	06/17/25 14:34	06/17/25 14:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2673		**Lims Reference ID:**		**ED53309-05**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/17/25 14:38	06/17/25 14:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2675		**Lims Reference ID:**		**ED53309-06**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 14:40	06/17/25 14:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2677		**Lims Reference ID:**		**ED53309-07**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	06/17/25 14:41	06/17/25 14:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2679		**Lims Reference ID:**		**ED53309-08**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.0		1	1.0	µg/L	06/17/25 14:42	06/17/25 14:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2681		**Lims Reference ID:**		**ED53309-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553309
LIMS Reference ID: ED53309
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School: 1 Melody Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:04
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2681 (Continued)		**Lims Reference ID:**		**ED53309-09**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	3.9		1	1.0	µg/L	06/17/25 14:44	06/17/25 14:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2685		**Lims Reference ID:**		**ED53309-10**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	2.1		1	1.0	µg/L	06/17/25 14:45	06/17/25 14:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2687		**Lims Reference ID:**		**ED53309-11**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	14.9		1	1.0	µg/L	06/17/25 14:49	06/17/25 14:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2689		**Lims Reference ID:**		**ED53309-12**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	06/16/25 18:52	06/16/25 18:52	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-2691		**Lims Reference ID:**		**ED53309-13**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	6.4		1	1.0	µg/L	06/17/25 14:50	06/17/25 14:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2695		**Lims Reference ID:**		**ED53309-14**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	06/17/25 15:04	06/17/25 15:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2698		**Lims Reference ID:**		**ED53309-15**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:05	06/17/25 15:05	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2700		**Lims Reference ID:**		**ED53309-16**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:06	06/17/25 15:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2702		**Lims Reference ID:**		**ED53309-17**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553309
LIMS Reference ID: ED53309
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School: 1 Melody Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:04
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2702 (Continued)		**Lims Reference ID:**		**ED53309-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:08	06/17/25 15:08	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2704		**Lims Reference ID:**		**ED53309-18**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:09	06/17/25 15:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2705		**Lims Reference ID:**		**ED53309-19**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	32.5		1	1.0	µg/L	06/17/25 15:10	06/17/25 15:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2708		**Lims Reference ID:**		**ED53309-20**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:11	06/17/25 15:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2717		**Lims Reference ID:**		**ED53309-21**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:22	06/17/25 13:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2719		**Lims Reference ID:**		**ED53309-22**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.7		1	1.0	µg/L	06/17/25 13:23	06/17/25 13:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2721		**Lims Reference ID:**		**ED53309-23**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:24	06/17/25 13:24	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2723		**Lims Reference ID:**		**ED53309-24**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	7.8		1	1.0	µg/L	06/17/25 13:26	06/17/25 13:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2725		**Lims Reference ID:**		**ED53309-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553309
LIMS Reference ID: ED53309
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School: 1 Melody Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:04
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2725 (Continued)		**Lims Reference ID:**		**ED53309-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:27	06/17/25 13:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2727		**Lims Reference ID:**		**ED53309-26**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.4		1	1.0	µg/L	06/17/25 18:48	06/17/25 18:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2731		**Lims Reference ID:**		**ED53309-27**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	16.7		1	1.0	µg/L	06/17/25 18:52	06/17/25 18:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2733		**Lims Reference ID:**		**ED53309-28**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.2		1	1.0	µg/L	06/17/25 15:27	06/17/25 15:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2988		**Lims Reference ID:**		**ED53309-29**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.0		1	1.0	µg/L	06/17/25 15:31	06/17/25 15:31	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3067		**Lims Reference ID:**		**ED53309-30**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:32	06/17/25 15:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3068		**Lims Reference ID:**		**ED53309-31**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:33	06/17/25 15:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3069		**Lims Reference ID:**		**ED53309-32**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:34	06/17/25 15:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3070		**Lims Reference ID:**		**ED53309-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553309
LIMS Reference ID: ED53309
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School: 1 Melody Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:04
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3070 (Continued)			**Lims Reference ID:**	**ED53309-33**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 15:38	06/17/25 15:38	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553309
LIMS Reference ID: ED53309
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School: 1 Melody Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:04
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553309
LIMS Reference ID: ED53309
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School: 1 Melody Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:04
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for E057887

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southeast Elementary School

SES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2705	KI	1029	Kitchen	HW	12/23/2025	6:54:00 AM

Samples Submitted 1

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:15

Pb 200.8 Lab Tubes 12/24/25

Building Address
1 Melody Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: James Han 12/23/25

Signature: 215 PM

Samplers Name: Danielle Balzano

Samplers Signature:

JCB Project Manager: Meghan Bergen

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557887
LIMS Reference ID: ED57887
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Southeast Elementary School SES - Brentwood Union Free School District - 1 Melody Lane Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:15
Reported: 12/24/2025 16:56

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2705			**Lims Reference ID:**	**ED57887-01**	**Matrix: Drinking Water**			**Sampled:**	**12/23/25 06:54:00**
Metals									
Lead	**10.3**		1	1.0	µg/L	12/24/25 13:22	12/24/25 13:22	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557887
LIMS Reference ID: ED57887
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	23-53744 - Southeast Elementary School SES - Brentwood Union Free School District - 1 Melody Lane Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 14:15
Reported:	12/24/2025 16:56

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557887
LIMS Reference ID: ED57887
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	23-53744 - Southeast Elementary School SES - Brentwood Union Free School District - 1 Melody Lane Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 14:15
Reported:	12/24/2025 16:56

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57969

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southeast Elementary School

SES

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2705	KI	1029	Kitchen	HW	12/30/2025	7:14:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:36

Pb 200.8
Kathwlw
12/31/25

Building Address
1 Melody Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/30/25 4:36 PM

Signature: Davi Wharton

Samplers Name: Donielle Bobagian

Samplers Signature:

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557969

LIMS Reference ID: ED57969

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Southeast Elementary School SES / 1 Melody Lane, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:36

Reported: 12/31/2025 15:33

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2705			**Lims Reference ID:**	**ED57969-01**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 00:00:00**
Metals									
Lead	**32.9**		1	1.0	µg/L	12/31/25 13:56	12/31/25 13:56	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557969

LIMS Reference ID: ED57969

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Southeast Elementary School SES / 1 Melody Lane, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:36

Reported: 12/31/2025 15:33

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557969

LIMS Reference ID: ED57969

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	23-53744 / Brentwood Union Free School District / Southeast Elementary School SES / 1 Melody Lane, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/30/2025 16:36
Reported:	12/31/2025 15:33

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50114

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southeast Elementary School
SES

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk **Rush** 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2668	CR	1002	Room 102	DW	1/9/2026	7:29:00 AM
BRTWD-2687	OF	1012	Room 3	DW	1/9/2026	7:27:00 AM
BRTWD-2691	CR	1014	Room 1	DW	1/9/2026	7:31:00 AM
BRTWD-2723	CR	1043	Room 15	DW	1/9/2026	7:19:00 AM
BRTWD-2731	CR	1047	Room 19	DW	1/9/2026	7:21:00 AM

Samples Submitted 5

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 09 26, PM02:54

Walk In

Building Address
1 Melody Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 1/9/26 2:54 PM

Signature:

Samplers Name: Danielle Sabagnini

Samplers Signature:

JCB Project Manager: Meghan Burgess

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650114
LIMS Reference ID: EE50114
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Southeast Elementary School SES / 1 Melody Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:54
Reported: 01/12/2026 08:55

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2668		**Lims Reference ID:**		**EE50114-01**	**Matrix: Drinking Water**				**Sampled: 01/09/26 07:29:00**
Metals									
Lead	**4.1**	1	1.0	µg/L	01/10/26 16:49	01/10/26 16:49	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2687		**Lims Reference ID:**		**EE50114-02**	**Matrix: Drinking Water**				**Sampled: 01/09/26 07:27:00**
Metals									
Lead	**4.3**	1	1.0	µg/L	01/10/26 16:50	01/10/26 16:50	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2691		**Lims Reference ID:**		**EE50114-03**	**Matrix: Drinking Water**				**Sampled: 01/09/26 07:31:00**
Metals									
Lead	**1.5**	1	1.0	µg/L	01/10/26 16:51	01/10/26 16:51	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2723		**Lims Reference ID:**		**EE50114-04**	**Matrix: Drinking Water**				**Sampled: 01/09/26 07:19:00**
Metals									
Lead	**8.6**	1	1.0	µg/L	01/10/26 16:53	01/10/26 16:53	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2731		**Lims Reference ID:**		**EE50114-05**	**Matrix: Drinking Water**				**Sampled: 01/09/26 07:21:00**
Metals									
Lead	**16.5**	1	1.0	µg/L	01/10/26 16:54	01/10/26 16:54	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650114
LIMS Reference ID: EE50114
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Southeast Elementary School SES / 1 Melody Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:54
Reported: 01/12/2026 08:55

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650114
LIMS Reference ID: EE50114
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Southeast Elementary School SES / 1 Melody Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:54
Reported: 01/12/2026 08:55

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE51081

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southeast Elementary School

SES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4288	HA	1032	Gym Corridor	WF	3/4/2026	7:12:00 AM
BRTWD-4289	HA	1032	Gym Corridor	WC	3/4/2026	7:12:00 AM

Samples Submitted 2

Walk In

Pb 200.8 Billing 3/5/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 04 26, PM04:53

Building Address
1 Melody Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 3/4/26 4:53 PM

Signature: Dair Wharton

Samplers Name: Danielle Galeguni

Samplers Signature: Dan

JCB Project Manager: Meghan Guyan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651081
LIMS Reference ID: EE51081
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School SES, 1 Melody Lane, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/04/2026 16:53
Reported: 03/05/2026 13:52

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4288		**Lims Reference ID:**		**EE51081-01**	**Matrix: Drinking Water**				**Sampled: 03/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/05/26 12:33	03/05/26 12:33	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4289		**Lims Reference ID:**		**EE51081-02**	**Matrix: Drinking Water**				**Sampled: 03/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/05/26 12:34	03/05/26 12:34	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651081
LIMS Reference ID: EE51081
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Southeast Elementary School SES, 1 Melody Lane, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/04/2026 16:53
Reported:	03/05/2026 13:52

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651081
LIMS Reference ID: EE51081
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Southeast Elementary School SES, 1 Melody Lane, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/04/2026 16:53
Reported:	03/05/2026 13:52

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE51665

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southeast Elementary School

SES

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2673	CR	1005	Room 12	DW	3/26/2026	7:23:00 AM
BRTWD-2723	CR	1043	Room 15	DW	3/26/2026	7:26:00 AM

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 26 26, PM03:46

Walk In

PO 3/26/26

Building Address
1 Melody Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 3/26/26 3:46 pm

Signature:

Samplers Name: Danielle Bolognese

Samplers Signature:

JCB Project Manager: Meghan Gaynor

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651665
LIMS Reference ID: EE51665
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School SES, 1 Melody Lane, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/26/2026 15:46
Reported: 03/28/2026 23:36

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2673		**Lims Reference ID:**		**EE51665-01**	**Matrix: Drinking Water**			**Sampled:**	**03/26/26 00:00:00**
Metals									
Lead	**11.9**		1	1.0	µg/L	03/28/26 20:16	03/28/26 20:16	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2723		**Lims Reference ID:**		**EE51665-02**	**Matrix: Drinking Water**			**Sampled:**	**03/26/26 00:00:00**
Metals									
Lead	**11.1**		1	1.0	µg/L	03/28/26 20:17	03/28/26 20:17	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651665
LIMS Reference ID: EE51665
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School SES, 1 Melody Lane, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/26/2026 15:46
Reported: 03/28/2026 23:36

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651665
LIMS Reference ID: EE51665
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southeast Elementary School SES, 1 Melody Lane, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/26/2026 15:46
Reported: 03/28/2026 23:36

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Walk In

Lead in Water: Chain of Custody for EE52508

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Southeast Elementary School

SES

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2673	CR	1005	Room 12	DW	5/1/2026	6:59:00 AM
BRTWD-2723	CR	1043	Room 15	DW	5/1/2026	6:56:00 AM

Samples Submitted 2

200.8 5/3/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAY 01 26, PM08:31

Building Address
1 Melody Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 5/1/26 20:31

Signature: Kay Washkin

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652508

LIMS Reference ID: EE52508

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Southeast Elementary School: 1 Melody Lnae, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 05/01/2026 20:31

Reported: 05/04/2026 09:04

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2673		**Lims Reference ID:**		**EE52508-01**	**Matrix: Drinking Water**				**Sampled: 05/01/26 00:00:00**
Metals									
Lead	**1.5**		1	1.0	µg/L	05/03/26 11:56	05/03/26 11:56	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-2723		**Lims Reference ID:**		**EE52508-02**	**Matrix: Drinking Water**				**Sampled: 05/01/26 00:00:00**
Metals									
Lead	**12.4**		1	1.0	µg/L	05/03/26 11:58	05/03/26 11:58	BP	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652508
LIMS Reference ID: EE52508
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Southeast Elementary School: 1 Melody Lnae, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/01/2026 20:31
Reported: 05/04/2026 09:04

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	05/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652508
LIMS Reference ID: EE52508
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Southeast Elementary School: 1 Melody Lnae, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/01/2026 20:31
Reported: 05/04/2026 09:04

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE52581

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Southeast Elementary School

SES

Client: Brentwood Union Free School District

Retest/New Install ☑

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2723	CR	1043	Room 15	DW	5/7/2026	7:05:00 AM

Samples Submitted 1

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAY 07 26, PM01:57

Walk In

Pb 200.8 ar 57876

Building Address
1 Melody Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 5/7/26 1:57 PM

Signature:

Samplers Name: Danielle Bolognese

Samplers Signature:

JCB Project Manager: Danielle Bolognese

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652581
LIMS Reference ID: EE52581
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Southeast Elementary School SES, 1 Melody Lane, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/07/2026 13:57
Reported: 05/08/2026 10:20

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2723			**Lims Reference ID:**	**EE52581-01**	**Matrix: Drinking Water**			**Sampled:**	**05/07/26 00:00:00**
Metals									
Lead	**4.4**		1	1.0	µg/L	05/08/26 01:19	05/08/26 01:19	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652581
LIMS Reference ID: EE52581
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Southeast Elementary School SES, 1 Melody Lane, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/07/2026 13:57
Reported: 05/08/2026 10:20

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	05/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652581
LIMS Reference ID: EE52581
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Southeast Elementary School SES, 1 Melody Lane, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/07/2026 13:57
Reported: 05/08/2026 10:20

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EDS 3239

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53477

Building: Brentwood Ross High School
ROSS

RECEIVED
ENSR ENVIRONMENTAL, INC.
Carle Place, NY
JUN 25, PM01:27

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal [ ] wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0357	HA	1025	Corridor Near Shop Storage Room (1004)	DW	6/7/2025	7:01:00 AM
BRTWD-0403	HA	N/A	Music Hallway	WC	6/7/2025	7:32:00 AM
BRTWD-0404	HA	N/A	Music Hallway	WC	6/7/2025	7:32:00 AM
BRTWD-0414	HA	1064	Corridor Near Room 1103 (1060)	DW	6/7/2025	7:25:00 AM
BRTWD-0415	HA	1064	Corridor Near Room 1110 (1057)	DW	6/7/2025	7:23:00 AM
BRTWD-0449	HA	N/A	Corridor Near Room 1117	WC	6/7/2025	6:48:00 AM
BRTWD-0450	HA	N/A	Corridor Near Room 1117	WC	6/7/2025	6:48:00 AM
BRTWD-0517	CC	1088	Custodial Closet	IM	6/7/2025	6:53:00 AM
BRTWD-0540	NO	1066B	Health Office Suite Nurse's Office	NS	6/7/2025	6:57:00 AM
BRTWD-0574	HA	N/A	Corridor Near Girls Bathroom	WC	6/7/2025	7:11:00 AM
BRTWD-0575	HA	N/A	Corridor Near Girls Bathroom	WC	6/7/2025	7:11:00 AM
BRTWD-0587	KI	1074	Kitchen	HW	6/7/2025	6:36:00 AM
BRTWD-0588	KI	1074	Kitchen	KC	6/7/2025	6:25:00 AM
BRTWD-0590	KI	1074	Kitchen	PK	6/7/2025	6:26:00 AM
BRTWD-0591	KI	1074	Kitchen	HW	6/7/2025	6:24:00 AM
BRTWD-0592	KI	1074	Kitchen	KC	6/7/2025	6:30:00 AM
BRTWD-0593	KI	N/A	Kitchen	HW	6/7/2025	6:31:00 AM
BRTWD-0594	KI	N/A	Kitchen	HW	6/12/2025	6:23:00 AM

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 13:27

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Guynn

Lead in Water: Chain of Custody for ED53239

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

RECEIVED
JUN 13 25, PM01:28

JCB #: 23-53477
Building: Brentwood Ross High School
ROSS

Client: Brentwood Union Free School District
ENSL ANALYTICAL, INC.
Carle Place, NY

Retest/New Install [ ]
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0598	KI	1074	Kitchen	HW	6/7/2025	6:26:00 AM
BRTWD-0599	KI	1074	Kitchen	KC	6/7/2025	6:28:00 AM
BRTWD-0601	KI	1074	Kitchen	KC	6/7/2025	6:28:00 AM
BRTWD-0602	KI	1074	Kitchen	KC	6/7/2025	6:29:00 AM
BRTWD-3100	HA	1086	Corridor to Locker Room	WC	6/7/2025	6:10:00 AM
BRTWD-3101	HA	1086	Corridor to Locker Room	WF	6/7/2025	6:10:00 AM
BRTWD-3102	HA	N/A	Corridor Outside Library Near Stairwell	WC	6/7/2025	7:12:00 AM
BRTWD-3103	HA	N/A	Corridor Outside Library Near Stairwell	WF	6/7/2025	7:12:00 AM
BRTWD-3104	HA	N/A	Vestibule Near Storage Room	WC	6/7/2025	7:08:00 AM
BRTWD-3105	HA	N/A	Vestibule Near Storage Room	WF	6/7/2025	7:08:00 AM
BRTWD-3164	CA	1075	Cafeteria	WC	6/7/2025	6:19:00 AM
BRTWD-3165	CA	1075	Cafeteria	WF	6/7/2025	6:19:00 AM
BRTWD-3616	CR	1002A	Room 1170 Storage	BWC	6/13/2025	6:17:00 AM
BRTWD-3617	CR	1002A	Room 1170 Storage	BWH	6/13/2025	6:17:00 AM
BRTWD-3671	LR	1081A	Girls Locker Room	WC	6/7/2025	6:15:00 AM
BRTWD-3672	LR	1081A	Girls Locker Room	WF	6/7/2025	6:15:00 AM
BRTWD-3673	LR	1084	Boys Locker Room	WC	6/7/2025	6:08:00 AM
BRTWD-3674	LR	1084	Boys Locker Room	WF	6/7/2025	6:08:00 AM

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: 6/13/25 13:27
Signature:

Samplers Name: Danielle Bolognini
Samplers Signature: Danielle Bolognini
JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for E053234

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53477

Building: Brentwood Ross High School

ROSS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3691	FL	1044	Room 1128 Faculty Lounge	KC	6/7/2025	7:23:00 AM
BRTWD-3947	HA	1099	Corridor 1171 to Boys Coach Office	WC	6/7/2025	6:06:00 AM
BRTWD-3948	HA	1099	Corridor 1171 to Boys Coach Office	WF	6/7/2025	6:06:00 AM
BRTWD-3949	SP	1101	Pool	WC	6/7/2025	6:12:00 AM
BRTWD-3950	SP	1101	Pool	WF	6/7/2025	6:13:00 AM
BRTWD-3955	HA	2017	Corridor Room 2202 to Room 2215	WC	6/7/2025	7:45:00 AM
BRTWD-3956	HA	2017	Corridor Room 2202 to Room 2215	WF	6/7/2025	7:45:00 AM
BRTWD-3963	HA	2017	Corridor Room 2202 to Room 2215	DW	6/7/2025	7:46:00 AM
BRTWD-3964	OF	1001A	Industrial Arts Room Storage	BWH	6/12/2025	6:28:00 AM
BRTWD-3968	OF	1001A	Industrial Arts Room Storage	BW	6/12/2025	6:28:00 AM
BRTWD-3969	OF	1001A	Industrial Arts Room Storage	BW	6/13/2025	6:20:00 AM
BRTWD-3970	ST	1002A	Room 1170 Storage	BW	6/13/2025	6:18:00 AM

Samples Submitted 48

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM01:28

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 13:25

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553239

LIMS Reference ID: ED53239

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53477

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 13:27

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0357		**Lims Reference ID:**		**ED53239-01**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:01:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 08:33	06/24/25 08:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0403		**Lims Reference ID:**		**ED53239-02**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:32:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 08:37	06/24/25 08:37	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0404		**Lims Reference ID:**		**ED53239-03**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:32:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 08:38	06/24/25 08:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0414		**Lims Reference ID:**		**ED53239-04**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:25:00**
Metals									
Lead	7.4		1	1.0	µg/L	06/24/25 08:40	06/24/25 08:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0415		**Lims Reference ID:**		**ED53239-05**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:23:00**
Metals									
Lead	6.6		1	1.0	µg/L	06/24/25 08:44	06/24/25 08:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0449		**Lims Reference ID:**		**ED53239-06**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:48:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 08:45	06/24/25 08:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0450		**Lims Reference ID:**		**ED53239-07**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:48:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 08:46	06/24/25 08:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0517		**Lims Reference ID:**		**ED53239-08**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:53:00**
Metals									
Lead	1.7		1	1.0	µg/L	06/24/25 08:48	06/24/25 08:48	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0540		**Lims Reference ID:**		**ED53239-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:57:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553239

LIMS Reference ID: ED53239

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53477

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 13:27

Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0540 (Continued)		**Lims Reference ID:**		**ED53239-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:57:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 08:49	06/24/25 08:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0574		**Lims Reference ID:**		**ED53239-10**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:11:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 08:50	06/24/25 08:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0575		**Lims Reference ID:**		**ED53239-11**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:11:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 08:51	06/24/25 08:51	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0587		**Lims Reference ID:**		**ED53239-12**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:36:00**
Metals									
Lead	1.5		1	1.0	µg/L	06/24/25 08:55	06/24/25 08:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0588		**Lims Reference ID:**		**ED53239-13**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:25:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 08:59	06/24/25 08:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0590		**Lims Reference ID:**		**ED53239-14**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:26:00**
Metals									
Lead	16.1		1	1.0	µg/L	06/24/25 09:01	06/24/25 09:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0591		**Lims Reference ID:**		**ED53239-15**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:24:00**
Metals									
Lead	3.1		1	1.0	µg/L	06/24/25 09:02	06/24/25 09:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0592		**Lims Reference ID:**		**ED53239-16**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:30:00**
Metals									
Lead	2.7		1	1.0	µg/L	06/24/25 09:03	06/24/25 09:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0593		**Lims Reference ID:**		**ED53239-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:31:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553239
LIMS Reference ID: ED53239
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53477
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 13:27
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0593 (Continued)		**Lims Reference ID:**		**ED53239-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:31:00**
Metals (Continued)									
Lead	1.3		1	1.0	µg/L	06/24/25 09:05	06/24/25 09:05	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0594		**Lims Reference ID:**		**ED53239-18**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:23:00**
Metals									
Lead	32.6		1	1.0	µg/L	06/24/25 09:20	06/24/25 09:20	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0598		**Lims Reference ID:**		**ED53239-19**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:26:00**
Metals									
Lead	2.7		1	1.0	µg/L	06/24/25 09:24	06/24/25 09:24	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0599		**Lims Reference ID:**		**ED53239-20**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:28:00**
Metals									
Lead	2.0		1	1.0	µg/L	06/24/25 09:25	06/24/25 09:25	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0601		**Lims Reference ID:**		**ED53239-21**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:28:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:26	06/24/25 09:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0602		**Lims Reference ID:**		**ED53239-22**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:29:00**
Metals									
Lead	20.7		1	1.0	µg/L	06/26/25 09:12	06/26/25 09:12	SEH	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-3100		**Lims Reference ID:**		**ED53239-23**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:10:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:28	06/24/25 09:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3101		**Lims Reference ID:**		**ED53239-24**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:10:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:32	06/24/25 09:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3102		**Lims Reference ID:**		**ED53239-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:12:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553239

LIMS Reference ID: ED53239

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53477

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 13:27

Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3102 (Continued)		**Lims Reference ID:**		**ED53239-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:12:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:33	06/24/25 09:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3103		**Lims Reference ID:**		**ED53239-26**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:12:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:34	06/24/25 09:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3104		**Lims Reference ID:**		**ED53239-27**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:08:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:36	06/24/25 09:36	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3105		**Lims Reference ID:**		**ED53239-28**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:08:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:37	06/24/25 09:37	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3164		**Lims Reference ID:**		**ED53239-29**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:19:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:38	06/24/25 09:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3165		**Lims Reference ID:**		**ED53239-30**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:19:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:42	06/24/25 09:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3616		**Lims Reference ID:**		**ED53239-31**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:17:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:44	06/24/25 09:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3617		**Lims Reference ID:**		**ED53239-32**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:17:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:48	06/24/25 09:48	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3671		**Lims Reference ID:**		**ED53239-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:15:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553239
LIMS Reference ID: ED53239
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53477
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 13:27
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3671 (Continued)		**Lims Reference ID:**		**ED53239-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:15:00**
Metals (Continued)									
Lead	2.6		1	1.0	µg/L	06/24/25 09:49	06/24/25 09:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3672		**Lims Reference ID:**		**ED53239-34**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:15:00**
Metals									
Lead	3.2		1	1.0	µg/L	06/24/25 09:50	06/24/25 09:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3673		**Lims Reference ID:**		**ED53239-35**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:08:00**
Metals									
Lead	1.6		1	1.0	µg/L	06/24/25 09:52	06/24/25 09:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3674		**Lims Reference ID:**		**ED53239-36**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:08:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:53	06/24/25 09:53	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3691		**Lims Reference ID:**		**ED53239-37**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:23:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:54	06/24/25 09:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3947		**Lims Reference ID:**		**ED53239-38**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:06:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 09:56	06/24/25 09:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3948		**Lims Reference ID:**		**ED53239-39**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:06:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:43	06/24/25 11:43	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3949		**Lims Reference ID:**		**ED53239-40**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:12:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:47	06/24/25 11:47	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3950		**Lims Reference ID:**		**ED53239-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:13:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553239
LIMS Reference ID: ED53239
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53477
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 13:27
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3950 (Continued)		**Lims Reference ID:**		**ED53239-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:13:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:48	06/24/25 11:48	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3955		**Lims Reference ID:**		**ED53239-42**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:45:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:50	06/24/25 11:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3956		**Lims Reference ID:**		**ED53239-43**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:45:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:51	06/24/25 11:51	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3963		**Lims Reference ID:**		**ED53239-44**	**Matrix: Drinking Water**				**Sampled: 06/13/25 07:46:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:55	06/24/25 11:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3964		**Lims Reference ID:**		**ED53239-45**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:28:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:56	06/24/25 11:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3968		**Lims Reference ID:**		**ED53239-46**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:28:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:57	06/24/25 11:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3969		**Lims Reference ID:**		**ED53239-47**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:20:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 11:59	06/24/25 11:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3970		**Lims Reference ID:**		**ED53239-48**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:18:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:00	06/24/25 12:00	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553239
LIMS Reference ID: ED53239
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53477
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 13:27
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553239

LIMS Reference ID: ED53239

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53477

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 13:27

Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED56323

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Ross High School

ROSS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4237	HA	1099	Corridor 1171 to Boys Coach Office	WF	10/2/2025	7:50:00 AM
BRTWD-4238	HA	1099	Corridor 1171 to Boys Coach Office	WC	10/2/2025	7:51:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 02 25, PM03:14

Pb 200.8 Kathleen 10/03/25

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/2/25 3:14 PM

Signature: David Wharton

Samplers Name: Meghan Guygan

Samplers Signature: Meghan Guygan

JCB Project Manager: Meghan Guy

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556323

LIMS Reference ID: ED56323

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Brentwood Ross High School (ROSS), 1 South Fifth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/02/2025 15:14

Reported: 10/04/2025 09:37

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4237		**Lims Reference ID:**		**ED56323-01**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 17:55	10/03/25 17:55	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4238		**Lims Reference ID:**		**ED56323-02**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 17:57	10/03/25 17:57	KT1	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556323

LIMS Reference ID: ED56323

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Brentwood Ross High School (ROSS), 1 South Fifth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/02/2025 15:14

Reported: 10/04/2025 09:37

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556323

LIMS Reference ID: ED56323

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Brentwood Ross High School (ROSS), 1 South Fifth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/02/2025 15:14

Reported: 10/04/2025 09:37

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

E056702

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Ross High School

ROSS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush** 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4250	HA	N/A	Corridor Outside Library Near Stairwell	WF	10/23/2025	6:38:00 AM
BRTWD-4251	HA	N/A	Corridor Outside Library Near Stairwell	WC	10/23/2025	6:39:00 AM

Samples Submitted 2

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 23 25, PM12:20

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: James Han 10/23/25

Signature: 1220PM

Samplers Name: Meghan Guynn

Samplers Signature: Meghan Guynn

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556702

LIMS Reference ID: ED56702

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Brentwood Ross High School ROSS - Brentwood Union Free School District - 1 South Fifth Avenue Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/23/2025 12:20

Reported: 10/25/2025 10:59

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4250		**Lims Reference ID:**		**ED56702-01**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:38:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/24/25 17:25	10/24/25 17:25	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4251		**Lims Reference ID:**		**ED56702-02**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:39:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/24/25 17:42	10/24/25 17:42	KT1	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556702
LIMS Reference ID: ED56702
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Brentwood Ross High School ROSS - Brentwood Union Free School District - 1 South Fifth Avenue Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 12:20
Reported: 10/25/2025 10:59

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556702

LIMS Reference ID: ED56702

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Brentwood Ross High School ROSS - Brentwood Union Free School District - 1 South Fifth Avenue Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/23/2025 12:20

Reported: 10/25/2025 10:59

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for E057885

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Ross High School

ROSS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0590	KI	1074	Kitchen	PK	12/23/2025	6:01:00 AM
BRTWD-0594	KI	N/A	Kitchen	HW	12/23/2025	6:18:00 AM
BRTWD-0602	KI	1074	Kitchen	KC	12/23/2025	6:02:00 AM

Samples Submitted 3

Pb 200.8 Rolling 12/24/25

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:17

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: James Hen 12/23/25

Signature: 2:17pm

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557885

LIMS Reference ID: ED57885

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Brentwood Ross High School ROSS - Brentwood Union Free School District - 1 South Fifth Avenue Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:17

Reported: 12/24/2025 15:52

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0590		**Lims Reference ID:**		**ED57885-01**	**Matrix: Drinking Water**				**Sampled: 12/23/25 06:01:00**
Metals									
Lead	**6.2**		1	1.0	µg/L	12/24/25 11:20	12/24/25 11:20	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0594		**Lims Reference ID:**		**ED57885-02**	**Matrix: Drinking Water**				**Sampled: 12/23/25 06:18:00**
Metals									
Lead	**12.2**		1	1.0	µg/L	12/24/25 11:21	12/24/25 11:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0602		**Lims Reference ID:**		**ED57885-03**	**Matrix: Drinking Water**				**Sampled: 12/23/25 06:02:00**
Metals									
Lead	**3.7**		1	1.0	µg/L	12/24/25 11:22	12/24/25 11:22	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557885
LIMS Reference ID: ED57885
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Brentwood Ross High School ROSS - Brentwood Union Free School District - 1 South Fifth Avenue Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:17
Reported: 12/24/2025 15:52

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557885

LIMS Reference ID: ED57885

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	23-53744 - Brentwood Ross High School ROSS - Brentwood Union Free School District - 1 South Fifth Avenue Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 14:17
Reported:	12/24/2025 15:52

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57960

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Ross High School

ROSS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0590	KI	1074	Kitchen	PK	12/30/2025	6:58:00 AM
BRTWD-0594	KI	N/A	Kitchen	HW	12/30/2025	6:57:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:37

Pb 200.8
Kathleen
12/31/25

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 12/30/25 16:37

Signature: KAY WARNER

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557960

LIMS Reference ID: ED57960

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:37

Reported: 12/31/2025 15:28

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0590		**Lims Reference ID:**		**ED57960-01**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 06:58:00**
Metals									
Lead	**6.0**		1	1.0	µg/L	12/31/25 13:44	12/31/25 13:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0594		**Lims Reference ID:**		**ED57960-02**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 06:57:00**
Metals									
Lead	**8.6**		1	1.0	µg/L	12/31/25 13:45	12/31/25 13:45	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557960

LIMS Reference ID: ED57960

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/30/2025 16:37
Reported:	12/31/2025 15:28

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557960

LIMS Reference ID: ED57960

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/30/2025 16:37
Reported:	12/31/2025 15:28

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50047

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Ross High School

ROSS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk /Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4267	HA	2017	Corridor Near Room 2215	WC	1/6/2026	6:33:00 AM

Samples Submitted 1

Pb 200.8 Bldg 1/8/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 06 26, PM06:15

Drop Box

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 1/6/26 6:15 pm

Signature: Dair Wha

Samplers Name: Meghan Guynn

Samplers Signature: Megha Guy

JCB Project Manager: Meghan Gu

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650047

LIMS Reference ID: EE50047

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Brentwood Ross High School ROSS / 1 South Fifth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 01/06/2026 18:15

Reported: 01/08/2026 12:13

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4267			**Lims Reference ID:**	**EE50047-01**	**Matrix: Drinking Water**			**Sampled:**	**01/06/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/08/26 11:12	01/08/26 11:12	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650047

LIMS Reference ID: EE50047

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Brentwood Ross High School ROSS / 1 South Fifth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 01/06/2026 18:15

Reported: 01/08/2026 12:13

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650047
LIMS Reference ID: EE50047
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	23-53744 / Brentwood Union Free School District / Brentwood Ross High School ROSS / 1 South Fifth Avenue, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	01/06/2026 18:15
Reported:	01/08/2026 12:13

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EE50868

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Ross High School

ROSS

Client: Brentwood Union Free School District

Retest/New Install N

Turn Around: Normal 1 wk Rush 48 hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0590	KI	1074	Kitchen	PK	2/18/2026	6:44:00 AM
BRTWD-0594	KI	N/A	Kitchen	HW	2/18/2026	6:47:00 AM

Samples Submitted 2

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 18 26, PM01:51

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved:

Signature:

Samplers Name: Danielle Colagiovanni

Samplers Signature:

JCB Project Manager: Meghan Gaughan

PO 2008 2/19/26

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650868

LIMS Reference ID: EE50868

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Brentwood Ross High School, Brentwood Union Free School District, 1 South Fifth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 02/18/2026 13:51

Reported: 02/19/2026 09:08

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0590			**Lims Reference ID:**		**EE50868-01**	**Matrix: Drinking Water**			**Sampled: 02/18/26 00:00:00**
Metals									
Lead	**5.7**		1	1.0	µg/L	02/19/26 01:22	02/19/26 01:22	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0594			**Lims Reference ID:**		**EE50868-02**	**Matrix: Drinking Water**			**Sampled: 02/18/26 00:00:00**
Metals									
Lead	**13.6**		1	1.0	µg/L	02/19/26 01:23	02/19/26 01:23	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650868
LIMS Reference ID: EE50868
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Brentwood Ross High School, Brentwood Union Free School District, 1 South Fifth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/18/2026 13:51
Reported: 02/19/2026 09:08

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650868
LIMS Reference ID: EE50868
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Brentwood Ross High School, Brentwood Union Free School District, 1 South Fifth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/18/2026 13:51
Reported: 02/19/2026 09:08

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE51052

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Brentwood Ross High School
ROSS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0590	KI	1074	Kitchen	PK	3/3/2026	6:56:00 AM

Samples Submitted 1

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 03 26, PM01:36

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 3/3/26 1:36 PM

Signature: Davi Wharton

PO 2003 3/3/26

Samplers Name: Meghan Gwynn

Samplers Signature: Meghan Gwynn

JCB Project Manager: Meghan Gwy

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651052

LIMS Reference ID: EE51052

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School ROSS, 1 South Fifth Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 03/03/2026 13:36

Reported: 03/05/2026 09:39

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0590			**Lims Reference ID:**	**EE51052-01**	**Matrix: Drinking Water**			**Sampled:**	**03/03/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/05/26 00:42	03/05/26 00:42	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651052
LIMS Reference ID: EE51052
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Brentwood Ross High School ROSS, 1 South Fifth Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/03/2026 13:36
Reported: 03/05/2026 09:39

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651052
LIMS Reference ID: EE51052
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Brentwood Ross High School ROSS, 1 South Fifth Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/03/2026 13:36
Reported:	03/05/2026 09:39

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Walk In

Lead in Water: Chain of Custody for EE52510

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123
Building: Brentwood Ross High School
ROSS

Client: Brentwood Union Free School District

Retest/New Install ✓
Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0370	HA	1025	Corridor Near Room 1157 (1018)	DW	5/1/2026	7:53:00 AM
BRTWD-4293	HA	N/A	Corridor Near Room 1117	WF	5/1/2026	7:42:00 AM
BRTWD-4294	HA	N/A	Corridor Near Room 1117	WC	5/1/2026	7:43:00 AM

Samples Submitted 3

Pb 200.8 Bllmy 5/3/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAY 01 26, PM08:31

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: 5/1/26 20:31
Signature: KAY WHEELER

Samplers Name: Danielle Bolognini
Samplers Signature:
JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652510
LIMS Reference ID: EE52510
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/01/2026 20:31
Reported: 05/04/2026 09:12

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0370		**Lims Reference ID:**		**EE52510-01**	**Matrix: Drinking Water**				**Sampled: 05/01/26 00:00:00**
Metals									
Lead	**1.7**		1	1.0	µg/L	05/03/26 12:03	05/03/26 12:03	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4293		**Lims Reference ID:**		**EE52510-02**	**Matrix: Drinking Water**				**Sampled: 05/01/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	05/03/26 12:04	05/03/26 12:04	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4294		**Lims Reference ID:**		**EE52510-03**	**Matrix: Drinking Water**				**Sampled: 05/01/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	05/03/26 12:06	05/03/26 12:06	BP	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652510

LIMS Reference ID: EE52510

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 05/01/2026 20:31

Reported: 05/04/2026 09:12

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	05/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652510
LIMS Reference ID: EE52510
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Ross High School: 1 South Fifth Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/01/2026 20:31
Reported: 05/04/2026 09:12

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE54403

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Brentwood Ross High School

ROSS

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4328	HA	1049	Corridor Assistant Principal Office to Room 1115	WF	9/4/2026	9:42:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
SEP 04 26, PM02:26

915726

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 9/4/2026

Signature:

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654403

LIMS Reference ID: EE54403

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: 26-64123, Brentwood Ross High School, Brentwood Union Free School District, 1 South Fifth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/04/2026 14:26

Reported: 09/08/2026 08:54

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4328			**Lims Reference ID:**	**EE54403-01**	**Matrix: Drinking Water**			**Sampled:**	**09/03/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/05/26 18:21	09/05/26 18:21	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654403

LIMS Reference ID: EE54403

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: 26-64123, Brentwood Ross High School, Brentwood Union Free School District, 1 South Fifth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/04/2026 14:26

Reported: 09/08/2026 08:54

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654403
LIMS Reference ID: EE54403
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: 26-64123, Brentwood Ross High School, Brentwood Union Free School District, 1 South Fifth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/04/2026 14:26
Reported: 09/08/2026 08:54

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE546664

Courier

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Brentwood Ross High School

ROSS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk (Rush 48 hour)

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3955	HA	2017	Corridor Room 2202 to Room 2215	WC	9/28/2026	6:42:00 AM
BRTWD-3956	HA	2017	Corridor Room 2202 to Room 2215	WF	9/28/2026	6:41:00 AM

Samples Submitted 2

Pb 200.8 Billing 10/1/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
SEP 29 26, PM01:02

Building Address
1 South Fifth Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 9/29/26 1:08pm

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654664

LIMS Reference ID: EE54664

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Ross High School, Brentwood Union Free School District, 26-64123, 1 South Fifth Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/29/2026 13:02

Reported: 10/01/2026 16:28

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3955		**Lims Reference ID:**		**EE54664-01**	**Matrix: Drinking Water**				**Sampled: 09/28/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/01/26 16:12	10/01/26 16:12	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3956		**Lims Reference ID:**		**EE54664-02**	**Matrix: Drinking Water**				**Sampled: 09/28/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/01/26 16:13	10/01/26 16:13	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654664
LIMS Reference ID: EE54664
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Ross High School, Brentwood Union Free School District, 26-64123, 1 South Fifth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/29/2026 13:02
Reported: 10/01/2026 16:28

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP ELLAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	11/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654664
LIMS Reference ID: EE54664
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Brentwood Ross High School, Brentwood Union Free School District, 26-64123, 1 South Fifth Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/29/2026 13:02
Reported: 10/01/2026 16:28

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

E D53307

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southwest Elementary School

SWES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0714	CR	1005	Kindergarten Room 2A	DW	6/5/2025	7:45:00 AM
BRTWD-0717	CR	1006	Kindergarten Room 1A	DW	6/5/2025	7:46:00 AM
BRTWD-0720	CR	1007	Room 3A	DW	6/5/2025	7:44:00 AM
BRTWD-0722	CR	1008	Room 4A	DW	6/5/2025	7:43:00 AM
BRTWD-0724	CR	1009	Room 5A	DW	6/5/2025	7:43:00 AM
BRTWD-0726	CR	1010	Room 6A	DW	6/5/2025	7:42:00 AM
BRTWD-0728	CR	1011	Room 7A	DW	6/5/2025	7:41:00 AM
BRTWD-0730	CR	1012	Room 8A	DW	6/5/2025	7:39:00 AM
BRTWD-0732	CR	1013	Room 9A	DW	6/5/2025	7:37:00 AM
BRTWD-0736	CR	1016	Room 11A	DW	6/5/2025	7:36:00 AM
BRTWD-0740	NO	1022B	Cafeteria Nurse's Office	NS	6/5/2025	7:28:00 AM
BRTWD-0743	KI	1022D	Kitchen	HW	6/5/2025	7:25:00 AM
BRTWD-0745	KI	1022D	Kitchen	KC	6/5/2025	7:26:00 AM
BRTWD-0749	CR	1025	Math Lab (Room 2)	DW	6/5/2025	8:07:00 AM
BRTWD-0750	LI	1026	Library	OF	6/5/2025	7:19:00 AM
BRTWD-0752	CR	1027	Room 4	DW	6/5/2025	7:17:00 AM
BRTWD-0754	CR	1029B	Speech Room 6 Work Room 2	DW	6/5/2025	7:21:00 AM
BRTWD-0759	CR	1041	Room 31	DW	6/5/2025	6:35:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM 07:01

Building Address
1095 Joselson Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: ABanley 6/13/25 7:09pm

Signature:

Samplers Name: Erika Wilson

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for

ED53307

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southwest Elementary School

SWES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around Normal 1 wk **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0761	CR	1042	Room 33	DW	6/5/2025	6:34:00 AM
BRTWD-0763	CR	1043	Room 35	DW	6/5/2025	6:37:00 AM
BRTWD-0765	CR	1045	Room 34	DW	6/5/2025	6:39:00 AM
BRTWD-0767	CR	1046	Room 32	DW	6/5/2025	6:36:00 AM
BRTWD-0769	CR	1047	Room 30	DW	6/5/2025	6:32:00 AM
BRTWD-0777	FL	1063	Faculty Room	KC	6/5/2025	6:47:00 AM
BRTWD-0779	NO	1065	Nurse's Office	NS	6/5/2025	6:48:00 AM
BRTWD-0787	CR	1071	Room 15	DW	6/5/2025	6:51:00 AM
BRTWD-0789	CR	1072	Room 16	DW	6/5/2025	6:52:00 AM
BRTWD-0791	CR	1073	Room 17	DW	6/5/2025	6:54:00 AM
BRTWD-0793	CR	1074	Room 18	DW	6/5/2025	6:55:00 AM
BRTWD-0795	CR	1075	Room 19	DW	6/5/2025	6:56:00 AM
BRTWD-0797	CR	1076	Room 20	DW	6/5/2025	6:58:00 AM
BRTWD-0801	CR	1079	Room 21	DW	6/5/2025	7:00:00 AM
BRTWD-0803	CR	1080	Room 22	DW	6/5/2025	7:03:00 AM
BRTWD-0805	CR	1081	Room 23	DW	6/5/2025	7:04:00 AM
BRTWD-0807	CR	1082	Room 24	DW	6/5/2025	7:05:00 AM
BRTWD-0809	CR	1083	Room 25	DW	6/5/2025	7:06:00 AM

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM03:22

Building Address
1095 Joselson Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: A Stanley 6/13/25

Signature: 9:01pm

Samplers Name: Erika Wilson

Samplers Signature:

JCB Project Manager: Meghan Grogan

Lead in Water: Chain of Custody for

ED53307

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southwest Elementary School

SWES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0811	CR	1084	Room 26	DW	6/5/2025	7:07:00 AM
BRTWD-0819	CR	3004	Room36	DW	6/5/2025	7:09:00 AM
BRTWD-0820	CR	3006	Room38	DW	6/5/2025	7:10:00 AM
BRTWD-0823	CR	3005	Room37	DW	6/5/2025	7:11:00 AM
BRTWD-0825	CR	3007	Room 39	DW	6/5/2025	7:12:00 AM
BRTWD-0827	CR	2003	Room 13A	DW	6/5/2025	7:49:00 AM
BRTWD-0833	CR	2006	Room 14A	DW	6/5/2025	7:51:00 AM
BRTWD-0835	CR	2007	Room 17A	DW	6/5/2025	7:53:00 AM
BRTWD-0837	CR	2008	Room 16A	DW	6/5/2025	7:54:00 AM
BRTWD-0839	CR	2009	Room 19A	DW	6/5/2025	7:55:00 AM
BRTWD-0841	CR	2010	Room 18A	DW	6/5/2025	7:56:00 AM
BRTWD-0843	CR	2011	Room 21A	DW	6/5/2025	7:57:00 AM
BRTWD-0845	CR	2012	Room 20A	DW	6/5/2025	8:00:00 AM
BRTWD-0847	CR	2014	Room 22A	DW	6/5/2025	8:01:00 AM
BRTWD-0852	CR	2021	Room 46	DW	6/5/2025	8:21:00 AM
BRTWD-0854	CR	2022	Room 45	DW	6/5/2025	8:20:00 AM
BRTWD-0856	CR	2023	Room 44	DW	6/5/2025	8:19:00 AM
BRTWD-0858	CR	2024	Room 43	DW	6/5/2025	8:18:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25

Building Address
1095 Joselson Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: Saturday 06/13/25 9:10pm

Signature:

Samplers Name: Erica Wilson

Samplers Signature:

JCB Project Manager: Meghan Burgin

EDS 3307

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southwest Elementary School

SWES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal ~~1 wk~~ ~~Rush~~_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0860	CR	2025	Room 42	DW	6/5/2025	8:17:00 AM
BRTWD-0862	CR	2026	Room 41	DW	6/5/2025	8:16:00 AM
BRTWD-0871	CR	2028	Room 40	DW	6/5/2025	8:15:00 AM
BRTWD-0872	KI	1058A	Kitchen	HW	6/5/2025	6:14:00 AM
BRTWD-0874	KI	1058A	Kitchen	KC	6/5/2025	6:12:00 AM
BRTWD-0876	KI	1058A	Kitchen	KC	6/5/2025	6:18:00 AM
BRTWD-0878	KI	1058A	Kitchen	KC	6/5/2025	6:20:00 AM
BRTWD-0879	KI	1058A	Kitchen	KC	6/5/2025	6:19:00 AM
BRTWD-0880	KI	1058A	Kitchen	HW	6/5/2025	6:21:00 AM
BRTWD-0886	CR	1028	Room 5	DW	6/5/2025	7:22:00 AM
BRTWD-3075	HA	1066	Corridor Near Custodial Closet (1059)	WC	6/5/2025	6:42:00 AM
BRTWD-3076	HA	1066	Corridor Near Custodial Closet (1059)	WF	6/5/2025	6:44:00 AM
BRTWD-3077	HA	1021	Corridor Near Main Office (1020)	WC	6/5/2025	7:33:00 AM
BRTWD-3078	HA	1021	Corridor Near Main Office (1020)	WF	6/5/2025	7:34:00 AM
BRTWD-3172	HA	3008	Corridor Near Room 32	WC	6/5/2025	8:25:00 AM
BRTWD-3583	CR	1029B	Speech Room 6 Work Room 2 (Interior Wall Removed)	BWC	6/5/2025	8:10:00 AM
BRTWD-3584	CR	1029B	Speech Room 6 Work Room 2 (Interior Wall Removed)	BWH	6/5/2025	8:10:00 AM
BRTWD-3586	HE	1030	Math Lab Room 7	DW	6/5/2025	8:12:00 AM

RECEIVED
EMS ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 7:54:00 AM

Building Address
1095 Joselson Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: A Stanley 6/13/25 9:01pm

Signature:

Samplers Name: Erika Wilson

Samplers Signature:

JCB Project Manager: Meghan Guyan

E053307

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southwest Elementary School

SWES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3587	HE	1030	Math Lab Room 7	EC	6/5/2025	8:12:00 AM
BRTWD-3588	KI	1058A	Kitchen	PK	6/5/2025	6:24:00 AM
BRTWD-3596	CR	1077A3	Room 20X Inner Classroom 2	BWH	6/5/2025	8:26:00 AM

Samples Submitted 75

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:02

Building Address
1095 Joselson Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: A Stanley 6/13/25 9:01pm

Signature:

Samplers Name: Erika Wilson

Samplers Signature:

JCB Project Manager: Meghan Grayson

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0714		**Lims Reference ID:**		**ED53307-01**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	06/17/25 08:58	06/17/25 08:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0717		**Lims Reference ID:**		**ED53307-02**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 08:59	06/17/25 08:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0720		**Lims Reference ID:**		**ED53307-03**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/17/25 09:03	06/17/25 09:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0722		**Lims Reference ID:**		**ED53307-04**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:04	06/17/25 09:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0724		**Lims Reference ID:**		**ED53307-05**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	06/17/25 09:06	06/17/25 09:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0726		**Lims Reference ID:**		**ED53307-06**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	06/17/25 09:07	06/17/25 09:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0728		**Lims Reference ID:**		**ED53307-07**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	06/17/25 09:08	06/17/25 09:08	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0730		**Lims Reference ID:**		**ED53307-08**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	06/17/25 09:10	06/17/25 09:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0732		**Lims Reference ID:**		**ED53307-09**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0732 (Continued)		**Lims Reference ID:**		**ED53307-09**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:11	06/17/25 09:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0736		**Lims Reference ID:**		**ED53307-10**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:15	06/17/25 09:15	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0740		**Lims Reference ID:**		**ED53307-11**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	2.7		1	1.0	µg/L	06/17/25 09:19	06/17/25 09:19	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0743		**Lims Reference ID:**		**ED53307-12**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:20	06/17/25 09:20	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0745		**Lims Reference ID:**		**ED53307-13**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:21	06/17/25 09:21	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0749		**Lims Reference ID:**		**ED53307-14**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:23	06/17/25 09:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0750		**Lims Reference ID:**		**ED53307-15**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/17/25 09:24	06/17/25 09:24	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0752		**Lims Reference ID:**		**ED53307-16**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	2.5		1	1.0	µg/L	06/17/25 09:25	06/17/25 09:25	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0754		**Lims Reference ID:**		**ED53307-17**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0754 (Continued)			**Lims Reference ID:**	**ED53307-17**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals (Continued)									
Lead	1.2		1	1.0	µg/L	06/17/25 09:27	06/17/25 09:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0759			**Lims Reference ID:**	**ED53307-18**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:28	06/17/25 09:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0761			**Lims Reference ID:**	**ED53307-19**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:40	06/17/25 09:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0763			**Lims Reference ID:**	**ED53307-20**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:44	06/17/25 09:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0765			**Lims Reference ID:**	**ED53307-21**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	45.0		1	1.0	µg/L	06/17/25 09:46	06/17/25 09:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0767			**Lims Reference ID:**	**ED53307-22**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:47	06/17/25 09:47	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0769			**Lims Reference ID:**	**ED53307-23**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	2.2		1	1.0	µg/L	06/17/25 09:48	06/17/25 09:48	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0777			**Lims Reference ID:**	**ED53307-24**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	06/17/25 09:52	06/17/25 09:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0779			**Lims Reference ID:**	**ED53307-25**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0779 (Continued)		**Lims Reference ID:**		**ED53307-25**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals (Continued)									
Lead	1.2		1	1.0	µg/L	06/17/25 09:54	06/17/25 09:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0787		**Lims Reference ID:**		**ED53307-26**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	3.0		1	1.0	µg/L	06/17/25 09:55	06/17/25 09:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0789		**Lims Reference ID:**		**ED53307-27**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	06/17/25 09:56	06/17/25 09:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0791		**Lims Reference ID:**		**ED53307-28**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 09:58	06/17/25 09:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0793		**Lims Reference ID:**		**ED53307-29**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	71.2		1	1.0	µg/L	06/17/25 09:59	06/17/25 09:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0795		**Lims Reference ID:**		**ED53307-30**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 10:03	06/17/25 10:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0797		**Lims Reference ID:**		**ED53307-31**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	75.3		1	1.0	µg/L	06/17/25 10:04	06/17/25 10:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0801		**Lims Reference ID:**		**ED53307-32**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	11.3		1	1.0	µg/L	06/19/25 11:10	06/19/25 11:10	SEH	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-0803		**Lims Reference ID:**		**ED53307-33**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0803 (Continued)			**Lims Reference ID:**	**ED53307-33**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 10:08	06/17/25 10:08	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0805			**Lims Reference ID:**	**ED53307-34**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/17/25 10:09	06/17/25 10:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0807			**Lims Reference ID:**	**ED53307-35**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/17/25 10:11	06/17/25 10:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0809			**Lims Reference ID:**	**ED53307-36**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	06/17/25 10:12	06/17/25 10:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0811			**Lims Reference ID:**	**ED53307-37**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	06/17/25 10:13	06/17/25 10:13	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0819			**Lims Reference ID:**	**ED53307-38**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 10:15	06/17/25 10:15	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0820			**Lims Reference ID:**	**ED53307-39**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 10:16	06/17/25 10:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0823			**Lims Reference ID:**	**ED53307-40**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:04	06/17/25 12:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0825			**Lims Reference ID:**	**ED53307-41**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0825 (Continued)		**Lims Reference ID:**		**ED53307-41**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:08	06/17/25 12:08	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0827		**Lims Reference ID:**		**ED53307-42**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/17/25 12:09	06/17/25 12:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0833		**Lims Reference ID:**		**ED53307-43**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	2.7		1	1.0	µg/L	06/17/25 12:10	06/17/25 12:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0835		**Lims Reference ID:**		**ED53307-44**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:12	06/17/25 12:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0837		**Lims Reference ID:**		**ED53307-45**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	4.5		1	1.0	µg/L	06/17/25 12:16	06/17/25 12:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0839		**Lims Reference ID:**		**ED53307-46**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:17	06/17/25 12:17	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0841		**Lims Reference ID:**		**ED53307-47**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:18	06/17/25 12:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0843		**Lims Reference ID:**		**ED53307-48**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:20	06/17/25 12:20	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0845		**Lims Reference ID:**		**ED53307-49**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0845 (Continued)			**Lims Reference ID:**	**ED53307-49**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals (Continued)									
Lead	1.5		1	1.0	µg/L	06/17/25 12:21	06/17/25 12:21	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0847			**Lims Reference ID:**	**ED53307-50**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	2.2		1	1.0	µg/L	06/17/25 12:22	06/17/25 12:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0852			**Lims Reference ID:**	**ED53307-51**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	2.0		1	1.0	µg/L	06/17/25 12:26	06/17/25 12:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0854			**Lims Reference ID:**	**ED53307-52**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	2.2		1	1.0	µg/L	06/17/25 12:27	06/17/25 12:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0856			**Lims Reference ID:**	**ED53307-53**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	6.3		1	1.0	µg/L	06/17/25 12:31	06/17/25 12:31	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0858			**Lims Reference ID:**	**ED53307-54**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	2.0		1	1.0	µg/L	06/17/25 12:33	06/17/25 12:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0860			**Lims Reference ID:**	**ED53307-55**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	2.7		1	1.0	µg/L	06/17/25 12:34	06/17/25 12:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0862			**Lims Reference ID:**	**ED53307-56**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	3.8		1	1.0	µg/L	06/17/25 12:35	06/17/25 12:35	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0871			**Lims Reference ID:**	**ED53307-57**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0871 (Continued)		**Lims Reference ID:**		**ED53307-57**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals (Continued)									
Lead	1.6		1	1.0	µg/L	06/17/25 12:37	06/17/25 12:37	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0872		**Lims Reference ID:**		**ED53307-58**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:38	06/17/25 12:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0874		**Lims Reference ID:**		**ED53307-59**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:39	06/17/25 12:39	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0876		**Lims Reference ID:**		**ED53307-60**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:51	06/17/25 12:51	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0878		**Lims Reference ID:**		**ED53307-61**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:55	06/17/25 12:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0879		**Lims Reference ID:**		**ED53307-62**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:56	06/17/25 12:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0880		**Lims Reference ID:**		**ED53307-63**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 12:58	06/17/25 12:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0886		**Lims Reference ID:**		**ED53307-64**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									
Lead	6.3		1	1.0	µg/L	06/17/25 12:59	06/17/25 12:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3075		**Lims Reference ID:**		**ED53307-65**	**Matrix: Drinking Water**			**Sampled:**	**06/05/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3075 (Continued)		**Lims Reference ID:**		**ED53307-65**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:03	06/17/25 13:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3076		**Lims Reference ID:**		**ED53307-66**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:04	06/17/25 13:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3077		**Lims Reference ID:**		**ED53307-67**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:06	06/17/25 13:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3078		**Lims Reference ID:**		**ED53307-68**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:07	06/17/25 13:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3172		**Lims Reference ID:**		**ED53307-69**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:08	06/17/25 13:08	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3583		**Lims Reference ID:**		**ED53307-70**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	32.0		1	1.0	µg/L	06/19/25 11:14	06/19/25 11:14	SEH	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-3584		**Lims Reference ID:**		**ED53307-71**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	3.4		1	1.0	µg/L	06/17/25 13:10	06/17/25 13:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3586		**Lims Reference ID:**		**ED53307-72**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	4.7		1	1.0	µg/L	06/17/25 13:14	06/17/25 13:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3587		**Lims Reference ID:**		**ED53307-73**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3587 (Continued)		**Lims Reference ID:**		**ED53307-73**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 13:15	06/17/25 13:15	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3588		**Lims Reference ID:**		**ED53307-74**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	**1.7**		1	1.0	µg/L	06/17/25 13:19	06/17/25 13:19	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3596		**Lims Reference ID:**		**ED53307-75**	**Matrix: Drinking Water**				**Sampled: 06/05/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 13:20	06/17/25 13:20	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553307
LIMS Reference ID: ED53307
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Southwest Elementary School, SWES, Brentwood Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:01
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED55549

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southwest Elementary School
SWES

Client: Brentwood Union Free School District

Courier

Retest/New Install ✓

Turn Around: Normal 1 wk **Rush** 48 hour

RECEIVED
EMSL ANALYTICAL, INC.
Cable Place, NY
AUG 28 25, PM01:13

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4128	CR	1041	Room 31	DW	8/28/2025	7:10:00 AM
BRTWD-4130	CR	1047	Room 30	DW	8/28/2025	7:11:00 AM
BRTWD-4132	CR	1042	Room 33	DW	8/28/2025	7:13:00 AM
BRTWD-4134	CR	1046	Room 32	DW	8/28/2025	7:14:00 AM
BRTWD-4136	CR	1043	Room 35	DW	8/28/2025	7:15:00 AM
BRTWD-4138	CR	1045	Room 34	DW	8/28/2025	7:16:00 AM
BRTWD-4140	CR	2021	Room 46	DW	8/28/2025	7:18:00 AM
BRTWD-4142	CR	2022	Room 45	DW	8/28/2025	7:19:00 AM
BRTWD-4144	CR	2023	Room 44	DW	8/28/2025	7:21:00 AM
BRTWD-4146	CR	2024	Room 43	DW	8/28/2025	7:22:00 AM
BRTWD-4148	CR	2025	Room 42	DW	8/28/2025	7:23:00 AM
BRTWD-4150	CR	2026	Room 41	DW	8/28/2025	7:25:00 AM
BRTWD-4152	CR	2028	Room 40	DW	8/28/2025	7:27:00 AM
BRTWD-4154	CR	1025	Math Lab (Room 2)	DW	8/28/2025	7:35:00 AM
BRTWD-4156	CR	1026	Library (1)	DW	8/28/2025	7:36:00 AM
BRTWD-4158	CR	1027	Room 4	DW	8/28/2025	7:38:00 AM
BRTWD-4160	CR	1028	Computer Room 5	DW	8/28/2025	7:39:00 AM
BRTWD-4162	CR	1029	Speech Room 6	DW	8/28/2025	7:40:00 AM

Building Address
1095 Joselson Avenue
Bay Shore , NY 11706

PB 2008 8/28/25

PB 2008 Kathish - 9/2/25

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/28/25 1:13 PM

Signature: David Wharton

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Bunyan

Lead in Water: Chain of Custody for ED55549

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southwest Elementary School
SWES

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4164	CR	1031	Room 8	DW	8/28/2025	7:42:00 AM
BRTWD-4166	CR	1071	Music Room 15	DW	8/28/2025	7:44:00 AM
BRTWD-4168	CR	1072	Art Room 16	DW	8/28/2025	7:45:00 AM
BRTWD-4170	CR	1073	Room 17	DW	8/28/2025	7:47:00 AM
BRTWD-4172	CR	1074	Room 18	DW	8/28/2025	7:48:00 AM
BRTWD-4174	CR	1076	Room 20	DW	8/28/2025	7:50:00 AM
BRTWD-4176	CR	1079	Room 21	DW	8/28/2025	7:51:00 AM
BRTWD-4178	CR	1080	Room 22	DW	8/28/2025	7:52:00 AM
BRTWD-4180	CR	1081	Room 23	DW	8/28/2025	7:53:00 AM
BRTWD-4182	CR	1082	Room 24	DW	8/28/2025	7:54:00 AM
BRTWD-4184	CR	1083	Room 25	DW	8/28/2025	7:55:00 AM
BRTWD-4186	CR	1084	Room 26	DW	8/28/2025	7:56:00 AM

Samples Submitted 30

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 28 25, PM01:14

8/28/25

P6 200.8 Kathleen 9/2/25

Building Address
1095 Joselson Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/28/25 1:14pm

Signature: David Wharton

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555549
LIMS Reference ID: ED55549
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Southwest Elementary School SWES, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/28/2025 13:13
Reported: 09/02/2025 20:44

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4128			**Lims Reference ID:**	**ED55549-01**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**2.7**		1	1.0	µg/L	08/30/25 10:09	08/30/25 10:09	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4130			**Lims Reference ID:**	**ED55549-02**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**3.5**		1	1.0	µg/L	08/30/25 10:53	08/30/25 10:53	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4132			**Lims Reference ID:**	**ED55549-03**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**3.3**		1	1.0	µg/L	08/30/25 12:29	08/30/25 12:29	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4134			**Lims Reference ID:**	**ED55549-04**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**4.1**		1	1.0	µg/L	08/30/25 12:33	08/30/25 12:33	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4136			**Lims Reference ID:**	**ED55549-05**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**2.0**		1	1.0	µg/L	08/30/25 12:34	08/30/25 12:34	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4138			**Lims Reference ID:**	**ED55549-06**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**3.0**		1	1.0	µg/L	08/30/25 12:36	08/30/25 12:36	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4140			**Lims Reference ID:**	**ED55549-07**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**2.5**		1	1.0	µg/L	08/30/25 12:37	08/30/25 12:37	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4142			**Lims Reference ID:**	**ED55549-08**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**4.8**		1	1.0	µg/L	08/30/25 14:21	08/30/25 14:21	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4144			**Lims Reference ID:**	**ED55549-09**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555549
LIMS Reference ID: ED55549
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Southwest Elementary School SWES, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/28/2025 13:13
Reported: 09/02/2025 20:44

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4144 (Continued)			**Lims Reference ID:**	**ED55549-09**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals (Continued)									
Lead	3.7		1	1.0	µg/L	08/30/25 14:25	08/30/25 14:25	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4146			**Lims Reference ID:**	**ED55549-10**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	3.1		1	1.0	µg/L	08/30/25 14:26	08/30/25 14:26	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4148			**Lims Reference ID:**	**ED55549-11**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	3.5		1	1.0	µg/L	08/30/25 12:41	08/30/25 12:41	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4150			**Lims Reference ID:**	**ED55549-12**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	5.5		1	1.0	µg/L	08/30/25 12:42	08/30/25 12:42	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4152			**Lims Reference ID:**	**ED55549-13**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	6.8		1	1.0	µg/L	08/30/25 14:27	08/30/25 14:27	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4154			**Lims Reference ID:**	**ED55549-14**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	6.8		1	1.0	µg/L	08/30/25 12:44	08/30/25 12:44	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4156			**Lims Reference ID:**	**ED55549-15**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	9.3		1	1.0	µg/L	08/30/25 12:45	08/30/25 12:45	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4158			**Lims Reference ID:**	**ED55549-16**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	13.6		1	1.0	µg/L	08/30/25 14:28	08/30/25 14:28	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4160			**Lims Reference ID:**	**ED55549-17**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555549
LIMS Reference ID: ED55549
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Southwest Elementary School SWES, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/28/2025 13:13
Reported: 09/02/2025 20:44

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4160 (Continued)		**Lims Reference ID:**		**ED55549-17**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals (Continued)									
Lead	26.4		1	1.0	µg/L	08/30/25 12:46	08/30/25 12:46	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4162		**Lims Reference ID:**		**ED55549-18**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	6.6		1	1.0	µg/L	08/30/25 14:32	08/30/25 14:32	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4164		**Lims Reference ID:**		**ED55549-19**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	9.3		1	1.0	µg/L	08/30/25 14:34	08/30/25 14:34	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4166		**Lims Reference ID:**		**ED55549-20**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	6.8		1	1.0	µg/L	08/30/25 12:48	08/30/25 12:48	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4168		**Lims Reference ID:**		**ED55549-21**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	40.9		1	1.0	µg/L	08/30/25 14:35	08/30/25 14:35	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4170		**Lims Reference ID:**		**ED55549-22**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	27.5		1	1.0	µg/L	08/30/25 12:52	08/30/25 12:52	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4172		**Lims Reference ID:**		**ED55549-23**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	56.5		1	1.0	µg/L	09/02/25 18:15	09/02/25 18:15	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4174		**Lims Reference ID:**		**ED55549-24**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	8.5		1	1.0	µg/L	08/30/25 14:36	08/30/25 14:36	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4176		**Lims Reference ID:**		**ED55549-25**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555549
LIMS Reference ID: ED55549
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Southwest Elementary School SWES, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/28/2025 13:13
Reported: 09/02/2025 20:44

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4176 (Continued)		**Lims Reference ID:**		**ED55549-25**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals (Continued)									
Lead	**4.5**	1		1.0	µg/L	08/30/25 14:38	08/30/25 14:38	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4178		**Lims Reference ID:**		**ED55549-26**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**4.4**	1		1.0	µg/L	08/30/25 12:53	08/30/25 12:53	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4180		**Lims Reference ID:**		**ED55549-27**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**4.3**	1		1.0	µg/L	08/30/25 14:39	08/30/25 14:39	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4182		**Lims Reference ID:**		**ED55549-28**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**4.5**	1		1.0	µg/L	09/02/25 18:16	09/02/25 18:16	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4184		**Lims Reference ID:**		**ED55549-29**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**5.3**	1		1.0	µg/L	08/30/25 12:57	08/30/25 12:57	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4186		**Lims Reference ID:**		**ED55549-30**	**Matrix: Drinking Water**				**Sampled: 08/28/25 00:00:00**
Metals									
Lead	**36.8**	1		1.0	µg/L	08/30/25 14:43	08/30/25 14:43	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555549
LIMS Reference ID: ED55549
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Southwest Elementary School SWES, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/28/2025 13:13
Reported: 09/02/2025 20:44

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555549

LIMS Reference ID: ED55549

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Southwest Elementary School SWES, 1095 Joselson Avenue, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/28/2025 13:13

Reported: 09/02/2025 20:44

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED56005

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southwest Elementary School

SWES

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4150	CR	2026	Room 41	DW	9/18/2025	7:05:00 AM
BRTWD-4152	CR	2028	Room 40	DW	9/18/2025	7:06:00 AM
BRTWD-4154	CR	1025	Math Lab (Room 2)	DW	9/18/2025	7:09:00 AM
BRTWD-4156	CR	1026	Library (1)	DW	9/18/2025	7:10:00 AM
BRTWD-4158	CR	1027	Room 4	DW	9/18/2025	7:12:00 AM
BRTWD-4160	CR	1028	Computer Room 5	DW	9/18/2025	7:13:00 AM
BRTWD-4162	CR	1029	Speech Room 6	DW	9/18/2025	7:14:00 AM
BRTWD-4164	CR	1031	Room 8	DW	9/18/2025	7:15:00 AM
BRTWD-4166	CR	1071	Music Room 15	DW	9/18/2025	7:17:00 AM
BRTWD-4168	CR	1072	Art Room 16	DW	9/18/2025	7:18:00 AM
BRTWD-4170	CR	1073	Room 17	DW	9/18/2025	7:19:00 AM
BRTWD-4172	CR	1074	Room 18	DW	9/18/2025	7:20:00 AM
BRTWD-4174	CR	1076	Room 20	DW	9/18/2025	7:23:00 AM
BRTWD-4184	CR	1083	Room 25	DW	9/18/2025	7:25:00 AM
BRTWD-4186	CR	1084	Room 26	DW	9/18/2025	7:26:00 AM
BRTWD-4238	CR	1075	Room 19	DW	9/18/2025	7:22:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
SEP 18 25 PM01:22

16 samples

Courier

Building Address
1095 Joselson Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 9/19/25

Signature:

Samplers Name: Meghan Gwynn

Samplers Signature: Meghan Gwynn

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556005

LIMS Reference ID: ED56005

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Southwest Elementary School, Brentwood Union Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/18/2025 13:22

Reported: 09/20/2025 15:17

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4150			**Lims Reference ID:**	**ED56005-01**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**1.0**		1	1.0	µg/L	09/20/25 12:33	09/20/25 12:33	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4152			**Lims Reference ID:**	**ED56005-02**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**1.0**		1	1.0	µg/L	09/20/25 12:37	09/20/25 12:37	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4154			**Lims Reference ID:**	**ED56005-03**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**6.4**		1	1.0	µg/L	09/20/25 12:38	09/20/25 12:38	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4156			**Lims Reference ID:**	**ED56005-04**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**3.0**		1	1.0	µg/L	09/20/25 12:40	09/20/25 12:40	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4158			**Lims Reference ID:**	**ED56005-05**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**4.7**		1	1.0	µg/L	09/20/25 12:41	09/20/25 12:41	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4160			**Lims Reference ID:**	**ED56005-06**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**2.6**		1	1.0	µg/L	09/20/25 12:45	09/20/25 12:45	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4162			**Lims Reference ID:**	**ED56005-07**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/20/25 12:46	09/20/25 12:46	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4164			**Lims Reference ID:**	**ED56005-08**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**1.9**		1	1.0	µg/L	09/20/25 12:48	09/20/25 12:48	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4166			**Lims Reference ID:**	**ED56005-09**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556005
LIMS Reference ID: ED56005
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Southwest Elementary School, Brentwood Union Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/18/2025 13:22
Reported: 09/20/2025 15:17

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4166 (Continued)		**Lims Reference ID:**		**ED56005-09**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals (Continued)									
Lead	**1.9**		1	1.0	µg/L	09/20/25 12:49	09/20/25 12:49	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4168		**Lims Reference ID:**		**ED56005-10**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**1.2**		1	1.0	µg/L	09/20/25 12:50	09/20/25 12:50	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4170		**Lims Reference ID:**		**ED56005-11**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**1.6**		1	1.0	µg/L	09/20/25 12:52	09/20/25 12:52	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4172		**Lims Reference ID:**		**ED56005-12**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**14.1**		1	1.0	µg/L	09/20/25 12:56	09/20/25 12:56	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4174		**Lims Reference ID:**		**ED56005-13**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**4.1**		1	1.0	µg/L	09/20/25 12:57	09/20/25 12:57	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4184		**Lims Reference ID:**		**ED56005-14**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/20/25 13:01	09/20/25 13:01	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4186		**Lims Reference ID:**		**ED56005-15**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**6.5**		1	1.0	µg/L	09/20/25 13:02	09/20/25 13:02	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4238		**Lims Reference ID:**		**ED56005-16**	**Matrix: Drinking Water**				**Sampled: 09/18/25 00:00:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	09/20/25 13:03	09/20/25 13:03	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556005
LIMS Reference ID: ED56005
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Southwest Elementary School, Brentwood Union Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/18/2025 13:22
Reported: 09/20/2025 15:17

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556005

LIMS Reference ID: ED56005

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	JCB#: 23-53744, Southwest Elementary School, Brentwood Union Free School District, 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	09/18/2025 13:22
Reported:	09/20/2025 15:17

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED56334

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southwest Elementary School

SWES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4154	CR	1025	Math Lab (Room 2)	DW	10/2/2025	8:43:00 AM
BRTWD-4172	CR	1074	Room 18	DW	10/2/2025	8:37:00 AM
BRTWD-4186	CR	1084	Room 26	DW	10/2/2025	8:39:00 AM
BRTWD-4239	CA	1058	Cafeteria	WF	10/2/2025	8:35:00 AM
BRTWD-4240	CA	1058	Cafeteria	WC	10/2/2025	8:35:00 AM

Samples Submitted 5

Pb 200.8 Kathleen Lin 10/03/25

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 02 25, PM03:11

Pb 200.8 Billing 10/3/25

Building Address
1095 Joselson Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/2/25 3:11 pm

Signature: David Wharton

Samplers Name: Meghan Guyan

Samplers Signature: Meghan Guyan

JCB Project Manager: Meghan Guyan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556334

LIMS Reference ID: ED56334

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Southwest Elementary School (SWES), 1095 Joselson Avenue, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/02/2025 15:11

Reported: 10/04/2025 09:53

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4154		**Lims Reference ID:**		**ED56334-01**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**1.5**		1	1.0	µg/L	10/03/25 13:41	10/03/25 13:41	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4172		**Lims Reference ID:**		**ED56334-02**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**2.8**		1	1.0	µg/L	10/03/25 13:42	10/03/25 13:42	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4186		**Lims Reference ID:**		**ED56334-03**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 14:38	10/03/25 14:38	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4239		**Lims Reference ID:**		**ED56334-04**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 18:04	10/03/25 18:04	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4240		**Lims Reference ID:**		**ED56334-05**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 14:39	10/03/25 14:39	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556334
LIMS Reference ID: ED56334
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Southwest Elementary School (SWES), 1095 Joselson Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/02/2025 15:11
Reported: 10/04/2025 09:53

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556334

LIMS Reference ID: ED56334

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Southwest Elementary School (SWES), 1095 Joselson Avenue, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/02/2025 15:11

Reported: 10/04/2025 09:53

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57389

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Southwest Elementary School

SWES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4258	HA	N/A	New Construction Corridor Outside Bathrooms	WF	11/25/2025	7:29:00 AM
BRTWD-4259	HA	N/A	New Construction Corridor Outside Bathrooms	WC	11/25/2025	7:29:00 AM

Samples Submitted 2

Drop Box

Pb 200.8
Kathleen
11/26/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 25 25, PM05:35

Building Address
1095 Joselson Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 11/25/25 17:35

Signature: KAY WAGNER

Samplers Name: Danielle Galagiuc

Samplers Signature:

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557389

LIMS Reference ID: ED57389

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Southwest Elementary School: 1095 Joselson Avenue, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/25/2025 17:35

Reported: 11/26/2025 15:06

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4258		**Lims Reference ID:**		**ED57389-01**	**Matrix: Drinking Water**				**Sampled: 11/25/25 07:29:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/26/25 13:25	11/26/25 13:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4259		**Lims Reference ID:**		**ED57389-02**	**Matrix: Drinking Water**				**Sampled: 11/25/25 07:29:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/26/25 13:26	11/26/25 13:26	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557389

LIMS Reference ID: ED57389

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Southwest Elementary School: 1095 Joselson Avenue, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	11/25/2025 17:35
Reported:	11/26/2025 15:06

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557389

LIMS Reference ID: ED57389

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Southwest Elementary School: 1095 Joselson Avenue, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	11/25/2025 17:35
Reported:	11/26/2025 15:06

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED53308

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Twin Pines Elementary School

TWIN

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0903	CR	N/A	Room 1A	DW	6/6/2025	7:50:00 AM
BRTWD-0904	CR	N/A	Room 2A	DW	6/6/2025	7:51:00 AM
BRTWD-0907	CR	1001	Kindergarten Room 2	DW	6/6/2025	7:49:00 AM
BRTWD-0909	CR	1000	Room 1	DW	6/6/2025	7:47:00 AM
BRTWD-0912	CR	1003	Room 3	DW	6/6/2025	7:46:00 AM
BRTWD-0914	CR	1004	Room 4	DW	6/6/2025	7:46:00 AM
BRTWD-0917	CR	1005	Room 5	DW	6/6/2025	7:45:00 AM
BRTWD-0918	CR	1007	Kindergarten Room 6	BW	6/6/2025	7:41:00 AM
BRTWD-0920	CR	1007	Kindergarten Room 6	DW	6/6/2025	7:42:00 AM
BRTWD-0923	CR	1008	Room 7	DW	6/6/2025	7:39:00 AM
BRTWD-0925	CR	1009	Room 8	DW	6/6/2025	7:38:00 AM
BRTWD-0927	CR	1010	Room 9	DW	6/6/2025	7:37:00 AM
BRTWD-0929	CR	1011	Room 10	DW	6/6/2025	7:36:00 AM
BRTWD-0931	CR	1012	Room 11	DW	6/6/2025	7:35:00 AM
BRTWD-0933	CR	1013	Room 12	DW	6/6/2025	7:34:00 AM
BRTWD-0935	CR	1014	Room 13	DW	6/6/2025	7:32:00 AM
BRTWD-0937	CR	1016	Room 15A	DW	6/6/2025	7:30:00 AM
BRTWD-0939	CR	1015	Computer Room 14	DW	6/6/2025	7:31:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM

Building Address
2 Mur Place
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:05

Signature:

Samplers Name: Tiffany Chen

Samplers Signature:

JCB Project Manager: Meghan Guyon

Lead in Water: Chain of Custody for ED53308

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Twin Pines Elementary School

TWIN

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0941	CR	1019	Room 16	DW	6/6/2025	7:28:00 AM
BRTWD-0947	NO	1036	Nurse's Office	NS	6/6/2025	7:27:00 AM
BRTWD-0955	FL	1048	Faculty Room	KC	6/6/2025	6:43:00 AM
BRTWD-0964	CR	1052	Room 18	DW	6/6/2025	6:45:00 AM
BRTWD-0966	CR	1053	Room 17	DW	6/6/2025	6:46:00 AM
BRTWD-0968	CR	1054	Room 20	DW	6/6/2025	6:47:00 AM
BRTWD-0970	CR	1055	Room 19	DW	6/6/2025	6:48:00 AM
BRTWD-0972	CR	1056	Room 22	DW	6/6/2025	6:58:00 AM
BRTWD-0974	CR	1057	Room 21	DW	6/6/2025	6:51:00 AM
BRTWD-0976	CR	1058	Room 24	DW	6/6/2025	6:52:00 AM
BRTWD-0978	CR	1059	Room 23	DW	6/6/2025	6:54:00 AM
BRTWD-0980	CR	1060	Room 26	DW	6/6/2025	6:56:00 AM
BRTWD-0984	CR	1062	Room 28	DW	6/6/2025	6:58:00 AM
BRTWD-0986	CR	1063	Room 27	DW	6/6/2025	7:00:00 AM
BRTWD-0988	CR	1064	Room 30	DW	6/6/2025	7:01:00 AM
BRTWD-0989	CR	1064	Room 30	BW	6/6/2025	7:05:00 AM
BRTWD-0991	CR	1065	Room 29	DW	6/6/2025	7:02:00 AM
BRTWD-0996	HA	N/A	Corridor Near Bathrooms	WC	6/6/2025	7:06:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM 00:05

Building Address
2 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 2:05

Signature:

Samplers Name:_____

Samplers Signature:_____

JCB Project Manager: Meghan Guyon

Lead in Water: Chain of Custody for ED53308

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Twin Pines Elementary School

TWIN

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1001	CR	N/A	Room 31	DW	6/6/2025	7:08:00 AM
BRTWD-1003	CR	N/A	Room 32	DW	6/6/2025	7:10:00 AM
BRTWD-1005	CR	N/A	Room 33	DW	6/6/2025	7:11:00 AM
BRTWD-1006	CR	N/A	Room 34	DW	6/6/2025	7:12:00 AM
BRTWD-1009	CR	N/A	Room 35	DW	6/6/2025	7:13:00 AM
BRTWD-1011	CR	N/A	Room 36	DW	6/6/2025	7:15:00 AM
BRTWD-1012	KI	1043	Kitchen	KC	6/6/2025	6:25:00 AM
BRTWD-1013	KI	1043	Kitchen	KC	6/6/2025	6:25:00 AM
BRTWD-1015	KI	1043	Kitchen	KC	6/6/2025	6:22:00 AM
BRTWD-1017	KI	1043	Kitchen	KC	6/6/2025	6:23:00 AM
BRTWD-1018	KI	1043	Kitchen	KC	6/6/2025	6:24:00 AM
BRTWD-1019	KI	1043	Kitchen	HW	6/6/2025	6:19:00 AM
BRTWD-1020	KI	1043	Kitchen	HW	6/6/2025	6:27:00 AM
BRTWD-2999	NO	1038	Nurse's Office Back Office	NS	6/6/2025	8:04:00 AM
BRTWD-3043	HA	1044	Corridor Kitchen to Faculty Bathrooms	WC	6/6/2025	6:32:00 AM
BRTWD-3044	HA	1044	Corridor Kitchen to Faculty Bathrooms	WF	6/6/2025	6:33:00 AM
BRTWD-3045	HA	1044	Corridor Kitchen to Faculty Bathrooms	WC	6/6/2025	6:30:00 AM
BRTWD-3046	HA	1044	Corridor Kitchen to Faculty Bathrooms	WF	6/6/2025	6:30:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Cinnaminson, NJ
JUN 13 25 PM 09:05

Building Address

2 Mur Place

Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:05

Signature: [signature] / KAY WATSON

Samplers Name:_____

Samplers Signature:_____

JCB Project Manager: Megan Guyon

Lead in Water: Chain of Custody for ED53309

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Twin Pines Elementary School

TWIN

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3316	CR	1007	Room 6	BWH	6/6/2025	7:41:00 AM
BRTWD-3323	KI	1043	Kitchen	PK	6/6/2025	6:20:00 AM

Samples Submitted 56

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:05

Building Address
2 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:05

Signature:

Samplers Name:_____

Samplers Signature:_____

JCB Project Manager: Meghan Kenyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553308

LIMS Reference ID: ED53308

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 21:05

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0903		**Lims Reference ID:**		**ED53308-01**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 10:41	06/17/25 10:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0904		**Lims Reference ID:**		**ED53308-02**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 10:42	06/17/25 10:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0907		**Lims Reference ID:**		**ED53308-03**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 10:44	06/17/25 10:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0909		**Lims Reference ID:**		**ED53308-04**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/17/25 10:45	06/17/25 10:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0912		**Lims Reference ID:**		**ED53308-05**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	06/17/25 10:46	06/17/25 10:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0914		**Lims Reference ID:**		**ED53308-06**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	06/17/25 10:50	06/17/25 10:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0917		**Lims Reference ID:**		**ED53308-07**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	4.2		1	1.0	µg/L	06/17/25 10:52	06/17/25 10:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0918		**Lims Reference ID:**		**ED53308-08**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 10:56	06/17/25 10:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0920		**Lims Reference ID:**		**ED53308-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553308
LIMS Reference ID: ED53308
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0920 (Continued)		**Lims Reference ID:**		**ED53308-09**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 10:57	06/17/25 10:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0923		**Lims Reference ID:**		**ED53308-10**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	2.8		1	1.0	µg/L	06/17/25 10:58	06/17/25 10:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0925		**Lims Reference ID:**		**ED53308-11**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:00	06/17/25 11:00	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0927		**Lims Reference ID:**		**ED53308-12**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/17/25 11:01	06/17/25 11:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0929		**Lims Reference ID:**		**ED53308-13**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	2.7		1	1.0	µg/L	06/17/25 11:02	06/17/25 11:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0931		**Lims Reference ID:**		**ED53308-14**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:04	06/17/25 11:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0933		**Lims Reference ID:**		**ED53308-15**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	06/17/25 11:16	06/17/25 11:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0935		**Lims Reference ID:**		**ED53308-16**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:20	06/17/25 11:20	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0937		**Lims Reference ID:**		**ED53308-17**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553308
LIMS Reference ID: ED53308
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0937 (Continued)		**Lims Reference ID:**		**ED53308-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:21	06/17/25 11:21	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0939		**Lims Reference ID:**		**ED53308-18**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:22	06/17/25 11:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0941		**Lims Reference ID:**		**ED53308-19**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/17/25 11:24	06/17/25 11:24	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0947		**Lims Reference ID:**		**ED53308-20**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.9		1	1.0	µg/L	06/17/25 11:28	06/17/25 11:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0955		**Lims Reference ID:**		**ED53308-21**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.6		1	1.0	µg/L	06/17/25 11:29	06/17/25 11:29	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0964		**Lims Reference ID:**		**ED53308-22**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:30	06/17/25 11:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0966		**Lims Reference ID:**		**ED53308-23**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	5.3		1	1.0	µg/L	06/17/25 11:32	06/17/25 11:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0968		**Lims Reference ID:**		**ED53308-24**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:33	06/17/25 11:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0970		**Lims Reference ID:**		**ED53308-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553308
LIMS Reference ID: ED53308
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0970 (Continued)		**Lims Reference ID:**		**ED53308-25**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:34	06/17/25 11:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0972		**Lims Reference ID:**		**ED53308-26**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:38	06/17/25 11:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0974		**Lims Reference ID:**		**ED53308-27**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/17/25 11:40	06/17/25 11:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0976		**Lims Reference ID:**		**ED53308-28**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	2.7		1	1.0	µg/L	06/17/25 11:44	06/17/25 11:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0978		**Lims Reference ID:**		**ED53308-29**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	12.8		1	1.0	µg/L	06/17/25 11:45	06/17/25 11:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0980		**Lims Reference ID:**		**ED53308-30**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	2.5		1	1.0	µg/L	06/17/25 11:46	06/17/25 11:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0984		**Lims Reference ID:**		**ED53308-31**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:48	06/17/25 11:48	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0986		**Lims Reference ID:**		**ED53308-32**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/17/25 11:49	06/17/25 11:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0988		**Lims Reference ID:**		**ED53308-33**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553308
LIMS Reference ID: ED53308
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0988 (Continued)		**Lims Reference ID:**		**ED53308-33**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	3.8		1	1.0	µg/L	06/17/25 11:50	06/17/25 11:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0989		**Lims Reference ID:**		**ED53308-34**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 11:52	06/17/25 11:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0991		**Lims Reference ID:**		**ED53308-35**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	2.6		1	1.0	µg/L	06/17/25 13:38	06/17/25 13:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0996		**Lims Reference ID:**		**ED53308-36**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:42	06/17/25 13:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1001		**Lims Reference ID:**		**ED53308-37**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:43	06/17/25 13:43	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1003		**Lims Reference ID:**		**ED53308-38**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:45	06/17/25 13:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1005		**Lims Reference ID:**		**ED53308-39**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 18:51	06/16/25 18:51	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-1006		**Lims Reference ID:**		**ED53308-40**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:46	06/17/25 13:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1009		**Lims Reference ID:**		**ED53308-41**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553308
LIMS Reference ID: ED53308
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1009 (Continued)		**Lims Reference ID:**		**ED53308-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	1.2		1	1.0	µg/L	06/17/25 13:50	06/17/25 13:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1011		**Lims Reference ID:**		**ED53308-42**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 13:51	06/17/25 13:51	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1012		**Lims Reference ID:**		**ED53308-43**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	4.4		1	1.0	µg/L	06/17/25 13:53	06/17/25 13:53	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1013		**Lims Reference ID:**		**ED53308-44**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.2		1	1.0	µg/L	06/17/25 13:54	06/17/25 13:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1015		**Lims Reference ID:**		**ED53308-45**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	7.9		1	1.0	µg/L	06/17/25 13:55	06/17/25 13:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1017		**Lims Reference ID:**		**ED53308-46**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	5.1		1	1.0	µg/L	06/17/25 13:57	06/17/25 13:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1018		**Lims Reference ID:**		**ED53308-47**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	41.5		1	1.0	µg/L	06/17/25 14:01	06/17/25 14:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1019		**Lims Reference ID:**		**ED53308-48**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.3		1	1.0	µg/L	06/17/25 14:02	06/17/25 14:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1020		**Lims Reference ID:**		**ED53308-49**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553308
LIMS Reference ID: ED53308
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1020 (Continued)		**Lims Reference ID:**		**ED53308-49**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	5.0		1	1.0	µg/L	06/17/25 14:06	06/17/25 14:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2999		**Lims Reference ID:**		**ED53308-50**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	13.5		1	1.0	µg/L	06/17/25 14:07	06/17/25 14:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3043		**Lims Reference ID:**		**ED53308-51**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 14:08	06/17/25 14:08	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3044		**Lims Reference ID:**		**ED53308-52**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 14:10	06/17/25 14:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3045		**Lims Reference ID:**		**ED53308-53**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 14:11	06/17/25 14:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3046		**Lims Reference ID:**		**ED53308-54**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 14:12	06/17/25 14:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3316		**Lims Reference ID:**		**ED53308-55**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 14:14	06/17/25 14:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3323		**Lims Reference ID:**		**ED53308-56**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	2.8		1	1.0	µg/L	06/17/25 14:26	06/17/25 14:26	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553308
LIMS Reference ID: ED53308
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553308

LIMS Reference ID: ED53308

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 21:05

Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EDS 7870

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Twin Pines Elementary School

TWIN

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48HR

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1015	KI	1043	Kitchen	KC	12/23/2025	6:32:00 AM
BRTWD-1017	KI	1043	Kitchen	KC	12/23/2025	6:32:00 AM
BRTWD-1018	KI	1043	Kitchen	KC	12/23/2025	6:34:00 AM
BRTWD-2999	NO	1038	Nurse's Office Back Office	NS	12/23/2025	7:03:00 AM

Samples Submitted 4

Courier

PO 2008 Billing 12/24/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:11

Building Address
2 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.8

Lab Recieved:

Signature:

Samplers Name: Molly Miller

Samplers Signature: Molly Miller

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557870

LIMS Reference ID: ED57870

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Twin Pines Elementary School, Brentwood Union Free School District, 2 Mur Place, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:11

Reported: 12/24/2025 14:58

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1015		**Lims Reference ID:**		**ED57870-01**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**3.1**		1	1.0	µg/L	12/24/25 11:05	12/24/25 11:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1017		**Lims Reference ID:**		**ED57870-02**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/24/25 11:06	12/24/25 11:06	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1018		**Lims Reference ID:**		**ED57870-03**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**16.6**		1	1.0	µg/L	12/24/25 11:08	12/24/25 11:08	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2999		**Lims Reference ID:**		**ED57870-04**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**5.4**		1	1.0	µg/L	12/24/25 11:09	12/24/25 11:09	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557870

LIMS Reference ID: ED57870

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Twin Pines Elementary School, Brentwood Union Free School District, 2 Mur Place, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:11

Reported: 12/24/2025 14:58

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557870

LIMS Reference ID: ED57870

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Twin Pines Elementary School, Brentwood Union Free School District, 2 Mur Place, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:11

Reported: 12/24/2025 14:58

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57964

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Twin Pines Elementary School

TWIN

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1018	KI	1043	Kitchen	KC	12/30/2025	7:36:00 AM
BRTWD-2999	NO	1038	Nurse's Office Back Office	NS	12/30/2025	7:39:00 AM

Samples Submitted 2

Pb 200.8 Billing 12/31/25

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:38

Building Address
2 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 12/30/25 16:38

Signature: KAY WALKER

Samplers Name: Jordan Molino

Samplers Signature: J. Molino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557964

LIMS Reference ID: ED57964

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:38

Reported: 12/31/2025 15:18

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1018		**Lims Reference ID:**		**ED57964-01**	**Matrix: Drinking Water**				**Sampled: 12/30/25 07:36:00**
Metals									
Lead	**6.2**		1	1.0	µg/L	12/31/25 10:03	12/31/25 10:03	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2999		**Lims Reference ID:**		**ED57964-02**	**Matrix: Drinking Water**				**Sampled: 12/30/25 07:36:00**
Metals									
Lead	**3.3**		1	1.0	µg/L	12/31/25 10:04	12/31/25 10:04	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557964
LIMS Reference ID: ED57964
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:38
Reported: 12/31/2025 15:18

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557964

LIMS Reference ID: ED57964

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School: 2 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:38

Reported: 12/31/2025 15:18

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50896

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Twin Pines Elementary School

TWIN

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk **Rush** 48 hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0966	CR	1053	Room 17	DW	2/19/2026	7:43:00 AM
BRTWD-1018	KI	1043	Kitchen	KC	2/19/2026	7:41:00 AM

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 19 26, PM01:17

Walk In

Building Address
2 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Sean Cull 02/19/26 1:17PM

Signature: Sean Cull

Samplers Name: Danielle Bolognino

Samplers Signature:

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650896

LIMS Reference ID: EE50896

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School, 2 Mur Place Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 02/19/2026 13:17

Reported: 02/21/2026 09:20

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0966			**Lims Reference ID:**	**EE50896-01**	**Matrix: Drinking Water**				**Sampled: 02/19/26 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	02/21/26 00:40	02/21/26 00:40	DAZ	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-1018			**Lims Reference ID:**	**EE50896-02**	**Matrix: Drinking Water**				**Sampled: 02/19/26 00:00:00**
Metals									
Lead	**4.0**		1	1.0	µg/L	02/21/26 00:44	02/21/26 00:44	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650896

LIMS Reference ID: EE50896

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School, 2 Mur Place Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 02/19/2026 13:17

Reported: 02/21/2026 09:20

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650896

LIMS Reference ID: EE50896

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Twin Pines Elementary School, 2 Mur Place Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 02/19/2026 13:17

Reported: 02/21/2026 09:20

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE53866

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123
Building: Twin Pines Elementary School
TWIN

Client: Brentwood Union Free School District
Retest/New Install ☑
Turn Around: Normal 1 wk Rush 48 hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0978	CR	1059	Room 23	DW	8/4/2026	7:48:00 AM
BRTWD-0982	CR	1061	Room 25	DW	8/4/2026	7:43:00 AM
BRTWD-3330	CR	1064	Room 30	BWH	8/4/2026	7:50:00 AM

Samples Submitted 3

Courier

Mb 200.8 8/5/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 04 26, PM01:04

Building Address
2 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: DAVID WHARTON 8/4/26 1:04 PM
Signature:

Samplers Name: Danielle Bolognini
Samplers Signature:
JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653866

LIMS Reference ID: EE53866

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Twin Pines Elementary School TWIN, 2 Mur Place, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/04/2026 13:04

Reported: 08/05/2026 15:37

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0978		**Lims Reference ID:**		**EE53866-01**	**Matrix: Drinking Water**				**Sampled: 08/04/26 00:00:00**
Metals									
Lead	**38.1**		1	1.0	µg/L	08/05/26 12:25	08/05/26 12:25	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0982		**Lims Reference ID:**		**EE53866-02**	**Matrix: Drinking Water**				**Sampled: 08/04/26 00:00:00**
Metals									
Lead	**5.8**		1	1.0	µg/L	08/05/26 12:29	08/05/26 12:29	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3330		**Lims Reference ID:**		**EE53866-03**	**Matrix: Drinking Water**				**Sampled: 08/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/05/26 12:31	08/05/26 12:31	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653866

LIMS Reference ID: EE53866

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Twin Pines Elementary School TWIN, 2 Mur Place, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/04/2026 13:04

Reported: 08/05/2026 15:37

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653866

LIMS Reference ID: EE53866

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	Twin Pines Elementary School TWIN, 2 Mur Place, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/04/2026 13:04
Reported:	08/05/2026 15:37

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE54122

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Twin Pines Elementary School

TWIN

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-0978	CR	1059	Room 23	DW	8/19/2026	8:28:00 AM
BRTWD-0982	CR	1061	Room 25	DW	8/19/2026	8:29:00 AM

Samples Submitted 2

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 19 26, PM12:38

Pb 200.8 8/20/26

Building Address
2 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WYNNTON 8/19/26 12:38pm

Signature:

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654122

LIMS Reference ID: EE54122

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Twin Pines Elementary School TWIN, 2 Mur Place, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/19/2026 12:38

Reported: 08/21/2026 09:48

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-0978		**Lims Reference ID:**		**EE54122-01**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**2.8**		1	1.0	µg/L	08/20/26 19:06	08/20/26 19:06	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-0982		**Lims Reference ID:**		**EE54122-02**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**1.6**		1	1.0	µg/L	08/20/26 19:07	08/20/26 19:07	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654122

LIMS Reference ID: EE54122

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	Twin Pines Elementary School TWIN, 2 Mur Place, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/19/2026 12:38
Reported:	08/21/2026 09:48

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654122
LIMS Reference ID: EE54122
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	Twin Pines Elementary School TWIN, 2 Mur Place, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/19/2026 12:38
Reported:	08/21/2026 09:48

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EDS3177

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Elementary School

NOR

Client: Brentwood Union Free School

Courier

Retest/New Install ( )

Turn Around: ~~Normal~~ 1 wk Rush_____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 12 25, PM01:08

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1039	CR	1004	Room A-11	DW	6/4/2025	6:16:00 AM
BRTWD-1042	CR	1005	Room A-10	DW	6/4/2025	6:18:00 AM
BRTWD-1045	CR	1006	Room A-9	DW	6/4/2025	6:20:00 AM
BRTWD-1047	CR	1007	Room A-8	DW	6/4/2025	6:21:00 AM
BRTWD-1049	CR	1008	Room A-7	DW	6/4/2025	6:23:00 AM
BRTWD-1051	CR	1009	Room A-6	DW	6/4/2025	6:24:00 AM
BRTWD-1053	CR	1010	Room A-5	DW	6/4/2025	6:26:00 AM
BRTWD-1055	CR	1011	Room A-4	DW	6/4/2025	6:27:00 AM
BRTWD-1057	CR	1012	Room A-3	DW	6/4/2025	6:39:00 AM
BRTWD-1059	CR	1013	Room A-2	DW	6/4/2025	6:30:00 AM
BRTWD-1061	CR	1015	Room A-1	DW	6/4/2025	6:32:00 AM
BRTWD-1066	HA	2019	Corridor Near Stairwell (2001)	DW	6/4/2025	7:00:00 AM
BRTWD-1070	CR	2005	Room A-12	DW	6/4/2025	6:59:00 AM
BRTWD-1074	CR	2008	Room A-14	DW	6/4/2025	6:57:00 AM
BRTWD-1076	CR	2009	Room A-15	DW	6/4/2025	6:56:00 AM
BRTWD-1078	CR	2010	Room A-16	DW	6/4/2025	6:54:00 AM
BRTWD-1080	CR	2011	Room A-17	DW	6/4/2025	6:53:00 AM
BRTWD-1082	CR	2012	Room A-18	DW	6/4/2025	6:51:00 AM

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/5/25

Signature:

Samplers Name: Erika Wilson

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Pb200.8 SM 6/5/25 Pb200.8 SM 6/6/25

EDS3177

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Elementary School

NOR

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 12 25, PM01:08

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1084	CR	2013	Room A-19	DW	6/4/2025	6:48:00 AM
BRTWD-1086	CR	2014	Room A-20	DW	6/4/2025	6:47:00 AM
BRTWD-1088	CR	2015	Room A-21	DW	6/4/2025	6:46:00 AM
BRTWD-1090	CR	2016	Room A-22	DW	6/4/2025	6:44:00 AM
BRTWD-1093	KI	1026	Kitchen (Annex)	HW	6/4/2025	7:06:00 AM
BRTWD-1094	KI	1026	Kitchen (Annex)	KC	6/4/2025	7:08:00 AM
BRTWD-1095	KI	1026	Kitchen (Annex)	KC	6/4/2025	7:10:00 AM
BRTWD-1098	CR	1031	Room 1	DW	6/4/2025	7:12:00 AM
BRTWD-1102	CR	1035	Room 3	DW	6/4/2025	7:14:00 AM
BRTWD-1104	CR	1036	Room 5	DW	6/4/2025	7:15:00 AM
BRTWD-1106	CR	1037	Room 6	DW	6/4/2025	7:17:00 AM
BRTWD-1108	CR	1038	Room 7	DW	6/4/2025	7:18:00 AM
BRTWD-1110	CR	1039	Room 8	DW	6/4/2025	7:20:00 AM
BRTWD-1112	CR	1040	Room 9	DW	6/4/2025	7:21:00 AM
BRTWD-1114	CR	1041	Room 10	DW	6/4/2025	7:22:00 AM
BRTWD-1116	CR	1042	Room 11	DW	6/4/2025	7:24:00 AM
BRTWD-1118	CR	1043	Room 12	DW	6/4/2025	7:25:00 AM
BRTWD-1120	CR	1044	Room 13	DW	6/4/2025	7:26:00 AM

Pb200.8 6/15/25 Pb200.8 6/16/25

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved:_____

Signature:_____

Samplers Name: Frank Wilson

Samplers Signature:_____

JCB Project Manager: Meghan Grayson

ED 53177

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Elementary School

NOR

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 12 25, PM01:09

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1122	CR	1045	Room 14	DW	6/4/2025	7:27:00 AM
BRTWD-1124	CR	1047	Room 15	DW	6/4/2025	7:28:00 AM
BRTWD-1128	NO	1056	Nurse's Office	NS	6/4/2025	7:24:00 AM
BRTWD-1132	FL	1057A	Faculty Room	KC	6/4/2025	7:37:00 AM
BRTWD-1134	KI	1065	Kitchen	KC	6/4/2025	7:43:00 AM
BRTWD-1137	KI	1065	Kitchen	KC	6/4/2025	7:44:00 AM
BRTWD-1138	KI	1065	Kitchen	KC	6/4/2025	7:48:00 AM
BRTWD-1139	KI	1065	Kitchen	KC	6/4/2025	7:49:00 AM
BRTWD-1150	CR	1073	Room 16	DW	6/4/2025	7:51:00 AM
BRTWD-1152	CR	1074	Room 17	DW	6/4/2025	7:52:00 AM
BRTWD-1154	CR	1075	Room 18	DW	6/4/2025	7:53:00 AM
BRTWD-1156	CR	1076	Room 19	DW	6/4/2025	7:54:00 AM
BRTWD-1158	CR	1077	Room 20	DW	6/4/2025	7:56:00 AM
BRTWD-1160	CR	1078	Room 21	DW	6/4/2025	7:57:00 AM
BRTWD-1162	CR	1079	Room 22	DW	6/4/2025	7:58:00 AM
BRTWD-1164	CR	1080	Room 23	DW	6/4/2025	7:59:00 AM
BRTWD-1166	CR	1081	Room 24	DW	6/4/2025	8:00:00 AM
BRTWD-1168	CR	1082	Room 25	DW	6/4/2025	8:02:00 AM

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/5/25

Signature:

Samplers Name: Erika Winter

Samplers Signature:

JCB Project Manager: Meghan Grogan

Phase 1 & 2 6/5/25 Phase 1 & 2 6/11/25

EDS3177

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Elementary School

NOR

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1170	CR	1083	Room 26	DW	6/4/2025	8:03:00 AM
BRTWD-1172	CR	1084	Room 27	DW	6/4/2025	8:04:00 AM
BRTWD-3051	HA	1086	Main Corridor Near Cafeteria (1063)	WC	6/4/2025	7:41:00 AM
BRTWD-3052	HA	1086	Main Corridor Near Cafeteria (1063)	WF	6/4/2025	7:39:00 AM
BRTWD-3053	HA	1017	Corridor Near Annex Office (1021)	WC	6/4/2025	8:15:00 AM
BRTWD-3054	HA	1017	Corridor Near Annex Office (1021)	WF	6/4/2025	6:35:00 AM
BRTWD-3886	CR	2007	Room A13	DW	6/4/2025	8:17:00 AM
BRTWD-3904	OF	1050C	Main Office Copy Room	BWC	6/4/2025	7:32:00 AM

Samples Submitted 62

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 12 25, PM01:09

Pb200.8 SM 6/13/25 Pb200.8 SM 6/16/25

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved:

Signature:

Samplers Name: Erin Wilson

Samplers Signature:

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553177
LIMS Reference ID: ED53177
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/12/2025 13:08
Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1039		**Lims Reference ID:**		**ED53177-01**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 13:59	06/15/25 13:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1042		**Lims Reference ID:**		**ED53177-02**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	3.7		1	1.0	µg/L	06/15/25 14:01	06/15/25 14:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1045		**Lims Reference ID:**		**ED53177-03**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:02	06/15/25 14:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1047		**Lims Reference ID:**		**ED53177-04**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:06	06/15/25 14:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1049		**Lims Reference ID:**		**ED53177-05**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:07	06/15/25 14:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1051		**Lims Reference ID:**		**ED53177-06**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:09	06/15/25 14:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1053		**Lims Reference ID:**		**ED53177-07**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:10	06/15/25 14:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1055		**Lims Reference ID:**		**ED53177-08**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:11	06/15/25 14:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1057		**Lims Reference ID:**		**ED53177-09**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553177
LIMS Reference ID: ED53177
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/12/2025 13:08
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1057 (Continued)		**Lims Reference ID:**		**ED53177-09**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:13	06/15/25 14:13	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1059		**Lims Reference ID:**		**ED53177-10**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:17	06/15/25 14:17	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1061		**Lims Reference ID:**		**ED53177-11**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/15/25 14:18	06/15/25 14:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1066		**Lims Reference ID:**		**ED53177-12**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	2.4		1	1.0	µg/L	06/15/25 14:22	06/15/25 14:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1070		**Lims Reference ID:**		**ED53177-13**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:23	06/15/25 14:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1074		**Lims Reference ID:**		**ED53177-14**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:25	06/15/25 14:25	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1076		**Lims Reference ID:**		**ED53177-15**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:26	06/15/25 14:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1078		**Lims Reference ID:**		**ED53177-16**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	3.1		1	1.0	µg/L	06/15/25 14:27	06/15/25 14:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1080		**Lims Reference ID:**		**ED53177-17**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553177
LIMS Reference ID: ED53177
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/12/2025 13:08
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1080 (Continued)		**Lims Reference ID:**		**ED53177-17**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:29	06/15/25 14:29	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1082		**Lims Reference ID:**		**ED53177-18**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:30	06/15/25 14:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1084		**Lims Reference ID:**		**ED53177-19**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	1.0		1	1.0	µg/L	06/15/25 14:41	06/15/25 14:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1086		**Lims Reference ID:**		**ED53177-20**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	5.2		1	1.0	µg/L	06/15/25 14:45	06/15/25 14:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1088		**Lims Reference ID:**		**ED53177-21**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	6.6		1	1.0	µg/L	06/15/25 14:46	06/15/25 14:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1090		**Lims Reference ID:**		**ED53177-22**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:48	06/15/25 14:48	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1093		**Lims Reference ID:**		**ED53177-23**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	3.8		1	1.0	µg/L	06/15/25 14:49	06/15/25 14:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1094		**Lims Reference ID:**		**ED53177-24**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:53	06/15/25 14:53	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1095		**Lims Reference ID:**		**ED53177-25**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553177
LIMS Reference ID: ED53177
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/12/2025 13:08
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1095 (Continued)		**Lims Reference ID:**		**ED53177-25**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals (Continued)									
Lead	28.0		1	1.0	µg/L	06/15/25 14:54	06/15/25 14:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1098		**Lims Reference ID:**		**ED53177-26**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	4.3		1	1.0	µg/L	06/15/25 14:56	06/15/25 14:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1102		**Lims Reference ID:**		**ED53177-27**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:57	06/15/25 14:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1104		**Lims Reference ID:**		**ED53177-28**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 14:58	06/15/25 14:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1106		**Lims Reference ID:**		**ED53177-29**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:00	06/15/25 15:00	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1108		**Lims Reference ID:**		**ED53177-30**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:04	06/15/25 15:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1110		**Lims Reference ID:**		**ED53177-31**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	06/15/25 15:05	06/15/25 15:05	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1112		**Lims Reference ID:**		**ED53177-32**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:09	06/15/25 15:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1114		**Lims Reference ID:**		**ED53177-33**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553177
LIMS Reference ID: ED53177
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/12/2025 13:08
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1114 (Continued)		**Lims Reference ID:**		**ED53177-33**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals (Continued)									
Lead	1.1		1	1.0	µg/L	06/15/25 15:10	06/15/25 15:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1116		**Lims Reference ID:**		**ED53177-34**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/15/25 15:12	06/15/25 15:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1118		**Lims Reference ID:**		**ED53177-35**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:13	06/15/25 15:13	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1120		**Lims Reference ID:**		**ED53177-36**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:14	06/15/25 15:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1122		**Lims Reference ID:**		**ED53177-37**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:15	06/15/25 15:15	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1124		**Lims Reference ID:**		**ED53177-38**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:17	06/15/25 15:17	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1128		**Lims Reference ID:**		**ED53177-39**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	8.3		1	1.0	µg/L	06/15/25 15:34	06/15/25 15:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1132		**Lims Reference ID:**		**ED53177-40**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:38	06/15/25 15:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1134		**Lims Reference ID:**		**ED53177-41**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553177
LIMS Reference ID: ED53177
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/12/2025 13:08
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1134 (Continued)		**Lims Reference ID:**		**ED53177-41**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:39	06/15/25 15:39	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1137		**Lims Reference ID:**		**ED53177-42**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	4.0		1	1.0	µg/L	06/15/25 15:41	06/15/25 15:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1138		**Lims Reference ID:**		**ED53177-43**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:42	06/15/25 15:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1139		**Lims Reference ID:**		**ED53177-44**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	1.7		1	1.0	µg/L	06/15/25 15:46	06/15/25 15:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1150		**Lims Reference ID:**		**ED53177-45**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:47	06/15/25 15:47	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1152		**Lims Reference ID:**		**ED53177-46**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/15/25 15:49	06/15/25 15:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1154		**Lims Reference ID:**		**ED53177-47**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:50	06/15/25 15:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1156		**Lims Reference ID:**		**ED53177-48**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:51	06/15/25 15:51	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1158		**Lims Reference ID:**		**ED53177-49**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553177
LIMS Reference ID: ED53177
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/12/2025 13:08
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1158 (Continued)		**Lims Reference ID:**		**ED53177-49**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals (Continued)									
Lead	1.3		1	1.0	µg/L	06/15/25 15:53	06/15/25 15:53	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1160		**Lims Reference ID:**		**ED53177-50**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	1.0		1	1.0	µg/L	06/15/25 15:57	06/15/25 15:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1162		**Lims Reference ID:**		**ED53177-51**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 15:58	06/15/25 15:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1164		**Lims Reference ID:**		**ED53177-52**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	5.0		1	1.0	µg/L	06/15/25 16:02	06/15/25 16:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1166		**Lims Reference ID:**		**ED53177-53**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 16:03	06/15/25 16:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1168		**Lims Reference ID:**		**ED53177-54**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	1.4		1	1.0	µg/L	06/15/25 16:05	06/15/25 16:05	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1170		**Lims Reference ID:**		**ED53177-55**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 16:06	06/15/25 16:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1172		**Lims Reference ID:**		**ED53177-56**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									
Lead	2.3		1	1.0	µg/L	06/15/25 16:07	06/15/25 16:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3051		**Lims Reference ID:**		**ED53177-57**	**Matrix: Drinking Water**			**Sampled:**	**06/04/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553177
LIMS Reference ID: ED53177
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/12/2025 13:08
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3051 (Continued)		**Lims Reference ID:**		**ED53177-57**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/15/25 16:09	06/15/25 16:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3052		**Lims Reference ID:**		**ED53177-58**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/15/25 16:10	06/15/25 16:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3053		**Lims Reference ID:**		**ED53177-59**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 09:39	06/16/25 09:39	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3054		**Lims Reference ID:**		**ED53177-60**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 09:43	06/16/25 09:43	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3886		**Lims Reference ID:**		**ED53177-61**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 09:44	06/16/25 09:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3904		**Lims Reference ID:**		**ED53177-62**	**Matrix: Drinking Water**				**Sampled: 06/04/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 09:46	06/16/25 09:46	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553177
LIMS Reference ID: ED53177
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/12/2025 13:08
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553177
LIMS Reference ID: ED53177
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/12/2025 13:08
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED55597

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: North Elementary School
NOR

Client: Brentwood Union Free School District

Retest/New Install M
Turn Around: Normal 1 wk **Rush** 48hour

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 29 25, PM01:22

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4188	CR	1031	Music Room 1	DW	8/29/2025	7:07:00 AM
BRTWD-4190	CR	1035	Math/Reading Lab 3	DW	8/29/2025	7:09:00 AM
BRTWD-4192	CR	1036	Computer Room 5	DW	8/29/2025	7:11:00 AM
BRTWD-4194	CR	1037	Room 6	DW	8/29/2025	7:13:00 AM
BRTWD-4196	CR	1038	Room 7	DW	8/29/2025	7:14:00 AM
BRTWD-4198	CR	1039	Room 8	DW	8/29/2025	7:16:00 AM
BRTWD-4200	CR	1040	Room 9	DW	8/29/2025	7:18:00 AM
BRTWD-4202	CR	1041	Room 10	DW	8/29/2025	7:20:00 AM
BRTWD-4204	CR	1042	Room 11	DW	8/29/2025	7:21:00 AM
BRTWD-4206	CR	1043	Room 12	DW	8/29/2025	7:23:00 AM
BRTWD-4208	CR	1044	Room 13	DW	8/29/2025	7:25:00 AM
BRTWD-4210	CR	1045	Room 14	DW	8/29/2025	7:26:00 AM
BRTWD-4212	CR	1047	Room 15	DW	8/29/2025	7:29:00 AM
BRTWD-4214	CR	1073	Room 16	DW	8/29/2025	7:31:00 AM
BRTWD-4216	CR	1074	Room 17	DW	8/29/2025	7:33:00 AM
BRTWD-4218	CR	1075	Room 18	DW	8/29/2025	7:34:00 AM
BRTWD-4220	CR	1076	Room 19	DW	8/29/2025	7:36:00 AM
BRTWD-4222	CR	1077	Room 20	DW	8/29/2025	7:37:00 AM

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved:
Signature:

Samplers Name: Danielle Sologaini
Samplers Signature:
JCB Project Manager: Meghan Grogan

ED5597

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Elementary School

NOR

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4224	CR	1078	Room 21	DW	8/29/2025	7:38:00 AM
BRTWD-4226	CR	1079	Room 22	DW	8/29/2025	7:39:00 AM
BRTWD-4228	CR	1080	Room 23	DW	8/29/2025	7:42:00 AM
BRTWD-4230	CR	1081	Room 24	DW	8/29/2025	7:48:00 AM
BRTWD-4232	CR	1082	Room 25	DW	8/29/2025	7:49:00 AM
BRTWD-4234	CR	1084	Room 27	DW	8/29/2025	7:50:00 AM
BRTWD-4236	CR	1083	Room 26	DW	8/29/2025	7:51:00 AM

Samples Submitted 25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 29 25, PM01:22

Pb2008 Kathrine 9/2/25

Building Address
50 West White Street
Brentwood , NY 11717

8/30/25 Pb 2008

Analysis Type: ELAP 200.5

Lab Recieved: Carle

Signature:

Samplers Name: Danielle Belogaini

Samplers Signature:

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555597
LIMS Reference ID: ED55597
EMSL Customer ID: JCBR50

Attention: Select Contact - JCBR50
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
elementsupport@emsl.com

Project Name: JCB# 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/29/2025 13:22
Reported: 09/02/2025 21:00

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4188			**Lims Reference ID:**	**ED55597-01**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**3.8**		1	1.0	µg/L	08/30/25 15:16	08/30/25 15:16	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4190			**Lims Reference ID:**	**ED55597-02**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**2.5**		1	1.0	µg/L	08/30/25 15:17	08/30/25 15:17	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4192			**Lims Reference ID:**	**ED55597-03**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**1.5**		1	1.0	µg/L	08/30/25 15:19	08/30/25 15:19	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4194			**Lims Reference ID:**	**ED55597-04**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**2.1**		1	1.0	µg/L	08/30/25 15:20	08/30/25 15:20	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4196			**Lims Reference ID:**	**ED55597-05**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**1.6**		1	1.0	µg/L	08/30/25 15:24	08/30/25 15:24	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4198			**Lims Reference ID:**	**ED55597-06**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**2.3**		1	1.0	µg/L	08/30/25 15:25	08/30/25 15:25	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4200			**Lims Reference ID:**	**ED55597-07**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**1.6**		1	1.0	µg/L	08/30/25 15:27	08/30/25 15:27	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4202			**Lims Reference ID:**	**ED55597-08**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**1.5**		1	1.0	µg/L	08/30/25 15:28	08/30/25 15:28	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4204			**Lims Reference ID:**	**ED55597-09**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555597
LIMS Reference ID: ED55597
EMSL Customer ID: JCBR50

Attention: Select Contact - JCBR50
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
elementsupport@emsl.com

Project Name: JCB# 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/29/2025 13:22
Reported: 09/02/2025 21:00

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4204 (Continued)			**Lims Reference ID:**	**ED55597-09**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals (Continued)									
Lead	1.4		1	1.0	µg/L	08/30/25 15:29	08/30/25 15:29	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4206			**Lims Reference ID:**	**ED55597-10**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	08/30/25 15:31	08/30/25 15:31	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4208			**Lims Reference ID:**	**ED55597-11**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	08/30/25 13:50	08/30/25 13:50	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4210			**Lims Reference ID:**	**ED55597-12**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	08/30/25 15:35	08/30/25 15:35	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4212			**Lims Reference ID:**	**ED55597-13**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	08/30/25 15:36	08/30/25 15:36	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4214			**Lims Reference ID:**	**ED55597-14**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	08/30/25 13:52	08/30/25 13:52	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4216			**Lims Reference ID:**	**ED55597-15**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	5.5		1	1.0	µg/L	09/02/25 18:24	09/02/25 18:24	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4218			**Lims Reference ID:**	**ED55597-16**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	7.9		1	1.0	µg/L	08/30/25 14:52	08/30/25 14:52	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4220			**Lims Reference ID:**	**ED55597-17**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555597
LIMS Reference ID: ED55597
EMSL Customer ID: JCBR50

Attention: Select Contact - JCBR50
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
elementsupport@emsl.com

Project Name: JCB# 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/29/2025 13:22
Reported: 09/02/2025 21:00

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4220 (Continued)			**Lims Reference ID:**	**ED55597-17**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals (Continued)									
Lead	4.3		1	1.0	µg/L	09/02/25 18:25	09/02/25 18:25	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4222			**Lims Reference ID:**	**ED55597-18**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	08/30/25 15:40	08/30/25 15:40	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4224			**Lims Reference ID:**	**ED55597-19**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	08/30/25 14:54	08/30/25 14:54	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4226			**Lims Reference ID:**	**ED55597-20**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	1.4		1	1.0	µg/L	08/30/25 14:55	08/30/25 14:55	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4228			**Lims Reference ID:**	**ED55597-21**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	6.8		1	1.0	µg/L	09/02/25 18:27	09/02/25 18:27	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4230			**Lims Reference ID:**	**ED55597-22**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	7.3		1	1.0	µg/L	09/02/25 18:28	09/02/25 18:28	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4232			**Lims Reference ID:**	**ED55597-23**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	14.7		1	1.0	µg/L	09/02/25 18:29	09/02/25 18:29	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4234			**Lims Reference ID:**	**ED55597-24**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	2.6		1	1.0	µg/L	08/30/25 14:56	08/30/25 14:56	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4236			**Lims Reference ID:**	**ED55597-25**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555597
LIMS Reference ID: ED55597
EMSL Customer ID: JCBR50

Attention: Select Contact - JCBR50
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
elementsupport@emsl.com

Project Name: JCB# 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/29/2025 13:22
Reported: 09/02/2025 21:00

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4236 (Continued)			**Lims Reference ID:**	**ED55597-25**	**Matrix: Drinking Water**			**Sampled:**	**08/29/25 00:00:00**
Metals (Continued)									
Lead	**3.0**		1	1.0	µg/L	09/02/25 18:33	09/02/25 18:33	KT1	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555597
LIMS Reference ID: ED55597
EMSL Customer ID: JCBR50

Attention: Select Contact - JCBR50
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
elementsupport@emsl.com

Project Name: JCB# 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/29/2025 13:22
Reported: 09/02/2025 21:00

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555597
LIMS Reference ID: ED55597
EMSL Customer ID: JCBR50

Attention: Select Contact - JCBR50
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
elementsupport@emsl.com

Project Name: JCB# 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/29/2025 13:22
Reported: 09/02/2025 21:00

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

E056028

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: North Elementary School
NOR

Client: Brentwood Union Free School District
Retest/New Install N
Turn Around: Normal 1 wk **Rush** 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4216	CR	1074	Room 17	DW	9/19/2025	7:07:00 AM
BRTWD-4218	CR	1075	Room 18	DW	9/19/2025	7:08:00 AM
BRTWD-4228	CR	1080	Room 23	DW	9/19/2025	7:09:00 AM
BRTWD-4230	CR	1081	Room 24	DW	9/19/2025	7:11:00 AM
BRTWD-4232	CR	1082	Room 25	DW	9/19/2025	7:12:00 AM

Samples Submitted 5

PB 200.8 N 5/24/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
SEP 19 25, PM02:01

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: James Ivan 9/19/25
Signature:

Samplers Name: Meghan Gwynn
Samplers Signature: Meghan Gwynn
JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556028
LIMS Reference ID: ED56028
EMSL Customer ID: JCBR50

Attention: Erin Todzia
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
etodzia@jcbroderick.com

Project Name: 23-53744 -North Elementary School NOR - Brentwood Union Free School District - 50 West White Street Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/19/2025 14:01
Reported: 09/20/2025 15:21

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4216		**Lims Reference ID:**		**ED56028-01**	**Matrix: Drinking Water**				**Sampled: 09/19/25 07:07:00**
Metals									
Lead	**1.3**	1	1.0	µg/L	09/20/25 14:37	09/20/25 14:37	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4218		**Lims Reference ID:**		**ED56028-02**	**Matrix: Drinking Water**				**Sampled: 09/19/25 07:08:00**
Metals									
Lead	**3.0**	1	1.0	µg/L	09/20/25 14:38	09/20/25 14:38	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4228		**Lims Reference ID:**		**ED56028-03**	**Matrix: Drinking Water**				**Sampled: 09/19/25 07:09:00**
Metals									
Lead	**< 1.0**	1	1.0	µg/L	09/20/25 14:39	09/20/25 14:39	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4230		**Lims Reference ID:**		**ED56028-04**	**Matrix: Drinking Water**				**Sampled: 09/19/25 07:11:00**
Metals									
Lead	**1.2**	1	1.0	µg/L	09/20/25 14:41	09/20/25 14:41	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4232		**Lims Reference ID:**		**ED56028-05**	**Matrix: Drinking Water**				**Sampled: 09/19/25 07:12:00**
Metals									
Lead	**1.4**	1	1.0	µg/L	09/20/25 14:45	09/20/25 14:45	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556028
LIMS Reference ID: ED56028
EMSL Customer ID: JCBR50

Attention: Erin Todzia
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
etodzia@jcbroderick.com

Project Name: 23-53744 -North Elementary School NOR - Brentwood Union Free School District - 50 West White Street Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/19/2025 14:01
Reported: 09/20/2025 15:21

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556028
LIMS Reference ID: ED56028
EMSL Customer ID: JCBR50

Attention: Erin Todzia
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
etodzia@jcbroderick.com

Project Name: 23-53744 -North Elementary School NOR - Brentwood Union Free School District - 50 West White Street Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/19/2025 14:01
Reported: 09/20/2025 15:21

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57891

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Elementary School

NOR

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48HR

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1095	KI	1026	Kitchen (Annex)	KC	12/23/2025	7:19:00 AM
BRTWD-1128	NO	1056	Nurse's Office	NS	12/23/2025	7:16:00 AM
BRTWD-1136	KI	1065	Kitchen	HW	12/23/2025	7:12:00 AM
BRTWD-3893	KI	1065	Kitchen	PK	12/23/2025	7:13:00 AM

Samples Submitted 4

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:09

Courier

46 200.8
Katherine
12/24/25

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.8

Lab Recieved: 12/23/25 14:09

Signature:

Samplers Name: Molly Miller

Samplers Signature: Molly Miller

JCB Project Manager: Meghan Gunnan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557891

LIMS Reference ID: ED57891

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Elementary School: 50 West White Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:09

Reported: 12/24/2025 16:58

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1095		**Lims Reference ID:**		**ED57891-01**	**Matrix: Drinking Water**				**Sampled: 12/23/25 07:19:00**
Metals									
Lead	**14.2**		1	1.0	µg/L	12/24/25 13:23	12/24/25 13:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1128		**Lims Reference ID:**		**ED57891-02**	**Matrix: Drinking Water**				**Sampled: 12/23/25 07:16:00**
Metals									
Lead	**5.6**		1	1.0	µg/L	12/24/25 13:25	12/24/25 13:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1136		**Lims Reference ID:**		**ED57891-03**	**Matrix: Drinking Water**				**Sampled: 12/23/25 07:12:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/24/25 13:29	12/24/25 13:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3893		**Lims Reference ID:**		**ED57891-04**	**Matrix: Drinking Water**				**Sampled: 12/23/25 07:13:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/24/25 13:33	12/24/25 13:33	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557891
LIMS Reference ID: ED57891
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Elementary School: 50 West White Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:09
Reported: 12/24/2025 16:58

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557891
LIMS Reference ID: ED57891
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Elementary School: 50 West White Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:09
Reported: 12/24/2025 16:58

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for E257958

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Elementary School

NOR

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1095	KI	1026	Kitchen (Annex)	KC	12/30/2025	8:00:00 AM
BRTWD-1128	NO	1056	Nurse's Office	NS	12/30/2025	7:57:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:37

Pb 200.8 Katherine 12/31/25

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 12/30/25 16:37

Signature:

Samplers Name: Jordan Miglino

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557958

LIMS Reference ID: ED57958

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Elementary School: 50 West White Street, Brontwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:37

Reported: 12/31/2025 15:27

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1095		**Lims Reference ID:**		**ED57958-01**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 08:00:00**
Metals									
Lead	**26.1**		1	1.0	µg/L	12/31/25 13:38	12/31/25 13:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1128		**Lims Reference ID:**		**ED57958-02**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 08:00:00**
Metals									
Lead	**6.8**		1	1.0	µg/L	12/31/25 13:42	12/31/25 13:42	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557958
LIMS Reference ID: ED57958
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Elementary School: 50 West White Street, Brontwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:37
Reported: 12/31/2025 15:27

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557958

LIMS Reference ID: ED57958

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Elementary School: 50 West White Street, Brontwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:37

Reported: 12/31/2025 15:27

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EES 0897

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Elementary School

NOR

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1086	CR	2014	Room A-20	DW	2/19/2026	7:55:00 AM
BRTWD-1088	CR	2015	Room A-21	DW	2/19/2026	7:56:00 AM

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 19 26, PM01:16

Walk In

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved:

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Guyon

PD 2008 2/21/26

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650897
LIMS Reference ID: EE50897
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/19/2026 13:16
Reported: 02/21/2026 09:21

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1086		**Lims Reference ID:**		**EE50897-01**	**Matrix: Drinking Water**			**Sampled:**	**02/19/26 00:00:00**
Metals									
Lead	**2.8**	1		1.0	µg/L	02/21/26 00:46	02/21/26 00:46	DAZ	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-1088		**Lims Reference ID:**		**EE50897-02**	**Matrix: Drinking Water**			**Sampled:**	**02/19/26 00:00:00**
Metals									
Lead	**2.2**	1		1.0	µg/L	02/21/26 00:47	02/21/26 00:47	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650897
LIMS Reference ID: EE50897
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/19/2026 13:16
Reported: 02/21/2026 09:21

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650897
LIMS Reference ID: EE50897
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	02/19/2026 13:16
Reported:	02/21/2026 09:21

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EES1108

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Elementary School

NOR

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1wk Rush 48hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1095	KI	1026	Kitchen (Annex)	KC	3/5/2026	7:37:00 AM

Samples Submitted 1

3/6/26 8:00

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 05 26, PM02:57

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved:

Signature:

Samplers Name: Danielle Colagrossi

Samplers Signature:

JCB Project Manager: Meghan Gaugna

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651108
LIMS Reference ID: EE51108
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/05/2026 14:57
Reported: 03/07/2026 13:42

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1095			**Lims Reference ID:**	**EE51108-01**	**Matrix: Drinking Water**			**Sampled:**	**03/04/26 00:00:00**
Metals									
Lead	**36.6**		1	1.0	µg/L	03/07/26 13:07	03/07/26 13:07	JH	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651108
LIMS Reference ID: EE51108
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/05/2026 14:57
Reported: 03/07/2026 13:42

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651108
LIMS Reference ID: EE51108
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Elementary School, Brentwood Union Free School District, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/05/2026 14:57
Reported: 03/07/2026 13:42

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE51195

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: North Elementary School
NOR

Client: Brentwood Union Free School District
Retest/New Install N
Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1095	KI	1026	Kitchen (Annex)	KC	3/11/2026	7:10:00 AM
BRTWD-1128	NO	1056	Nurse's Office	NS	3/11/2026	7:12:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 11 26, PM03:36

Pb 200.8
Kallidlw
3/12/26

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: 3/11/26 15:36
Signature: KAY WAGNER

Samplers Name: Daniella Balzano
Samplers Signature:
JCB Project Manager: Meghan Grunza

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651195
LIMS Reference ID: EE51195
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Elementary School: 50 West White Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/11/2026 15:36
Reported: 03/13/2026 09:08

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1095		**Lims Reference ID:**		**EE51195-01**	**Matrix: Drinking Water**				**Sampled: 03/11/26 07:10:00**
Metals									
Lead	**10.8**		1	1.0	µg/L	03/12/26 16:30	03/12/26 16:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1128		**Lims Reference ID:**		**EE51195-02**	**Matrix: Drinking Water**				**Sampled: 03/11/26 07:12:00**
Metals									
Lead	**7.7**		1	1.0	µg/L	03/12/26 16:32	03/12/26 16:32	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651195

LIMS Reference ID: EE51195

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	North Elementary School: 50 West White Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/11/2026 15:36
Reported:	03/13/2026 09:08

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651195
LIMS Reference ID: EE51195
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	North Elementary School: 50 West White Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/11/2026 15:36
Reported:	03/13/2026 09:08

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EE51730

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: North Elementary School
NOR

Client: Brentwood Union Free School District
Retest/New Install [ ]
Turn Around: Normal 1 wk Rush 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1095	KI	1026	Kitchen (Annex)	KC	3/20/2026	7:54:00 AM
BRTWD-1128	NO	1056	Nurse's Office	NS	3/20/2026	7:57:00 AM

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 20 26, PM12:44

pb 200.8
3/24/26

Building Address
50 West White Street
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5
Lab Recieved: 3/20/26 12:44PM
Signature:

Samplers Name: Jordan Miglino
Samplers Signature:
JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651430
LIMS Reference ID: EE51430
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - North Elementary School NOR - Brentwood Union Free School District - 50 West White Street Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/20/2026 12:44
Reported: 03/24/2026 19:39

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1095			**Lims Reference ID:**	**EE51430-01**	**Matrix: Drinking Water**				**Sampled: 03/20/26 07:54:00**
Metals									
Lead	**20.7**		1	1.0	µg/L	03/24/26 18:06	03/24/26 18:06	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-1128			**Lims Reference ID:**	**EE51430-02**	**Matrix: Drinking Water**				**Sampled: 03/20/26 07:57:00**
Metals									
Lead	**4.9**		1	1.0	µg/L	03/24/26 18:08	03/24/26 18:08	KT1	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651430
LIMS Reference ID: EE51430
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	23-53744 - North Elementary School NOR - Brentwood Union Free School District - 50 West White Street Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/20/2026 12:44
Reported:	03/24/2026 19:39

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651430
LIMS Reference ID: EE51430
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	23-53744 - North Elementary School NOR - Brentwood Union Free School District - 50 West White Street Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/20/2026 12:44
Reported:	03/24/2026 19:39

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EE51670

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Elementary School

NOR

Client: Brentwood Union Free School District

Retest/New Install [✓]

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1095	KI	1026	Kitchen (Annex)	KC	3/26/2026	7:09:00 AM

Samples Submitted 1

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 26 26, PM03:46

PO 3/28/26

Building Address
50 West White Street
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 3/26/26 3:46pm

Signature: David Wharton

Samplers Name: Meghan Gwyn

Samplers Signature: Meghan Gwyn

JCB Project Manager: Meghan Gwyn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651670

LIMS Reference ID: EE51670

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Elementary School NOR, 50 West White Street, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 03/26/2026 15:46

Reported: 03/28/2026 23:43

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1095			**Lims Reference ID:**	**EE51670-01**	**Matrix: Drinking Water**			**Sampled:**	**03/26/26 00:00:00**
Metals									
Lead	**3.0**		1	1.0	µg/L	03/28/26 20:28	03/28/26 20:28	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651670
LIMS Reference ID: EE51670
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	North Elementary School NOR, 50 West White Street, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/26/2026 15:46
Reported:	03/28/2026 23:43

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651670
LIMS Reference ID: EE51670
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	North Elementary School NOR, 50 West White Street, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/26/2026 15:46
Reported:	03/28/2026 23:43

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED533 12

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Northeast Elementary School

NES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Pb200 & 8260 6hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1188	CR	1001	Room 32	DW	6/4/2025	6:41:00 AM
BRTWD-1196	CR	1005	Room 28	DW	6/4/2025	6:39:00 AM
BRTWD-1210	NO	1031	Nurse's Office	NS	6/4/2025	6:59:00 AM
BRTWD-1221	CR	1038	Room 16	DW	6/4/2025	6:54:00 AM
BRTWD-1223	CR	1039	Room 17	DW	6/4/2025	6:57:00 AM
BRTWD-1227	CR	1041	Room 19	DW	6/4/2025	7:00:00 AM
BRTWD-1229	CR	1042	Room 20	DW	6/4/2025	6:53:00 AM
BRTWD-1232	CR	1047	Room 21	DW	6/4/2025	6:47:00 AM
BRTWD-1236	CR	1049	Room 23	DW	6/4/2025	6:50:00 AM
BRTWD-1238	CR	1050	Room 24	DW	6/4/2025	6:55:00 AM
BRTWD-1240	CR	1051	Room 25	DW	6/4/2025	6:57:00 AM
BRTWD-1242	CR	1052	Room 26	DW	6/4/2025	6:58:00 AM
BRTWD-1244	CR	N/A	Room 410	DW	6/4/2025	7:03:00 AM
BRTWD-1246	CR	N/A	Room 412	DW	6/4/2025	7:04:00 AM
BRTWD-1255	CR	N/A	Room 414	DW	6/4/2025	7:06:00 AM
BRTWD-1257	CR	N/A	Room 416	DW	6/4/2025	7:07:00 AM
BRTWD-1260	FL	1055	Faculty Room 8	KC	6/4/2025	6:24:00 AM
BRTWD-1264	CR	1057	Room 5	DW	6/4/2025	6:20:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM 3:18

Building Address
2 Devon Road
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:18

Signature:

Samplers Name: Danielle Balzarini

Samplers Signature:

JCB Project Manager: Meghan Guyon

Lead in Water: Chain of Custody for E053312

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Northeast Elementary School

NES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush _____

Phase 1 & 2 Splits

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1268	CR	1060	Room 1	DW	6/4/2025	6:17:00 AM
BRTWD-1270	CR	1061	Room 2	DW	6/4/2025	6:18:00 AM
BRTWD-1271	KI	1067	Annex Kitchen	HW	6/4/2025	6:03:00 AM
BRTWD-1272	KI	1067	Annex Kitchen	KC	6/4/2025	6:03:00 AM
BRTWD-1274	KI	1067	Annex Kitchen	KC	6/4/2025	6:04:00 AM
BRTWD-1278	HA	1085	Corridor Near Speech Room (1070)	WC	6/4/2025	6:16:00 AM
BRTWD-1280	CR	1071	Room 9A	DW	6/4/2025	6:14:00 AM
BRTWD-1284	CR	1073	Room 7A	DW	6/4/2025	6:14:00 AM
BRTWD-1286	CR	1074	Room 10A	DW	6/4/2025	6:13:00 AM
BRTWD-1288	CR	1075	Room 5A	DW	6/4/2025	6:12:00 AM
BRTWD-1291	CR	1077	Room 8A	DW	6/4/2025	6:11:00 AM
BRTWD-1295	CR	1079	Room 3A	DW	6/4/2025	6:09:00 AM
BRTWD-1301	CR	1082	Room 2A	DW	6/4/2025	6:06:00 AM
BRTWD-1303	CR	1083	Room 1A	DW	6/4/2025	6:05:00 AM
BRTWD-1305	CA	1018	Cafeteria	WC	6/4/2025	6:00:00 AM
BRTWD-1306	KI	1018B	Kitchen	KC	6/4/2025	5:53:00 AM
BRTWD-1308	KI	1018B	Kitchen	KC	6/4/2025	5:56:00 AM
BRTWD-1309	KI	1018B	Kitchen	KC	6/4/2025	5:55:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Cherry Hill, NJ
JUN 13 25 PM 03:18

Building Address
2 Devon Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:18

Signature: Mary Worster

Samplers Name: Danielle Bongiovi

Samplers Signature: _____

JCB Project Manager: Meghan Grayson

Lead in Water: Chain of Custody for ED53312

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Northeast Elementary School

NES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1310	KI	1018B	Kitchen	HW	6/4/2025	5:59:00 AM
BRTWD-1312	KI	1018B	Kitchen	KC	6/4/2025	5:58:00 AM
BRTWD-1318	CR	2009	Room 34	DW	6/4/2025	6:48:00 AM
BRTWD-1320	CR	2010	Room 35	DW	6/4/2025	6:48:00 AM
BRTWD-1322	CR	2008	Room 37	DW	6/4/2025	6:47:00 AM
BRTWD-1326	CR	2006	Room 39	DW	6/4/2025	6:44:00 AM
BRTWD-1328	CR	2005	Room 38	DW	6/4/2025	6:43:00 AM
BRTWD-1330	CR	2003	Room 40	DW	6/4/2025	6:41:00 AM
BRTWD-3055	HA	N/A	Corridor Near Bathrooms (New Construction)	WC	6/4/2025	7:00:00 AM
BRTWD-3056	HA	N/A	Corridor Near Bathrooms (New Construction)	WF	6/4/2025	7:01:00 AM
BRTWD-3057	HA	1032	Corridor Between Gym & Library	WC	6/4/2025	6:29:00 AM
BRTWD-3058	HA	1032	Corridor Between Gym & Library	WF	6/4/2025	6:29:00 AM
BRTWD-3109	CR	1081	Room 4A	DW	6/4/2025	7:25:00 AM
BRTWD-3177	CR	1058	Art Room 4	DW	6/4/2025	6:19:00 AM
BRTWD-3178	CR	1037	Room 15	DW	6/4/2025	6:56:00 AM
BRTWD-3444	CR	1002	Room 33	DW	6/4/2025	6:39:00 AM
BRTWD-3448	CR	1006	Room 29	DW	6/4/2025	6:39:00 AM
BRTWD-3451	KI	1018B	Kitchen	PK	6/4/2025	5:57:00 AM

RECEIVED
ENSL ANALYTICAL, INC.
Carle Placem
JUN 13 25 PM 2:15

Building Address
2 Devon Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 7:18

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Guzman

Lead in Water: Chain of Custody for ED53312

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: Northeast Elementary School
NES

Client: Brentwood Union Free School District

Retest/New Install [ ]
Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3452	OF	1024	Main Office	BWC	6/4/2025	6:32:00 AM
BRTWD-3473	FL	1055	Faculty Room 8	BWH	6/4/2025	6:25:00 AM
BRTWD-3486	CR	2007	Room 36	DW	6/4/2025	6:46:00 AM
BRTWD-3957	CR	1056	Room 6	DW	6/4/2025	6:22:00 AM
BRTWD-3958	FL	1055	Faculty Room 8	BWC	6/4/2025	6:25:00 AM
BRTWD-3959	FL	1055	Faculty Room 8	BWC	6/4/2025	6:25:00 AM
BRTWD-3960	CR	1007	Room 27	DW	6/4/2025	6:37:00 AM

Samples Submitted 61

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:18

Building Address
2 Devon Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: 6/13/25 21:14
Signature: [signature] [illegible]

Samplers Name: [illegible]
Samplers Signature: [signature]
JCB Project Manager: [illegible]

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553312

LIMS Reference ID: ED53312

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 21:18

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1188		**Lims Reference ID:**		**ED53312-01**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:29	06/25/25 09:29	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1196		**Lims Reference ID:**		**ED53312-02**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:30	06/25/25 09:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1210		**Lims Reference ID:**		**ED53312-03**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	2.9		1	1.0	µg/L	06/25/25 09:32	06/25/25 09:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1221		**Lims Reference ID:**		**ED53312-04**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:36	06/25/25 09:36	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1223		**Lims Reference ID:**		**ED53312-05**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	4.8		1	1.0	µg/L	06/25/25 09:37	06/25/25 09:37	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1227		**Lims Reference ID:**		**ED53312-06**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/25/25 09:38	06/25/25 09:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1229		**Lims Reference ID:**		**ED53312-07**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	3.7		1	1.0	µg/L	06/25/25 09:40	06/25/25 09:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1232		**Lims Reference ID:**		**ED53312-08**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:41	06/25/25 09:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1236		**Lims Reference ID:**		**ED53312-09**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553312
LIMS Reference ID: ED53312
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:18
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1236 (Continued)		**Lims Reference ID:**		**ED53312-09**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:42	06/25/25 09:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1238		**Lims Reference ID:**		**ED53312-10**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	7.7		1	1.0	µg/L	06/25/25 09:44	06/25/25 09:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1240		**Lims Reference ID:**		**ED53312-11**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:48	06/25/25 09:48	SE	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1242		**Lims Reference ID:**		**ED53312-12**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:52	06/25/25 09:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1244		**Lims Reference ID:**		**ED53312-13**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:53	06/25/25 09:53	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1246		**Lims Reference ID:**		**ED53312-14**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:54	06/25/25 09:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1255		**Lims Reference ID:**		**ED53312-15**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:56	06/25/25 09:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1257		**Lims Reference ID:**		**ED53312-16**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 09:57	06/25/25 09:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1260		**Lims Reference ID:**		**ED53312-17**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553312
LIMS Reference ID: ED53312
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:18
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1260 (Continued)		**Lims Reference ID:**		**ED53312-17**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	1.3		1	1.0	µg/L	06/25/25 09:58	06/25/25 09:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1264		**Lims Reference ID:**		**ED53312-18**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 10:00	06/25/25 10:00	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1268		**Lims Reference ID:**		**ED53312-19**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	3.5		1	1.0	µg/L	06/25/25 10:01	06/25/25 10:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1270		**Lims Reference ID:**		**ED53312-20**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 10:30	06/25/25 10:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1271		**Lims Reference ID:**		**ED53312-21**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 10:34	06/25/25 10:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1272		**Lims Reference ID:**		**ED53312-22**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	7.0		1	1.0	µg/L	06/25/25 10:35	06/25/25 10:35	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1274		**Lims Reference ID:**		**ED53312-23**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 10:37	06/25/25 10:37	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1278		**Lims Reference ID:**		**ED53312-24**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 10:38	06/25/25 10:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1280		**Lims Reference ID:**		**ED53312-25**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553312
LIMS Reference ID: ED53312
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:18
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1280 (Continued)			**Lims Reference ID:**	**ED53312-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	1.5		1	1.0	µg/L	06/25/25 10:42	06/25/25 10:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1284			**Lims Reference ID:**	**ED53312-26**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/25/25 10:43	06/25/25 10:43	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1286			**Lims Reference ID:**	**ED53312-27**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 10:45	06/25/25 10:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1288			**Lims Reference ID:**	**ED53312-28**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.6		1	1.0	µg/L	06/25/25 10:46	06/25/25 10:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1291			**Lims Reference ID:**	**ED53312-29**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 10:47	06/25/25 10:47	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1295			**Lims Reference ID:**	**ED53312-30**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.6		1	1.0	µg/L	06/25/25 10:49	06/25/25 10:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1301			**Lims Reference ID:**	**ED53312-31**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	06/25/25 10:53	06/25/25 10:53	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1303			**Lims Reference ID:**	**ED53312-32**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.1		1	1.0	µg/L	06/25/25 10:54	06/25/25 10:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1305			**Lims Reference ID:**	**ED53312-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553312
LIMS Reference ID: ED53312
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:18
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1305 (Continued)		**Lims Reference ID:**		**ED53312-33**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/25/25 10:58	06/25/25 10:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1306		**Lims Reference ID:**		**ED53312-34**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 10:59	06/25/25 10:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1308		**Lims Reference ID:**		**ED53312-35**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	4.1		1	1.0	µg/L	06/25/25 11:01	06/25/25 11:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1309		**Lims Reference ID:**		**ED53312-36**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:02	06/25/25 11:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1310		**Lims Reference ID:**		**ED53312-37**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:03	06/25/25 11:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1312		**Lims Reference ID:**		**ED53312-38**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:04	06/25/25 11:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1318		**Lims Reference ID:**		**ED53312-39**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:06	06/25/25 11:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1320		**Lims Reference ID:**		**ED53312-40**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 12:58	06/25/25 12:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1322		**Lims Reference ID:**		**ED53312-41**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553312
LIMS Reference ID: ED53312
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:18
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1322 (Continued)		**Lims Reference ID:**		**ED53312-41**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:02	06/25/25 13:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1326		**Lims Reference ID:**		**ED53312-42**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/25/25 13:04	06/25/25 13:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1328		**Lims Reference ID:**		**ED53312-43**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:05	06/25/25 13:05	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1330		**Lims Reference ID:**		**ED53312-44**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.0		1	1.0	µg/L	06/25/25 13:06	06/25/25 13:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3055		**Lims Reference ID:**		**ED53312-45**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:10	06/25/25 13:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3056		**Lims Reference ID:**		**ED53312-46**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:12	06/25/25 13:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3057		**Lims Reference ID:**		**ED53312-47**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:13	06/25/25 13:13	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3058		**Lims Reference ID:**		**ED53312-48**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:14	06/25/25 13:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3109		**Lims Reference ID:**		**ED53312-49**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553312
LIMS Reference ID: ED53312
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:18
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3109 (Continued)		**Lims Reference ID:**		**ED53312-49**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:16	06/25/25 13:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3177		**Lims Reference ID:**		**ED53312-50**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.8		1	1.0	µg/L	06/25/25 13:17	06/25/25 13:17	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3178		**Lims Reference ID:**		**ED53312-51**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:21	06/25/25 13:21	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3444		**Lims Reference ID:**		**ED53312-52**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:22	06/25/25 13:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3448		**Lims Reference ID:**		**ED53312-53**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:26	06/25/25 13:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3451		**Lims Reference ID:**		**ED53312-54**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/25/25 13:27	06/25/25 13:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3452		**Lims Reference ID:**		**ED53312-55**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:29	06/25/25 13:29	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3473		**Lims Reference ID:**		**ED53312-56**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 13:30	06/25/25 13:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3486		**Lims Reference ID:**		**ED53312-57**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553312
LIMS Reference ID: ED53312
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:18
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3486 (Continued)		**Lims Reference ID:**		**ED53312-57**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	**1.8**		1	1.0	µg/L	06/25/25 13:31	06/25/25 13:31	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3957		**Lims Reference ID:**		**ED53312-58**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/25/25 13:33	06/25/25 13:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3958		**Lims Reference ID:**		**ED53312-59**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/25/25 13:34	06/25/25 13:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3959		**Lims Reference ID:**		**ED53312-60**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/25/25 14:00	06/25/25 14:00	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3960		**Lims Reference ID:**		**ED53312-61**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/25/25 14:04	06/25/25 14:04	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553312
LIMS Reference ID: ED53312
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:18
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553312
LIMS Reference ID: ED53312
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:18
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EDS 7893

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Northeast Elementary School

NES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush** 48HR

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1272	KI	1067	Annex Kitchen	KC	12/23/2025	7:34:00 AM

Samples Submitted 1

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:10

PB Kathy Dlw 12/24/25

Building Address
2 Devon Road
Brentwood , NY 11717

Analysis Type: ELAP 200.8

Lab Recieved: 12/23/25 14:10

Signature:

Samplers Name: Molly Miller

Samplers Signature: Molly Miller

JCB Project Manager: Meghan Gwinn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557893

LIMS Reference ID: ED57893

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:10

Reported: 12/24/2025 17:01

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1272			**Lims Reference ID:**	**ED57893-01**	**Matrix: Drinking Water**			**Sampled:**	**12/23/25 07:34:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/24/25 13:37	12/24/25 13:37	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557893

LIMS Reference ID: ED57893

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 14:10
Reported:	12/24/2025 17:01

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557893

LIMS Reference ID: ED57893

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School: 2 Devon Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:10

Reported: 12/24/2025 17:01

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE 50420

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Northeast Elementary School

NES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1225	CR	1040	Room 18	DW	1/23/2026	7:18:00 AM
BRTWD-1234	CR	1048	Room 22	DW	1/23/2026	7:21:00 AM
BRTWD-1238	CR	1050	Room 24	DW	1/23/2026	7:24:00 AM
BRTWD-1293	CR	1078	Room 6A	DW	1/23/2026	7:37:00 AM
BRTWD-3453	OF	1024	Main Office	BWH	1/23/2026	7:30:00 AM

Samples Submitted 5

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 23 26, PM01:44

Courier

Building Address
2 Devon Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 1/23

Signature:

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650420
LIMS Reference ID: EE50420
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Northeast Elementary School, Brentwood Union Free School District, 2 Devon Road, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/23/2026 13:44
Reported: 01/26/2026 13:19

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1225		**Lims Reference ID:**		**EE50420-01**	**Matrix: Drinking Water**			**Sampled:**	**01/23/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/24/26 17:00	01/24/26 17:00	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1234		**Lims Reference ID:**		**EE50420-02**	**Matrix: Drinking Water**			**Sampled:**	**01/23/26 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	01/24/26 17:01	01/24/26 17:01	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1238		**Lims Reference ID:**		**EE50420-03**	**Matrix: Drinking Water**			**Sampled:**	**01/23/26 00:00:00**
Metals									
Lead	**3.8**		1	1.0	µg/L	01/24/26 17:05	01/24/26 17:05	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1293		**Lims Reference ID:**		**EE50420-04**	**Matrix: Drinking Water**			**Sampled:**	**01/23/26 00:00:00**
Metals									
Lead	**1.6**		1	1.0	µg/L	01/24/26 17:06	01/24/26 17:06	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3453		**Lims Reference ID:**		**EE50420-05**	**Matrix: Drinking Water**			**Sampled:**	**01/23/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/24/26 17:08	01/24/26 17:08	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650420
LIMS Reference ID: EE50420
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Northeast Elementary School, Brentwood Union Free School District, 2 Devon Road, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/23/2026 13:44
Reported: 01/26/2026 13:19

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650420
LIMS Reference ID: EE50420
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	JCB#: 23-53744, Northeast Elementary School, Brentwood Union Free School District, 2 Devon Road, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	01/23/2026 13:44
Reported:	01/26/2026 13:19

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50917

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Northeast Elementary School
NES

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1282	CR	1072	Room 12A	DW	2/20/2026	6:59:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 20 26, PM03:29

Building Address
2 Devon Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: James Ham

Signature: 2/20/26 329PM

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Bergen

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650917
LIMS Reference ID: EE50917
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Northeast Elementary School NES - Brentwood Union Free School District - 2 Devon Road Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/20/2026 15:29
Reported: 02/24/2026 08:55

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1282			**Lims Reference ID:**	**EE50917-01**	**Matrix: Drinking Water**			**Sampled:**	**02/20/26 06:59:00**
Metals									
Lead	**11.6**		1	1.0	µg/L	02/21/26 17:35	02/21/26 17:35	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650917
LIMS Reference ID: EE50917
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Northeast Elementary School NES - Brentwood Union Free School District - 2 Devon Road Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/20/2026 15:29
Reported: 02/24/2026 08:55

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650917
LIMS Reference ID: EE50917
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Northeast Elementary School NES - Brentwood Union Free School District - 2 Devon Road Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/20/2026 15:29
Reported: 02/24/2026 08:55

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE51082

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Northeast Elementary School
NES

Client: Brentwood Union Free School District

Retest/New Install M ✓

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1282	CR	1072	Room 12A	DW	3/4/2026	7:41:00 AM

Samples Submitted 1

Walk In

Pb 200.8 BHong 3/5/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 04 26, PM04:53

Building Address
2 Devon Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 3/4/26 4:53 PM

Signature:

Samplers Name: Daniella Colagiani

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651082
LIMS Reference ID: EE51082
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Northeast Elementary School NES, 2 Devon Road, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/04/2026 16:53
Reported: 03/05/2026 13:54

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1282			**Lims Reference ID:**	**EE51082-01**	**Matrix: Drinking Water**			**Sampled:**	**03/04/26 00:00:00**
Metals									
Lead	**1.1**		1	1.0	µg/L	03/05/26 12:36	03/05/26 12:36	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651082
LIMS Reference ID: EE51082
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Northeast Elementary School NES, 2 Devon Road, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/04/2026 16:53
Reported:	03/05/2026 13:54

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651082
LIMS Reference ID: EE51082
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Northeast Elementary School NES, 2 Devon Road, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/04/2026 16:53
Reported:	03/05/2026 13:54

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED53305

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Middle School

EMS

Client: Brentwood Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1377	HA	N/A	Corridor Near Basement Stairwell	WC	6/7/2025	7:37:00 AM
BRTWD-1378	HA	N/A	Corridor Near Basement Stairwell	WC	6/7/2025	7:38:00 AM
BRTWD-1384	HA	N/A	Corridor Near Bathrooms	WC	6/7/2025	7:41:00 AM
BRTWD-1385	HA	N/A	Corridor Near Bathrooms	WC	6/7/2025	7:41:00 AM
BRTWD-1393	HA	1056	Corridor Near Faculty Room (1026A)	WC	6/7/2025	6:42:00 AM
BRTWD-1394	HA	1056	Corridor Near Faculty Room (1026A)	WF	6/7/2025	6:42:00 AM
BRTWD-1396	NO	1029	Nurse's Office	NS	6/7/2025	6:48:00 AM
BRTWD-1400	HA	1056	Corridor Near Girls Locker Room (1033A)	DW	6/7/2025	6:18:00 AM
BRTWD-1404	LR	1033A	Girls Locker Room	DW	6/7/2025	6:20:00 AM
BRTWD-1408	LR	1042B	Boys Locker Room	DW	6/7/2025	6:24:00 AM
BRTWD-1411	HA	1056	Corridor Near Room 110 (1044)	DW	6/7/2025	6:15:00 AM
BRTWD-1426	HA	1056	Corridor Near Room 104 (1052)	DW	6/7/2025	6:38:00 AM
BRTWD-1434	HA	2021	Corridor Near Room 202 (2002)	WC	6/7/2025	7:19:00 AM
BRTWD-1446	OF	2017A	Library Work Room	OF	6/7/2025	7:15:00 AM
BRTWD-1450	HA	N/A	Corridor Near Faculty Bathrooms	WC	6/7/2025	7:30:00 AM
BRTWD-1454	HA	N/A	Corridor Near Room 246	WC	6/7/2025	7:24:00 AM
BRTWD-1455	HA	N/A	Corridor Near Room 246	WC	6/7/2025	7:25:00 AM
BRTWD-1456	HA	2041	Corridor Near Room 218 (2024)	DW	6/7/2025	7:21:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 AM

Building Address
70 Hilltop Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: ABlanley 6/13/25

Signature: 9:09pm

Samplers Name: Lexi Farwell

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for

EDS3305

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Middle School

EMS

Client: Brentwood Union Free School District

Retest/New Install

Turn Around: (Normal) 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1462	HA	2041	Corridor Near Room 226 (2033)	DW	6/7/2025	7:09:00 AM
BRTWD-1463	HA	2041	Corridor Near Room 226 (2033)	WF	6/7/2025	7:11:00 AM
BRTWD-1474	FL	N/A	Basement Technology Suite Break Room	BW	6/7/2025	8:00:00 AM
BRTWD-1476	KI	1036	Kitchen	HW	6/7/2025	6:10:00 AM
BRTWD-1477	KI	1036	Kitchen	KC	6/7/2025	6:07:00 AM
BRTWD-1478	KI	1036	Kitchen	KC	6/7/2025	6:07:00 AM
BRTWD-1479	KI	1036	Kitchen	KC	6/7/2025	6:06:00 AM
BRTWD-1481	KI	1036	Kitchen	KC	6/7/2025	6:05:00 AM
BRTWD-1482	KI	1036	Kitchen	HW	6/7/2025	6:03:00 AM
BRTWD-1484	KI	1036	Kitchen	HW	6/7/2025	6:04:00 AM
BRTWD-3014	HA	1056	Corridor Near Boiler Room (1001)	WC	6/7/2025	6:13:00 AM
BRTWD-3015	HA	1056	Corridor Near Boiler Room (1001)	WF	6/7/2025	6:13:00 AM
BRTWD-3016	HA	1023	Corridor Near Room 124 (1014)	WC	6/7/2025	6:54:00 AM
BRTWD-3017	HA	1023	Corridor Near Room 124 (1014)	WF	6/7/2025	6:54:00 AM
BRTWD-3019	HA	N/A	Corridor Near Bathrooms (New Construction)	WF	6/7/2025	7:35:00 AM
BRTWD-3020	HA	2021	Corridor Near Room 216 (2019)	WC	6/7/2025	7:14:00 AM
BRTWD-3021	HA	2021	Corridor Near Room 216 (2019)	WF	6/7/2025	7:14:00 AM
BRTWD-3106	HA	2021	Corridor Near Room 210 (2010)	WC	6/7/2025	7:17:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM 12:00

Building Address
70 Hilltop Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: A Stanley 6/13/25

Signature: 9:09pm

Samplers Name: Lexi Farrell

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for EDD 3305

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Middle School

EMS

Client: Brentwood Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3107	HA	1006A	Auditorium Lobby	WC	6/7/2025	6:57:00 AM
BRTWD-3230	FL	1026A	Faculty Lounge Room 114	KC	6/7/2025	7:02:00 AM
BRTWD-3233	KI	1036	Kitchen	PK	6/7/2025	6:02:00 AM
BRTWD-3237	HE	1048	Room 106	EC	6/7/2025	6:30:00 AM
BRTWD-3238	HE	1048	Room 106	EC	6/7/2025	6:29:00 AM
BRTWD-3239	HE	1048	Room 106	EC	6/7/2025	6:28:00 AM
BRTWD-3240	HE	1048A	Room 106 Laundry Room	EC	6/7/2025	6:31:00 AM
BRTWD-3241	HE	1052	Room 104	EC	6/7/2025	6:34:00 AM
BRTWD-3242	HE	1052	Room 104	EC	6/7/2025	6:34:00 AM
BRTWD-3243	HE	1052	Room 104	EC	6/7/2025	6:34:00 AM
BRTWD-3244	HE	1052	Room 104	EC	6/7/2025	6:35:00 AM
BRTWD-3257	FL	N/A	Basement Technology Suite Break Room	BWH	6/7/2025	8:01:00 AM

Samples Submitted 48

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:07

Building Address
70 Hilltop Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Ashley 6/13/25 9:09

Signature:

Samplers Name: Lexi Fahrwell

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553305
LIMS Reference ID: ED53305
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Middle School, EMS, Brentwood Union Free School District, 70 Hilltop Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:07
Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1377		**Lims Reference ID:**		**ED53305-01**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:35	06/24/25 20:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1378		**Lims Reference ID:**		**ED53305-02**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:36	06/24/25 20:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1384		**Lims Reference ID:**		**ED53305-03**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	06/24/25 20:38	06/24/25 20:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1385		**Lims Reference ID:**		**ED53305-04**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	2.3		1	1.0	µg/L	06/24/25 20:39	06/24/25 20:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1393		**Lims Reference ID:**		**ED53305-05**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:53	06/24/25 20:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1394		**Lims Reference ID:**		**ED53305-06**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:57	06/24/25 20:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1396		**Lims Reference ID:**		**ED53305-07**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	4.4		1	1.0	µg/L	06/24/25 20:58	06/24/25 20:58	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1400		**Lims Reference ID:**		**ED53305-08**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:00	06/24/25 21:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1404		**Lims Reference ID:**		**ED53305-09**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553305
LIMS Reference ID: ED53305
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Middle School, EMS, Brentwood Union Free School District, 70 Hilltop Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:07
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1404 (Continued)		**Lims Reference ID:**		**ED53305-09**	**Matrix: Drinking Water**				**Sampled: 06/07/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:01	06/24/25 21:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1408		**Lims Reference ID:**		**ED53305-10**	**Matrix: Drinking Water**				**Sampled: 06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:05	06/24/25 21:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1411		**Lims Reference ID:**		**ED53305-11**	**Matrix: Drinking Water**				**Sampled: 06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:06	06/24/25 21:06	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1426		**Lims Reference ID:**		**ED53305-12**	**Matrix: Drinking Water**				**Sampled: 06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:08	06/24/25 21:08	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1434		**Lims Reference ID:**		**ED53305-13**	**Matrix: Drinking Water**				**Sampled: 06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:09	06/24/25 21:09	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1446		**Lims Reference ID:**		**ED53305-14**	**Matrix: Drinking Water**				**Sampled: 06/07/25 00:00:00**
Metals									
Lead	4.5		1	1.0	µg/L	06/24/25 21:10	06/24/25 21:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1450		**Lims Reference ID:**		**ED53305-15**	**Matrix: Drinking Water**				**Sampled: 06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:12	06/24/25 21:12	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1454		**Lims Reference ID:**		**ED53305-16**	**Matrix: Drinking Water**				**Sampled: 06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:15	06/24/25 21:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1455		**Lims Reference ID:**		**ED53305-17**	**Matrix: Drinking Water**				**Sampled: 06/07/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553305
LIMS Reference ID: ED53305
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Middle School, EMS, Brentwood Union Free School District, 70 Hilltop Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:07
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1455 (Continued)		**Lims Reference ID:**		**ED53305-17**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:17	06/24/25 21:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1456		**Lims Reference ID:**		**ED53305-18**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	2.1		1	1.0	µg/L	06/24/25 21:21	06/24/25 21:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1462		**Lims Reference ID:**		**ED53305-19**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	4.4		1	1.0	µg/L	06/24/25 21:22	06/24/25 21:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1463		**Lims Reference ID:**		**ED53305-20**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	4.0		1	1.0	µg/L	06/24/25 21:23	06/24/25 21:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1474		**Lims Reference ID:**		**ED53305-21**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:25	06/24/25 21:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1476		**Lims Reference ID:**		**ED53305-22**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	11.7		1	1.0	µg/L	06/24/25 21:26	06/24/25 21:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1477		**Lims Reference ID:**		**ED53305-23**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	2.4		1	1.0	µg/L	06/24/25 21:27	06/24/25 21:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1478		**Lims Reference ID:**		**ED53305-24**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 21:29	06/24/25 21:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1479		**Lims Reference ID:**		**ED53305-25**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553305
LIMS Reference ID: ED53305
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Middle School, EMS, Brentwood Union Free School District, 70 Hilltop Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:07
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1479 (Continued)		**Lims Reference ID:**		**ED53305-25**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals (Continued)									
Lead	1.7		1	1.0	µg/L	06/25/25 11:18	06/25/25 11:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1481		**Lims Reference ID:**		**ED53305-26**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/25/25 11:22	06/25/25 11:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1482		**Lims Reference ID:**		**ED53305-27**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:23	06/25/25 11:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1484		**Lims Reference ID:**		**ED53305-28**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/25/25 11:25	06/25/25 11:25	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3014		**Lims Reference ID:**		**ED53305-29**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:26	06/25/25 11:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3015		**Lims Reference ID:**		**ED53305-30**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:30	06/25/25 11:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3016		**Lims Reference ID:**		**ED53305-31**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:31	06/25/25 11:31	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3017		**Lims Reference ID:**		**ED53305-32**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:33	06/25/25 11:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3019		**Lims Reference ID:**		**ED53305-33**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553305
LIMS Reference ID: ED53305
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Middle School, EMS, Brentwood Union Free School District, 70 Hilltop Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:07
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3019 (Continued)		**Lims Reference ID:**		**ED53305-33**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:34	06/25/25 11:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3020		**Lims Reference ID:**		**ED53305-34**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:35	06/25/25 11:35	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3021		**Lims Reference ID:**		**ED53305-35**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:37	06/25/25 11:37	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3106		**Lims Reference ID:**		**ED53305-36**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:41	06/25/25 11:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3107		**Lims Reference ID:**		**ED53305-37**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	1.0		1	1.0	µg/L	06/25/25 11:42	06/25/25 11:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3230		**Lims Reference ID:**		**ED53305-38**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/25/25 11:46	06/25/25 11:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3233		**Lims Reference ID:**		**ED53305-39**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	2.2		1	1.0	µg/L	06/25/25 11:47	06/25/25 11:47	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3237		**Lims Reference ID:**		**ED53305-40**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:49	06/25/25 11:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3238		**Lims Reference ID:**		**ED53305-41**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553305
LIMS Reference ID: ED53305
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Middle School, EMS, Brentwood Union Free School District, 70 Hilltop Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:07
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3238 (Continued)		**Lims Reference ID:**		**ED53305-41**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals (Continued)									
Lead	1.1		1	1.0	µg/L	06/25/25 11:50	06/25/25 11:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3239		**Lims Reference ID:**		**ED53305-42**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:51	06/25/25 11:51	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3240		**Lims Reference ID:**		**ED53305-43**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	15.5		1	1.0	µg/L	06/25/25 11:52	06/25/25 11:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3241		**Lims Reference ID:**		**ED53305-44**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 11:54	06/25/25 11:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3242		**Lims Reference ID:**		**ED53305-45**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 12:06	06/25/25 12:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3243		**Lims Reference ID:**		**ED53305-46**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 12:10	06/25/25 12:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3244		**Lims Reference ID:**		**ED53305-47**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 12:11	06/25/25 12:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3257		**Lims Reference ID:**		**ED53305-48**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/25/25 12:12	06/25/25 12:12	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553305
LIMS Reference ID: ED53305
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Middle School, EMS, Brentwood Union Free School District, 70 Hilltop Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:07
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553305
LIMS Reference ID: ED53305
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Middle School, EMS, Brentwood Union Free School District, 70 Hilltop Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:07
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57869

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Middle School

EMS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1476	KI	1036	Kitchen	HW	12/23/2025	6:42:00 AM

Samples Submitted 1

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:06

Pb 200.8
Kathrubw
12/24/25

Building Address
70 Hilltop Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/23/25 2:06pm

Signature: Dair Wharton

Samplers Name: Danielle Bahgjiai

Samplers Signature:

JCB Project Manager: Meghan Bunyan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557869

LIMS Reference ID: ED57869

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / East Middle School EMS / 70 Hilltop Drive, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:06

Reported: 12/24/2025 16:48

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1476			**Lims Reference ID:**	**ED57869-01**	**Matrix: Drinking Water**			**Sampled:**	**12/23/25 00:00:00**
Metals									
Lead	**7.1**		1	1.0	µg/L	12/24/25 12:57	12/24/25 12:57	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557869

LIMS Reference ID: ED57869

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / East Middle School EMS / 70 Hilltop Drive, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:06

Reported: 12/24/2025 16:48

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557869

LIMS Reference ID: ED57869

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / East Middle School EMS / 70 Hilltop Drive, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:06

Reported: 12/24/2025 16:48

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57968

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Middle School

EMS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1476	KI	1036	Kitchen	HW	12/30/2025	8:22:00 AM
BRTWD-3240	HE	1048A	Room 106 Laundry Room	EC	12/30/2025	8:24:00 AM

Samples Submitted 2

Walk In

Pb 200.8
Kathleen
12/31/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:36

Building Address
70 Hilltop Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/30/25 4:36 PM

Signature: Dave Wh

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557968

LIMS Reference ID: ED57968

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / East Middle School EMS / 70 Hilltop Drive, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:36

Reported: 12/31/2025 15:32

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1476			**Lims Reference ID:**		**ED57968-01**	**Matrix: Drinking Water**			**Sampled: 12/30/25 00:00:00**
Metals									
Lead	**2.1**		1	1.0	µg/L	12/31/25 13:53	12/31/25 13:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3240			**Lims Reference ID:**		**ED57968-02**	**Matrix: Drinking Water**			**Sampled: 12/30/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/31/25 13:54	12/31/25 13:54	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557968

LIMS Reference ID: ED57968

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	23-53744 / Brentwood Union Free School District / East Middle School EMS / 70 Hilltop Drive, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/30/2025 16:36
Reported:	12/31/2025 15:32

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557968
LIMS Reference ID: ED57968
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / East Middle School EMS / 70 Hilltop Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:36
Reported: 12/31/2025 15:32

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50694

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Middle School

EMS

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3018	HA	N/A	Corridor Near Bathrooms (New Construction)	WC	2/19/2026	6:59:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 19 26, PM01:17

Building Address
70 Hilltop Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Sean Cahill 02/19/26 1:17PM

Signature:

Samplers Name: Danielle Balsamo

Samplers Signature:

JCB Project Manager: Meghan Gwynn

200.8 2/21/26

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650894
LIMS Reference ID: EE50894
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: East Middle School, 70 Hilltop Drive Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/19/2026 13:17
Reported: 02/21/2026 09:16

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3018			**Lims Reference ID:**	**EE50894-01**	**Matrix: Drinking Water**			**Sampled:**	**02/19/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	02/21/26 00:34	02/21/26 00:34	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650894
LIMS Reference ID: EE50894
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: East Middle School, 70 Hilltop Drive Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/19/2026 13:17
Reported: 02/21/2026 09:16

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650894
LIMS Reference ID: EE50894
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: East Middle School, 70 Hilltop Drive Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/19/2026 13:17
Reported: 02/21/2026 09:16

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE53371

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: East Middle School

EMS

Client: Brentwood Union Free School District

Retest/New Install [✓]

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4296	HA	1056	Cafeteria Corridor	WF	6/26/2026	6:54:00 AM
BRTWD-4297	HA	1056	Cafeteria Corridor	WC	6/26/2026	6:55:00 AM

Samples Submitted 2

Ab 200-8 Billing 6/29/26

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 26 26, PM01:01

Building Address
70 Hilltop Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 6/26/26 1:01 pm

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Danielle Bolognini

Ab 200-8 6/27/26

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653371

LIMS Reference ID: EE53371

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: East Middle School EMS, 70 Hilltop Drive, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/26/2026 13:01

Reported: 06/29/2026 15:53

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4296		**Lims Reference ID:**		**EE53371-01**	**Matrix: Drinking Water**			**Sampled:**	**06/26/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/29/26 14:24	06/29/26 14:24	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4297		**Lims Reference ID:**		**EE53371-02**	**Matrix: Drinking Water**			**Sampled:**	**06/26/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/29/26 14:25	06/29/26 14:25	BP	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653371

LIMS Reference ID: EE53371

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	East Middle School EMS, 70 Hilltop Drive, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	06/26/2026 13:01
Reported:	06/29/2026 15:53

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	05/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653371

LIMS Reference ID: EE53371

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	East Middle School EMS, 70 Hilltop Drive, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	06/26/2026 13:01
Reported:	06/29/2026 15:53

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for E053232

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Walk In

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush**_____

RECEIVED
ENVIRONMENTAL INC.
Carle Place, NY
JUN 13 25 PM12:03

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1501	NO	1010	Health Suite	NS	6/7/2025	7:03:00 AM
BRTWD-1516	HA	1042	Corridor Near Room 48 (1034)	DW	6/7/2025	6:54:00 AM
BRTWD-1517	KI	1036	Cafeteria (Area Reconstructed)	HW	6/7/2025	6:51:00 AM
BRTWD-1518	KI	1036	Cafeteria (Area Reconstructed)	KC	6/7/2025	6:50:00 AM
BRTWD-1519	KI	1036	Cafeteria (Area Reconstructed)	HW	6/7/2025	6:49:00 AM
BRTWD-1520	KI	1038	Kitchen	HW	6/7/2025	6:37:00 AM
BRTWD-1521	KI	1038	Kitchen	KC	6/7/2025	6:38:00 AM
BRTWD-1522	KI	1038	Kitchen	KC	6/7/2025	6:39:00 AM
BRTWD-1523	KI	1038	Kitchen	KC	6/7/2025	6:42:00 AM
BRTWD-1526	KI	1038	Kitchen	HW	6/7/2025	6:40:00 AM
BRTWD-1541	LR	1073	Girls Locker Room	WC	6/7/2025	6:29:00 AM
BRTWD-1544	GY	1075	Gymnasium	DW	6/7/2025	6:26:00 AM
BRTWD-1546	LR	1071	Boys Locker Room	DW	6/7/2025	6:33:00 AM
BRTWD-1614	HA	2014	Corridor Near Room 209 (2008)	DW	6/7/2025	6:20:00 AM
BRTWD-2993	CA	1036	Cafeteria (Expanded in 2012)	WF	6/7/2025	6:49:00 AM
BRTWD-2994	HA	1076	Corridor Between Library & Gym	WF	6/7/2025	7:06:00 AM
BRTWD-3094	HA	N/A	Corridor Across From Room 217	WC	6/7/2025	6:08:00 AM
BRTWD-3095	HA	N/A	Corridor Across From Room 217	WF	6/7/2025	6:09:00 AM

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 12:03

Signature:

Samplers Name: Aileen McNamee

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for

ED53232

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3108	LR	1071	Boys Locker Room	DW	6/7/2025	6:31:00 AM
BRTWD-3366	HE	1028A	Home Ec. Kitchen	EC	6/7/2025	7:09:00 AM
BRTWD-3367	HE	1028A	Home Ec. Kitchen	EC	6/7/2025	7:10:00 AM
BRTWD-3368	HE	1028A	Home Ec. Kitchen	EC	6/7/2025	7:11:00 AM
BRTWD-3369	FL	1034	Faculty Room	KC	6/7/2025	6:55:00 AM
BRTWD-3370	KI	1038	Kitchen	KC	6/7/2025	6:45:00 AM
BRTWD-3371	KI	1038	Kitchen	PK	6/7/2025	6:41:00 AM

Samples Submitted 25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM12:03

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25, 12:03

Signature:

Samplers Name: Aileen McNamee

Samplers Signature: Aileen M.

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553232

LIMS Reference ID: ED53232

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 12:03

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1501		**Lims Reference ID:**		**ED53232-01**	**Matrix: Drinking Water**				**Sampled: 06/07/25 07:03:00**
Metals									
Lead	**6.3**		1	1.0	µg/L	06/23/25 16:16	06/23/25 16:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1516		**Lims Reference ID:**		**ED53232-02**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:54:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 17:28	06/23/25 17:28	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1517		**Lims Reference ID:**		**ED53232-03**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:51:00**
Metals									
Lead	**16.8**		1	1.0	µg/L	06/23/25 17:32	06/23/25 17:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1518		**Lims Reference ID:**		**ED53232-04**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:50:00**
Metals									
Lead	**12.1**		1	1.0	µg/L	06/23/25 17:33	06/23/25 17:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1519		**Lims Reference ID:**		**ED53232-05**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:49:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 17:35	06/23/25 17:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1520		**Lims Reference ID:**		**ED53232-06**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:37:00**
Metals									
Lead	**10.2**		1	1.0	µg/L	06/23/25 17:36	06/23/25 17:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1521		**Lims Reference ID:**		**ED53232-07**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:38:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	06/23/25 17:40	06/23/25 17:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1522		**Lims Reference ID:**		**ED53232-08**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:39:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 17:41	06/23/25 17:41	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1523		**Lims Reference ID:**		**ED53232-09**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:42:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553232
LIMS Reference ID: ED53232
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 12:03
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1523 (Continued)		**Lims Reference ID:**		**ED53232-09**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 06:42:00**
Metals (Continued)									
Lead	1.0		1	1.0	µg/L	06/23/25 17:43	06/23/25 17:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1526		**Lims Reference ID:**		**ED53232-10**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 06:40:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 17:44	06/23/25 17:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1541		**Lims Reference ID:**		**ED53232-11**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 06:29:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 17:45	06/23/25 17:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1544		**Lims Reference ID:**		**ED53232-12**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 06:26:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/23/25 17:47	06/23/25 17:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1546		**Lims Reference ID:**		**ED53232-13**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 06:33:00**
Metals									
Lead	20.2		1	1.0	µg/L	06/23/25 17:51	06/23/25 17:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1614		**Lims Reference ID:**		**ED53232-14**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 06:20:00**
Metals									
Lead	13.8		1	1.0	µg/L	06/23/25 17:52	06/23/25 17:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2993		**Lims Reference ID:**		**ED53232-15**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 06:49:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 17:56	06/23/25 17:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2994		**Lims Reference ID:**		**ED53232-16**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 07:06:00**
Metals									
Lead	1.7		1	1.0	µg/L	06/23/25 17:57	06/23/25 17:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3094		**Lims Reference ID:**		**ED53232-17**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 06:08:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553232
LIMS Reference ID: ED53232
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 12:03
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3094 (Continued)		**Lims Reference ID:**		**ED53232-17**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:08:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/23/25 17:58	06/23/25 17:58	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3095		**Lims Reference ID:**		**ED53232-18**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:09:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 18:00	06/23/25 18:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3108		**Lims Reference ID:**		**ED53232-19**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:31:00**
Metals									
Lead	19.6		1	1.0	µg/L	06/23/25 18:01	06/23/25 18:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3366		**Lims Reference ID:**		**ED53232-20**	**Matrix: Drinking Water**				**Sampled: 06/07/25 07:09:00**
Metals									
Lead	40.9		1	1.0	µg/L	06/23/25 18:02	06/23/25 18:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3367		**Lims Reference ID:**		**ED53232-21**	**Matrix: Drinking Water**				**Sampled: 06/07/25 07:10:00**
Metals									
Lead	119		2	2.0	µg/L	06/23/25 18:10	06/23/25 18:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3368		**Lims Reference ID:**		**ED53232-22**	**Matrix: Drinking Water**				**Sampled: 06/07/25 07:11:00**
Metals									
Lead	2.5		1	1.0	µg/L	06/23/25 18:22	06/23/25 18:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3369		**Lims Reference ID:**		**ED53232-23**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:55:00**
Metals									
Lead	2.9		1	1.0	µg/L	06/23/25 18:26	06/23/25 18:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3370		**Lims Reference ID:**		**ED53232-24**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:45:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 18:27	06/23/25 18:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3371		**Lims Reference ID:**		**ED53232-25**	**Matrix: Drinking Water**				**Sampled: 06/07/25 06:41:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553232
LIMS Reference ID: ED53232
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 12:03
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3371 (Continued)			**Lims Reference ID:**	**ED53232-25**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 06:41:00**
Metals (Continued)									
Lead	**1.0**		1	1.0	µg/L	06/23/25 18:28	06/23/25 18:28	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553232
LIMS Reference ID: ED53232
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 12:03
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553232
LIMS Reference ID: ED53232
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 12:03
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for E D56325

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4244	HA	N/A	New Construction Corridor Near Room 14	WF	10/2/2025	9:28:00 AM
BRTWD-4245	HA	N/A	New Construction Corridor Near Room 14	WC	10/2/2025	9:29:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 02 25, PM03:10

Pb 200.8 Billing 10/3/25

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/2/25 3:10 PM

Signature: David Wharton

Samplers Name: Meghan Guygnn

Samplers Signature: Meghan Guygnn

JCB Project Manager: Meghan Guygnn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556325

LIMS Reference ID: ED56325

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Freshman Center (FRESH), 33 Leahy Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/02/2025 15:10

Reported: 10/04/2025 09:40

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4244		**Lims Reference ID:**		**ED56325-01**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 13:11	10/03/25 13:11	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4245		**Lims Reference ID:**		**ED56325-02**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 13:12	10/03/25 13:12	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556325
LIMS Reference ID: ED56325
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Freshman Center (FRESH), 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/02/2025 15:10
Reported: 10/04/2025 09:40

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556325
LIMS Reference ID: ED56325
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Freshman Center (FRESH), 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/02/2025 15:10
Reported: 10/04/2025 09:40

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57780

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4265	CA	1036	Cafeteria (Expanded in 2012)	WF	12/18/2025	7:10:00 AM
BRTWD-4266	CA	1036	Cafeteria (Expanded in 2012)	GS	12/18/2025	7:16:00 AM

Samples Submitted 2

RB 200.8 BHong 12/19/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 18 25, PM01:49

Courier

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Rael

Signature:

Samplers Name: Meghan Guynn

Samplers Signature: Meghan Guynn

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557780
LIMS Reference ID: ED57780
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Freshman Center, Brentwood Union Free School District, 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/18/2025 13:49
Reported: 12/20/2025 12:20

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4265		**Lims Reference ID:**		**ED57780-01**	**Matrix: Drinking Water**				**Sampled: 12/18/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/20/25 12:00	12/20/25 12:00	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4266		**Lims Reference ID:**		**ED57780-02**	**Matrix: Drinking Water**				**Sampled: 12/18/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/19/25 15:00	12/19/25 15:00	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557780

LIMS Reference ID: ED57780

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Freshman Center, Brentwood Union Free School District, 33 Leahy Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/18/2025 13:49

Reported: 12/20/2025 12:20

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557780
LIMS Reference ID: ED57780
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	JCB#: 23-53744, Freshman Center, Brentwood Union Free School District, 33 Leahy Avenue, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/18/2025 13:49
Reported:	12/20/2025 12:20

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

ED578910

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1501	NO	1010	Health Suite	NS	12/23/2025	6:53:00 AM
BRTWD-1517	KI	1036	Cafeteria (Area Reconstructed)	HW	12/23/2025	6:49:00 AM
BRTWD-1518	KI	1036	Cafeteria (Area Reconstructed)	KC	12/23/2025	6:48:00 AM
BRTWD-1520	KI	1038	Kitchen	HW	12/23/2025	6:51:00 AM

Samples Submitted 4

Courier

Pb 200.8 Rush 12/24/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:17

Pb 200.8
Rush
12/26/25

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 12/23/25 14:17

Signature: [signature] MAY WAGNER

Samplers Name: Meghan Guynn

Samplers Signature: [signature]

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557890

LIMS Reference ID: ED57890

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School Districtr: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:17

Reported: 12/26/2025 16:28

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1501		**Lims Reference ID:**		**ED57890-01**	**Matrix: Drinking Water**				**Sampled: 12/23/25 06:53:00**
Metals									
Lead	**12.5**	1	1.0	µg/L	12/24/25 11:24	12/24/25 11:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1517		**Lims Reference ID:**		**ED57890-02**	**Matrix: Drinking Water**				**Sampled: 12/23/25 06:49:00**
Metals									
Lead	**< 1.0**	1	1.0	µg/L	12/24/25 11:25	12/24/25 11:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1518		**Lims Reference ID:**		**ED57890-03**	**Matrix: Drinking Water**				**Sampled: 12/23/25 06:48:00**
Metals									
Lead	**76.1**	1	1.0	µg/L	12/26/25 15:54	12/26/25 15:54	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-1520		**Lims Reference ID:**		**ED57890-04**	**Matrix: Drinking Water**				**Sampled: 12/23/25 06:51:00**
Metals									
Lead	**1.8**	1	1.0	µg/L	12/24/25 11:26	12/24/25 11:26	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557890
LIMS Reference ID: ED57890
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School Districtr: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:17
Reported: 12/26/2025 16:28

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557890
LIMS Reference ID: ED57890
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School Districtr: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:17
Reported: 12/26/2025 16:28

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EDS7963

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1501	NO	1010	Health Suite	NS	12/30/2025	7:24:00 AM
BRTWD-1518	KI	1036	Cafeteria (Area Reconstructed)	KC	12/30/2025	7:27:00 AM
BRTWD-3366	HE	1028A	Home Ec. Kitchen	EC	12/30/2025	7:25:00 AM
BRTWD-3367	HE	1028A	Home Ec. Kitchen	EC	12/30/2025	7:26:00 AM

Samples Submitted 4

Walk In

Pb 200.8 Battery 12/31/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:38

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 12/30/25 16:38

Signature: [signature]

Samplers Name: Jordan Miglino

Samplers Signature: [signature]

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557963

LIMS Reference ID: ED57963

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:38

Reported: 12/31/2025 15:17

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1501		**Lims Reference ID:**		**ED57963-01**	**Matrix: Drinking Water**				**Sampled: 12/30/25 07:24:00**
Metals									
Lead	**222**		5	5.0	µg/L	12/31/25 10:07	12/31/25 10:07	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1518		**Lims Reference ID:**		**ED57963-02**	**Matrix: Drinking Water**				**Sampled: 12/30/25 07:27:00**
Metals									
Lead	**12.1**		1	1.0	µg/L	12/31/25 09:59	12/31/25 09:59	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3366		**Lims Reference ID:**		**ED57963-03**	**Matrix: Drinking Water**				**Sampled: 12/30/25 07:25:00**
Metals									
Lead	**18.2**		1	1.0	µg/L	12/31/25 10:00	12/31/25 10:00	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3367		**Lims Reference ID:**		**ED57963-04**	**Matrix: Drinking Water**				**Sampled: 12/30/25 07:26:00**
Metals									
Lead	**8.3**		1	1.0	µg/L	12/31/25 10:02	12/31/25 10:02	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557963
LIMS Reference ID: ED57963
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:38
Reported: 12/31/2025 15:17

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557963
LIMS Reference ID: ED57963
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Freshman Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:38
Reported: 12/31/2025 15:17

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EE50116

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1501	NO	1010	Health Suite	NS	1/9/2026	6:50:00 AM
BRTWD-3366	HE	1028A	Home Ec. Kitchen	EC	1/9/2026	6:45:00 AM
BRTWD-3367	HE	1028A	Home Ec. Kitchen	EC	1/9/2026	6:45:00 AM

Samples Submitted 3

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 09 26, PM02:54

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 1/9/26 2:54 pm

Signature:

Samplers Name: Meghan Guzman

Samplers Signature:

JCB Project Manager: Meghan Guz

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650116
LIMS Reference ID: EE50116
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Freshman Center FRESH / 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:54
Reported: 01/12/2026 09:50

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1501		**Lims Reference ID:**		**EE50116-01**	**Matrix: Drinking Water**			**Sampled:**	**01/09/26 06:50:00**
Metals									
Lead	**3.7**		1	1.0	µg/L	01/10/26 17:01	01/10/26 17:01	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3366		**Lims Reference ID:**		**EE50116-02**	**Matrix: Drinking Water**			**Sampled:**	**01/09/26 06:45:00**
Metals									
Lead	**11.6**		1	1.0	µg/L	01/10/26 13:53	01/10/26 13:53	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-3367		**Lims Reference ID:**		**EE50116-03**	**Matrix: Drinking Water**			**Sampled:**	**01/09/26 06:45:00**
Metals									
Lead	**9.8**		1	1.0	µg/L	01/10/26 17:02	01/10/26 17:02	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650116
LIMS Reference ID: EE50116
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Freshman Center FRESH / 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:54
Reported: 01/12/2026 09:50

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650116
LIMS Reference ID: EE50116
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Freshman Center FRESH / 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:54
Reported: 01/12/2026 09:50

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EE50205

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3366	HE	1028A	Home Ec. Kitchen	EC	1/14/2026	7:06:00 AM
BRTWD-3367	HE	1028A	Home Ec. Kitchen	EC	1/14/2026	7:06:00 AM

Samples Submitted 2

Courier

PB Billing 1/15/26

200.8

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 14 26, PM01:29

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 1/14/26 1:29 PM

Signature: David Wharton

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650205
LIMS Reference ID: EE50205
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Freshman Center FRESH / 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/14/2026 13:29
Reported: 01/15/2026 12:38

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3366			**Lims Reference ID:**	**EE50205-01**	**Matrix: Drinking Water**				**Sampled: 01/14/26 00:00:00**
Metals									
Lead	**3.0**		1	1.0	µg/L	01/15/26 11:19	01/15/26 11:19	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3367			**Lims Reference ID:**	**EE50205-02**	**Matrix: Drinking Water**				**Sampled: 01/14/26 00:00:00**
Metals									
Lead	**3.7**		1	1.0	µg/L	01/15/26 11:43	01/15/26 11:43	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650205
LIMS Reference ID: EE50205
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Freshman Center FRESH / 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/14/2026 13:29
Reported: 01/15/2026 12:38

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650205
LIMS Reference ID: EE50205
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Freshman Center FRESH / 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/14/2026 13:29
Reported: 01/15/2026 12:38

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EE53869

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4304	HA	2014	Corridor Room 203 to 209	WF	8/4/2026	7:14:00 AM
BRTWD-4305	HA	2014	Corridor Room 203 to 209	WC	8/4/2026	7:15:00 AM

Samples Submitted 2

Courier

Pb 200.8 Bking 8/15/26

Pb 200.8 Bking 8/16/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 04 26, PM01:05

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/4/26 1:05 PM

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653869

LIMS Reference ID: EE53869

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Freshman Center FRESH, 33 Leahy Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/04/2026 13:05

Reported: 08/06/2026 11:50

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4304		**Lims Reference ID:**		**EE53869-01**	**Matrix: Drinking Water**				**Sampled: 08/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/06/26 10:34	08/06/26 10:34	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4305		**Lims Reference ID:**		**EE53869-02**	**Matrix: Drinking Water**				**Sampled: 08/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/05/26 12:40	08/05/26 12:40	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653869

LIMS Reference ID: EE53869

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Freshman Center FRESH, 33 Leahy Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/04/2026 13:05

Reported: 08/06/2026 11:50

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653869

LIMS Reference ID: EE53869

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	Freshman Center FRESH, 33 Leahy Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/04/2026 13:05
Reported:	08/06/2026 11:50

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EES 4120

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Retest/New Install [✓]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1518	KI	1036	Cafeteria (Area Reconstructed)	KC	8/19/2026	8:51:00 AM
BRTWD-1546	LR	1071	Boys Locker Room	DW	8/19/2026	8:56:00 AM
BRTWD-1548	OF	1068C	Library Work Room	OF	8/19/2026	8:55:00 AM
BRTWD-3108	LR	1071	Boys Locker Room	DW	8/19/2026	8:56:00 AM
BRTWD-4324	GY	1075	Gym	WF	8/19/2026	8:58:00 AM
BRTWD-4325	GY	1075	Gym	WF	8/19/2026	8:59:00 AM

Samples Submitted 6

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 19 26, PM12:39

ID 2008

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Charlotte

Signature:

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Danielle Bologna

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654120
LIMS Reference ID: EE54120
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: JCB#: 26-64123, Brentwood Union Free School District, 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/19/2026 12:39
Reported: 08/21/2026 09:28

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1518		**Lims Reference ID:**		**EE54120-01**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**5.1**	1		1.0	µg/L	08/20/26 18:47	08/20/26 18:47	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1546		**Lims Reference ID:**		**EE54120-02**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**9.6**	1		1.0	µg/L	08/20/26 18:48	08/20/26 18:48	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1548		**Lims Reference ID:**		**EE54120-03**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**2.1**	1		1.0	µg/L	08/20/26 18:50	08/20/26 18:50	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3108		**Lims Reference ID:**		**EE54120-04**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**5.5**	1		1.0	µg/L	08/20/26 18:51	08/20/26 18:51	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4324		**Lims Reference ID:**		**EE54120-05**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**< 1.0**	1		1.0	µg/L	08/20/26 18:52	08/20/26 18:52	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4325		**Lims Reference ID:**		**EE54120-06**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**< 1.0**	1		1.0	µg/L	08/20/26 18:54	08/20/26 18:54	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654120
LIMS Reference ID: EE54120
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: JCB#: 26-64123, Brentwood Union Free School District, 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/19/2026 12:39
Reported: 08/21/2026 09:28

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654120
LIMS Reference ID: EE54120
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: JCB#: 26-64123, Brentwood Union Free School District, 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/19/2026 12:39
Reported: 08/21/2026 09:28

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for [redacted] MA EE54402

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Freshman Center

FRESH

Client: Brentwood Union Free School District

Retest/New Install H

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1518	KI	1036	Cafeteria (Area Reconstructed)	KC	9/4/2026	6:48:00 AM
BRTWD-1546	LR	1071	Boys Locker Room	DW	9/4/2026	6:52:00 AM
BRTWD-3108	LR	1071	Boys Locker Room	DW	9/4/2026	6:51:00 AM

Samples Submitted 3

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
SEP 04 26, PM02:25

Pb 200.8 915716

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Mateo Martinic 9/4/26

Signature: MM 2:25 PM

Samplers Name: Jordan Miglino

Samplers Signature: Jordan Miglino

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654402

LIMS Reference ID: EE54402

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: #26-64123, Brentwood Union Free School District, Freshman Center, 33 Leahy Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/04/2026 14:25

Reported: 09/08/2026 08:52

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1518		**Lims Reference ID:**		**EE54402-01**	**Matrix: Drinking Water**			**Sampled:**	**09/04/26 06:48:00**
Metals									
Lead	**2.0**		1	1.0	µg/L	09/05/26 18:14	09/05/26 18:14	DAZ	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-1546		**Lims Reference ID:**		**EE54402-02**	**Matrix: Drinking Water**			**Sampled:**	**09/04/26 06:48:00**
Metals									
Lead	**20.7**		1	1.0	µg/L	09/05/26 18:18	09/05/26 18:18	DAZ	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-3108		**Lims Reference ID:**		**EE54402-03**	**Matrix: Drinking Water**			**Sampled:**	**09/04/26 06:48:00**
Metals									
Lead	**6.9**		1	1.0	µg/L	09/05/26 18:19	09/05/26 18:19	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654402

LIMS Reference ID: EE54402

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	#26-64123, Brentwood Union Free School District, Freshman Center, 33 Leahy Avenue, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	09/04/2026 14:25
Reported:	09/08/2026 08:52

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654402
LIMS Reference ID: EE54402
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: #26-64123, Brentwood Union Free School District, Freshman Center, 33 Leahy Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/04/2026 14:25
Reported: 09/08/2026 08:52

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED53231

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: Instructional Media Center
IMC

Client:
Brentwood Union Free School District

Retest/New Install [ ]
Turn Around: Normal 1 wk Rush_____

Pb 200.8 Dellolo25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1652	HA	N/A	Corridor Near Room 43	WC	6/7/2025	7:13:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM12:03

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: 6/13/25, 12:03
Signature:

Samplers Name: Aileen McNamee
Samplers Signature: Aileen McNamee
JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553231
LIMS Reference ID: ED53231
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Instructional Media Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 12:03
Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1652			**Lims Reference ID:**	**ED53231-01**	**Matrix: Drinking Water**			**Sampled:**	**06/07/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/16/25 12:25	06/16/25 12:25	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553231

LIMS Reference ID: ED53231

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Instructional Media Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 12:03

Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553231
LIMS Reference ID: ED53231
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Instructional Media Center: 33 Leahy Avenue, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 12:03
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE53868

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Instructional Media Center

IMC

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4306	HA	N/A	Corridor Near Room 43	WF	8/4/2026	7:23:00 AM
BRTWD-4307	HA	N/A	Corridor Near Room 43	WC	8/4/2026	7:24:00 AM

Samples Submitted 2

Courier

Pb 200.8 Bkmg 8/5/26

Pb 200.8 Bkmg 8/6/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 04 26, PM01:05

Building Address
33 Leahy Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/4/26 1:05pm

Signature:

Samplers Name: Danielle Belegnini

Samplers Signature:

JCB Project Manager: Danielle Belegnini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653868

LIMS Reference ID: EE53868

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Instructional Media Center IMC, 33 Leahy Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/04/2026 13:05

Reported: 08/06/2026 11:47

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4306		**Lims Reference ID:**		**EE53868-01**	**Matrix: Drinking Water**			**Sampled:**	**08/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/06/26 10:29	08/06/26 10:29	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4307		**Lims Reference ID:**		**EE53868-02**	**Matrix: Drinking Water**			**Sampled:**	**08/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/05/26 12:39	08/05/26 12:39	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653868

LIMS Reference ID: EE53868

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Instructional Media Center IMC, 33 Leahy Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/04/2026 13:05

Reported: 08/06/2026 11:47

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653868

LIMS Reference ID: EE53868

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	Instructional Media Center IMC, 33 Leahy Avenue, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/04/2026 13:05
Reported:	08/06/2026 11:47

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Walk In

E253302

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Middle School

NMS

Client:
Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1671	HA	1023	Corridor Near Room 123 (1013)	DW	6/11/2025	6:38:00 AM
BRTWD-1677	HA	1023	Corridor Near Room 116 (1021)	DW	6/11/2025	6:36:00 AM
BRTWD-1694	FL	1026	Faculty Room	KC	6/11/2025	6:35:00 AM
BRTWD-1700	NO	1029	Nurse's Office	NS	6/11/2025	6:32:00 AM
BRTWD-1707	LR	1033	Girls Locker Room	DW	6/11/2025	6:28:00 AM
BRTWD-1709	KI	1034	Kitchen	KC	6/11/2025	5:47:00 AM
BRTWD-1710	KI	1034	Kitchen	KC	6/11/2025	5:47:00 AM
BRTWD-1711	KI	1034	Kitchen	KC	6/11/2025	5:45:00 AM
BRTWD-1713	KI	1034	Kitchen	KC	6/11/2025	5:46:00 AM
BRTWD-1715	KI	1034	Kitchen	HW	6/11/2025	5:43:00 AM
BRTWD-1725	HA	1057	Corridor Near Room 110 (1044)	DW	6/11/2025	6:11:00 AM
BRTWD-1756	HA	2018	Corridor Near Room 228 (2008)	DW	6/11/2025	6:04:00 AM
BRTWD-1761	HA	2018	Corridor Near Room 220 (2016)	DW	6/11/2025	6:02:00 AM
BRTWD-1776	OF	2023A	Library Work Room	OF	6/11/2025	6:58:00 AM
BRTWD-1777	HA	2043	Corridor Near Stairwell (2030)	DW	6/11/2025	5:53:00 AM
BRTWD-1788	HA	2043	Corridor Near Art Room 202 (2041)	DW	6/11/2025	5:54:00 AM
BRTWD-3005	CR	2019	Room 218 Life Skills	EC	6/11/2025	6:01:00 AM
BRTWD-3028	HA	1057	Corridor Near Elevator	WC	6/11/2025	5:50:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 2025 8:57

Building Address
350 Wicks Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/12/25 20:52

Signature:

Samplers Name: Tiffany Chen

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for ED53302

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Middle School

NMS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3029	HA	1057	Corridor Near Elevator	WF	6/11/2025	5:51:00 AM
BRTWD-3030	HA	N/A	Corridor Near Bathrooms (New Construction)	WC	6/11/2025	6:47:00 AM
BRTWD-3031	HA	N/A	Corridor Near Bathrooms (New Construction)	WF	6/11/2025	6:47:00 AM
BRTWD-3032	HA	1008	Corridor Near Auditorium (1005)	WC	6/11/2025	6:41:00 AM
BRTWD-3033	HA	1008	Corridor Near Auditorium (1005)	WF	6/11/2025	6:41:00 AM
BRTWD-3034	HA	2043	Corridor Near Room 216 (2021)	WC	6/11/2025	6:00:00 AM
BRTWD-3035	HA	2043	Corridor Near Room 216 (2021)	WF	6/11/2025	5:59:00 AM
BRTWD-3090	HA	1058	Corridor Near Faculty Room (1026)	WC	6/11/2025	6:33:00 AM
BRTWD-3091	HA	1058	Corridor Near Faculty Room (1026)	WF	6/11/2025	6:33:00 AM
BRTWD-3092	HA	N/A	Corridor Near Room 146	WC	6/11/2025	6:50:00 AM
BRTWD-3093	HA	N/A	Corridor Near Room 146	WC	6/11/2025	6:49:00 AM
BRTWD-3382	CR	1024	Room 114	BWC	6/11/2025	6:54:00 AM
BRTWD-3383	CR	1024	Room 114	BWH	6/11/2025	6:55:00 AM
BRTWD-3395	NO	1029C	Nurses Office Inner Room 2	NS	6/11/2025	6:44:00 AM
BRTWD-3396	KI	1034	Kitchen	PK	6/11/2025	5:44:00 AM
BRTWD-3397	HE	1048	Room 106	EC	6/11/2025	6:14:00 AM
BRTWD-3398	HE	1048	Room 106	EC	6/11/2025	6:13:00 AM
BRTWD-3399	HE	1048	Room 106	EC	6/11/2025	6:15:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
JUN 13 25

Building Address
350 Wicks Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 W.J.T

Signature:

Samplers Name: Tiffany Chen

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for ED53302

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: North Middle School
NMS

Client:
Brentwood Union Free School District

Retest/New Install [ ]
Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3402	HE	1051	Room 104	EC	6/11/2025	6:22:00 AM
BRTWD-3403	HE	1051	Room 104	EC	6/11/2025	6:22:00 AM
BRTWD-3404	HE	1051	Room 104	EC	6/11/2025	6:21:00 AM
BRTWD-3405	HE	1051	Room 104	EC	6/11/2025	6:20:00 AM
BRTWD-3406	HE	1051A	Room 104 Storage	EC	6/11/2025	6:10:00 AM
BRTWD-3412	SP	N/A	Teacher Center Kitchen (exterior access)	KC	6/11/2025	7:04:00 AM
BRTWD-3413	SP	N/A	Teacher Center Kitchen (exterior access)	BWC	6/11/2025	7:02:00 AM
BRTWD-3414	SP	N/A	Teacher Center Kitchen (exterior access)	BWH	6/11/2025	7:03:00 AM
BRTWD-3416	HA	1058	Corridor Main Lobby to Receiving	WC	6/11/2025	6:30:00 AM
BRTWD-3417	HA	1058	Corridor Main Lobby to Receiving	WF	6/11/2025	6:30:00 AM

Samples Submitted 46

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM08:57

Building Address
350 Wicks Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: 6/13/25 20:57
Signature:

Samplers Name: Tiffany Chen
Samplers Signature:
JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553302

LIMS Reference ID: ED53302

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 20:57

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1671		**Lims Reference ID:**		**ED53302-01**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:00	06/23/25 20:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1677		**Lims Reference ID:**		**ED53302-02**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:04	06/23/25 20:04	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1694		**Lims Reference ID:**		**ED53302-03**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.0		1	1.0	µg/L	06/23/25 20:05	06/23/25 20:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1700		**Lims Reference ID:**		**ED53302-04**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.2		1	1.0	µg/L	06/23/25 20:06	06/23/25 20:06	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1707		**Lims Reference ID:**		**ED53302-05**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:08	06/23/25 20:08	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1709		**Lims Reference ID:**		**ED53302-06**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/23/25 20:12	06/23/25 20:12	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1710		**Lims Reference ID:**		**ED53302-07**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:13	06/23/25 20:13	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1711		**Lims Reference ID:**		**ED53302-08**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:14	06/23/25 20:14	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1713		**Lims Reference ID:**		**ED53302-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553302
LIMS Reference ID: ED53302
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:57
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1713 (Continued)		**Lims Reference ID:**		**ED53302-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:16	06/23/25 20:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1715		**Lims Reference ID:**		**ED53302-10**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:17	06/23/25 20:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1725		**Lims Reference ID:**		**ED53302-11**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:18	06/23/25 20:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1756		**Lims Reference ID:**		**ED53302-12**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:22	06/23/25 20:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1761		**Lims Reference ID:**		**ED53302-13**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:23	06/23/25 20:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1776		**Lims Reference ID:**		**ED53302-14**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	10.0		1	1.0	µg/L	06/23/25 20:27	06/23/25 20:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1777		**Lims Reference ID:**		**ED53302-15**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:29	06/23/25 20:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1788		**Lims Reference ID:**		**ED53302-16**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:30	06/23/25 20:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3005		**Lims Reference ID:**		**ED53302-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553302
LIMS Reference ID: ED53302
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:57
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3005 (Continued)			**Lims Reference ID:**	**ED53302-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:31	06/23/25 20:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3028			**Lims Reference ID:**	**ED53302-18**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:33	06/23/25 20:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3029			**Lims Reference ID:**	**ED53302-19**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:34	06/23/25 20:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3030			**Lims Reference ID:**	**ED53302-20**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 20:35	06/23/25 20:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3031			**Lims Reference ID:**	**ED53302-21**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:01	06/24/25 12:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3032			**Lims Reference ID:**	**ED53302-22**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:05	06/24/25 12:05	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3033			**Lims Reference ID:**	**ED53302-23**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:07	06/24/25 12:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3034			**Lims Reference ID:**	**ED53302-24**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:11	06/24/25 12:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3035			**Lims Reference ID:**	**ED53302-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553302
LIMS Reference ID: ED53302
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:57
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3035 (Continued)		**Lims Reference ID:**		**ED53302-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:12	06/24/25 12:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3090		**Lims Reference ID:**		**ED53302-26**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:13	06/24/25 12:13	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3091		**Lims Reference ID:**		**ED53302-27**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:15	06/24/25 12:15	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3092		**Lims Reference ID:**		**ED53302-28**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:16	06/24/25 12:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3093		**Lims Reference ID:**		**ED53302-29**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:17	06/24/25 12:17	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3382		**Lims Reference ID:**		**ED53302-30**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:19	06/24/25 12:19	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3383		**Lims Reference ID:**		**ED53302-31**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:35	06/24/25 12:35	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3395		**Lims Reference ID:**		**ED53302-32**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:39	06/24/25 12:39	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3396		**Lims Reference ID:**		**ED53302-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553302
LIMS Reference ID: ED53302
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:57
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3396 (Continued)		**Lims Reference ID:**		**ED53302-33**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	3.1		1	1.0	µg/L	06/24/25 12:40	06/24/25 12:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3397		**Lims Reference ID:**		**ED53302-34**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:42	06/24/25 12:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3398		**Lims Reference ID:**		**ED53302-35**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	06/24/25 12:43	06/24/25 12:43	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3399		**Lims Reference ID:**		**ED53302-36**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:47	06/24/25 12:47	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3402		**Lims Reference ID:**		**ED53302-37**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:48	06/24/25 12:48	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3403		**Lims Reference ID:**		**ED53302-38**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:50	06/24/25 12:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3404		**Lims Reference ID:**		**ED53302-39**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:51	06/24/25 12:51	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3405		**Lims Reference ID:**		**ED53302-40**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 12:52	06/24/25 12:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3406		**Lims Reference ID:**		**ED53302-41**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553302
LIMS Reference ID: ED53302
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:57
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3406 (Continued)		**Lims Reference ID:**		**ED53302-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 12:54	06/24/25 12:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3412		**Lims Reference ID:**		**ED53302-42**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**18.1**		1	1.0	µg/L	06/24/25 12:58	06/24/25 12:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3413		**Lims Reference ID:**		**ED53302-43**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 12:59	06/24/25 12:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3414		**Lims Reference ID:**		**ED53302-44**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 13:03	06/24/25 13:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3416		**Lims Reference ID:**		**ED53302-45**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 19:45	06/23/25 19:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3417		**Lims Reference ID:**		**ED53302-46**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 19:47	06/23/25 19:47	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553302
LIMS Reference ID: ED53302
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:57
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553302
LIMS Reference ID: ED53302
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:57
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for E056706

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Middle School

NMS

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4242	HA	N/A	New Construction Corridor Near Room 246	WC	10/23/2025	6:57:00 AM
BRTWD-4243	HA	N/A	New COnstructionCorridor Near Room 246	WC	10/23/2025	6:57:00 AM

Samples Submitted 2

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 23 25, PM12:21

Building Address
350 Wicks Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: James Han 10/23/25

Signature: 1221 Pm

Samplers Name: Meghan Guynn

Samplers Signature: Meghan Guynn

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556706

LIMS Reference ID: ED56706

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - North Middle School NMS - Brentwood Union Free School District - 350 Wicks Road Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/23/2025 12:21

Reported: 10/25/2025 10:53

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4242		**Lims Reference ID:**		**ED56706-01**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:57:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/24/25 16:35	10/24/25 16:35	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4243		**Lims Reference ID:**		**ED56706-02**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:57:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/24/25 16:36	10/24/25 16:36	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556706

LIMS Reference ID: ED56706

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - North Middle School NMS - Brentwood Union Free School District - 350 Wicks Road Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/23/2025 12:21

Reported: 10/25/2025 10:53

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556706

LIMS Reference ID: ED56706

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - North Middle School NMS - Brentwood Union Free School District - 350 Wicks Road Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/23/2025 12:21

Reported: 10/25/2025 10:53

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EE 50203

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Middle School

NMS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4274	HA	N/A	Corridor Near Faculty Bathrooms (New Construction)	WC	1/14/2026	7:47:00 AM
BRTWD-4275	HA	N/A	Corridor Near Faculty Bathrooms (New Construction)	WF	1/14/2026	7:47:00 AM

Samples Submitted 2

Pb 200.8 B 1/15/26

Pb 200.5 B 1/16/26

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 14 26, PM01:30

Building Address
350 Wicks Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved:

Signature:

Samplers Name: Jordan Migliino

Samplers Signature:

JCB Project Manager: Meghan Gwy

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650203

LIMS Reference ID: EE50203

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Middle School, Brentwood Union Free School District, 350 Wicks Road, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 01/14/2026 13:30

Reported: 01/16/2026 11:05

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4274		**Lims Reference ID:**		**EE50203-01**	**Matrix: Drinking Water**				**Sampled: 01/14/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/15/26 11:13	01/15/26 11:13	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4275		**Lims Reference ID:**		**EE50203-02**	**Matrix: Drinking Water**				**Sampled: 01/14/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/16/26 10:25	01/16/26 10:25	BP	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650203
LIMS Reference ID: EE50203
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Middle School, Brentwood Union Free School District, 350 Wicks Road, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/14/2026 13:30
Reported: 01/16/2026 11:05

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650203
LIMS Reference ID: EE50203
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, North Middle School, Brentwood Union Free School District, 350 Wicks Road, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/14/2026 13:30
Reported: 01/16/2026 11:05

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE51194

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Middle School

NMS

Client: Brentwood Union Free School District

Retest/New Install N

Turn Around: Normal 1 wk Rush 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3412	SP	N/A	Teacher Center Kitchen (exterior access)	KC	3/11/2026	6:55:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 11 26, PM03:36

Pb 200.8
Kathleen
3/12/26

Building Address
350 Wicks Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 3/11/26 15:36

Signature: KAY WAGNER

Samplers Name: Danielle Bolognese

Samplers Signature:

JCB Project Manager: Meghan Bunyan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651194
LIMS Reference ID: EE51194
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/11/2026 15:36
Reported: 03/13/2026 09:07

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3412			**Lims Reference ID:**	**EE51194-01**	**Matrix: Drinking Water**			**Sampled:**	**03/11/26 06:55:00**
Metals									
Lead	**15.5**		1	1.0	µg/L	03/12/26 16:29	03/12/26 16:29	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651194

LIMS Reference ID: EE51194

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/11/2026 15:36
Reported:	03/13/2026 09:07

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651194
LIMS Reference ID: EE51194
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	North Middle School: 350 Wicks Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/11/2026 15:36
Reported:	03/13/2026 09:07

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EE51428

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Middle School

NMS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3412	SP	N/A	Teacher Center Kitchen (exterior access)	KC	3/20/2026	7:42:00 AM

Samples Submitted 1

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 20 26, PM12:43

Pb 200.8
Kathleen
3/24/26

Building Address
350 Wicks Road
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: James Han 3/20/26

Signature: 1243 PM

Samplers Name: Jordan Miglino

Samplers Signature: J Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651428
LIMS Reference ID: EE51428
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - North Middle School - NMS - Brentwood Union Free School District - 350 Wicks Road Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/20/2026 12:43
Reported: 03/24/2026 19:28

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3412			**Lims Reference ID:**	**EE51428-01**	**Matrix: Drinking Water**			**Sampled:**	**03/20/26 07:42:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/24/26 18:00	03/24/26 18:00	KT1	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651428

LIMS Reference ID: EE51428

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - North Middle School - NMS - Brentwood Union Free School District - 350 Wicks Road Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 03/20/2026 12:43

Reported: 03/24/2026 19:28

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651428

LIMS Reference ID: EE51428

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - North Middle School - NMS - Brentwood Union Free School District - 350 Wicks Road Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 03/20/2026 12:43

Reported: 03/24/2026 19:28

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EES1666

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: North Middle School

NMS

Client: Brentwood Union Free School District

Retest/New Install [✓]

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1776	OF	2023A	Library Work Room	OF	3/26/2026	6:56:00 AM

Samples Submitted 1

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
MAR 26 26, PM03:45

Pb 328876

Building Address
350 Wicks Road
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 3/26/26 3:45pm

Signature: Dave Wharton

Samplers Name: Meghan Gwynn

Samplers Signature: Meghan Gwynn

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651666

LIMS Reference ID: EE51666

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School NMS, 350 Wicks Road, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 03/26/2026 15:45

Reported: 03/28/2026 23:38

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1776			**Lims Reference ID:**	**EE51666-01**	**Matrix: Drinking Water**			**Sampled:**	**03/26/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/28/26 20:18	03/28/26 20:18	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651666
LIMS Reference ID: EE51666
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School NMS, 350 Wicks Road, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/26/2026 15:45
Reported: 03/28/2026 23:38

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651666
LIMS Reference ID: EE51666
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: North Middle School NMS, 350 Wicks Road, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/26/2026 15:45
Reported: 03/28/2026 23:38

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EE52583

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: North Middle School

NMS

Client: Brentwood Union Free School District

Retest/New Install N

Turn Around: Normal 1 wk Rush 48hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4295	LR	1041	Boys Locker Room	DW	5/7/2026	6:39:00 AM

Samples Submitted 1

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAY 07 26, PM01:56

Walk In

No Pass 5/8/26

Building Address
350 Wicks Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 5/7/26 1:56 pm

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652583
LIMS Reference ID: EE52583
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: North Middle School NMS, 350 Wicks Road, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/07/2026 13:56
Reported: 05/08/2026 10:23

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4295			**Lims Reference ID:**	**EE52583-01**	**Matrix: Drinking Water**			**Sampled:**	**05/07/26 00:00:00**
Metals									
Lead	**2.8**		1	1.0	µg/L	05/08/26 01:24	05/08/26 01:24	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652583
LIMS Reference ID: EE52583
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: North Middle School NMS, 350 Wicks Road, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/07/2026 13:56
Reported: 05/08/2026 10:23

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	05/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652583
LIMS Reference ID: EE52583
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: North Middle School NMS, 350 Wicks Road, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/07/2026 13:56
Reported: 05/08/2026 10:23

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED53306

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1812	OF	1032A	Guidance Office Storage	BWC	6/7/2025	6:50:00 AM
BRTWD-1813	HA	1047	Corridor Near Room 116 (1036)	DW	6/7/2025	6:48:00 AM
BRTWD-1827	HA	N/A	Corridor Near Room 146	WC	6/7/2025	6:42:00 AM
BRTWD-1828	HA	N/A	Corridor Near Room 146	WC	6/7/2025	6:41:00 AM
BRTWD-1830	FL	1028	Faculty Room	KC	6/7/2025	6:34:00 AM
BRTWD-1832	HA	1029	Corridor Near Faculty Room (1028)	DW	6/7/2025	6:33:00 AM
BRTWD-1834	NO	1025	Nurse's Office	NS	6/7/2025	6:32:00 AM
BRTWD-1838	HA	1029	Corridor Near Girls Locker Room (1022)	WC	6/7/2025	6:25:00 AM
BRTWD-1839	HA	1029	Corridor Near Girls Locker Room (1022)	WF	6/7/2025	6:24:00 AM
BRTWD-1842	LR	1022	Girls Locker Room	DW	6/7/2025	6:29:00 AM
BRTWD-1846	KI	1021	Kitchen	KC	6/7/2025	6:09:00 AM
BRTWD-1848	KI	1021	Kitchen	KC	6/7/2025	6:11:00 AM
BRTWD-1850	KI	1021	Kitchen	KC	6/7/2025	6:11:00 AM
BRTWD-1856	LR	1014	Weight Room	DW	6/7/2025	6:21:00 AM
BRTWD-1860	HA	1029	Corridor Near Room 110 (1011)	DW	6/7/2025	6:15:00 AM
BRTWD-1873	HA	1029	Corridor Near Room 104 (1004)	DW	6/7/2025	7:08:00 AM
BRTWD-1883	HA	2042	Corridor Near Room 202 (2038)	DW	6/7/2025	7:29:00 AM
BRTWD-1895	HA	2042	Corridor Near Stairwell (2029)	DW	6/7/2025	7:30:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM08:56

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 20:56

Signature:

Samplers Name: Tiffany Chen

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for ED53306

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1896	OF	2021A	Library Work Room	OF	6/7/2025	7:24:00 AM
BRTWD-1897	HA	2042	Corridor Near Room 216 (2020)	WC	6/7/2025	7:18:00 AM
BRTWD-1898	HA	2042	Corridor Near Room 216 (2020)	WF	6/7/2025	7:19:00 AM
BRTWD-1904	HA	N/A	Corridor Near Bathrooms	WC	6/7/2025	7:37:00 AM
BRTWD-1912	HA	2025	Corridor Near Room 218 (2016)	DW	6/7/2025	7:32:00 AM
BRTWD-3002	CR	1042	Room 123 Life Skills	EC	6/7/2025	7:14:00 AM
BRTWD-3022	HA	1050	Auditorium Lobby	WC	6/7/2025	6:55:00 AM
BRTWD-3023	HA	1050	Auditorium Lobby	WF	6/7/2025	6:56:00 AM
BRTWD-3024	HA	2025	Corridor Near Room 226 (2008)	WC	6/7/2025	7:34:00 AM
BRTWD-3025	HA	2025	Corridor Near Room 226 (2008)	WF	6/7/2025	7:35:00 AM
BRTWD-3833	HA	N/A	Corridor (near Bathrooms)	DW	6/7/2025	6:39:00 AM
BRTWD-3845	KI	1021	Kitchen	KC	6/7/2025	6:08:00 AM
BRTWD-3846	KI	1021	Kitchen	HW	6/7/2025	6:09:00 AM
BRTWD-3847	KI	1021	Kitchen	PK	6/7/2025	6:12:00 AM
BRTWD-3850	HE	1007	Room 106	EC	6/7/2025	7:03:00 AM
BRTWD-3851	HE	1007	Room 106	EC	6/7/2025	7:02:00 AM
BRTWD-3852	HE	1007	Room 106	EC	6/7/2025	7:01:00 AM
BRTWD-3853	HE	1004	Room 104	EC	6/7/2025	7:05:00 AM

RECEIVED
ENCL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM 3:56

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 20:56

Signature: Kate Worster

Samplers Name: Tiffany Chun

Samplers Signature:

JCB Project Manager: Meghan Grayson

Lead in Water: Chain of Custody for ED53306

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest/New Install ( )

Turn Around: Normal 1wk **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3854	HE	1004	Room 104	EC	6/7/2025	7:05:00 AM
BRTWD-3855	HE	1004	Room 104	EC	6/7/2025	7:06:00 AM
BRTWD-3856	HE	1004	Room 104	EC	6/7/2025	7:07:00 AM
BRTWD-3857	HE	1004A	Room 104 Closet	EC	6/7/2025	7:04:00 AM

Samples Submitted 40

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM08:56

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 20:30

Signature:

Samplers Name: Tiffany Chen

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553306

LIMS Reference ID: ED53306

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: South Middle School: 785 Candlewood Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 20:56

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1812		**Lims Reference ID:**		**ED53306-01**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 13:04	06/24/25 13:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1813		**Lims Reference ID:**		**ED53306-02**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 13:06	06/24/25 13:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1827		**Lims Reference ID:**		**ED53306-03**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 13:07	06/24/25 13:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1828		**Lims Reference ID:**		**ED53306-04**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 13:08	06/24/25 13:08	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1830		**Lims Reference ID:**		**ED53306-05**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**2.9**		1	1.0	µg/L	06/24/25 13:10	06/24/25 13:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1832		**Lims Reference ID:**		**ED53306-06**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**1.9**		1	1.0	µg/L	06/24/25 13:11	06/24/25 13:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1834		**Lims Reference ID:**		**ED53306-07**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**8.8**		1	1.0	µg/L	06/24/25 13:22	06/24/25 13:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1838		**Lims Reference ID:**		**ED53306-08**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 13:26	06/24/25 13:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1839		**Lims Reference ID:**		**ED53306-09**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553306
LIMS Reference ID: ED53306
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: South Middle School: 785 Candlewood Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:56
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1839 (Continued)		**Lims Reference ID:**		**ED53306-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 13:28	06/24/25 13:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1842		**Lims Reference ID:**		**ED53306-10**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	4.4		1	1.0	µg/L	06/24/25 13:29	06/24/25 13:29	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1846		**Lims Reference ID:**		**ED53306-11**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.7		1	1.0	µg/L	06/24/25 13:30	06/24/25 13:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1848		**Lims Reference ID:**		**ED53306-12**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 13:34	06/24/25 13:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1850		**Lims Reference ID:**		**ED53306-13**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 13:36	06/24/25 13:36	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1856		**Lims Reference ID:**		**ED53306-14**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.5		1	1.0	µg/L	06/24/25 13:37	06/24/25 13:37	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1860		**Lims Reference ID:**		**ED53306-15**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.0		1	1.0	µg/L	06/24/25 13:38	06/24/25 13:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1873		**Lims Reference ID:**		**ED53306-16**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 13:40	06/24/25 13:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1883		**Lims Reference ID:**		**ED53306-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553306
LIMS Reference ID: ED53306
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: South Middle School: 785 Candlewood Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:56
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1883 (Continued)			**Lims Reference ID:**	**ED53306-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	1.2		1	1.0	µg/L	06/24/25 13:41	06/24/25 13:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1895			**Lims Reference ID:**	**ED53306-18**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 13:45	06/24/25 13:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1896			**Lims Reference ID:**	**ED53306-19**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	8.8		1	1.0	µg/L	06/24/25 13:46	06/24/25 13:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1897			**Lims Reference ID:**	**ED53306-20**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 13:50	06/24/25 13:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1898			**Lims Reference ID:**	**ED53306-21**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 13:52	06/24/25 13:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1904			**Lims Reference ID:**	**ED53306-22**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 13:53	06/24/25 13:53	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1912			**Lims Reference ID:**	**ED53306-23**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.6		1	1.0	µg/L	06/24/25 13:54	06/24/25 13:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3002			**Lims Reference ID:**	**ED53306-24**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.2		1	1.0	µg/L	06/24/25 13:56	06/24/25 13:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3022			**Lims Reference ID:**	**ED53306-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553306
LIMS Reference ID: ED53306
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: South Middle School: 785 Candlewood Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:56
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3022 (Continued)			**Lims Reference ID:**	**ED53306-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 13:57	06/24/25 13:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3023			**Lims Reference ID:**	**ED53306-26**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 13:58	06/24/25 13:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3024			**Lims Reference ID:**	**ED53306-27**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:11	06/24/25 14:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3025			**Lims Reference ID:**	**ED53306-28**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:15	06/24/25 14:15	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3833			**Lims Reference ID:**	**ED53306-29**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.7		1	1.0	µg/L	06/24/25 14:16	06/24/25 14:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3845			**Lims Reference ID:**	**ED53306-30**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/24/25 14:17	06/24/25 14:17	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3846			**Lims Reference ID:**	**ED53306-31**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	9.6		1	1.0	µg/L	06/24/25 14:18	06/24/25 14:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3847			**Lims Reference ID:**	**ED53306-32**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.8		1	1.0	µg/L	06/24/25 14:22	06/24/25 14:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3850			**Lims Reference ID:**	**ED53306-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553306
LIMS Reference ID: ED53306
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: South Middle School: 785 Candlewood Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:56
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3850 (Continued)			**Lims Reference ID:**	**ED53306-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	1.6		1	1.0	µg/L	06/24/25 14:24	06/24/25 14:24	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3851			**Lims Reference ID:**	**ED53306-34**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:25	06/24/25 14:25	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3852			**Lims Reference ID:**	**ED53306-35**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:26	06/24/25 14:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3853			**Lims Reference ID:**	**ED53306-36**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	4.0		1	1.0	µg/L	06/24/25 14:28	06/24/25 14:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3854			**Lims Reference ID:**	**ED53306-37**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/24/25 14:29	06/24/25 14:29	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3855			**Lims Reference ID:**	**ED53306-38**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:33	06/24/25 14:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3856			**Lims Reference ID:**	**ED53306-39**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.0		1	1.0	µg/L	06/24/25 14:34	06/24/25 14:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3857			**Lims Reference ID:**	**ED53306-40**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.3		1	1.0	µg/L	06/24/25 14:38	06/24/25 14:38	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553306
LIMS Reference ID: ED53306
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: South Middle School: 785 Candlewood Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:56
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553306

LIMS Reference ID: ED53306

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: South Middle School: 785 Candlewood Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 20:56

Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED56326

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest/New Install H

Turn Around: Normal 1 wk Rush 48hr.

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4246	HA	1029	Corridor Near Cafeteria A (1020)	WF	10/2/2025	11:31:00 AM
BRTWD-4247	HA	1029	Corridor Near Cafeteria A (1020)	WC	10/2/2025	11:30:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 02 25, PM03:09

Pb 200.8 Billing 10/3/25

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WARRTOW 10/2/25 3:09 PM

Signature: David Warrtow

Samplers Name: Brian Bunore

Samplers Signature: Brian Bunore

JCB Project Manager: Meghan Gwyn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556326

LIMS Reference ID: ED56326

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, South Middle School (SMS), 785 Candlewood Road, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/02/2025 15:09

Reported: 10/04/2025 09:41

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4246		**Lims Reference ID:**		**ED56326-01**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 13:16	10/03/25 13:16	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4247		**Lims Reference ID:**		**ED56326-02**	**Matrix: Drinking Water**				**Sampled: 10/02/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/03/25 13:17	10/03/25 13:17	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556326

LIMS Reference ID: ED56326

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, South Middle School (SMS), 785 Candlewood Road, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/02/2025 15:09

Reported: 10/04/2025 09:41

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556326

LIMS Reference ID: ED56326

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, South Middle School (SMS), 785 Candlewood Road, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/02/2025 15:09

Reported: 10/04/2025 09:41

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57881

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1834	NO	1025	Nurse's Office	NS	12/23/2025	6:31:00 AM
BRTWD-3846	KI	1021	Kitchen	HW	12/23/2025	6:29:00 AM

Samples Submitted 2

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:14

Pb 200.8
Kathy Law
12/24/25

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/23/25 2:14pm

Signature:

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557881

LIMS Reference ID: ED57881

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / South Middle School SMS / 785 Candlewood Road, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:14

Reported: 12/24/2025 16:53

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1834			**Lims Reference ID:**		**ED57881-01**	**Matrix: Drinking Water**			**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**5.6**		1	1.0	µg/L	12/24/25 13:17	12/24/25 13:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3846			**Lims Reference ID:**		**ED57881-02**	**Matrix: Drinking Water**			**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**2.0**		1	1.0	µg/L	12/24/25 13:18	12/24/25 13:18	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557881
LIMS Reference ID: ED57881
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / South Middle School SMS / 785 Candlewood Road, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:14
Reported: 12/24/2025 16:53

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557881
LIMS Reference ID: ED57881
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / South Middle School SMS / 785 Candlewood Road, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:14
Reported: 12/24/2025 16:53

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57971

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest/New Install M ✓

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1834	NO	1025	Nurse's Office	NS	12/30/2025	7:04:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:39

Pb 200.8 Kathwilliams 12/31/25

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/30/25 4:39 pm

Signature: David Wharton

Samplers Name: Danielle Bobyajian

Samplers Signature:

JCB Project Manager: Meghan Burgos

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557971
LIMS Reference ID: ED57971
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / South Middle School SMS / 785 Candlewood Road, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:39
Reported: 12/31/2025 15:22

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1834			**Lims Reference ID:**	**ED57971-01**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 00:00:00**
Metals									
Lead	**21.4**		1	1.0	µg/L	12/31/25 12:37	12/31/25 12:37	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557971

LIMS Reference ID: ED57971

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / South Middle School SMS / 785 Candlewood Road, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:39

Reported: 12/31/2025 15:22

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557971
LIMS Reference ID: ED57971
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / South Middle School SMS / 785 Candlewood Road, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:39
Reported: 12/31/2025 15:22

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EE50776

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest [**New Install**] |

Turn Around: **Normal** 1 wk **Rush** 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4278	HA	2042	Corridor Room 202 to 216	WF	2/11/2026	6:49:00 AM
BRTWD-4279	HA	2042	Corridor Room 202 to 216	WC	2/11/2026	6:49:00 AM

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 11 26, PM03:23

Pb 200.8 2/11/26

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved:

Signature:

Samplers Name: Jordan Miglino

Samplers Signature: Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650776

LIMS Reference ID: EE50776

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, South Middle School, Brentwood Union Free School District, 785 Candlewood Road, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 02/11/2026 15:23

Reported: 02/12/2026 15:58

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4278		**Lims Reference ID:**		**EE50776-01**	**Matrix: Drinking Water**				**Sampled: 02/11/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	02/12/26 14:58	02/12/26 14:58	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4279		**Lims Reference ID:**		**EE50776-02**	**Matrix: Drinking Water**				**Sampled: 02/11/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	02/12/26 14:59	02/12/26 14:59	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650776

LIMS Reference ID: EE50776

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, South Middle School, Brentwood Union Free School District, 785 Candlewood Road, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 02/11/2026 15:23

Reported: 02/12/2026 15:58

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650776
LIMS Reference ID: EE50776
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, South Middle School, Brentwood Union Free School District, 785 Candlewood Road, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/11/2026 15:23
Reported: 02/12/2026 15:58

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50866

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1896	OF	2021A	Library Work Room	OF	2/18/2026	7:12:00 AM

Samples Submitted 1

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 18 26, PM01:49

Pb 200.8
Kathleen Lee 2/19/26

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: James Han 2/18/26 1449hrs

Signature:

Samplers Name: Danielle Bolognino

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650866
LIMS Reference ID: EE50866
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - South Middle School SMS - Brentwood Union Free School District - 785 Candlewood Road Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/18/2026 13:49
Reported: 02/19/2026 13:47

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1896			**Lims Reference ID:**	**EE50866-01**	**Matrix: Drinking Water**			**Sampled:**	**02/18/26 07:12:00**
Metals									
Lead	**5.9**		1	1.0	µg/L	02/19/26 13:26	02/19/26 13:26	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650866
LIMS Reference ID: EE50866
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - South Middle School SMS - Brentwood Union Free School District - 785 Candlewood Road Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/18/2026 13:49
Reported: 02/19/2026 13:47

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650866
LIMS Reference ID: EE50866
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - South Middle School SMS - Brentwood Union Free School District - 785 Candlewood Road Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/18/2026 13:49
Reported: 02/19/2026 13:47

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE51051

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: South Middle School

SMS

Client: Brentwood Union Free School District

(Retest) New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1896	OF	2021A	Library Work Room	OF	3/3/2026	7:10:00 AM
BRTWD-4284	HA	N/A	2nd Floor New Wing by Gang Bathrooms	WC	3/3/2026	7:17:00 AM
BRTWD-4285	HA	N/A	2nd Floor New Wing by Gang Bathrooms	WC	3/3/2026	7:17:00 AM
BRTWD-4286	HA	N/A	2nd Floor New Wing by Room 248	WC	3/3/2026	7:19:00 AM
BRTWD-4287	HA	N/A	2nd Floor New Wing by Room 248	WC	3/3/2026	7:19:00 AM

Samples Submitted 5

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 03 26, PM01:37

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 3/3/26 1:37 PM

Signature: David Wharton

Samplers Name: Meghan Gwynn

Samplers Signature: Meghan Gwynn

JCB Project Manager: Meghan Gwynn

Page 4 of 4

Rec'd 3/3/26

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651051
LIMS Reference ID: EE51051
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: South Middle School SMS, 785 Candlewood Road, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/03/2026 13:37
Reported: 03/05/2026 09:36

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1896		**Lims Reference ID:**		**EE51051-01**	**Matrix: Drinking Water**				**Sampled: 03/03/26 00:00:00**
Metals									
Lead	**13.7**		1	1.0	µg/L	03/05/26 00:30	03/05/26 00:30	DAZ	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4284		**Lims Reference ID:**		**EE51051-02**	**Matrix: Drinking Water**				**Sampled: 03/03/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/05/26 00:34	03/05/26 00:34	DAZ	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4285		**Lims Reference ID:**		**EE51051-03**	**Matrix: Drinking Water**				**Sampled: 03/03/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/05/26 00:35	03/05/26 00:35	DAZ	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4286		**Lims Reference ID:**		**EE51051-04**	**Matrix: Drinking Water**				**Sampled: 03/03/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/05/26 00:36	03/05/26 00:36	DAZ	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4287		**Lims Reference ID:**		**EE51051-05**	**Matrix: Drinking Water**				**Sampled: 03/03/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/05/26 00:40	03/05/26 00:40	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651051
LIMS Reference ID: EE51051
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	South Middle School SMS, 785 Candlewood Road, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/03/2026 13:37
Reported:	03/05/2026 09:36

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651051
LIMS Reference ID: EE51051
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	South Middle School SMS, 785 Candlewood Road, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/03/2026 13:37
Reported:	03/05/2026 09:36

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE52507

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26--64123

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1896	OF	2021A	Library Work Room	OF	5/1/2026	6:29:00 AM

Samples Submitted 1

Pb 200.8 5/3/26

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAY 01 26, PM08:30

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 5/1/26 20:30

Signature: KAY MANAGER

Samplers Name: Danielle Bolognini

Samplers Signature: [signature]

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652507
LIMS Reference ID: EE52507
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: South Middle School: 785 Candlewood Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/01/2026 20:30
Reported: 05/04/2026 09:02

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1896			**Lims Reference ID:**	**EE52507-01**	**Matrix: Drinking Water**			**Sampled:**	**05/01/26 00:00:00**
Metals									
Lead	**6.3**		1	1.0	µg/L	05/03/26 11:53	05/03/26 11:53	BP	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652507
LIMS Reference ID: EE52507
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: South Middle School: 785 Candlewood Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/01/2026 20:30
Reported: 05/04/2026 09:02

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	05/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652507

LIMS Reference ID: EE52507

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	South Middle School: 785 Candlewood Road, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	05/01/2026 20:30
Reported:	05/04/2026 09:02

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE52580

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1896	OF	2021A	Library Work Room	OF	5/7/2026	6:53:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAY 07 26, PM01:57

No 200.8 on 3 bottles

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 5/7/26 1:57 PM

Signature:

Samplers Name: Danielle Balogiani

Samplers Signature:

JCB Project Manager: Danielle Balogiani

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652580
LIMS Reference ID: EE52580
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: South Middle School SMS, Brentwood Union Free School District, 785 Candlewood Road, Brentwood, NY 11717, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/07/2026 13:57
Reported: 05/08/2026 10:10

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1896			**Lims Reference ID:**	**EE52580-01**	**Matrix: Drinking Water**			**Sampled:**	**05/07/26 00:00:00**
Metals									
Lead	**6.0**		1	1.0	µg/L	05/08/26 01:17	05/08/26 01:17	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652580
LIMS Reference ID: EE52580
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: South Middle School SMS, Brentwood Union Free School District, 785 Candlewood Road, Brentwood, NY 11717, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/07/2026 13:57
Reported: 05/08/2026 10:10

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	05/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652580
LIMS Reference ID: EE52580
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: South Middle School SMS, Brentwood Union Free School District, 785 Candlewood Road, Brentwood, NY 11717, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/07/2026 13:57
Reported: 05/08/2026 10:10

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EE64405

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: South Middle School

SMS

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1834	NO	1025	Nurse's Office	NS	9/4/2026	7:33:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
SEP 04 26, PM02:26

Dec 8

Building Address
785 Candlewood Road
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Mia Bang

Signature: Mia Bang

Samplers Name: Jordan Miglino

Samplers Signature: Jordan Miglino

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654405

LIMS Reference ID: EE54405

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: 26-64123, South Middle School, Brentwood Union Free School District, 785 Candlewood Road, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/04/2026 14:26

Reported: 09/08/2026 08:57

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1834			**Lims Reference ID:**	**EE54405-01**	**Matrix: Drinking Water**			**Sampled:**	**09/03/26 00:00:00**
Metals									
Lead	**30.4**		1	1.0	µg/L	09/05/26 18:26	09/05/26 18:26	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654405

LIMS Reference ID: EE54405

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: 26-64123, South Middle School, Brentwood Union Free School District, 785 Candlewood Road, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/04/2026 14:26

Reported: 09/08/2026 08:57

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654405

LIMS Reference ID: EE54405

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	26-64123, South Middle School, Brentwood Union Free School District, 785 Candlewood Road, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	09/04/2026 14:26
Reported:	09/08/2026 08:57

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED53304

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: West Middle School
WMS

Client: Brentwood Union Free School District

Retest/New Install [ ]
Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1942	HA	1002	Corridor Near Auditorium	DW	6/10/2025	6:20:00 AM
BRTWD-1973	FL	1027	Faculty Room	KC	6/10/2025	6:30:00 AM
BRTWD-1975	HA	1050	Corridor Near Faculty Room (1027)	DW	6/10/2025	6:28:00 AM
BRTWD-1977	NO	1029	Nurse's Office	NS	6/10/2025	5:50:00 AM
BRTWD-1978	NO	1029C	Nurse's Office - Inner Office	NS	6/10/2025	5:51:00 AM
BRTWD-1982	HA	1050	Corridor Near Girls Locker Room (1030)	DW	6/10/2025	5:55:00 AM
BRTWD-1985	LR	1035B	Girls Locker Room	DW	6/10/2025	5:54:00 AM
BRTWD-1987	KI	1033	Kitchen	KC	6/10/2025	5:45:00 AM
BRTWD-1988	KI	1033	Kitchen	KC	6/10/2025	5:45:00 AM
BRTWD-1989	KI	1033	Kitchen	HW	6/10/2025	5:44:00 AM
BRTWD-1990	KI	1033	Kitchen	KC	6/10/2025	5:42:00 AM
BRTWD-1992	KI	1033	Kitchen	KC	6/10/2025	5:42:00 AM
BRTWD-1994	KI	1033	Kitchen	KC	6/10/2025	5:40:00 AM
BRTWD-1995	KI	1033	Kitchen	HW	6/10/2025	5:39:00 AM
BRTWD-2000	LR	1035A	Boys Locker Room	DW	6/10/2025	5:58:00 AM
BRTWD-2004	HA	1050	Corridor Near Room 110 (1039)	DW	6/10/2025	6:11:00 AM
BRTWD-2017	HA	1050	Corridor Near Room 104 (1047)	DW	6/10/2025	6:09:00 AM
BRTWD-2028	HA	2043	Corridor Near Room 202 (2041)	DW	6/10/2025	6:39:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM08:59

Walk in

Building Address
2030 Udall Road
Bay Shore , NY 11706

Analysis Type: ELAP 200.5
Lab Recieved: 6/13/25 20:59
Signature:

Samplers Name: Lexi Fawcett
Samplers Signature:
JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for ED53304

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: West Middle School

WMS

Client: Brentwood Union Free School District

Retest/New Install ☐

Turn Around: (Normal) 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2039	HA	2043	Corridor Near Room 210 (2031)	DW	6/10/2025	6:41:00 AM
BRTWD-2040	OF	2022A	Library Work Room	OF	6/10/2025	6:43:00 AM
BRTWD-2042	HA	2019	Corridor Near Room 220 (2016)	DW	6/10/2025	6:47:00 AM
BRTWD-3008	HA	1026	Corridor Near Student Management Office (1023)	WF	6/10/2025	6:16:00 AM
BRTWD-3009	HA	1026	Corridor Near Room 124 (1016)	WF	6/10/2025	6:18:00 AM
BRTWD-3010	HA	1026	Corridor Near Room 124 (1016)	WC	6/10/2025	6:18:00 AM
BRTWD-3038	HA	1050	Corridor Near Cafeteria (1034)	WC	6/10/2025	6:13:00 AM
BRTWD-3039	HA	1050	Corridor Near Cafeteria (1034)	WF	6/10/2025	6:13:00 AM
BRTWD-3040	HA	2043	Corridor Near Room 216 (2021)	WF	6/10/2025	6:45:00 AM
BRTWD-3041	HA	2019	Corridor Near Room 228 (2008)	WC	6/10/2025	6:50:00 AM
BRTWD-3042	HA	2019	Corridor Near Room 228 (2008)	WF	6/10/2025	6:50:00 AM
BRTWD-3087	HA	N/A	Corridor Near Bathrooms	WC	6/10/2025	6:25:00 AM
BRTWD-3088	HA	N/A	Corridor Near Bathrooms	WF	6/10/2025	6:26:00 AM
BRTWD-3498	KI	1033	Kitchen	PK	6/10/2025	5:41:00 AM
BRTWD-3511	HE	1043	Room 106	EC	6/10/2025	6:01:00 AM
BRTWD-3512	HE	1043	Room 106	EC	6/10/2025	6:03:00 AM
BRTWD-3513	HE	1043	Room 106	EC	6/10/2025	6:02:00 AM
BRTWD-3515	HE	1047	Room 104	EC	6/10/2025	6:06:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 P[illegible]

Building Address
2030 Udall Road
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 20:[illegible]

Signature: [illegible] WAGNER

Samplers Name: Lexi Farrell

Samplers Signature: [signature]

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for ED53304

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: West Middle School

WMS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal ( ) wk **Rush** _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3516	HE	1047	Room 104	EC	6/10/2025	6:06:00 AM
BRTWD-3517	HE	1047	Room 104	EC	6/10/2025	6:05:00 AM
BRTWD-3518	HE	1047	Room 104	EC	6/10/2025	6:05:00 AM
BRTWD-3519	HE	1047A	Room 104 Laundry Room	EC	6/10/2025	6:03:00 AM
BRTWD-3529	CR	2023	Room 214 Life Skills	EC	6/10/2025	6:52:00 AM

Samples Submitted 41

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM08:59

Building Address
2030 Udall Road
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 20:54

Signature:

Samplers Name: Lexi Carwell

Samplers Signature:

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553304

LIMS Reference ID: ED53304

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 20:59

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1942		**Lims Reference ID:**		**ED53304-01**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**11.3**	1	1.0	µg/L	06/24/25 18:51	06/24/25 18:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1973		**Lims Reference ID:**		**ED53304-02**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**	1	1.0	µg/L	06/24/25 18:53	06/24/25 18:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1975		**Lims Reference ID:**		**ED53304-03**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**5.1**	1	1.0	µg/L	06/24/25 18:54	06/24/25 18:54	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1977		**Lims Reference ID:**		**ED53304-04**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**2.2**	1	1.0	µg/L	06/24/25 18:55	06/24/25 18:55	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1978		**Lims Reference ID:**		**ED53304-05**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**19.0**	1	1.0	µg/L	06/24/25 19:13	06/24/25 19:13	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1982		**Lims Reference ID:**		**ED53304-06**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**1.2**	1	1.0	µg/L	06/24/25 19:17	06/24/25 19:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1985		**Lims Reference ID:**		**ED53304-07**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**1.1**	1	1.0	µg/L	06/24/25 19:18	06/24/25 19:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1987		**Lims Reference ID:**		**ED53304-08**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**6.2**	1	1.0	µg/L	06/24/25 19:19	06/24/25 19:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1988		**Lims Reference ID:**		**ED53304-09**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553304
LIMS Reference ID: ED53304
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:59
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1988 (Continued)			**Lims Reference ID:**	**ED53304-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:21	06/24/25 19:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1989			**Lims Reference ID:**	**ED53304-10**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:25	06/24/25 19:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1990			**Lims Reference ID:**	**ED53304-11**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:26	06/24/25 19:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1992			**Lims Reference ID:**	**ED53304-12**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:27	06/24/25 19:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1994			**Lims Reference ID:**	**ED53304-13**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.0		1	1.0	µg/L	06/24/25 19:28	06/24/25 19:28	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1995			**Lims Reference ID:**	**ED53304-14**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:30	06/24/25 19:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2000			**Lims Reference ID:**	**ED53304-15**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.5		1	1.0	µg/L	06/24/25 19:31	06/24/25 19:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2004			**Lims Reference ID:**	**ED53304-16**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:35	06/24/25 19:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2017			**Lims Reference ID:**	**ED53304-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553304
LIMS Reference ID: ED53304
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:59
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2017 (Continued)		**Lims Reference ID:**		**ED53304-17**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:36	06/24/25 19:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2028		**Lims Reference ID:**		**ED53304-18**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:40	06/24/25 19:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2039		**Lims Reference ID:**		**ED53304-19**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	99.7		1	1.0	µg/L	06/24/25 19:42	06/24/25 19:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2040		**Lims Reference ID:**		**ED53304-20**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	3.3		1	1.0	µg/L	06/24/25 19:43	06/24/25 19:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2042		**Lims Reference ID:**		**ED53304-21**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	14.5		1	1.0	µg/L	06/24/25 19:44	06/24/25 19:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3008		**Lims Reference ID:**		**ED53304-22**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:46	06/24/25 19:46	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3009		**Lims Reference ID:**		**ED53304-23**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:47	06/24/25 19:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3010		**Lims Reference ID:**		**ED53304-24**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 19:48	06/24/25 19:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3038		**Lims Reference ID:**		**ED53304-25**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553304
LIMS Reference ID: ED53304
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:59
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3038 (Continued)			**Lims Reference ID:**	**ED53304-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:03	06/24/25 20:03	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3039			**Lims Reference ID:**	**ED53304-26**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:07	06/24/25 20:07	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3040			**Lims Reference ID:**	**ED53304-27**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:09	06/24/25 20:09	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3041			**Lims Reference ID:**	**ED53304-28**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:10	06/24/25 20:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3042			**Lims Reference ID:**	**ED53304-29**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:11	06/24/25 20:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3087			**Lims Reference ID:**	**ED53304-30**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:15	06/24/25 20:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3088			**Lims Reference ID:**	**ED53304-31**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:17	06/24/25 20:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3498			**Lims Reference ID:**	**ED53304-32**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 20:18	06/24/25 20:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3511			**Lims Reference ID:**	**ED53304-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553304
LIMS Reference ID: ED53304
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:59
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3511 (Continued)			**Lims Reference ID:**	**ED53304-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	3.8		1	1.0	µg/L	06/24/25 20:19	06/24/25 20:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3512			**Lims Reference ID:**	**ED53304-34**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	5.2		1	1.0	µg/L	06/24/25 20:21	06/24/25 20:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3513			**Lims Reference ID:**	**ED53304-35**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	6.3		1	1.0	µg/L	06/24/25 20:22	06/24/25 20:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3515			**Lims Reference ID:**	**ED53304-36**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	19.8		1	1.0	µg/L	06/24/25 20:26	06/24/25 20:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3516			**Lims Reference ID:**	**ED53304-37**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	52.8		1	1.0	µg/L	06/24/25 20:27	06/24/25 20:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3517			**Lims Reference ID:**	**ED53304-38**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	28.5		1	1.0	µg/L	06/24/25 20:31	06/24/25 20:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3518			**Lims Reference ID:**	**ED53304-39**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	12.4		1	1.0	µg/L	06/24/25 20:32	06/24/25 20:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3519			**Lims Reference ID:**	**ED53304-40**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	7.4		1	1.0	µg/L	06/24/25 20:34	06/24/25 20:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3529			**Lims Reference ID:**	**ED53304-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553304
LIMS Reference ID: ED53304
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:59
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3529 (Continued)			**Lims Reference ID:**	**ED53304-41**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	06/25/25 09:25	06/25/25 09:25	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553304
LIMS Reference ID: ED53304
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:59
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553304
LIMS Reference ID: ED53304
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:59
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EDSS464

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: West Middle School

WMS

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4123	HA	N/A	Corridor Near Room 148	WC	8/27/2025	9:26:00 AM
BRTWD-4124	HA	N/A	Corridor Near Room 148	WC	8/26/2025	9:26:00 AM
BRTWD-4125	HA	N/A	Corridor Near Room 243	WC	8/26/2025	9:30:00 AM
BRTWD-4126	HA	N/A	Corridor Near Room 243	WC	8/26/2025	9:30:00 AM

Samples Submitted 4

Building Address
2030 Udall Road
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: _____

Signature: _____

Samplers Name: Daniela Bolognini

Samplers Signature: _____

JCB Project Manager: Meghan Grayson

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555464
LIMS Reference ID: ED55464
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/26/2025 15:43
Reported: 08/28/2025 13:27

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4123		**Lims Reference ID:**		**ED55464-01**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/27/25 19:44	08/27/25 19:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4124		**Lims Reference ID:**		**ED55464-02**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/27/25 19:48	08/27/25 19:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4125		**Lims Reference ID:**		**ED55464-03**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/27/25 19:49	08/27/25 19:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4126		**Lims Reference ID:**		**ED55464-04**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/27/25 19:50	08/27/25 19:50	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555464
LIMS Reference ID: ED55464
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/26/2025 15:43
Reported: 08/28/2025 13:27

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555464
LIMS Reference ID: ED55464
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/26/2025 15:43
Reported: 08/28/2025 13:27

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EDS7895

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: West Middle School

WMS

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1978	NO	1029C	Nurse's Office - Inner Office	NS	12/23/2025	7:22:00 AM
BRTWD-1987	KI	1033	Kitchen	KC	12/23/2025	7:20:00 AM

Samples Submitted 2

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:16

Rb Kathleen
12/24/25

Building Address
2030 Udall Road
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 12/23/25 14:16

Signature:

Samplers Name: Meghan Guynn

Samplers Signature: Meghan Guynn

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557895

LIMS Reference ID: ED57895

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School Districtr: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 16:16

Reported: 12/24/2025 17:05

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1978		**Lims Reference ID:**		**ED57895-01**	**Matrix: Drinking Water**				**Sampled: 12/23/25 07:22:00**
Metals									
Lead	**12.2**		1	1.0	µg/L	12/24/25 13:39	12/24/25 13:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1987		**Lims Reference ID:**		**ED57895-02**	**Matrix: Drinking Water**				**Sampled: 12/23/25 07:20:00**
Metals									
Lead	**45.2**		1	1.0	µg/L	12/24/25 13:41	12/24/25 13:41	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557895

LIMS Reference ID: ED57895

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School Districtr: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 16:16
Reported:	12/24/2025 17:05

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557895

LIMS Reference ID: ED57895

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	West Middle School: 2030 Udall Road, Bay Shore, NY 11706: Brentwood Union Free School Districtr: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 16:16
Reported:	12/24/2025 17:05

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57957

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: West Middle School

WMS

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-1978	NO	1029C	Nurse's Office - Inner Office	NS	12/30/2025	7:56:00 AM
BRTWD-1987	KI	1033	Kitchen	KC	12/30/2025	7:55:00 AM
BRTWD-3512	HE	1043	Room 106	EC	12/30/2025	7:47:00 AM
BRTWD-3513	HE	1043	Room 106	EC	12/30/2025	7:47:00 AM
BRTWD-3515	HE	1047	Room 104	EC	12/30/2025	7:48:00 AM
BRTWD-3516	HE	1047	Room 104	EC	12/30/2025	7:50:00 AM
BRTWD-3517	HE	1047	Room 104	EC	12/30/2025	7:50:00 AM
BRTWD-3518	HE	1047	Room 104	EC	12/30/2025	7:51:00 AM
BRTWD-3519	HE	1047A	Room 104 Laundry Room	EC	12/30/2025	7:51:00 AM

Samples Submitted 9

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:40

Pb 200.8 Katherine 12/31/25

Building Address
2030 Udall Road
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/30/25 4:40 PM

Signature: Dair Wharton

Samplers Name: Danielle Belgiorno

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557957

LIMS Reference ID: ED57957

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / West Middle School WMS / 2030 Udall Road, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:40

Reported: 12/31/2025 15:04

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-1978		**Lims Reference ID:**		**ED57957-01**	**Matrix: Drinking Water**				**Sampled: 12/30/25 00:00:00**
Metals									
Lead	**36.3**		1	1.0	µg/L	12/31/25 11:17	12/31/25 11:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-1987		**Lims Reference ID:**		**ED57957-02**	**Matrix: Drinking Water**				**Sampled: 12/30/25 00:00:00**
Metals									
Lead	**15.9**		1	1.0	µg/L	12/31/25 11:18	12/31/25 11:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3512		**Lims Reference ID:**		**ED57957-03**	**Matrix: Drinking Water**				**Sampled: 12/30/25 00:00:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	12/31/25 11:22	12/31/25 11:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3513		**Lims Reference ID:**		**ED57957-04**	**Matrix: Drinking Water**				**Sampled: 12/30/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/31/25 11:23	12/31/25 11:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3515		**Lims Reference ID:**		**ED57957-05**	**Matrix: Drinking Water**				**Sampled: 12/30/25 00:00:00**
Metals									
Lead	**1.2**		1	1.0	µg/L	12/31/25 11:25	12/31/25 11:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3516		**Lims Reference ID:**		**ED57957-06**	**Matrix: Drinking Water**				**Sampled: 12/30/25 00:00:00**
Metals									
Lead	**2.3**		1	1.0	µg/L	12/31/25 11:26	12/31/25 11:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3517		**Lims Reference ID:**		**ED57957-07**	**Matrix: Drinking Water**				**Sampled: 12/30/25 00:00:00**
Metals									
Lead	**1.1**		1	1.0	µg/L	12/31/25 11:27	12/31/25 11:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3518		**Lims Reference ID:**		**ED57957-08**	**Matrix: Drinking Water**				**Sampled: 12/30/25 00:00:00**
Metals									
Lead	**2.6**		1	1.0	µg/L	12/31/25 11:29	12/31/25 11:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3519		**Lims Reference ID:**		**ED57957-09**	**Matrix: Drinking Water**				**Sampled: 12/30/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557957
LIMS Reference ID: ED57957
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / West Middle School WMS / 2030 Udall Road, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:40
Reported: 12/31/2025 15:04

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3519 (Continued)			**Lims Reference ID:**	**ED57957-09**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 00:00:00**
Metals (Continued)									
Lead	**3.6**		1	1.0	µg/L	12/31/25 11:30	12/31/25 11:30	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557957
LIMS Reference ID: ED57957
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / West Middle School WMS / 2030 Udall Road, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:40
Reported: 12/31/2025 15:04

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557957
LIMS Reference ID: ED57957
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / West Middle School WMS / 2030 Udall Road, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:40
Reported: 12/31/2025 15:04

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EE50867

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: West Middle School

WMS

Client: Brentwood Union Free School District

Retest/New Install [Y]

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3097	HA	N/A	Corridor Near Room 248	WC	2/18/2026	7:32:00 AM
BRTWD-3098	HA	N/A	Corridor Near Room 248	WC	2/18/2026	7:32:00 AM
BRTWD-3099	GY	N/A	Wrestling Room	WC	2/18/2026	7:37:00 AM

Samples Submitted 3

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 18 26, PM01:51

Building Address
2030 Udall Road
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: Sean Cecil

Signature:

02/18/26 1:51 PM

Samplers Name: Danielle Bolognese

Samplers Signature:

JCB Project Manager: Meghan Gwynn

No door hanger

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650867
LIMS Reference ID: EE50867
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School, 2030 Udall Road Bay Shore NY 11706, JCB#:23-53744, Brentwood Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/18/2026 13:51
Reported: 02/19/2026 09:06

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3097		**Lims Reference ID:**		**EE50867-01**	**Matrix: Drinking Water**				**Sampled: 02/18/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	02/19/26 01:18	02/19/26 01:18	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3098		**Lims Reference ID:**		**EE50867-02**	**Matrix: Drinking Water**				**Sampled: 02/18/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	02/19/26 01:19	02/19/26 01:19	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3099		**Lims Reference ID:**		**EE50867-03**	**Matrix: Drinking Water**				**Sampled: 02/18/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	02/19/26 01:20	02/19/26 01:20	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650867
LIMS Reference ID: EE50867
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	West Middle School, 2030 Udall Road Bay Shore NY 11706, JCB#:23-53744, Brentwood Union Free School District
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	02/18/2026 13:51
Reported:	02/19/2026 09:06

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650867
LIMS Reference ID: EE50867
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School, 2030 Udall Road Bay Shore NY 11706, JCB#:23-53744, Brentwood Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/18/2026 13:51
Reported: 02/19/2026 09:06

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE51669

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: West Middle School

WMS

Client: Brentwood Union Free School District

Retest/New Install N

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4291	HA	1050	Corridor 101 to Main Lobby	WF	3/26/2026	6:57:00 AM
BRTWD-4292	HA	1050	Corridor 101 to Main Lobby	WC	3/26/2026	6:57:00 AM

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 26 26, PM03:46

Pb 3/28/26

Building Address
2030 Udall Road
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 3/26/26 3:46 PM

Signature: Dair Wht

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Grogan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651669
LIMS Reference ID: EE51669
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/26/2026 15:46
Reported: 03/28/2026 23:40

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4291			**Lims Reference ID:**	**EE51669-01**	**Matrix: Drinking Water**				**Sampled: 03/26/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/28/26 20:20	03/28/26 20:20	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4292			**Lims Reference ID:**	**EE51669-02**	**Matrix: Drinking Water**				**Sampled: 03/26/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/28/26 20:24	03/28/26 20:24	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651669
LIMS Reference ID: EE51669
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/26/2026 15:46
Reported: 03/28/2026 23:40

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651669
LIMS Reference ID: EE51669
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/26/2026 15:46
Reported:	03/28/2026 23:40

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE53870

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: West Middle School

WMS

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4302	SP	1052	Wrestling Room	WF	8/4/2026	6:55:00 AM
BRTWD-4303	SP	1052	Wrestling Room	WC	8/4/2026	6:55:00 AM

Samples Submitted 2

Courier

200.8 8/6/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 04 26, PM01:06

Building Address
2030 Udall Road
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/4/26 1:06PM

Signature:

Samplers Name: Danielle Belogaini

Samplers Signature:

JCB Project Manager: Danielle Belogaini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653870

LIMS Reference ID: EE53870

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/04/2026 13:06

Reported: 08/06/2026 11:52

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4302		**Lims Reference ID:**		**EE53870-01**	**Matrix: Drinking Water**				**Sampled: 08/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/06/26 10:35	08/06/26 10:35	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4303		**Lims Reference ID:**		**EE53870-02**	**Matrix: Drinking Water**				**Sampled: 08/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/06/26 10:40	08/06/26 10:40	BP	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653870

LIMS Reference ID: EE53870

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/04/2026 13:06
Reported:	08/06/2026 11:52

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653870

LIMS Reference ID: EE53870

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/04/2026 13:06
Reported:	08/06/2026 11:52

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EE54124

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: West Middle School

WMS

Client: Brentwood Union Free School District

Retest/New Install [✓]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4323	LR	1035B	Girls Locker Room	DW	8/19/2026	7:46:00 AM

Samples Submitted 1

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 19 26, PM12:40

PO 200.8 8/20/26

Building Address
2030 Udall Road
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/19/26 12:40PM

Signature:

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654124

LIMS Reference ID: EE54124

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/19/2026 12:40

Reported: 08/21/2026 09:55

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4323			**Lims Reference ID:**	**EE54124-01**	**Matrix: Drinking Water**			**Sampled:**	**08/19/26 00:00:00**
Metals									
Lead	**12.6**		1	1.0	µg/L	08/20/26 19:08	08/20/26 19:08	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654124
LIMS Reference ID: EE54124
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706, Brentwood Union Free School District, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/19/2026 12:40
Reported: 08/21/2026 09:55

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654124
LIMS Reference ID: EE54124
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: West Middle School WMS, 2030 Udall Road, Bay Shore, NY 11706, Brentwood Union Free School District, #26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/19/2026 12:40
Reported: 08/21/2026 09:55

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED53315

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Pine Park Elementary School

PPES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: ~~Normal~~ 1 wk ~~Rush~~ _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2086	CR	2000	Room 33	DW	6/6/2025	6:38:00 AM
BRTWD-2090	CR	2002	Room35	DW	6/6/2025	6:37:00 AM
BRTWD-2093	CR	2003	Room 36	DW	6/6/2025	6:35:00 AM
BRTWD-2097	CR	2004	Room 34	DW	6/6/2025	6:36:00 AM
BRTWD-2100	CR	2005	Room 32	DW	6/6/2025	6:41:00 AM
BRTWD-2101	CR	2005A	Room 32 Bathroom	DW	6/6/2025	6:40:00 AM
BRTWD-2109	CR	1004	Room 3	DW	6/6/2025	6:44:00 AM
BRTWD-2111	CR	1005	Room 4	DW	6/6/2025	6:45:00 AM
BRTWD-2113	CR	1006	Room 5	DW	6/6/2025	6:47:00 AM
BRTWD-2115	CR	1007	Room 6	DW	6/6/2025	6:49:00 AM
BRTWD-2121	CR	1010	Room 9	DW	6/6/2025	6:59:00 AM
BRTWD-2123	CR	1011	Room 10	DW	6/6/2025	7:00:00 AM
BRTWD-2125	CR	1012	Room 11	DW	6/6/2025	7:03:00 AM
BRTWD-2129	CR	1014	Room 13	DW	6/6/2025	7:15:00 AM
BRTWD-2131	CR	1015	Room 14	DW	6/6/2025	7:17:00 AM
BRTWD-2133	CR	1016	Room 15	DW	6/6/2025	7:19:00 AM
BRTWD-2137	OF	1024B	Rear Psychologist Office	OF	6/6/2025	6:25:00 AM
BRTWD-2139	NO	1025	Nurse's Office	NS	6/6/2025	6:19:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:06

Building Address
1 Mur Place
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:06

Signature: _____

Samplers Name: Lexi Carwell

Samplers Signature: _____

JCB Project Manager: _____

Lead in Water: Chain of Custody for E053315

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Pine Park Elementary School

PPES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: ~~Normal 1 wk~~ **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2141	FL	1033	Faculty Room	KC	6/6/2025	6:12:00 AM
BRTWD-2144	KI	1036	Kitchen	KC	6/6/2025	5:55:00 AM
BRTWD-2145	KI	1036	Kitchen	KC	6/6/2025	5:56:00 AM
BRTWD-2146	KI	1036	Kitchen	HW	6/6/2025	5:57:00 AM
BRTWD-2148	KI	1036	Kitchen	KC	6/6/2025	6:01:00 AM
BRTWD-2150	KI	1036	Kitchen	KC	6/6/2025	6:02:00 AM
BRTWD-2151	KI	1036	Kitchen	KC	6/6/2025	6:02:00 AM
BRTWD-2152	KI	1036	Kitchen	HW	6/6/2025	6:04:00 AM
BRTWD-2163	CR	1044	Room 16	DW	6/6/2025	7:39:00 AM
BRTWD-2165	CR	1045	Room 17	DW	6/6/2025	7:38:00 AM
BRTWD-2167	CR	1046	Room 18	DW	6/6/2025	7:37:00 AM
BRTWD-2169	CR	1047	Room 19	DW	6/6/2025	7:35:00 AM
BRTWD-2171	CR	1048	Room 20	DW	6/6/2025	7:34:00 AM
BRTWD-2175	CR	1050	Room 22	DW	6/6/2025	7:32:00 AM
BRTWD-2177	CR	1052	Room 24	DW	6/6/2025	7:31:00 AM
BRTWD-2179	CR	1053	Room 25	DW	6/6/2025	7:29:00 AM
BRTWD-2181	CR	1055	Room 27	DW	6/6/2025	7:28:00 AM
BRTWD-2183	CR	1054	Room 26	DW	6/6/2025	7:26:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM

Building Address
1 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/12/25 21:06

Signature: [signature]

Samplers Name: Lexi Farrell

Samplers Signature: [signature]

JCB Project Manager: Megan Gwynn

Lead in Water: Chain of Custody for EDS3315

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Pine Park Elementary School

PPES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2187	CR	1056	Room 28	DW	6/6/2025	7:25:00 AM
BRTWD-3047	HA	1061	Corridor Near Faculty Room (1033)	WC	6/6/2025	6:07:00 AM
BRTWD-3048	HA	1061	Corridor Near Faculty Room (1033)	WF	6/6/2025	6:08:00 AM
BRTWD-3049	HA	1061	Corridor Adjacent Gender Neutral Bathroom (1022)	WC	6/6/2025	6:29:00 AM
BRTWD-3050	HA	1061	Corridor Adjacent Gender Neutral Bathroom (1022)	WF	6/6/2025	6:28:00 AM
BRTWD-3294	CR	1008	Room 7	DW	6/6/2025	6:55:00 AM
BRTWD-3296	CR	1009	Room 8	DW	6/6/2025	6:57:00 AM
BRTWD-3303	KI	1036	Kitchen	PK	6/6/2025	5:58:00 AM
BRTWD-3962	CR	1013	Room 12	DW	6/6/2025	7:07:00 AM

Samples Submitted 45

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:06

Building Address
1 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:06

Signature: Ivan Martinez

Samplers Name: Lexi Famuch

Samplers Signature:

JCB Project Manager: Meghan Brogan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553315

LIMS Reference ID: ED53315

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 21:06

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2086		**Lims Reference ID:**		**ED53315-01**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 08:59	06/19/25 08:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2090		**Lims Reference ID:**		**ED53315-02**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:03	06/19/25 09:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2093		**Lims Reference ID:**		**ED53315-03**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:04	06/19/25 09:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2097		**Lims Reference ID:**		**ED53315-04**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:06	06/19/25 09:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2100		**Lims Reference ID:**		**ED53315-05**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:10	06/19/25 09:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2101		**Lims Reference ID:**		**ED53315-06**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	5.9		1	1.0	µg/L	06/19/25 09:11	06/19/25 09:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2109		**Lims Reference ID:**		**ED53315-07**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:12	06/19/25 09:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2111		**Lims Reference ID:**		**ED53315-08**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.0		1	1.0	µg/L	06/19/25 09:14	06/19/25 09:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2113		**Lims Reference ID:**		**ED53315-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553315
LIMS Reference ID: ED53315
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:06
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2113 (Continued)		**Lims Reference ID:**		**ED53315-09**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	2.2		1	1.0	µg/L	06/19/25 09:15	06/19/25 09:15	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2115		**Lims Reference ID:**		**ED53315-10**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:16	06/19/25 09:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2121		**Lims Reference ID:**		**ED53315-11**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:18	06/19/25 09:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2123		**Lims Reference ID:**		**ED53315-12**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:22	06/19/25 09:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2125		**Lims Reference ID:**		**ED53315-13**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	7.0		1	1.0	µg/L	06/19/25 09:26	06/19/25 09:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2129		**Lims Reference ID:**		**ED53315-14**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:27	06/19/25 09:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2131		**Lims Reference ID:**		**ED53315-15**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:28	06/19/25 09:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2133		**Lims Reference ID:**		**ED53315-16**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	11.2		1	1.0	µg/L	06/19/25 09:30	06/19/25 09:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2137		**Lims Reference ID:**		**ED53315-17**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553315
LIMS Reference ID: ED53315
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:06
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2137 (Continued)		**Lims Reference ID:**		**ED53315-17**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	2.0		1	1.0	µg/L	06/19/25 09:31	06/19/25 09:31	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2139		**Lims Reference ID:**		**ED53315-18**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	3.9		1	1.0	µg/L	06/19/25 09:32	06/19/25 09:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2141		**Lims Reference ID:**		**ED53315-19**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:34	06/19/25 09:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2144		**Lims Reference ID:**		**ED53315-20**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	19.5		1	1.0	µg/L	06/19/25 09:35	06/19/25 09:35	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2145		**Lims Reference ID:**		**ED53315-21**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/19/25 09:54	06/19/25 09:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2146		**Lims Reference ID:**		**ED53315-22**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 09:58	06/19/25 09:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2148		**Lims Reference ID:**		**ED53315-23**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 10:00	06/19/25 10:00	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2150		**Lims Reference ID:**		**ED53315-24**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	4.9		1	1.0	µg/L	06/19/25 10:01	06/19/25 10:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2151		**Lims Reference ID:**		**ED53315-25**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553315
LIMS Reference ID: ED53315
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:06
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2151 (Continued)		**Lims Reference ID:**		**ED53315-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	2.9		1	1.0	µg/L	06/19/25 10:02	06/19/25 10:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2152		**Lims Reference ID:**		**ED53315-26**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	12.7		1	1.0	µg/L	06/19/25 10:06	06/19/25 10:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2163		**Lims Reference ID:**		**ED53315-27**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.1		1	1.0	µg/L	06/19/25 10:08	06/19/25 10:08	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2165		**Lims Reference ID:**		**ED53315-28**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.4		1	1.0	µg/L	06/19/25 10:09	06/19/25 10:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2167		**Lims Reference ID:**		**ED53315-29**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.5		1	1.0	µg/L	06/19/25 10:10	06/19/25 10:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2169		**Lims Reference ID:**		**ED53315-30**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 10:12	06/19/25 10:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2171		**Lims Reference ID:**		**ED53315-31**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 10:13	06/19/25 10:13	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2175		**Lims Reference ID:**		**ED53315-32**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 10:17	06/19/25 10:17	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2177		**Lims Reference ID:**		**ED53315-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553315
LIMS Reference ID: ED53315
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:06
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2177 (Continued)		**Lims Reference ID:**		**ED53315-33**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	**16.3**		1	1.0	µg/L	06/19/25 10:18	06/19/25 10:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2179		**Lims Reference ID:**		**ED53315-34**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**7.4**		1	1.0	µg/L	06/19/25 10:22	06/19/25 10:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2181		**Lims Reference ID:**		**ED53315-35**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	06/19/25 10:24	06/19/25 10:24	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2183		**Lims Reference ID:**		**ED53315-36**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**6.2**		1	1.0	µg/L	06/19/25 10:25	06/19/25 10:25	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2187		**Lims Reference ID:**		**ED53315-37**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/19/25 10:26	06/19/25 10:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3047		**Lims Reference ID:**		**ED53315-38**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/19/25 10:28	06/19/25 10:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3048		**Lims Reference ID:**		**ED53315-39**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/19/25 10:29	06/19/25 10:29	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3049		**Lims Reference ID:**		**ED53315-40**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/19/25 10:30	06/19/25 10:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3050		**Lims Reference ID:**		**ED53315-41**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553315
LIMS Reference ID: ED53315
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:06
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3050 (Continued)		**Lims Reference ID:**		**ED53315-41**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	06/22/25 16:21	06/22/25 16:21	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3294		**Lims Reference ID:**		**ED53315-42**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**2.0**		1	1.0	µg/L	06/22/25 16:52	06/22/25 16:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3296		**Lims Reference ID:**		**ED53315-43**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**4.0**		1	1.0	µg/L	06/22/25 16:54	06/22/25 16:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3303		**Lims Reference ID:**		**ED53315-44**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**3.3**		1	1.0	µg/L	06/22/25 16:55	06/22/25 16:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3962		**Lims Reference ID:**		**ED53315-45**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/22/25 16:56	06/22/25 16:56	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553315
LIMS Reference ID: ED53315
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:06
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553315

LIMS Reference ID: ED53315

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 21:06

Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57892

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Pine Park Elementary School

PPES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48HR

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2144	KI	1036	Kitchen	KC	12/23/2025	6:38:00 AM
BRTWD-2152	KI	1036	Kitchen	HW	12/23/2025	7:48:00 AM

Samples Submitted 2

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:09

Pb Kathleen 12/24/25

Building Address
1 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.8

Lab Recieved: 12/23/25 14:04

Signature: [signature]

Samplers Name: Molly Miller

Samplers Signature: [signature]

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557892

LIMS Reference ID: ED57892

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:09

Reported: 12/24/2025 16:59

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2144		**Lims Reference ID:**		**ED57892-01**	**Matrix: Drinking Water**				**Sampled: 12/23/25 06:38:00**
Metals									
Lead	**5.3**		1	1.0	µg/L	12/24/25 13:34	12/24/25 13:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2152		**Lims Reference ID:**		**ED57892-02**	**Matrix: Drinking Water**				**Sampled: 12/23/25 07:48:00**
Metals									
Lead	**4.3**		1	1.0	µg/L	12/24/25 13:35	12/24/25 13:35	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557892

LIMS Reference ID: ED57892

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 14:09
Reported:	12/24/2025 16:59

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557892

LIMS Reference ID: ED57892

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 14:09
Reported:	12/24/2025 16:59

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.



James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57966

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: Pine Park Elementary School
PPES

Client:
Brentwood Union Free School District

Retest/New Install [ ]
Turn Around: Normal 1 wk Rush 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2144	KI	1036	Kitchen	KC	12/30/2025	7:44:00 AM

Samples Submitted 1

Pb 200.8 BBerry 12/31/25

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:37

Building Address
1 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: 12/30/25 16:37
Signature: [illegible]

Samplers Name: Jordan Miglino
Samplers Signature: [illegible]
JCB Project Manager: Meghan Gi[illegible]

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557966

LIMS Reference ID: ED57966

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:37

Reported: 12/31/2025 15:20

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2144			**Lims Reference ID:**	**ED57966-01**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 07:44:00**
Metals									
Lead	**1.2**		1	1.0	µg/L	12/31/25 10:05	12/31/25 10:05	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557966

LIMS Reference ID: ED57966

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/30/2025 16:37
Reported:	12/31/2025 15:20

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557966

LIMS Reference ID: ED57966

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Pine Park Elementary School: 1 Mur Place, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/30/2025 16:37
Reported:	12/31/2025 15:20

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50898

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: Pine Park Elementary School
PPES

Client: Brentwood Union Free School District
Retest/New Install [✓]
Turn Around: Normal 1 wk **Rush** 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2183	CR	1054	Room 26	DW	2/19/2026	7:30:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 19 26, PM01:16

Building Address
1 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved:
Signature:

Samplers Name: Danielle Bolognino
Samplers Signature:
JCB Project Manager: Meghan Grogan

Page 4 of 4

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650898

LIMS Reference ID: EE50898

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Pine Park Elementary School, Brentwood Union Free School District, 1 Mur Place, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 02/19/2026 13:16

Reported: 02/21/2026 09:23

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2183			**Lims Reference ID:**	**EE50898-01**	**Matrix: Drinking Water**			**Sampled:**	**02/19/26 00:00:00**
Metals									
Lead	**8.3**		1	1.0	µg/L	02/21/26 00:48	02/21/26 00:48	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650898

LIMS Reference ID: EE50898

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Pine Park Elementary School, Brentwood Union Free School District, 1 Mur Place, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 02/19/2026 13:16

Reported: 02/21/2026 09:23

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650898
LIMS Reference ID: EE50898
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Pine Park Elementary School, Brentwood Union Free School District, 1 Mur Place, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/19/2026 13:16
Reported: 02/21/2026 09:23

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EES 4121

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Pine Park Elementary School

PPES

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2125	CR	1012	Room 11	DW	8/19/2026	8:18:00 AM
BRTWD-2179	CR	1053	Room 25	DW	8/19/2026	8:11:00 AM
BRTWD-3300	FL	1033	Faculty Room	BWC	8/19/2026	8:16:00 AM
BRTWD-3301	FL	1033	Faculty Room	BWH	8/19/2026	8:15:00 AM

Samples Submitted 4

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 19 26, PM12:39

Building Address
1 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Charlotte Eagle

Signature:

Samplers Name: Jordan Migliino

Samplers Signature: J. Migliino

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654121

LIMS Reference ID: EE54121

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: JCB# 26-64123, Pine Park Elementary School, Brentwood Union Free School District, 1 Mur Place, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/19/2026 12:39

Reported: 08/21/2026 09:33

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2125		**Lims Reference ID:**		**EE54121-01**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**2.5**	1	1.0	µg/L	08/20/26 18:58	08/20/26 18:58	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2179		**Lims Reference ID:**		**EE54121-02**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**16.0**	1	1.0	µg/L	08/20/26 19:02	08/20/26 19:02	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3300		**Lims Reference ID:**		**EE54121-03**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**< 1.0**	1	1.0	µg/L	08/20/26 19:03	08/20/26 19:03	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3301		**Lims Reference ID:**		**EE54121-04**	**Matrix: Drinking Water**				**Sampled: 08/19/26 00:00:00**
Metals									
Lead	**< 1.0**	1	1.0	µg/L	08/20/26 19:04	08/20/26 19:04	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654121
LIMS Reference ID: EE54121
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: JCB# 26-64123, Pine Park Elementary School, Brentwood Union Free School District, 1 Mur Place, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/19/2026 12:39
Reported: 08/21/2026 09:33

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654121

LIMS Reference ID: EE54121

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	JCB# 26-64123, Pine Park Elementary School, Brentwood Union Free School District, 1 Mur Place, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/19/2026 12:39
Reported:	08/21/2026 09:33

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE 54404

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Pine Park Elementary School
PPES

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2179	CR	1053	Room 25	DW	9/4/2026	7:06:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
SEP 04 26, PM02:25

9/5/26

Building Address
1 Mur Place
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Matteo Mariani 9/4/26

Signature: MM 2:25 PM

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654404

LIMS Reference ID: EE54404

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: #26-64123, Brentwood Union Free School District, Pine Park Elementary School, 1 Mur Place, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/04/2026 14:25

Reported: 09/08/2026 08:55

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2179			**Lims Reference ID:**	**EE54404-01**	**Matrix: Drinking Water**			**Sampled:**	**09/04/26 07:06:00**
Metals									
Lead	**8.4**		1	1.0	µg/L	09/05/26 18:25	09/05/26 18:25	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654404
LIMS Reference ID: EE54404
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: #26-64123, Brentwood Union Free School District, Pine Park Elementary School, 1 Mur Place, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/04/2026 14:25
Reported: 09/08/2026 08:55

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654404
LIMS Reference ID: EE54404
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: #26-64123, Brentwood Union Free School District, Pine Park Elementary School, 1 Mur Place, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 09/04/2026 14:25
Reported: 09/08/2026 08:55

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EO53320

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Hemlock Park Elementary School

HEM

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2205	CR	1001	Room 2	DW	6/5/2025	6:27:00 AM
BRTWD-2208	CR	1000	Room 1	DW	6/5/2025	6:29:00 AM
BRTWD-2213	CR	1004	Room 4	DW	6/5/2025	6:32:00 AM
BRTWD-2216	CR	1005	Room 5	DW	6/5/2025	6:37:00 AM
BRTWD-2218	CR	1007	Room 6	DW	6/5/2025	6:39:00 AM
BRTWD-2221	CR	1008	Room 7	DW	6/5/2025	6:40:00 AM
BRTWD-2225	CR	1010	Room 9	DW	6/5/2025	6:43:00 AM
BRTWD-2227	CR	1011	Room 10	DW	6/5/2025	6:44:00 AM
BRTWD-2229	CR	1012	Room 11	DW	6/5/2025	6:46:00 AM
BRTWD-2231	CR	1013	Room 12	DW	6/5/2025	6:48:00 AM
BRTWD-2233	CR	1014	Room 13	DW	6/5/2025	6:50:00 AM
BRTWD-2235	CR	1015	Room 14	DW	6/5/2025	6:51:00 AM
BRTWD-2239	CR	1017	Room 16	DW	6/5/2025	6:54:00 AM
BRTWD-2244	NO	1025	Nurse's Office	NS	6/5/2025	6:22:00 AM
BRTWD-2246	NO	1025A	Nurse Sick Room	NS	6/5/2025	6:20:00 AM
BRTWD-2248	FL	1030	Faculty Room	KC	6/5/2025	6:15:00 AM
BRTWD-2259	CR	1040	Room 18	DW	6/5/2025	7:29:00 AM
BRTWD-2261	CR	1041	Room 17	DW	6/5/2025	7:28:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM03:05

Building Address
19 Hemlock Drive
Bay Shore , NY 11706

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:05

Signature:

Samplers Name: Lexi Farwell

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for

ED53310

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Hemlock Park Elementary School

HEM

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2263	CR	1043	Room 19	DW	6/5/2025	7:27:00 AM
BRTWD-2267	CR	1045	Room 24	DW	6/5/2025	7:23:00 AM
BRTWD-2269	CR	1046	Room 23	DW	6/5/2025	7:22:00 AM
BRTWD-2271	CR	1047	Room 26	DW	6/5/2025	7:21:00 AM
BRTWD-2273	CR	1048	Room 25	DW	6/5/2025	7:19:00 AM
BRTWD-2275	CR	1049	Room 28	DW	6/5/2025	7:18:00 AM
BRTWD-2277	CR	1050	Room 27	DW	6/5/2025	7:17:00 AM
BRTWD-2279	CR	1052	Room 29	DW	6/5/2025	7:16:00 AM
BRTWD-2281	CR	1051	Room 30	DW	6/5/2025	7:14:00 AM
BRTWD-2283	CR	N/A	Room 31	DW	6/5/2025	7:13:00 AM
BRTWD-2285	CR	N/A	Room 32	DW	6/5/2025	7:11:00 AM
BRTWD-2296	CR	N/A	Room 35	DW	6/5/2025	7:07:00 AM
BRTWD-2299	CR	N/A	Room 34	DW	6/5/2025	7:05:00 AM
BRTWD-2300	CR	N/A	Room 37	DW	6/5/2025	7:04:00 AM
BRTWD-2303	CR	N/A	Room 36	DW	6/5/2025	7:01:00 AM
BRTWD-2304	CR	N/A	Room 39	DW	6/5/2025	7:00:00 AM
BRTWD-2307	CR	N/A	Room 38	DW	6/5/2025	6:59:00 AM
BRTWD-2308	KI	1033	Kitchen	KC	6/5/2025	5:56:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM09:05

Building Address
19 Hemlock Drive
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:05

Signature: Kai Pagdon

Samplers Name: Lexi Carucci

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for E053310

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Hemlock Park Elementary School

HEM

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2309	KI	1033	Kitchen	KC	6/5/2025	5:56:00 AM
BRTWD-2310	KI	1033	Kitchen	HW	6/5/2025	5:59:00 AM
BRTWD-2312	KI	1033	Kitchen	KC	6/5/2025	5:57:00 AM
BRTWD-2313	KI	1033	Kitchen	KC	6/5/2025	5:58:00 AM
BRTWD-2314	KI	1033	Kitchen	KC	6/5/2025	5:59:00 AM
BRTWD-2315	KI	1033	Kitchen	HW	6/5/2025	6:01:00 AM
BRTWD-3079	HA	1054	Corridor Near Custodial Office (1034A)	WC	6/5/2025	6:09:00 AM
BRTWD-3080	HA	1054	Corridor Near Custodial Office (1034A)	WF	6/5/2025	6:07:00 AM
BRTWD-3081	HA	1054	Corridor Near Gym (1024)	WC	6/5/2025	6:12:00 AM
BRTWD-3082	HA	1054	Corridor Near Gym (1024)	WF	6/5/2025	6:12:00 AM
BRTWD-3552	CR	1003	Room 3	DW	6/5/2025	6:34:00 AM
BRTWD-3554	CR	1009	Room 8	DW	6/5/2025	6:41:00 AM
BRTWD-3558	KI	1033	Kitchen	PK	6/5/2025	6:00:00 AM
BRTWD-3559	CR	1044	Room 21	DW	6/5/2025	7:25:00 AM
BRTWD-3563	HA	N/A	Corridor near Bathrooms	WC	6/5/2025	6:57:00 AM
BRTWD-3566	CR	N/A	Room 33	DW	6/5/2025	7:08:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:06

Building Address
19 Hemlock Drive
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 9:05

Signature: [signature] / Ken Wawrzyk

Samplers Name: Lexi Farwell

Samplers Signature: [signature]

JCB Project Manager: Meghan Grayson

Lead in Water: Chain of Custody for E0533088

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Hemlock Park Elementary School

HEM

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time

Samples Submitted 52

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:06

Building Address
19 Hemlock Drive
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:00

Signature: Mary Wachnicka

Samplers Name: Lexi Farmer

Samplers Signature: [signature]

JCB Project Manager: Meghan Brogan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553310
LIMS Reference ID: ED53310
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Hemlock Park Elementary School: 19 Hemlock Drive, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2205		**Lims Reference ID:**		**ED53310-01**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:40	06/24/25 14:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2208		**Lims Reference ID:**		**ED53310-02**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:41	06/24/25 14:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2213		**Lims Reference ID:**		**ED53310-03**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:42	06/24/25 14:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2216		**Lims Reference ID:**		**ED53310-04**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:44	06/24/25 14:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2218		**Lims Reference ID:**		**ED53310-05**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:45	06/24/25 14:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2221		**Lims Reference ID:**		**ED53310-06**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:46	06/24/25 14:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2225		**Lims Reference ID:**		**ED53310-07**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 14:57	06/24/25 14:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2227		**Lims Reference ID:**		**ED53310-08**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:01	06/24/25 15:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2229		**Lims Reference ID:**		**ED53310-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553310
LIMS Reference ID: ED53310
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Hemlock Park Elementary School: 19 Hemlock Drive, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2229 (Continued)		**Lims Reference ID:**		**ED53310-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:03	06/24/25 15:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2231		**Lims Reference ID:**		**ED53310-10**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:04	06/24/25 15:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2233		**Lims Reference ID:**		**ED53310-11**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:05	06/24/25 15:05	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2235		**Lims Reference ID:**		**ED53310-12**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:09	06/24/25 15:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2239		**Lims Reference ID:**		**ED53310-13**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:11	06/24/25 15:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2244		**Lims Reference ID:**		**ED53310-14**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:12	06/24/25 15:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2246		**Lims Reference ID:**		**ED53310-15**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	79.8		1	1.0	µg/L	06/24/25 15:13	06/24/25 15:13	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2248		**Lims Reference ID:**		**ED53310-16**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/24/25 15:15	06/24/25 15:15	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2259		**Lims Reference ID:**		**ED53310-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553310
LIMS Reference ID: ED53310
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Hemlock Park Elementary School: 19 Hemlock Drive, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2259 (Continued)		**Lims Reference ID:**		**ED53310-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	34.5		1	1.0	µg/L	06/24/25 15:16	06/24/25 15:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2261		**Lims Reference ID:**		**ED53310-18**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	7.3		1	1.0	µg/L	06/24/25 15:20	06/24/25 15:20	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2263		**Lims Reference ID:**		**ED53310-19**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/24/25 15:21	06/24/25 15:21	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2267		**Lims Reference ID:**		**ED53310-20**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	7.0		1	1.0	µg/L	06/24/25 15:25	06/24/25 15:25	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2269		**Lims Reference ID:**		**ED53310-21**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	7.5		1	1.0	µg/L	06/24/25 15:27	06/24/25 15:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2271		**Lims Reference ID:**		**ED53310-22**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	06/24/25 15:28	06/24/25 15:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2273		**Lims Reference ID:**		**ED53310-23**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	4.5		1	1.0	µg/L	06/24/25 15:29	06/24/25 15:29	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2275		**Lims Reference ID:**		**ED53310-24**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	23.5		1	1.0	µg/L	06/24/25 15:30	06/24/25 15:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2277		**Lims Reference ID:**		**ED53310-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553310
LIMS Reference ID: ED53310
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Hemlock Park Elementary School: 19 Hemlock Drive, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2277 (Continued)		**Lims Reference ID:**		**ED53310-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	4.4		1	1.0	µg/L	06/24/25 15:32	06/24/25 15:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2279		**Lims Reference ID:**		**ED53310-26**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.1		1	1.0	µg/L	06/24/25 15:33	06/24/25 15:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2281		**Lims Reference ID:**		**ED53310-27**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.6		1	1.0	µg/L	06/24/25 15:45	06/24/25 15:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2283		**Lims Reference ID:**		**ED53310-28**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:49	06/24/25 15:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2285		**Lims Reference ID:**		**ED53310-29**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/24/25 15:50	06/24/25 15:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2296		**Lims Reference ID:**		**ED53310-30**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:51	06/24/25 15:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2299		**Lims Reference ID:**		**ED53310-31**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:53	06/24/25 15:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2300		**Lims Reference ID:**		**ED53310-32**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:57	06/24/25 15:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2303		**Lims Reference ID:**		**ED53310-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553310
LIMS Reference ID: ED53310
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Hemlock Park Elementary School: 19 Hemlock Drive, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2303 (Continued)			**Lims Reference ID:**	**ED53310-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:58	06/24/25 15:58	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2304			**Lims Reference ID:**	**ED53310-34**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 15:59	06/24/25 15:59	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2307			**Lims Reference ID:**	**ED53310-35**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:01	06/24/25 16:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2308			**Lims Reference ID:**	**ED53310-36**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	06/24/25 16:02	06/24/25 16:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2309			**Lims Reference ID:**	**ED53310-37**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/24/25 16:03	06/24/25 16:03	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2310			**Lims Reference ID:**	**ED53310-38**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:07	06/24/25 16:07	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2312			**Lims Reference ID:**	**ED53310-39**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:09	06/24/25 16:09	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2313			**Lims Reference ID:**	**ED53310-40**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	06/24/25 16:13	06/24/25 16:13	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2314			**Lims Reference ID:**	**ED53310-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553310
LIMS Reference ID: ED53310
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Hemlock Park Elementary School: 19 Hemlock Drive, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2314 (Continued)			**Lims Reference ID:**	**ED53310-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	2.6		1	1.0	µg/L	06/24/25 16:14	06/24/25 16:14	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2315			**Lims Reference ID:**	**ED53310-42**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	4.2		1	1.0	µg/L	06/24/25 16:15	06/24/25 16:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3079			**Lims Reference ID:**	**ED53310-43**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:16	06/24/25 16:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3080			**Lims Reference ID:**	**ED53310-44**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:18	06/24/25 16:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3081			**Lims Reference ID:**	**ED53310-45**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:19	06/24/25 16:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3082			**Lims Reference ID:**	**ED53310-46**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:20	06/24/25 16:20	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3552			**Lims Reference ID:**	**ED53310-47**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:36	06/24/25 16:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3554			**Lims Reference ID:**	**ED53310-48**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:40	06/24/25 16:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3558			**Lims Reference ID:**	**ED53310-49**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553310
LIMS Reference ID: ED53310
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Hemlock Park Elementary School: 19 Hemlock Drive, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3558 (Continued)		**Lims Reference ID:**		**ED53310-49**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	**31.6**		1	1.0	µg/L	06/24/25 16:41	06/24/25 16:41	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3559		**Lims Reference ID:**		**ED53310-50**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**3.2**		1	1.0	µg/L	06/24/25 16:43	06/24/25 16:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3563		**Lims Reference ID:**		**ED53310-51**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 16:44	06/24/25 16:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3566		**Lims Reference ID:**		**ED53310-52**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/24/25 16:48	06/24/25 16:48	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553310
LIMS Reference ID: ED53310
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Hemlock Park Elementary School: 19 Hemlock Drive, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553310
LIMS Reference ID: ED53310
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Hemlock Park Elementary School: 19 Hemlock Drive, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:05
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EDS7882

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Hemlock Park Elementary School

HEM

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2246	NO	1025A	Nurse Sick Room	NS	12/23/2025	7:38:00 AM
BRTWD-3558	KI	1033	Kitchen	PK	12/23/2025	7:36:00 AM

Samples Submitted 2

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:08

Pb 2008
Kathedw
12/24/25

Building Address
19 Hemlock Drive
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/23/25 2:08 pm

Signature: Dair Wha

Samplers Name: Meghan Guyon

Samplers Signature: Meghan Guyon

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557882

LIMS Reference ID: ED57882

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Hemlock Park Elementary School HEM / 19 Hemlock Drive, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:08

Reported: 12/24/2025 16:55

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2246		**Lims Reference ID:**		**ED57882-01**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/24/25 13:19	12/24/25 13:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3558		**Lims Reference ID:**		**ED57882-02**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/24/25 13:21	12/24/25 13:21	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557882

LIMS Reference ID: ED57882

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Hemlock Park Elementary School HEM / 19 Hemlock Drive, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:08

Reported: 12/24/2025 16:55

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557882
LIMS Reference ID: ED57882
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Hemlock Park Elementary School HEM / 19 Hemlock Drive, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:08
Reported: 12/24/2025 16:55

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50113

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Hemlock Park Elementary School

HEM

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2237	CR	1016	Room 15	DW	1/9/2026	7:18:00 AM
BRTWD-2259	CR	1040	Room 18	DW	1/9/2026	7:08:00 AM
BRTWD-2261	CR	1041	Room 17	DW	1/9/2026	7:09:00 AM
BRTWD-2267	CR	1045	Room 24	DW	1/9/2026	7:11:00 AM
BRTWD-2269	CR	1046	Room 23	DW	1/9/2026	7:12:00 AM
BRTWD-2275	CR	1049	Room 28	DW	1/9/2026	7:14:00 AM

Samples Submitted 6

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 09 26, PM02:54

Walk In

Building Address
19 Hemlock Drive
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 1/9/26 2:54 pm

Signature:

Samplers Name: Meghan Guynn

Samplers Signature: Meghan Guynn

JCB Project Manager: Meghan Guynn

ELAP 200.8 Pb 1/10/26

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650113
LIMS Reference ID: EE50113
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Hemlock Park Elementary School HEM / 19 Hemlock Drive, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:54
Reported: 01/12/2026 08:47

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2237		**Lims Reference ID:**		**EE50113-01**	**Matrix: Drinking Water**				**Sampled: 01/09/26 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	01/10/26 16:36	01/10/26 16:36	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2259		**Lims Reference ID:**		**EE50113-02**	**Matrix: Drinking Water**				**Sampled: 01/09/26 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	01/10/26 16:39	01/10/26 16:39	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2261		**Lims Reference ID:**		**EE50113-03**	**Matrix: Drinking Water**				**Sampled: 01/09/26 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	01/10/26 16:41	01/10/26 16:41	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2267		**Lims Reference ID:**		**EE50113-04**	**Matrix: Drinking Water**				**Sampled: 01/09/26 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	01/10/26 16:45	01/10/26 16:45	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2269		**Lims Reference ID:**		**EE50113-05**	**Matrix: Drinking Water**				**Sampled: 01/09/26 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	01/10/26 16:46	01/10/26 16:46	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2275		**Lims Reference ID:**		**EE50113-06**	**Matrix: Drinking Water**				**Sampled: 01/09/26 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	01/10/26 16:47	01/10/26 16:47	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650113
LIMS Reference ID: EE50113
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Hemlock Park Elementary School HEM / 19 Hemlock Drive, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:54
Reported: 01/12/2026 08:47

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650113
LIMS Reference ID: EE50113
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Hemlock Park Elementary School HEM / 19 Hemlock Drive, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/09/2026 14:54
Reported: 01/12/2026 08:47

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

ED53311

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Loretta Park Elementary School

LORE

Client: Brentwood Union Free School District

Retest/New Install ( )

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2328	CR	N/A	Room 5A	DW	6/4/2025	7:26:00 AM
BRTWD-2331	CR	N/A	Room 6A	DW	6/4/2025	7:27:00 AM
BRTWD-2333	CR	N/A	Room 4A	DW	6/4/2025	7:24:00 AM
BRTWD-2334	CR	N/A	Room 3A	DW	6/4/2025	7:23:00 AM
BRTWD-2337	CR	N/A	Room 2A	DW	6/4/2025	7:22:00 AM
BRTWD-2338	CR	N/A	Room 1A	DW	6/4/2025	7:21:00 AM
BRTWD-2344	HA	N/A	Corridor Near Faculty Bathroom	WC	6/4/2025	7:19:00 AM
BRTWD-2349	CR	1000	Room 1	DW	6/4/2025	7:18:00 AM
BRTWD-2352	CR	1001	Room 2	DW	6/4/2025	7:17:00 AM
BRTWD-2359	CR	1004	Room 5	DW	6/4/2025	7:13:00 AM
BRTWD-2361	CR	1005	Room 6	DW	6/4/2025	7:11:00 AM
BRTWD-2363	CR	1006	Room 7	DW	6/4/2025	7:10:00 AM
BRTWD-2365	CR	1007	Room 8	DW	6/4/2025	7:09:00 AM
BRTWD-2367	CR	1008	Room 9	DW	6/4/2025	7:08:00 AM
BRTWD-2369	CR	1009	Room 10	DW	6/4/2025	7:06:00 AM
BRTWD-2371	CR	1010	Room 11	DW	6/4/2025	7:05:00 AM
BRTWD-2373	CR	1011	Room 12	DW	6/4/2025	7:04:00 AM
BRTWD-2375	CR	1013	Room 14	DW	6/4/2025	7:02:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:16

Building Address
77 Stahley Street
Brentwood , NY 11717

Walk in

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:16

Signature:

Samplers Name: Tiffany Chen

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Lead in Water: Chain of Custody for

E0533 11

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Loretta Park Elementary School

LORE

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2376	FL	1014	Faculty Room	KC	6/4/2025	7:31:00 AM
BRTWD-2384	KI	1035	Kitchen	KC	6/4/2025	6:04:00 AM
BRTWD-2385	KI	1035	Kitchen	KC	6/4/2025	6:04:00 AM
BRTWD-2388	KI	1035	Kitchen	KC	6/4/2025	6:02:00 AM
BRTWD-2390	KI	1035	Kitchen	KC	6/4/2025	6:01:00 AM
BRTWD-2391	KI	1035	Kitchen	KC	6/4/2025	6:00:00 AM
BRTWD-2403	CR	1045	Room 16	DW	6/4/2025	6:15:00 AM
BRTWD-2405	CR	1047	Room 18	DW	6/4/2025	6:15:00 AM
BRTWD-2407	CR	1048	Room 20	DW	6/4/2025	6:25:00 AM
BRTWD-2413	CR	1051	Room 23	DW	6/4/2025	6:36:00 AM
BRTWD-2415	CR	1052	Room 24	DW	6/4/2025	6:37:00 AM
BRTWD-2417	CR	1053	Room 25	DW	6/4/2025	6:38:00 AM
BRTWD-2419	CR	1054	Room 26	DW	6/4/2025	6:40:00 AM
BRTWD-2423	CR	1056	Room 28	DW	6/4/2025	6:43:00 AM
BRTWD-2425	CR	1057	Room 29	DW	6/4/2025	6:44:00 AM
BRTWD-3063	HA	1038	Corridor Near Room 17 (1026)	WC	6/4/2025	6:49:00 AM
BRTWD-3064	HA	1038	Corridor Near Room 17 (1026)	WF	6/4/2025	6:48:00 AM
BRTWD-3065	HA	1038	Corridor Near Men's Bathroom (1020)	WC	6/4/2025	6:58:00 AM

Building Address
77 Stahley Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:16

Signature:

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM09:16

Samplers Name:

Samplers Signature:

JCB Project Manager: Meghan Gunyon

Lead in Water: Chain of Custody for ED53311

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Loretta Park Elementary School

LORE

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3066	HA	1038	Corridor Near Men's Bathroom (1020)	WF	6/4/2025	6:58:00 AM
BRTWD-3202	CR	1002	Room 3	DW	6/4/2025	7:15:00 AM
BRTWD-3203	CR	1003	Room 4	DW	6/4/2025	7:14:00 AM
BRTWD-3204	KI	1035	Kitchen	PK	6/4/2025	6:09:00 AM
BRTWD-3211	CR	1050	Room 22	DW	6/4/2025	6:34:00 AM
BRTWD-3212	CR	1055	Room 27	DW	6/4/2025	6:41:00 AM
BRTWD-3961	CR	1049	Room 21	DW	6/4/2025	6:29:00 AM

Samples Submitted 43

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:17

Building Address
77 Stahley Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 2:16

Signature:

Samplers Name:_____

Samplers Signature:_____

JCB Project Manager: Meghan Burgos

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553311

LIMS Reference ID: ED53311

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 21:16

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2328			**Lims Reference ID:**	**ED53311-01**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:40	06/17/25 15:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2331			**Lims Reference ID:**	**ED53311-02**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:41	06/17/25 15:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2333			**Lims Reference ID:**	**ED53311-03**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:42	06/17/25 15:42	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2334			**Lims Reference ID:**	**ED53311-04**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:44	06/17/25 15:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2337			**Lims Reference ID:**	**ED53311-05**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:45	06/17/25 15:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2338			**Lims Reference ID:**	**ED53311-06**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:49	06/17/25 15:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2344			**Lims Reference ID:**	**ED53311-07**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:50	06/17/25 15:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2349			**Lims Reference ID:**	**ED53311-08**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 15:54	06/17/25 15:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2352			**Lims Reference ID:**	**ED53311-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553311
LIMS Reference ID: ED53311
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:16
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2352 (Continued)			**Lims Reference ID:**	**ED53311-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	**9.3**		1	1.0	µg/L	06/17/25 15:56	06/17/25 15:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2359			**Lims Reference ID:**	**ED53311-10**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**10.9**		1	1.0	µg/L	06/17/25 15:57	06/17/25 15:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2361			**Lims Reference ID:**	**ED53311-11**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 15:58	06/17/25 15:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2363			**Lims Reference ID:**	**ED53311-12**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 16:00	06/17/25 16:00	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2365			**Lims Reference ID:**	**ED53311-13**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**13.2**		1	1.0	µg/L	06/17/25 16:01	06/17/25 16:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2367			**Lims Reference ID:**	**ED53311-14**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**4.1**		1	1.0	µg/L	06/17/25 16:02	06/17/25 16:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2369			**Lims Reference ID:**	**ED53311-15**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 16:15	06/17/25 16:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2371			**Lims Reference ID:**	**ED53311-16**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	06/17/25 16:19	06/17/25 16:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2373			**Lims Reference ID:**	**ED53311-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553311
LIMS Reference ID: ED53311
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:16
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2373 (Continued)			**Lims Reference ID:**	**ED53311-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	6.5		1	1.0	µg/L	06/17/25 16:20	06/17/25 16:20	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2375			**Lims Reference ID:**	**ED53311-18**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	9.5		1	1.0	µg/L	06/17/25 16:21	06/17/25 16:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2376			**Lims Reference ID:**	**ED53311-19**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	6.6		1	1.0	µg/L	06/17/25 16:23	06/17/25 16:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2384			**Lims Reference ID:**	**ED53311-20**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	9.4		1	1.0	µg/L	06/17/25 16:27	06/17/25 16:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2385			**Lims Reference ID:**	**ED53311-21**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.2		1	1.0	µg/L	06/17/25 16:28	06/17/25 16:28	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2388			**Lims Reference ID:**	**ED53311-22**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 16:29	06/17/25 16:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2390			**Lims Reference ID:**	**ED53311-23**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	2.2		1	1.0	µg/L	06/17/25 16:31	06/17/25 16:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2391			**Lims Reference ID:**	**ED53311-24**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	5.9		1	1.0	µg/L	06/17/25 16:32	06/17/25 16:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2403			**Lims Reference ID:**	**ED53311-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553311
LIMS Reference ID: ED53311
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:16
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2403 (Continued)			**Lims Reference ID:**	**ED53311-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	4.3		1	1.0	µg/L	06/17/25 16:33	06/17/25 16:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2405			**Lims Reference ID:**	**ED53311-26**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.4		1	1.0	µg/L	06/17/25 16:37	06/17/25 16:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2407			**Lims Reference ID:**	**ED53311-27**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.1		1	1.0	µg/L	06/17/25 16:39	06/17/25 16:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2413			**Lims Reference ID:**	**ED53311-28**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.1		1	1.0	µg/L	06/17/25 16:43	06/17/25 16:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2415			**Lims Reference ID:**	**ED53311-29**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	26.3		1	1.0	µg/L	06/17/25 16:44	06/17/25 16:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2417			**Lims Reference ID:**	**ED53311-30**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	9.4		1	1.0	µg/L	06/17/25 16:45	06/17/25 16:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2419			**Lims Reference ID:**	**ED53311-31**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	5.0		1	1.0	µg/L	06/17/25 16:47	06/17/25 16:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2423			**Lims Reference ID:**	**ED53311-32**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	06/17/25 16:48	06/17/25 16:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2425			**Lims Reference ID:**	**ED53311-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553311
LIMS Reference ID: ED53311
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:16
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2425 (Continued)		**Lims Reference ID:**		**ED53311-33**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals (Continued)									
Lead	2.7		1	1.0	µg/L	06/17/25 16:49	06/17/25 16:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3063		**Lims Reference ID:**		**ED53311-34**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 16:51	06/17/25 16:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3064		**Lims Reference ID:**		**ED53311-35**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 17:07	06/17/25 17:07	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3065		**Lims Reference ID:**		**ED53311-36**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 17:11	06/17/25 17:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3066		**Lims Reference ID:**		**ED53311-37**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 17:12	06/17/25 17:12	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3202		**Lims Reference ID:**		**ED53311-38**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	7.3		1	1.0	µg/L	06/17/25 17:13	06/17/25 17:13	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3203		**Lims Reference ID:**		**ED53311-39**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 17:15	06/17/25 17:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3204		**Lims Reference ID:**		**ED53311-40**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	11.4		1	1.0	µg/L	06/17/25 17:19	06/17/25 17:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3211		**Lims Reference ID:**		**ED53311-41**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553311
LIMS Reference ID: ED53311
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:16
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3211 (Continued)		**Lims Reference ID:**		**ED53311-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	**6.9**		1	1.0	µg/L	06/17/25 17:20	06/17/25 17:20	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3212		**Lims Reference ID:**		**ED53311-42**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**30.6**		1	1.0	µg/L	06/17/25 17:21	06/17/25 17:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3961		**Lims Reference ID:**		**ED53311-43**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**1.1**		1	1.0	µg/L	06/17/25 17:22	06/17/25 17:22	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553311
LIMS Reference ID: ED53311
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:16
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553311
LIMS Reference ID: ED53311
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:16
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED55319

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Loretta Park Elementary School

LORE

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4030	CR	1056	Room 28	DW	8/20/2025	8:16:00 AM
BRTWD-4032	CR	1055	Room 27	DW	8/20/2025	8:20:00 AM
BRTWD-4034	CR	1054	Room 26	DW	8/20/2025	8:22:00 AM
BRTWD-4036	CR	1053	Room 25	DW	8/20/2025	8:23:00 AM
BRTWD-4038	CR	1052	Room 24	DW	8/20/2025	8:24:00 AM
BRTWD-4040	CR	1051	Room 23	DW	8/20/2025	8:26:00 AM
BRTWD-4042	CR	1050	Room 22	DW	8/20/2025	8:27:00 AM
BRTWD-4044	CR	1049	Room 21	DW	8/20/2025	8:29:00 AM
BRTWD-4046	CR	1048	Room 20	DW	8/20/2025	8:31:00 AM
BRTWD-4048	CR	1047	Room 18	DW	8/20/2025	8:35:00 AM
BRTWD-4050	CR	1045	Room 16	DW	8/20/2025	8:36:00 AM
BRTWD-4052	CR	1013	Room 14	DW	8/20/2025	8:39:00 AM
BRTWD-4054	CR	1011	Room 12	DW	8/20/2025	8:41:00 AM
BRTWD-4056	CR	1010	Room 11	DW	8/20/2025	8:43:00 AM
BRTWD-4058	CR	1009	Room 10	DW	8/20/2025	8:44:00 AM
BRTWD-4060	CR	1008	Room 9	DW	8/20/2025	8:47:00 AM
BRTWD-4062	CR	1007	Room 8	DW	8/20/2025	8:48:00 AM
BRTWD-4064	CR	1006	Room 7	DW	8/20/2025	8:50:00 AM

RECEIVED
ENSL ANALYTICAL LLC.
Carle Place, NY
AUG 20 25, PM03:46

Building Address
77 Stahley Street
Brentwood , NY 11717

Walk in

Analysis Type: ELAP 200.5

Lab Recieved: Abigail Minnfield

Signature: A. Minnfield

8/20/25 3:46pm

Samplers Name: Daniel Bolognini

Samplers Signature:

JCB Project Manager: Meghan Burgan

Lead in Water: Chain of Custody for ED 55319

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Loretta Park Elementary School

LORE

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4066	CR	1005	Room 6	DW	8/20/2025	8:51:00 AM
BRTWD-4068	CR	1004	Room 5	DW	8/20/2025	8:54:00 AM
BRTWD-4070	CR	1003	Room 4	DW	8/20/2025	8:55:00 AM
BRTWD-4072	CR	1002	Room 3	DW	8/20/2025	8:57:00 AM
BRTWD-4074	CR	1001	Room 2	DW	8/20/2025	8:59:00 AM
BRTWD-4076	CR	1000	Room 1	DW	8/20/2025	9:00:00 AM

Samples Submitted 24

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 20 25, PM03:46

Building Address
77 Stahley Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Abigail Minnfield

Signature: 8/20/25 3:46 PM

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Grogan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555319

LIMS Reference ID: ED55319

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Loretta Park Elementary School, LORE, Brentwood Union Free School District, 77 Stahley Street, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/20/2025 15:46

Reported: 08/22/2025 16:48

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4030			**Lims Reference ID:**	**ED55319-01**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**2.8**		1	1.0	µg/L	08/22/25 13:31	08/22/25 13:31	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4032			**Lims Reference ID:**	**ED55319-02**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**2.4**		1	1.0	µg/L	08/22/25 13:35	08/22/25 13:35	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4034			**Lims Reference ID:**	**ED55319-03**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/22/25 13:37	08/22/25 13:37	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4036			**Lims Reference ID:**	**ED55319-04**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**1.1**		1	1.0	µg/L	08/22/25 13:38	08/22/25 13:38	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4038			**Lims Reference ID:**	**ED55319-05**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**2.1**		1	1.0	µg/L	08/22/25 13:42	08/22/25 13:42	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4040			**Lims Reference ID:**	**ED55319-06**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**2.0**		1	1.0	µg/L	08/22/25 13:43	08/22/25 13:43	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4042			**Lims Reference ID:**	**ED55319-07**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/22/25 13:44	08/22/25 13:44	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4044			**Lims Reference ID:**	**ED55319-08**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/22/25 13:46	08/22/25 13:46	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4046			**Lims Reference ID:**	**ED55319-09**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555319
LIMS Reference ID: ED55319
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Loretta Park Elementary School, LORE, Brentwood Union Free School District, 77 Stahley Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/20/2025 15:46
Reported: 08/22/2025 16:48

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4046 (Continued)		**Lims Reference ID:**		**ED55319-09**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	08/22/25 13:47	08/22/25 13:47	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4048		**Lims Reference ID:**		**ED55319-10**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**1.0**		1	1.0	µg/L	08/22/25 13:48	08/22/25 13:48	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4050		**Lims Reference ID:**		**ED55319-11**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/22/25 13:50	08/22/25 13:50	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4052		**Lims Reference ID:**		**ED55319-12**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	08/22/25 13:54	08/22/25 13:54	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4054		**Lims Reference ID:**		**ED55319-13**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**1.7**		1	1.0	µg/L	08/22/25 13:58	08/22/25 13:58	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4056		**Lims Reference ID:**		**ED55319-14**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**3.4**		1	1.0	µg/L	08/22/25 13:59	08/22/25 13:59	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4058		**Lims Reference ID:**		**ED55319-15**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**2.3**		1	1.0	µg/L	08/22/25 14:00	08/22/25 14:00	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4060		**Lims Reference ID:**		**ED55319-16**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**1.6**		1	1.0	µg/L	08/22/25 14:02	08/22/25 14:02	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4062		**Lims Reference ID:**		**ED55319-17**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555319
LIMS Reference ID: ED55319
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Loretta Park Elementary School, LORE, Brentwood Union Free School District, 77 Stahley Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/20/2025 15:46
Reported: 08/22/2025 16:48

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4062 (Continued)		**Lims Reference ID:**		**ED55319-17**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	08/22/25 14:03	08/22/25 14:03	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4064		**Lims Reference ID:**		**ED55319-18**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	1.4		1	1.0	µg/L	08/22/25 14:04	08/22/25 14:04	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4066		**Lims Reference ID:**		**ED55319-19**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	08/22/25 14:06	08/22/25 14:06	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4068		**Lims Reference ID:**		**ED55319-20**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/22/25 14:07	08/22/25 14:07	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4070		**Lims Reference ID:**		**ED55319-21**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	08/22/25 15:41	08/22/25 15:41	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4072		**Lims Reference ID:**		**ED55319-22**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	2.3		1	1.0	µg/L	08/22/25 15:42	08/22/25 15:42	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4074		**Lims Reference ID:**		**ED55319-23**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	3.5		1	1.0	µg/L	08/22/25 15:44	08/22/25 15:44	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4076		**Lims Reference ID:**		**ED55319-24**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	1.4		1	1.0	µg/L	08/22/25 15:45	08/22/25 15:45	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555319

LIMS Reference ID: ED55319

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Loretta Park Elementary School, LORE, Brentwood Union Free School District, 77 Stahley Street, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/20/2025 15:46

Reported: 08/22/2025 16:48

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555319

LIMS Reference ID: ED55319

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Loretta Park Elementary School, LORE, Brentwood Union Free School District, 77 Stahley Street, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/20/2025 15:46

Reported: 08/22/2025 16:48

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EDS7867

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Loretta Park Elementary School
LORE

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48 hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2376	FL	1014	Faculty Room	KC	12/23/2025	7:20:00 AM
BRTWD-2380	NO	1022	Nurse's Office	NS	12/23/2025	7:19:00 AM
BRTWD-2384	KI	1035	Kitchen	KC	12/23/2025	7:15:00 AM
BRTWD-2386	KI	1035	Kitchen	HW	12/23/2025	7:14:00 AM
BRTWD-2391	KI	1035	Kitchen	KC	12/23/2025	7:16:00 AM
BRTWD-2392	KI	1035	Kitchen	HW	12/23/2025	7:16:00 AM
BRTWD-3204	KI	1035	Kitchen	PK	12/23/2025	7:13:00 AM

Samples Submitted 7

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:13

Courier

Pb 200.8 Billing 12/24/25

Building Address
77 Stahley Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/23/25 2:13 pm

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557867

LIMS Reference ID: ED57867

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Loretta Park Elementary School LORE / 77 Stahley Street, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:13

Reported: 12/24/2025 14:51

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2376		**Lims Reference ID:**		**ED57867-01**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	12/24/25 10:50	12/24/25 10:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2380		**Lims Reference ID:**		**ED57867-02**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**1.6**		1	1.0	µg/L	12/24/25 10:54	12/24/25 10:54	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2384		**Lims Reference ID:**		**ED57867-03**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**2.4**		1	1.0	µg/L	12/24/25 10:56	12/24/25 10:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2386		**Lims Reference ID:**		**ED57867-04**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/24/25 11:00	12/24/25 11:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2391		**Lims Reference ID:**		**ED57867-05**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/24/25 11:01	12/24/25 11:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2392		**Lims Reference ID:**		**ED57867-06**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**8.8**		1	1.0	µg/L	12/24/25 11:02	12/24/25 11:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3204		**Lims Reference ID:**		**ED57867-07**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/24/25 11:04	12/24/25 11:04	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557867
LIMS Reference ID: ED57867
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Loretta Park Elementary School LORE / 77 Stahley Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:13
Reported: 12/24/2025 14:51

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557867
LIMS Reference ID: ED57867
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Loretta Park Elementary School LORE / 77 Stahley Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/23/2025 14:13
Reported: 12/24/2025 14:51

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57970

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Loretta Park Elementary School

LORE

Client: Brentwood Union Free School District

Retest/New Install [✓]

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2392	KI	1035	Kitchen	HW	12/30/2025	7:27:00 AM

Samples Submitted 1

Walk in

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:39

Pb 200.8
Kathleen Lyn
12/31/25

Building Address
77 Stahley Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/30/25 4:39 pm

Signature: David Wharton

Samplers Name: Daniel Bolognini

Samplers Signature: Daniel

JCB Project Manager: Megan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557970

LIMS Reference ID: ED57970

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Loretta Park Elementary School LORE / 77 Stahley Street, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:39

Reported: 12/31/2025 15:20

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2392			**Lims Reference ID:**	**ED57970-01**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 00:00:00**
Metals									
Lead	**66.2**		1	1.0	µg/L	12/31/25 11:47	12/31/25 11:47	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557970

LIMS Reference ID: ED57970

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Loretta Park Elementary School LORE / 77 Stahley Street, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:39

Reported: 12/31/2025 15:20

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557970

LIMS Reference ID: ED57970

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Loretta Park Elementary School LORE / 77 Stahley Street, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:39

Reported: 12/31/2025 15:20

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for FES0063

Walk In

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Loretta Park Elementary School

LORE

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2392	KI	1035	Kitchen	HW	1/7/2026	6:47:00 AM
BRTWD-4028	CR	1057	Room 29	DW	1/7/2026	6:49:00 AM

Samples Submitted 2

Pb 200.8 Bfthy 1/8/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 07 26, PM03:48

Pb 200.8 1/8/26

Building Address
77 Stahley Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: James Han 1/7/26

Signature: 3:48 PM

Samplers Name: Danielle Bolognese

Samplers Signature:

JCB Project Manager: Meghan Grogan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650063
LIMS Reference ID: EE50063
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Loretta Park Elementary School - Brentwood Union Free School District - 77 Stahley Street Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/07/2026 15:48
Reported: 01/09/2026 12:49

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2392		**Lims Reference ID:**		**EE50063-01**	**Matrix: Drinking Water**			**Sampled:**	**01/07/26 06:47:00**
Metals									
Lead	**31.9**		1	1.0	µg/L	01/08/26 11:41	01/08/26 11:41	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4028		**Lims Reference ID:**		**EE50063-02**	**Matrix: Drinking Water**			**Sampled:**	**01/07/26 06:49:00**
Metals									
Lead	**9.5**		1	1.0	µg/L	01/08/26 22:35	01/08/26 22:35	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650063
LIMS Reference ID: EE50063
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Loretta Park Elementary School - Brentwood Union Free School District - 77 Stahley Street Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/07/2026 15:48
Reported: 01/09/2026 12:49

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650063
LIMS Reference ID: EE50063
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Loretta Park Elementary School - Brentwood Union Free School District - 77 Stahley Street Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/07/2026 15:48
Reported: 01/09/2026 12:49

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE52509

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123
Building: Loretta Park Elementary School
LORE

Client: Brentwood Union Free School District
Retest/New Install ✓
Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4028	CR	1057	Room 29	DW	5/1/2026	7:09:00 AM

Samples Submitted 1

Walk In

Pb 200.8 Billing 5/3/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAY 01 26, PM08:32

Building Address
77 Stahley Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: 5/1/26 20:32
Signature: KATY HALTNER

Samplers Name: Danielle Bolognini
Samplers Signature:
JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652509
LIMS Reference ID: EE52509
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/01/2026 20:32
Reported: 05/04/2026 09:10

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4028			**Lims Reference ID:**	**EE52509-01**	**Matrix: Drinking Water**			**Sampled:**	**05/01/26 00:00:00**
Metals									
Lead	**1.7**		1	1.0	µg/L	05/03/26 12:02	05/03/26 12:02	BP	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652509
LIMS Reference ID: EE52509
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/01/2026 20:32
Reported: 05/04/2026 09:10

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	05/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062652509
LIMS Reference ID: EE52509
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Loretta Park Elementary School: 77 Stahley Street, Brentwood, NY 11717: Brentwood Union Free School District: Project# 26-64123
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 05/01/2026 20:32
Reported: 05/04/2026 09:10

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE54939

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Loretta Park Elementary School

LORE

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4329	HA	1038	Corridor Main Office To Maintenance	WF	10/19/2026	7:08:00 AM
BRTWD-4330	HA	1038	Corridor Main Office To Maintenance	WC	10/19/2026	7:09:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 20 26, PM12:58

Pb Test 10/20/26

Building Address
77 Stahley Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 10/20/26 10:58pm

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654939

LIMS Reference ID: EE54939

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: 26-64123 Loretta Park Elementary School, Brentwood Union Free School District, 77 Stahley Street, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/20/2026 12:58

Reported: 10/22/2026 16:03

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4329		**Lims Reference ID:**		**EE54939-01**	**Matrix: Drinking Water**				**Sampled: 10/19/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/22/26 15:20	10/22/26 15:20	HOK	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4330		**Lims Reference ID:**		**EE54939-02**	**Matrix: Drinking Water**				**Sampled: 10/19/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/22/26 15:21	10/22/26 15:21	HOK	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654939
LIMS Reference ID: EE54939
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: 26-64123 Loretta Park Elementary School, Brentwood Union Free School District, 77 Stahley Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/20/2026 12:58
Reported: 10/22/2026 16:03

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP ELLAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	11/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654939
LIMS Reference ID: EE54939
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: 26-64123 Loretta Park Elementary School, Brentwood Union Free School District, 77 Stahley Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/20/2026 12:58
Reported: 10/22/2026 16:03

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED533 13

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: Laurel Park Elementary School
LAUR

Client: Brentwood Union Free School District

Retest/New Install [ ]
Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2447	CR	1004	Room 2	DW	6/4/2025	6:41:00 AM
BRTWD-2450	CR	1006	Room 4	DW	6/4/2025	6:43:00 AM
BRTWD-2452	CR	1007	Room 3	DW	6/4/2025	6:45:00 AM
BRTWD-2457	CR	1010	Room 5	DW	6/4/2025	6:47:00 AM
BRTWD-2460	CR	1011	Room 8	DW	6/4/2025	6:49:00 AM
BRTWD-2462	CR	1012	Room 7	DW	6/4/2025	6:50:00 AM
BRTWD-2464	CR	1013	Room 10	DW	6/4/2025	6:51:00 AM
BRTWD-2466	CR	1014	Room 9	DW	6/4/2025	6:53:00 AM
BRTWD-2468	CR	1015	Room 12	DW	6/4/2025	6:54:00 AM
BRTWD-2470	CR	1016	Room 11	DW	6/4/2025	6:56:00 AM
BRTWD-2472	CR	1017	Room 14	DW	6/4/2025	6:59:00 AM
BRTWD-2474	CR	1018	Room 13	DW	6/4/2025	7:00:00 AM
BRTWD-2476	CR	1019	Room 16	DW	6/4/2025	7:02:00 AM
BRTWD-2478	CR	1020	Room 15	DW	6/4/2025	6:33:00 AM
BRTWD-2485	NO	1029	Nurse's Office	NS	6/4/2025	6:34:00 AM
BRTWD-2487	OF	1030A	Speech Therapist Office	OF	6/4/2025	6:25:00 AM
BRTWD-2489	FL	1035	Faculty Room	KC	6/4/2025	6:25:00 AM
BRTWD-2493	KI	1038	Kitchen	KC	6/4/2025	6:11:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25

Building Address
48 Swan Lane
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5
Lab Recieved: 6/13/25 21:17
Signature:

Samplers Name: Lexi Farwell
Samplers Signature:
JCB Project Manager: Meghan Grayson

Lead in Water: Chain of Custody for ED53313

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Laurel Park Elementary School

LAUR

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2494	KI	1038	Kitchen	KC	6/4/2025	6:11:00 AM
BRTWD-2496	KI	1038	Kitchen	HW	6/4/2025	6:20:00 AM
BRTWD-2497	KI	1038	Kitchen	KC	6/4/2025	6:15:00 AM
BRTWD-2499	KI	1038	Kitchen	KC	6/4/2025	6:16:00 AM
BRTWD-2500	KI	1038	Kitchen	KC	6/4/2025	6:18:00 AM
BRTWD-2501	KI	1038	Kitchen	HW	6/4/2025	6:13:00 AM
BRTWD-2505	CR	1041	Room 20	DW	6/4/2025	7:32:00 AM
BRTWD-2514	CR	1047	Room 17	DW	6/4/2025	7:30:00 AM
BRTWD-2516	CR	1048	Room 19	DW	6/4/2025	7:28:00 AM
BRTWD-2518	CR	1049	Room 22	DW	6/4/2025	7:27:00 AM
BRTWD-2520	CR	1051	Room 24	DW	6/4/2025	7:24:00 AM
BRTWD-2522	CR	1052	Room 23	DW	6/4/2025	7:22:00 AM
BRTWD-2524	CR	1053	Room 26	DW	6/4/2025	7:20:00 AM
BRTWD-2526	CR	1054	Room 25	DW	6/4/2025	7:16:00 AM
BRTWD-2528	CR	1055	Room 28	DW	6/4/2025	7:15:00 AM
BRTWD-2530	CR	1056	Room 27	DW	6/4/2025	7:13:00 AM
BRTWD-2532	CR	1057	Room 30	DW	6/4/2025	7:11:00 AM
BRTWD-2534	CR	1058	Room 29	DW	6/4/2025	7:10:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM09:17

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 21:17

Signature:

Samplers Name: Lexi Farwell

Samplers Signature:

JCB Project Manager: Meghan Guyon

Lead in Water: Chain of Custody for ED53313

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Laurel Park Elementary School

LAUR

Client: Brentwood Union Free School District

Retest/New Install | |

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2536	CR	N/A	Room 31	DW	6/4/2025	7:07:00 AM
BRTWD-3059	HA	1040	Corridor Near Kitchen (1038)	WC	6/4/2025	6:00:00 AM
BRTWD-3060	HA	1040	Corridor Near Kitchen (1038)	WF	6/4/2025	5:59:00 AM
BRTWD-3061	HA	1040	Corridor Near Gymnasium (1031B)	WC	6/4/2025	6:06:00 AM
BRTWD-3062	HA	1040	Corridor Near Gymnasium (1031B)	WF	6/4/2025	6:05:00 AM
BRTWD-3183	KI	1038	Kitchen	PK	6/4/2025	5:55:00 AM

Samples Submitted 42

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:17

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 @ 17

Signature:

Samplers Name: Lexi Farwell

Samplers Signature:

JCB Project Manager: Meghan Grayson

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553313

LIMS Reference ID: ED53313

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Laurel Park Elementary School: 48 Swan Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 21:17

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2447		**Lims Reference ID:**		**ED53313-01**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**6.2**		1	1.0	µg/L	06/17/25 17:24	06/17/25 17:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2450		**Lims Reference ID:**		**ED53313-02**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 17:25	06/17/25 17:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2452		**Lims Reference ID:**		**ED53313-03**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**1.9**		1	1.0	µg/L	06/17/25 17:29	06/17/25 17:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2457		**Lims Reference ID:**		**ED53313-04**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**3.9**		1	1.0	µg/L	06/17/25 17:30	06/17/25 17:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2460		**Lims Reference ID:**		**ED53313-05**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**4.9**		1	1.0	µg/L	06/17/25 17:34	06/17/25 17:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2462		**Lims Reference ID:**		**ED53313-06**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**1.7**		1	1.0	µg/L	06/17/25 17:36	06/17/25 17:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2464		**Lims Reference ID:**		**ED53313-07**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**4.4**		1	1.0	µg/L	06/17/25 17:37	06/17/25 17:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2466		**Lims Reference ID:**		**ED53313-08**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 17:38	06/17/25 17:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2468		**Lims Reference ID:**		**ED53313-09**	**Matrix: Drinking Water**			**Sampled:**	**06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553313
LIMS Reference ID: ED53313
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Laurel Park Elementary School: 48 Swan Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:17
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2468 (Continued)			**Lims Reference ID:**	**ED53313-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	3.0		1	1.0	µg/L	06/17/25 17:40	06/17/25 17:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2470			**Lims Reference ID:**	**ED53313-10**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/17/25 17:41	06/17/25 17:41	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2472			**Lims Reference ID:**	**ED53313-11**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	9.0		1	1.0	µg/L	06/17/25 17:42	06/17/25 17:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2474			**Lims Reference ID:**	**ED53313-12**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.7		1	1.0	µg/L	06/17/25 17:57	06/17/25 17:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2476			**Lims Reference ID:**	**ED53313-13**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 18:01	06/17/25 18:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2478			**Lims Reference ID:**	**ED53313-14**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	6.9		1	1.0	µg/L	06/17/25 18:02	06/17/25 18:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2485			**Lims Reference ID:**	**ED53313-15**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	06/17/25 18:04	06/17/25 18:04	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2487			**Lims Reference ID:**	**ED53313-16**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	5.9		1	1.0	µg/L	06/17/25 18:05	06/17/25 18:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2489			**Lims Reference ID:**	**ED53313-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553313
LIMS Reference ID: ED53313
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Laurel Park Elementary School: 48 Swan Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:17
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2489 (Continued)		**Lims Reference ID:**		**ED53313-17**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 18:09	06/17/25 18:09	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2493		**Lims Reference ID:**		**ED53313-18**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	4.6		1	1.0	µg/L	06/17/25 18:10	06/17/25 18:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2494		**Lims Reference ID:**		**ED53313-19**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/17/25 18:12	06/17/25 18:12	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2496		**Lims Reference ID:**		**ED53313-20**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.0		1	1.0	µg/L	06/17/25 18:13	06/17/25 18:13	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2497		**Lims Reference ID:**		**ED53313-21**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 18:14	06/17/25 18:14	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2499		**Lims Reference ID:**		**ED53313-22**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 18:16	06/17/25 18:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2500		**Lims Reference ID:**		**ED53313-23**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.7		1	1.0	µg/L	06/17/25 18:19	06/17/25 18:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2501		**Lims Reference ID:**		**ED53313-24**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	15.3		1	1.0	µg/L	06/17/25 18:21	06/17/25 18:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2505		**Lims Reference ID:**		**ED53313-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553313
LIMS Reference ID: ED53313
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Laurel Park Elementary School: 48 Swan Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:17
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2505 (Continued)		**Lims Reference ID:**		**ED53313-25**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	8.7		1	1.0	µg/L	06/17/25 18:25	06/17/25 18:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2514		**Lims Reference ID:**		**ED53313-26**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	6.2		1	1.0	µg/L	06/17/25 18:26	06/17/25 18:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2516		**Lims Reference ID:**		**ED53313-27**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	17.3		1	1.0	µg/L	06/17/25 18:27	06/17/25 18:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2518		**Lims Reference ID:**		**ED53313-28**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/17/25 18:29	06/17/25 18:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2520		**Lims Reference ID:**		**ED53313-29**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.8		1	1.0	µg/L	06/17/25 18:30	06/17/25 18:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2522		**Lims Reference ID:**		**ED53313-30**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.5		1	1.0	µg/L	06/17/25 18:31	06/17/25 18:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2524		**Lims Reference ID:**		**ED53313-31**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	3.0		1	1.0	µg/L	06/17/25 18:33	06/17/25 18:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2526		**Lims Reference ID:**		**ED53313-32**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 18:54	06/17/25 18:54	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2528		**Lims Reference ID:**		**ED53313-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553313
LIMS Reference ID: ED53313
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Laurel Park Elementary School: 48 Swan Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:17
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2528 (Continued)			**Lims Reference ID:**	**ED53313-33**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	1.5		1	1.0	µg/L	06/17/25 18:55	06/17/25 18:55	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2530			**Lims Reference ID:**	**ED53313-34**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	06/17/25 18:56	06/17/25 18:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2532			**Lims Reference ID:**	**ED53313-35**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	15.1		1	1.0	µg/L	06/17/25 19:00	06/17/25 19:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2534			**Lims Reference ID:**	**ED53313-36**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	6.2		1	1.0	µg/L	06/17/25 19:02	06/17/25 19:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2536			**Lims Reference ID:**	**ED53313-37**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 19:03	06/17/25 19:03	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3059			**Lims Reference ID:**	**ED53313-38**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 19:04	06/17/25 19:04	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3060			**Lims Reference ID:**	**ED53313-39**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 19:05	06/17/25 19:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3061			**Lims Reference ID:**	**ED53313-40**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 19:07	06/17/25 19:07	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3062			**Lims Reference ID:**	**ED53313-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553313
LIMS Reference ID: ED53313
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Laurel Park Elementary School: 48 Swan Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:17
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3062 (Continued)			**Lims Reference ID:**	**ED53313-41**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 19:11	06/17/25 19:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3183			**Lims Reference ID:**	**ED53313-42**	**Matrix: Drinking Water**				**Sampled: 06/13/25 00:00:00**
Metals									
Lead	**7.9**		1	1.0	µg/L	06/17/25 19:12	06/17/25 19:12	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553313
LIMS Reference ID: ED53313
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Laurel Park Elementary School: 48 Swan Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:17
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553313
LIMS Reference ID: ED53313
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Laurel Park Elementary School: 48 Swan Lane, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:17
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED 55317

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Laurel Park Elementary School

LAUR

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3972	CR	1020	Room 15	DW	8/20/2025	7:04:00 AM
BRTWD-3974	CR	1019	Room 16	DW	8/20/2025	7:07:00 AM
BRTWD-3976	CR	1018	Room 13	DW	8/20/2025	7:09:00 AM
BRTWD-3978	CR	1017	Room 14	DW	8/20/2025	7:11:00 AM
BRTWD-3980	CR	1016	Room 11	DW	8/20/2025	7:12:00 AM
BRTWD-3982	CR	1015	Room 12	DW	8/20/2025	7:13:00 AM
BRTWD-3984	CR	1014	Room 9	DW	8/20/2025	7:15:00 AM
BRTWD-3986	CR	1013	Room 10	DW	8/20/2025	7:16:00 AM
BRTWD-3988	CR	1012	Room 7	DW	8/20/2025	7:17:00 AM
BRTWD-3990	CR	1011	Room 8	DW	8/20/2025	7:19:00 AM
BRTWD-3992	CR	1010	Room 5	DW	8/20/2025	7:21:00 AM
BRTWD-3994	CR	1008	Room 6	DW	8/20/2025	7:23:00 AM
BRTWD-3996	CR	1007	Room 3	DW	8/20/2025	7:25:00 AM
BRTWD-3998	CR	1006	Room 4	DW	8/20/2025	7:27:00 AM
BRTWD-4000	CR	1004	Kindergarten Room 2	DW	8/20/2025	7:29:00 AM
BRTWD-4002	CR	1003	Kindergarten Room 1	DW	8/20/2025	7:31:00 AM
BRTWD-4004	CR	1047	Room 17	DW	8/20/2025	7:37:00 AM
BRTWD-4006	CR	1048	Room 19	DW	8/20/2025	7:40:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 20 25, PM03:45

Building Address
48 Swan Lane
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/20/25 3:45 pm

Signature: David Wharton

Samplers Name: Danielle Belegrinis

Samplers Signature:

JCB Project Manager: Meghan Gurgo

Lead in Water: Chain of Custody for ED55317

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Laurel Park Elementary School

LAUR

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk Rush 48hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4008	CR	1049	Room 22	DW	8/20/2025	7:42:00 AM
BRTWD-4010	CR	1050	Computer Lab Room 21	DW	8/20/2025	7:44:00 AM
BRTWD-4012	CR	1051	Room 24	DW	8/20/2025	7:46:00 AM
BRTWD-4014	CR	1052	Room 23	DW	8/20/2025	7:48:00 AM
BRTWD-4016	CR	1053	Room 26	DW	8/20/2025	7:50:00 AM
BRTWD-4018	CR	1054	Room 25	DW	8/20/2025	7:52:00 AM
BRTWD-4020	CR	1055	Room 28	DW	8/20/2025	7:54:00 AM
BRTWD-4022	CR	1056	Room 27	DW	8/20/2025	7:55:00 AM
BRTWD-4024	CR	1058	Room 29	DW	8/20/2025	7:59:00 AM
BRTWD-4026	CR	1057	Room 30	DW	8/20/2025	8:01:00 AM

Samples Submitted 28

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
AUG 20 25, PM03:45

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/20/25 3:45pm

Signature: David Wharton

Samplers Name: Danielle Bolognino

Samplers Signature: Danielle Bolognino

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555317

LIMS Reference ID: ED55317

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Laurel Park Elementary School LAUR, 48 Swan Lane, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/20/2025 15:45

Reported: 08/22/2025 16:15

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3972		**Lims Reference ID:**		**ED55317-01**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**3.5**	1	1.0	µg/L	08/22/25 14:34	08/22/25 14:34	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3974		**Lims Reference ID:**		**ED55317-02**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**4.0**	1	1.0	µg/L	08/22/25 14:38	08/22/25 14:38	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3976		**Lims Reference ID:**		**ED55317-03**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**2.6**	1	1.0	µg/L	08/22/25 14:40	08/22/25 14:40	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3978		**Lims Reference ID:**		**ED55317-04**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**4.2**	1	1.0	µg/L	08/22/25 14:41	08/22/25 14:41	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3980		**Lims Reference ID:**		**ED55317-05**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**4.4**	1	1.0	µg/L	08/22/25 14:45	08/22/25 14:45	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3982		**Lims Reference ID:**		**ED55317-06**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**3.9**	1	1.0	µg/L	08/22/25 14:46	08/22/25 14:46	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3984		**Lims Reference ID:**		**ED55317-07**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**4.4**	1	1.0	µg/L	08/22/25 14:48	08/22/25 14:48	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3986		**Lims Reference ID:**		**ED55317-08**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**6.9**	1	1.0	µg/L	08/22/25 14:49	08/22/25 14:49	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3988		**Lims Reference ID:**		**ED55317-09**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555317
LIMS Reference ID: ED55317
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Laurel Park Elementary School LAUR, 48 Swan Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/20/2025 15:45
Reported: 08/22/2025 16:15

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3988 (Continued)			**Lims Reference ID:**	**ED55317-09**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals (Continued)									
Lead	5.3		1	1.0	µg/L	08/22/25 14:50	08/22/25 14:50	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3990			**Lims Reference ID:**	**ED55317-10**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	3.9		1	1.0	µg/L	08/22/25 14:52	08/22/25 14:52	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3992			**Lims Reference ID:**	**ED55317-11**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	5.9		1	1.0	µg/L	08/22/25 14:53	08/22/25 14:53	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3994			**Lims Reference ID:**	**ED55317-12**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	5.9		1	1.0	µg/L	08/22/25 14:57	08/22/25 14:57	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3996			**Lims Reference ID:**	**ED55317-13**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	13.7		1	1.0	µg/L	08/22/25 15:01	08/22/25 15:01	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3998			**Lims Reference ID:**	**ED55317-14**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	4.1		1	1.0	µg/L	08/22/25 15:02	08/22/25 15:02	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4000			**Lims Reference ID:**	**ED55317-15**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	18.8		1	1.0	µg/L	08/22/25 15:03	08/22/25 15:03	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4002			**Lims Reference ID:**	**ED55317-16**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	5.1		1	1.0	µg/L	08/22/25 15:05	08/22/25 15:05	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4004			**Lims Reference ID:**	**ED55317-17**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555317
LIMS Reference ID: ED55317
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Laurel Park Elementary School LAUR, 48 Swan Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/20/2025 15:45
Reported: 08/22/2025 16:15

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4004 (Continued)		**Lims Reference ID:**		**ED55317-17**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals (Continued)									
Lead	**15.9**		1	1.0	µg/L	08/22/25 11:40	08/22/25 11:40	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4006		**Lims Reference ID:**		**ED55317-18**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**9.0**		1	1.0	µg/L	08/22/25 15:06	08/22/25 15:06	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4008		**Lims Reference ID:**		**ED55317-19**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**6.6**		1	1.0	µg/L	08/22/25 15:07	08/22/25 15:07	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4010		**Lims Reference ID:**		**ED55317-20**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**7.9**		1	1.0	µg/L	08/22/25 15:09	08/22/25 15:09	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4012		**Lims Reference ID:**		**ED55317-21**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**9.4**		1	1.0	µg/L	08/22/25 15:10	08/22/25 15:10	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4014		**Lims Reference ID:**		**ED55317-22**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**4.7**		1	1.0	µg/L	08/22/25 15:26	08/22/25 15:26	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4016		**Lims Reference ID:**		**ED55317-23**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**35.9**		1	1.0	µg/L	08/22/25 15:30	08/22/25 15:30	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4018		**Lims Reference ID:**		**ED55317-24**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**6.6**		1	1.0	µg/L	08/22/25 15:32	08/22/25 15:32	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4020		**Lims Reference ID:**		**ED55317-25**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555317
LIMS Reference ID: ED55317
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Laurel Park Elementary School LAUR, 48 Swan Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/20/2025 15:45
Reported: 08/22/2025 16:15

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4020 (Continued)			**Lims Reference ID:**	**ED55317-25**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals (Continued)									
Lead	**6.0**		1	1.0	µg/L	08/22/25 15:33	08/22/25 15:33	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4022			**Lims Reference ID:**	**ED55317-26**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**9.7**		1	1.0	µg/L	08/22/25 15:37	08/22/25 15:37	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4024			**Lims Reference ID:**	**ED55317-27**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**5.6**		1	1.0	µg/L	08/22/25 15:38	08/22/25 15:38	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4026			**Lims Reference ID:**	**ED55317-28**	**Matrix: Drinking Water**				**Sampled: 08/20/25 00:00:00**
Metals									
Lead	**6.4**		1	1.0	µg/L	08/22/25 15:40	08/22/25 15:40	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555317
LIMS Reference ID: ED55317
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Laurel Park Elementary School LAUR, 48 Swan Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/20/2025 15:45
Reported: 08/22/2025 16:15

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555317
LIMS Reference ID: ED55317
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Laurel Park Elementary School LAUR, 48 Swan Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/20/2025 15:45
Reported: 08/22/2025 16:15

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED555586

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Client: Brentwood Union Free School District

Building: Laurel Park Elementary School

LAUR

Retest/New Install [✓]

Turn Around: Normal 1 wk Rush 48hour

RECEIVED
ENGL ANALYTICAL, INC.
Carle Place, NY
AUG 29 25, PM01:24

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3986	CR	1013	Room 10	DW	8/29/2025	8:35:00 AM
BRTWD-3988	CR	1012	Room 7	DW	8/29/2025	8:36:00 AM
BRTWD-3992	CR	1010	Room 5	DW	8/29/2025	8:37:00 AM
BRTWD-3994	CR	1008	Room 6	DW	8/29/2025	8:31:00 AM
BRTWD-3996	CR	1007	Room 3	DW	8/29/2025	8:39:00 AM
BRTWD-4000	CR	1004	Kindergarten Room 2	DW	8/29/2025	8:41:00 AM
BRTWD-4002	CR	1003	Kindergarten Room 1	DW	8/29/2025	8:41:00 AM
BRTWD-4004	CR	1047	Room 17	DW	8/29/2025	8:27:00 AM
BRTWD-4006	CR	1048	Room 19	DW	8/29/2025	8:26:00 AM
BRTWD-4008	CR	1049	Room 22	DW	8/29/2025	8:25:00 AM
BRTWD-4010	CR	1050	Computer Lab Room 21	DW	8/29/2025	8:24:00 AM
BRTWD-4012	CR	1051	Room 24	DW	8/29/2025	8:23:00 AM
BRTWD-4016	CR	1053	Room 26	DW	8/29/2025	8:22:00 AM
BRTWD-4018	CR	1054	Room 25	DW	8/29/2025	8:19:00 AM
BRTWD-4020	CR	1055	Room 28	DW	8/29/2025	8:18:00 AM
BRTWD-4022	CR	1056	Room 27	DW	8/29/2025	8:17:00 AM
BRTWD-4024	CR	1058	Room 29	DW	8/29/2025	8:16:00 AM
BRTWD-4026	CR	1057	Room 30	DW	8/29/2025	8:15:00 AM

COURIER

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Abigail Minnfield

Signature: A. Minnfield
8/29/25 1:24pm

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Guyon

Lead in Water: Chain of Custody for ED555586

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: Laurel Park Elementary School
LAUR

Client: Brentwood Union Free School District
Retest/New Install [✓]
Turn Around: Normal 1 wk **Rush** 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time

Samples Submitted 18

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
AUG 29 25, PM01:24

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: A. Minnifield / A. Murphy
Signature: A. Murphy
8/29/25 1:24pm

Samplers Name: Danielle Belogenis
Samplers Signature: Dan
JCB Project Manager: Meghan Bunyan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555586

LIMS Reference ID: ED55586

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Laurel Park Elementary School, LAUR, Brentwood Union Free School District, 48 Swan Lane, Brentwood NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/29/2025 13:24

Reported: 08/30/2025 14:52

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3986			**Lims Reference ID:**	**ED55586-01**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**2.6**		1	1.0	µg/L	08/30/25 13:16	08/30/25 13:16	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3988			**Lims Reference ID:**	**ED55586-02**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**1.5**		1	1.0	µg/L	08/30/25 13:20	08/30/25 13:20	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3992			**Lims Reference ID:**	**ED55586-03**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**1.8**		1	1.0	µg/L	08/30/25 13:21	08/30/25 13:21	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3994			**Lims Reference ID:**	**ED55586-04**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**2.6**		1	1.0	µg/L	08/30/25 13:23	08/30/25 13:23	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3996			**Lims Reference ID:**	**ED55586-05**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**2.8**		1	1.0	µg/L	08/30/25 13:24	08/30/25 13:24	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4000			**Lims Reference ID:**	**ED55586-06**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**7.7**		1	1.0	µg/L	08/30/25 13:28	08/30/25 13:28	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4002			**Lims Reference ID:**	**ED55586-07**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**2.5**		1	1.0	µg/L	08/30/25 13:29	08/30/25 13:29	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4004			**Lims Reference ID:**	**ED55586-08**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**3.2**		1	1.0	µg/L	08/30/25 13:31	08/30/25 13:31	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4006			**Lims Reference ID:**	**ED55586-09**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555586
LIMS Reference ID: ED55586
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Laurel Park Elementary School, LAUR, Brentwood Union Free School District, 48 Swan Lane, Brentwood NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/29/2025 13:24
Reported: 08/30/2025 14:52

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4006 (Continued)			**Lims Reference ID:**	**ED55586-09**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals (Continued)									
Lead	2.3		1	1.0	µg/L	08/30/25 13:32	08/30/25 13:32	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4008			**Lims Reference ID:**	**ED55586-10**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	8.7		1	1.0	µg/L	08/30/25 13:33	08/30/25 13:33	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4010			**Lims Reference ID:**	**ED55586-11**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	4.5		1	1.0	µg/L	08/30/25 13:35	08/30/25 13:35	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4012			**Lims Reference ID:**	**ED55586-12**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	5.9		1	1.0	µg/L	08/30/25 13:38	08/30/25 13:38	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4016			**Lims Reference ID:**	**ED55586-13**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	9.4		1	1.0	µg/L	08/30/25 13:40	08/30/25 13:40	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4018			**Lims Reference ID:**	**ED55586-14**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	2.4		1	1.0	µg/L	08/30/25 13:44	08/30/25 13:44	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4020			**Lims Reference ID:**	**ED55586-15**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	4.7		1	1.0	µg/L	08/30/25 13:45	08/30/25 13:45	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4022			**Lims Reference ID:**	**ED55586-16**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	3.6		1	1.0	µg/L	08/30/25 13:46	08/30/25 13:46	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4024			**Lims Reference ID:**	**ED55586-17**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555586
LIMS Reference ID: ED55586
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Laurel Park Elementary School, LAUR, Brentwood Union Free School District, 48 Swan Lane, Brentwood NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/29/2025 13:24
Reported: 08/30/2025 14:52

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4024 (Continued)			**Lims Reference ID:**	**ED55586-17**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals (Continued)									
Lead	**3.8**		1	1.0	µg/L	08/30/25 13:48	08/30/25 13:48	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4026			**Lims Reference ID:**	**ED55586-18**	**Matrix: Drinking Water**				**Sampled: 08/29/25 00:00:00**
Metals									
Lead	**2.5**		1	1.0	µg/L	08/30/25 13:49	08/30/25 13:49	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555586
LIMS Reference ID: ED55586
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Laurel Park Elementary School, LAUR, Brentwood Union Free School District, 48 Swan Lane, Brentwood NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/29/2025 13:24
Reported: 08/30/2025 14:52

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555586
LIMS Reference ID: ED55586
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Laurel Park Elementary School, LAUR, Brentwood Union Free School District, 48 Swan Lane, Brentwood NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/29/2025 13:24
Reported: 08/30/2025 14:52

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED55950

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Laurel Park Elementary School

LAUR

Client: Brentwood Union Free School District

Retest/New Install [✓]

Turn Around: Normal 1 wk **Rush** 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4000	CR	1004	Kindergarten Room 2	DW	9/17/2025	7:10:00 AM
BRTWD-4008	CR	1049	Room 22	DW	9/17/2025	7:04:00 AM
BRTWD-4012	CR	1051	Room 24	DW	9/17/2025	7:05:00 AM
BRTWD-4016	CR	1053	Room 26	DW	9/17/2025	7:06:00 AM

Samples Submitted 4

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
SEP 17 25, PM01:18

Courier

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Abigail Minnfield

Signature: A. Minnfield
9-17-25 1:18 pm

Samplers Name: Meghan Guynn

Samplers Signature: Meghan Guynn

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555950

LIMS Reference ID: ED55950

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 , Laurel Park Elementary School, LAUR, Brentwood Union Free School District, 48 Swan Lane, Brentwood NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/17/2025 13:18

Reported: 09/18/2025 13:49

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4000		**Lims Reference ID:**		**ED55950-01**	**Matrix: Drinking Water**				**Sampled: 09/17/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/18/25 12:34	09/18/25 12:34	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4008		**Lims Reference ID:**		**ED55950-02**	**Matrix: Drinking Water**				**Sampled: 09/17/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/18/25 12:36	09/18/25 12:36	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4012		**Lims Reference ID:**		**ED55950-03**	**Matrix: Drinking Water**				**Sampled: 09/17/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/18/25 12:37	09/18/25 12:37	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4016		**Lims Reference ID:**		**ED55950-04**	**Matrix: Drinking Water**				**Sampled: 09/17/25 00:00:00**
Metals									
Lead	**5.8**		1	1.0	µg/L	09/18/25 12:38	09/18/25 12:38	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555950

LIMS Reference ID: ED55950

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 , Laurel Park Elementary School, LAUR, Brentwood Union Free School District, 48 Swan Lane, Brentwood NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/17/2025 13:18

Reported: 09/18/2025 13:49

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555950

LIMS Reference ID: ED55950

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 , Laurel Park Elementary School, LAUR, Brentwood Union Free School District, 48 Swan Lane, Brentwood NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/17/2025 13:18

Reported: 09/18/2025 13:49

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for E056703

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Laurel Park Elementary School

LAUR

Client: Brentwood Union Free School District

Retest/New Install [Y]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4016	CR	1053	Room 26	DW	10/23/2025	7:18:00 AM

Samples Submitted 1

Courier

Pb 200.8 10/24/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 23 25, PM12:22

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Jones/tm 10/23/25

Signature: 1223PM

Samplers Name: Meghan Guynn

Samplers Signature: Meghan Guynn

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556703

LIMS Reference ID: ED56703

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Laurel Park Elementary School LAUR - Brentwood Union Free School District - 48 Swan Lane Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/23/2025 12:22

Reported: 10/25/2025 10:55

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4016			**Lims Reference ID:**	**ED56703-01**	**Matrix: Drinking Water**			**Sampled:**	**10/23/25 07:18:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/24/25 16:31	10/24/25 16:31	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556703

LIMS Reference ID: ED56703

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Laurel Park Elementary School LAUR - Brentwood Union Free School District - 48 Swan Lane Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/23/2025 12:22

Reported: 10/25/2025 10:55

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556703

LIMS Reference ID: ED56703

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Laurel Park Elementary School LAUR - Brentwood Union Free School District - 48 Swan Lane Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/23/2025 12:22

Reported: 10/25/2025 10:55

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED51873

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Laurel Park Elementary School

LAUR

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2487	OF	1030A	Speech Therapist Office	OF	12/23/2025	7:08:00 AM
BRTWD-2501	KI	1038	Kitchen	HW	12/23/2025	7:02:00 AM
BRTWD-3183	KI	1038	Kitchen	PK	12/23/2025	7:01:00 AM

Samples Submitted 3

Pb 200.8 Billing 12/24/25

Pb 200.8
Kathleen
12/26/25

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:14

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/23/25 2:14 PM

Signature:

Samplers Name: Danielle Belegianni

Samplers Signature:

JCB Project Manager: Meghan Bergan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557873

LIMS Reference ID: ED57873

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Laurel Park Elementary School LAUR / 48 Swan Lane, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:14

Reported: 12/26/2025 16:30

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2487		**Lims Reference ID:**		**ED57873-01**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**58.4**		1	1.0	µg/L	12/24/25 11:16	12/24/25 11:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2501		**Lims Reference ID:**		**ED57873-02**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**19.4**		1	1.0	µg/L	12/26/25 15:50	12/26/25 15:50	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-3183		**Lims Reference ID:**		**ED57873-03**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**2.8**		1	1.0	µg/L	12/24/25 11:17	12/24/25 11:17	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557873

LIMS Reference ID: ED57873

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Laurel Park Elementary School LAUR / 48 Swan Lane, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:14

Reported: 12/26/2025 16:30

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557873

LIMS Reference ID: ED57873

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Laurel Park Elementary School LAUR / 48 Swan Lane, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:14

Reported: 12/26/2025 16:30

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EDS7965

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Laurel Park Elementary School

LAUR

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk Rush 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2501	KI	1038	Kitchen	HW	12/30/2025	7:20:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:36

Pb 200.8
Kathleen 12/31/25

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Jon Cull 12/30/25 4:36PM

Signature: [signature]

Samplers Name: Danielle Calogero

Samplers Signature: [signature]

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557965
LIMS Reference ID: ED57965
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 48 Swan Lane Brentwood NY 11717, Laurel Park Elementary School, JCB#: 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:36
Reported: 12/31/2025 15:30

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2501			**Lims Reference ID:**	**ED57965-01**	**Matrix: Drinking Water**			**Sampled:**	**12/30/25 07:20:00**
Metals									
Lead	**6.9**		1	1.0	µg/L	12/31/25 13:49	12/31/25 13:49	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557965
LIMS Reference ID: ED57965
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 48 Swan Lane Brentwood NY 11717, Laurel Park Elementary School, JCB#: 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:36
Reported: 12/31/2025 15:30

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557965
LIMS Reference ID: ED57965
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 48 Swan Lane Brentwood NY 11717, Laurel Park Elementary School, JCB#: 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/30/2025 16:36
Reported: 12/31/2025 15:30

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Laurel Park Elementary School

LAUR

Walk In

Client: EE50068

Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2501	KI	1038	Kitchen	HW	1/7/2026	6:55:00 AM
BRTWD-4271	CR	1041	Room 20	DW	1/7/2026	6:58:00 AM

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 07 26, PM03:47

Pb 200.8 Bllng 1/8/26

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 1/7/26 3:47pm

Signature: David Wharton

Samplers Name: Danielle Bolognini

Samplers Signature: Danielle

JCB Project Manager: Meghan Bergen

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650068
LIMS Reference ID: EE50068
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Laurel Park Elementary School LAUR / 48 Swan Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/07/2026 15:47
Reported: 01/08/2026 12:21

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2501			**Lims Reference ID:**		**EE50068-01**	**Matrix: Drinking Water**			**Sampled: 01/07/26 00:00:00**
Metals									
Lead	**8.5**		1	1.0	µg/L	01/08/26 11:46	01/08/26 11:46	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4271			**Lims Reference ID:**		**EE50068-02**	**Matrix: Drinking Water**			**Sampled: 01/07/26 00:00:00**
Metals									
Lead	**3.7**		1	1.0	µg/L	01/08/26 11:48	01/08/26 11:48	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650068
LIMS Reference ID: EE50068
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Laurel Park Elementary School LAUR / 48 Swan Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/07/2026 15:47
Reported: 01/08/2026 12:21

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650068
LIMS Reference ID: EE50068
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Laurel Park Elementary School LAUR / 48 Swan Lane, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/07/2026 15:47
Reported: 01/08/2026 12:21

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EES0865

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Laurel Park Elementary School

LAUR

Client: Brentwood Union Free School District

Retest/New Install ✓

Turn Around: Normal 1 wk (Rush) 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2501	KI	1038	Kitchen	HW	2/18/2026	7:55:00 AM

Samples Submitted 1

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 18 26, PM01:52

No Dous on 2/19/26

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Sega Cook 02/18/26 1:52PM

Signature:

Samplers Name: Danielle Bolognese

Samplers Signature:

JCB Project Manager: Meghan Gurgan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650865
LIMS Reference ID: EE50865
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Laurel Park Elementary School, 48 Swan Lane Brentwood NY 11717, JCB#:23-53744, Brentwood Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/18/2026 13:52
Reported: 02/19/2026 09:06

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2501			**Lims Reference ID:**	**EE50865-01**	**Matrix: Drinking Water**			**Sampled:**	**02/18/26 00:00:00**
Metals									
Lead	**23.2**		1	1.0	µg/L	02/19/26 01:16	02/19/26 01:16	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650865
LIMS Reference ID: EE50865
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Laurel Park Elementary School, 48 Swan Lane Brentwood NY 11717, JCB#:23-53744, Brentwood Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/18/2026 13:52
Reported: 02/19/2026 09:06

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650865
LIMS Reference ID: EE50865
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Laurel Park Elementary School, 48 Swan Lane Brentwood NY 11717, JCB#:23-53744, Brentwood Union Free School District
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	02/18/2026 13:52
Reported:	02/19/2026 09:06

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE53867

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Laurel Park Elementary School

LAUR

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4308	HA	1040	Corridor Near Kitchen (1038)	WF	8/4/2026	8:16:00 AM
BRTWD-4309	HA	1040	Corridor Near Kitchen (1038)	WC	8/4/2026	8:16:00 AM

Samples Submitted 2

Courier

Pb 200.8 BHung 8/5/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 04 26, PM01:05

Building Address
48 Swan Lane
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/4/26 1:05PM

Signature:

Samplers Name: Danielle Belegnini

Samplers Signature:

JCB Project Manager: Danielle Belegnini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653867

LIMS Reference ID: EE53867

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Laurel Park Elementary School LAUR, 48 Swan Lane, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/04/2026 13:05

Reported: 08/05/2026 15:42

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4308		**Lims Reference ID:**		**EE53867-01**	**Matrix: Drinking Water**				**Sampled: 08/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/05/26 12:32	08/05/26 12:32	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4309		**Lims Reference ID:**		**EE53867-02**	**Matrix: Drinking Water**				**Sampled: 08/04/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/05/26 12:37	08/05/26 12:37	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653867
LIMS Reference ID: EE53867
EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	Laurel Park Elementary School LAUR, 48 Swan Lane, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/04/2026 13:05
Reported:	08/05/2026 15:42

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653867

LIMS Reference ID: EE53867

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	Laurel Park Elementary School LAUR, 48 Swan Lane, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/04/2026 13:05
Reported:	08/05/2026 15:42

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654406

LIMS Reference ID: EE54406

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: #26-64123, Brentwood Union Free School District, Laurel Park Elementary School, 48 Swan Lane, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/04/2026 14:25

Reported: 09/08/2026 09:05

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4326		**Lims Reference ID:**		**EE54406-01**	**Matrix: Drinking Water**				**Sampled: 09/04/26 08:03:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/05/26 18:27	09/05/26 18:27	DAZ	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4327		**Lims Reference ID:**		**EE54406-02**	**Matrix: Drinking Water**				**Sampled: 09/04/26 08:03:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/05/26 18:29	09/05/26 18:29	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654406

LIMS Reference ID: EE54406

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: #26-64123, Brentwood Union Free School District, Laurel Park Elementary School, 48 Swan Lane, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/04/2026 14:25

Reported: 09/08/2026 09:05

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654406

LIMS Reference ID: EE54406

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	#26-64123, Brentwood Union Free School District, Laurel Park Elementary School, 48 Swan Lane, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	09/04/2026 14:25
Reported:	09/08/2026 09:05

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED53302

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Kindergarten Center

EKC

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2549	CR	N/A	Room 1	DW	6/10/2025	6:15:00 AM
BRTWD-2552	CR	N/A	Room 2	DW	6/10/2025	6:10:00 AM
BRTWD-2556	CR	N/A	Room 3	DW	6/10/2025	6:18:00 AM
BRTWD-2558	CR	N/A	Room 4	DW	6/10/2025	6:19:00 AM
BRTWD-2562	CR	N/A	Room 5	DW	6/10/2025	6:20:00 AM
BRTWD-2565	CR	N/A	Room 6	DW	6/10/2025	6:20:00 AM
BRTWD-2573	CR	1003	Room 8	DW	6/10/2025	6:25:00 AM
BRTWD-2575	CR	1004	Room 9	DW	6/10/2025	6:27:00 AM
BRTWD-2577	CR	1005	Room 10	DW	6/10/2025	6:28:00 AM
BRTWD-2579	CR	1006	Room 11	DW	6/10/2025	6:29:00 AM
BRTWD-2581	CR	1007	Room 12	DW	6/10/2025	6:31:00 AM
BRTWD-2583	CR	1008	Room 13	DW	6/10/2025	6:32:00 AM
BRTWD-2585	CR	1011	Room 15	DW	6/10/2025	6:34:00 AM
BRTWD-2587	CR	1014	Room 17	DW	6/10/2025	6:35:00 AM
BRTWD-2589	CR	1015	Room 20	DW	6/10/2025	6:36:00 AM
BRTWD-2592	CR	1018	Room 22	DW	6/10/2025	6:39:00 AM
BRTWD-2597	NO	1031	Nurse's Office	NS	6/10/2025	6:45:00 AM
BRTWD-2600	FL	1037	Faculty Room	KC	6/10/2025	6:41:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:00

Building Address
50 Timberline Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: AStanley 6/13/25

Signature: 9:30pm

Samplers Name: Tiffany Chen

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EDS3302

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Kindergarten Center

EKC

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2602	KI	1041	Kitchen	KC	6/10/2025	6:00:00 AM
BRTWD-2603	KI	1041	Kitchen	KC	6/10/2025	6:01:00 AM
BRTWD-2604	KI	1041	Kitchen	HW	6/10/2025	5:59:00 AM
BRTWD-2606	KI	1041	Kitchen	KC	6/10/2025	6:04:00 AM
BRTWD-2607	KI	1041	Kitchen	KC	6/10/2025	6:04:00 AM
BRTWD-2609	KI	1041	Kitchen	KC	6/10/2025	6:05:00 AM
BRTWD-2624	CR	1053	Room 31	DW	6/10/2025	6:48:00 AM
BRTWD-2626	CR	1054	Room 34	DW	6/10/2025	6:49:00 AM
BRTWD-2628	CR	1055	Room 33	DW	6/10/2025	6:51:00 AM
BRTWD-2630	CR	1056	Room 36	DW	6/10/2025	6:53:00 AM
BRTWD-2636	CR	1060	Room 40	DW	6/10/2025	6:57:00 AM
BRTWD-2638	CR	1061	Room 39	DW	6/10/2025	6:58:00 AM
BRTWD-2640	CR	1062	Room 42	DW	6/10/2025	7:00:00 AM
BRTWD-2646	CR	N/A	Room 46	DW	6/10/2025	7:03:00 AM
BRTWD-2650	CR	N/A	Room 47	DW	6/10/2025	7:07:00 AM
BRTWD-3071	HA	1044	Corridor Near Faculty Room (1037)	WC	6/10/2025	6:45:00 AM
BRTWD-3072	HA	1044	Corridor Near Faculty Room (1037)	WF	6/10/2025	6:44:00 AM
BRTWD-3073	HA	1025	Corridor Near Room 19 (1016)	WC	6/10/2025	6:38:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25 PM09:08

Building Address
50 Timberline Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: ASTanley 6/13/25

Signature: 9:00pm

Samplers Name: Tiffany Cea

Samplers Signature:

JCB Project Manager: Meghan Gwynn

E053300

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Kindergarten Center

EKC

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3074	HA	1025	Corridor Near Room 19 (1016)	WF	6/10/2025	6:38:00 AM
BRTWD-3271	KI	1041	Kitchen	PK	6/10/2025	6:03:00 AM
BRTWD-3280	CR	1057	Room 35	DW	6/10/2025	6:54:00 AM

Samples Submitted 39

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM09:00

Building Address
50 Timberline Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/18/25

Signature: 9:02pm

Samplers Name: Tiffany Chen

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553300

LIMS Reference ID: ED53300

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Kindergarten Center, EKC, Brentwood Union Free School District, 50 Timberline Drive, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 21:00

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2549		**Lims Reference ID:**		**ED53300-01**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 15:09	06/16/25 15:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2552		**Lims Reference ID:**		**ED53300-02**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 15:10	06/16/25 15:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2556		**Lims Reference ID:**		**ED53300-03**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 15:12	06/16/25 15:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2558		**Lims Reference ID:**		**ED53300-04**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 15:13	06/16/25 15:13	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2562		**Lims Reference ID:**		**ED53300-05**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	2.5		1	1.0	µg/L	06/16/25 15:17	06/16/25 15:17	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2565		**Lims Reference ID:**		**ED53300-06**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	06/16/25 15:18	06/16/25 15:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2573		**Lims Reference ID:**		**ED53300-07**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 15:22	06/16/25 15:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2575		**Lims Reference ID:**		**ED53300-08**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	4.4		1	1.0	µg/L	06/16/25 15:23	06/16/25 15:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2577		**Lims Reference ID:**		**ED53300-09**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553300
LIMS Reference ID: ED53300
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Kindergarten Center, EKC, Brentwood Union Free School District, 50 Timberline Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2577 (Continued)		**Lims Reference ID:**		**ED53300-09**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals (Continued)									
Lead	14.1		1	1.0	µg/L	06/16/25 15:25	06/16/25 15:25	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2579		**Lims Reference ID:**		**ED53300-10**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	7.2		1	1.0	µg/L	06/16/25 15:26	06/16/25 15:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2581		**Lims Reference ID:**		**ED53300-11**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 15:27	06/16/25 15:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2583		**Lims Reference ID:**		**ED53300-12**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	3.5		1	1.0	µg/L	06/16/25 15:29	06/16/25 15:29	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2585		**Lims Reference ID:**		**ED53300-13**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	3.9		1	1.0	µg/L	06/16/25 15:30	06/16/25 15:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2587		**Lims Reference ID:**		**ED53300-14**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 15:45	06/16/25 15:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2589		**Lims Reference ID:**		**ED53300-15**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	12.1		1	1.0	µg/L	06/16/25 15:49	06/16/25 15:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2592		**Lims Reference ID:**		**ED53300-16**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	2.0		1	1.0	µg/L	06/16/25 15:50	06/16/25 15:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2597		**Lims Reference ID:**		**ED53300-17**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553300
LIMS Reference ID: ED53300
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Kindergarten Center, EKC, Brentwood Union Free School District, 50 Timberline Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2597 (Continued)		**Lims Reference ID:**		**ED53300-17**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/16/25 15:52	06/16/25 15:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2600		**Lims Reference ID:**		**ED53300-18**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 15:53	06/16/25 15:53	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2602		**Lims Reference ID:**		**ED53300-19**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	06/16/25 15:57	06/16/25 15:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2603		**Lims Reference ID:**		**ED53300-20**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 15:58	06/16/25 15:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2604		**Lims Reference ID:**		**ED53300-21**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 16:00	06/16/25 16:00	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2606		**Lims Reference ID:**		**ED53300-22**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 16:01	06/16/25 16:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2607		**Lims Reference ID:**		**ED53300-23**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	2.2		1	1.0	µg/L	06/16/25 16:02	06/16/25 16:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2609		**Lims Reference ID:**		**ED53300-24**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	2.9		1	1.0	µg/L	06/16/25 16:04	06/16/25 16:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2624		**Lims Reference ID:**		**ED53300-25**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553300
LIMS Reference ID: ED53300
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Kindergarten Center, EKC, Brentwood Union Free School District, 50 Timberline Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2624 (Continued)		**Lims Reference ID:**		**ED53300-25**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/16/25 16:08	06/16/25 16:08	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2626		**Lims Reference ID:**		**ED53300-26**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	06/16/25 16:09	06/16/25 16:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2628		**Lims Reference ID:**		**ED53300-27**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	13.5		1	1.0	µg/L	06/16/25 18:49	06/16/25 18:49	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-2630		**Lims Reference ID:**		**ED53300-28**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 16:13	06/16/25 16:13	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2636		**Lims Reference ID:**		**ED53300-29**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	1.8		1	1.0	µg/L	06/16/25 16:14	06/16/25 16:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2638		**Lims Reference ID:**		**ED53300-30**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	6.3		1	1.0	µg/L	06/16/25 16:16	06/16/25 16:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2640		**Lims Reference ID:**		**ED53300-31**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	5.1		1	1.0	µg/L	06/16/25 16:17	06/16/25 16:17	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2646		**Lims Reference ID:**		**ED53300-32**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/16/25 16:18	06/16/25 16:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2650		**Lims Reference ID:**		**ED53300-33**	**Matrix: Drinking Water**				**Sampled: 06/10/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553300
LIMS Reference ID: ED53300
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Kindergarten Center, EKC, Brentwood Union Free School District, 50 Timberline Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2650 (Continued)		**Lims Reference ID:**		**ED53300-33**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	06/16/25 16:20	06/16/25 16:20	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3071		**Lims Reference ID:**		**ED53300-34**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/16/25 16:21	06/16/25 16:21	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3072		**Lims Reference ID:**		**ED53300-35**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 10:28	06/17/25 10:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3073		**Lims Reference ID:**		**ED53300-36**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 10:33	06/17/25 10:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3074		**Lims Reference ID:**		**ED53300-37**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 10:34	06/17/25 10:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3271		**Lims Reference ID:**		**ED53300-38**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	**7.0**		1	1.0	µg/L	06/17/25 10:36	06/17/25 10:36	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3280		**Lims Reference ID:**		**ED53300-39**	**Matrix: Drinking Water**			**Sampled:**	**06/10/25 00:00:00**
Metals									
Lead	**2.4**		1	1.0	µg/L	06/17/25 10:40	06/17/25 10:40	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553300
LIMS Reference ID: ED53300
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Kindergarten Center, EKC, Brentwood Union Free School District, 50 Timberline Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553300
LIMS Reference ID: ED53300
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, East Kindergarten Center, EKC, Brentwood Union Free School District, 50 Timberline Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 21:00
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED55450

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Kindergarten Center

EKC

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4078	CR	1064	Room 44	DW	8/26/2025	7:18:00 AM
BRTWD-4080	CR	1062	Room 42	DW	8/26/2025	7:21:00 AM
BRTWD-4082	CR	1061	Room 39	DW	8/26/2025	7:23:00 AM
BRTWD-4084	CR	1060	Room 40	DW	8/26/2025	7:24:00 AM
BRTWD-4086	CR	1058	Room 38	DW	8/26/2025	7:27:00 AM
BRTWD-4088	CR	1057	Room 35	DW	8/26/2025	7:29:00 AM
BRTWD-4090	CR	1056	Room 36	DW	8/26/2025	7:31:00 AM
BRTWD-4092	CR	1055	Room 33	DW	8/26/2025	7:37:00 AM
BRTWD-4094	CR	1054	Room 34	DW	8/26/2025	7:38:00 AM
BRTWD-4096	CR	1053	Room 31	DW	8/26/2025	7:40:00 AM
BRTWD-4098	CR	1052	Room 32	DW	8/26/2025	7:43:00 AM
BRTWD-4100	CR	1018	Room 22	DW	8/26/2025	7:49:00 AM
BRTWD-4102	CR	1015	Room 20	DW	8/26/2025	7:51:00 AM
BRTWD-4104	CR	1014	Room 17	DW	8/26/2025	7:53:00 AM
BRTWD-4106	CR	1011	Room 15	DW	8/26/2025	7:56:00 AM
BRTWD-4108	CR	1008	Room 13	DW	8/26/2025	7:59:00 AM
BRTWD-4110	CR	1007	Room 12	DW	8/26/2025	8:01:00 AM
BRTWD-4112	CR	1006	Room 11	DW	8/26/2025	8:02:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 26 25, PM03:43

Building Address
50 Timberline Drive
Brentwood , NY 11717

Walk In

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/26/25 3:43 PM

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Gwynn

Pb 200.8 Modified 8/27/25

Lead in Water: Chain of Custody for ED55450

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Kindergarten Center

EKC

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4114	CR	1005	Room 10	DW	8/26/2025	8:03:00 AM
BRTWD-4116	CR	1004	Room 9	DW	8/26/2025	8:05:00 AM
BRTWD-4118	CR	1003	Room 8	DW	8/26/2025	8:07:00 AM
BRTWD-4120	CR	1001	Room 7	DW	8/26/2025	8:08:00 AM

Samples Submitted 22

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 26 25, PM03:43

Pb 200.8 Kathi Jones 8/27/25

Building Address
50 Timberline Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/26/25 3:43 PM

Signature:

Samplers Name: Danielle Bobbagiani

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555450
LIMS Reference ID: ED55450
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/26/2025 15:43
Reported: 08/28/2025 21:10

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4078		**Lims Reference ID:**		**ED55450-01**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	08/27/25 16:31	08/27/25 16:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4080		**Lims Reference ID:**		**ED55450-02**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**17.3**		1	1.0	µg/L	08/28/25 18:47	08/28/25 18:47	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4082		**Lims Reference ID:**		**ED55450-03**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/27/25 16:35	08/27/25 16:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4084		**Lims Reference ID:**		**ED55450-04**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**1.6**		1	1.0	µg/L	08/27/25 16:36	08/27/25 16:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4086		**Lims Reference ID:**		**ED55450-05**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	08/27/25 16:37	08/27/25 16:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4088		**Lims Reference ID:**		**ED55450-06**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	08/27/25 16:39	08/27/25 16:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4090		**Lims Reference ID:**		**ED55450-07**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**1.0**		1	1.0	µg/L	08/27/25 16:43	08/27/25 16:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4092		**Lims Reference ID:**		**ED55450-08**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/27/25 16:44	08/27/25 16:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4094		**Lims Reference ID:**		**ED55450-09**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555450
LIMS Reference ID: ED55450
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/26/2025 15:43
Reported: 08/28/2025 21:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4094 (Continued)		**Lims Reference ID:**		**ED55450-09**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals (Continued)									
Lead	13.9		1	1.0	µg/L	08/27/25 16:45	08/27/25 16:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4096		**Lims Reference ID:**		**ED55450-10**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	4.5		1	1.0	µg/L	08/27/25 16:47	08/27/25 16:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4098		**Lims Reference ID:**		**ED55450-11**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	21.0		1	1.0	µg/L	08/27/25 16:48	08/27/25 16:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4100		**Lims Reference ID:**		**ED55450-12**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	2.7		1	1.0	µg/L	08/27/25 16:49	08/27/25 16:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4102		**Lims Reference ID:**		**ED55450-13**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	1.4		1	1.0	µg/L	08/27/25 16:53	08/27/25 16:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4104		**Lims Reference ID:**		**ED55450-14**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	08/27/25 16:55	08/27/25 16:55	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4106		**Lims Reference ID:**		**ED55450-15**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/27/25 16:59	08/27/25 16:59	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4108		**Lims Reference ID:**		**ED55450-16**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/27/25 17:00	08/27/25 17:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4110		**Lims Reference ID:**		**ED55450-17**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555450
LIMS Reference ID: ED55450
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/26/2025 15:43
Reported: 08/28/2025 21:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4110 (Continued)		**Lims Reference ID:**		**ED55450-17**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals (Continued)									
Lead	**1.2**		1	1.0	µg/L	08/27/25 17:01	08/27/25 17:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4112		**Lims Reference ID:**		**ED55450-18**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/27/25 17:02	08/27/25 17:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4114		**Lims Reference ID:**		**ED55450-19**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**1.1**		1	1.0	µg/L	08/27/25 17:04	08/27/25 17:04	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4116		**Lims Reference ID:**		**ED55450-20**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**6.1**		1	1.0	µg/L	08/27/25 17:05	08/27/25 17:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4118		**Lims Reference ID:**		**ED55450-21**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	08/27/25 17:06	08/27/25 17:06	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4120		**Lims Reference ID:**		**ED55450-22**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**1.6**		1	1.0	µg/L	08/27/25 17:39	08/27/25 17:39	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555450

LIMS Reference ID: ED55450

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/26/2025 15:43

Reported: 08/28/2025 21:10

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555450

LIMS Reference ID: ED55450

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/26/2025 15:43

Reported: 08/28/2025 21:10

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

ED 55949

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Kindergarten Center

EKC

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4080	CR	1062	Room 42	DW	9/17/2025	7:26:00 AM
BRTWD-4094	CR	1054	Room 34	DW	9/17/2025	7:25:00 AM
BRTWD-4098	CR	1052	Room 32	DW	9/17/2025	7:24:00 AM
BRTWD-4116	CR	1004	Room 9	DW	9/17/2025	7:30:00 AM

Samples Submitted 4

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
SEP 17 25, PM01:19

B 200.8 Billing 9/18/25

Building Address
50 Timberline Drive
Brentwood , NY 11717

Courier

Analysis Type: ELAP 200.5

Lab Recieved:

Signature:

Samplers Name: Meghan Guynn

Samplers Signature: Meghan Guynn

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555949

LIMS Reference ID: ED55949

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, East Kindergarten Center, Brentwood Union Free School District, 50 Timberline Drive, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/17/2025 13:19

Reported: 09/19/2025 09:47

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4080		**Lims Reference ID:**		**ED55949-01**	**Matrix: Drinking Water**				**Sampled: 09/17/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/18/25 12:57	09/18/25 12:57	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4094		**Lims Reference ID:**		**ED55949-02**	**Matrix: Drinking Water**				**Sampled: 09/17/25 00:00:00**
Metals									
Lead	**1.1**		1	1.0	µg/L	09/18/25 13:01	09/18/25 13:01	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4098		**Lims Reference ID:**		**ED55949-03**	**Matrix: Drinking Water**				**Sampled: 09/17/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/18/25 13:02	09/18/25 13:02	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4116		**Lims Reference ID:**		**ED55949-04**	**Matrix: Drinking Water**				**Sampled: 09/17/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	09/18/25 13:04	09/18/25 13:04	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555949

LIMS Reference ID: ED55949

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	JCB#: 23-53744, East Kindergarten Center, Brentwood Union Free School District, 50 Timberline Drive, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	09/17/2025 13:19
Reported:	09/19/2025 09:47

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555949

LIMS Reference ID: ED55949

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, East Kindergarten Center, Brentwood Union Free School District, 50 Timberline Drive, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 09/17/2025 13:19

Reported: 09/19/2025 09:47

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57896

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Kindergarten Center
EKC

Client:
Brentwood Union Free School District

Retest/New Install [ ]
Turn Around: Normal 1 wk Rush 4 bus ✓

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3271	KI	1041	Kitchen	PK	12/23/2025	6:47:00 AM

Samples Submitted 1

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:17

12/24/25

Building Address
50 Timberline Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 12/23/25 14:17

Signature:

Samplers Name:

Samplers Signature:

JCB Project Manager: Meghan Bergen

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557896

LIMS Reference ID: ED57896

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: East Kindergarten Center: 50 Timberline Drive, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 21:09

Reported: 12/24/2025 17:07

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3271			**Lims Reference ID:**	**ED57896-01**	**Matrix: Drinking Water**			**Sampled:**	**12/23/25 06:47:00**
Metals									
Lead	**3.4**		1	1.0	µg/L	12/24/25 13:42	12/24/25 13:42	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557896

LIMS Reference ID: ED57896

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	East Kindergarten Center: 50 Timberline Drive, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 21:09
Reported:	12/24/2025 17:07

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557896

LIMS Reference ID: ED57896

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	East Kindergarten Center: 50 Timberline Drive, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/23/2025 21:09
Reported:	12/24/2025 17:07

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50895

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Kindergarten Center

EKC

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4280	CR	1065	Room 43	DW	2/19/2026	7:12:00 AM
BRTWD-4282	CR	1063	Room 41	DW	2/19/2026	7:13:00 AM

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
FEB 19 26, PM01:16

Walk In

Building Address
50 Timberline Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Sean Cecil 02/19/26 1:16PM

Signature: Sean Cecil

Samplers Name: Danielle Bahgiani

Samplers Signature:

JCB Project Manager: Meghan Guyon

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650895
LIMS Reference ID: EE50895
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: East Kindergarten Center, 50 Timberline Drive Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 02/19/2026 13:16
Reported: 02/21/2026 09:18

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4280			**Lims Reference ID:**	**EE50895-01**	**Matrix: Drinking Water**				**Sampled: 02/19/26 00:00:00**
Metals									
Lead	**7.3**		1	1.0	µg/L	02/21/26 00:38	02/21/26 00:38	DAZ	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4282			**Lims Reference ID:**	**EE50895-02**	**Matrix: Drinking Water**				**Sampled: 02/19/26 00:00:00**
Metals									
Lead	**7.9**		1	1.0	µg/L	02/21/26 00:39	02/21/26 00:39	DAZ	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650895

LIMS Reference ID: EE50895

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: East Kindergarten Center, 50 Timberline Drive Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 02/19/2026 13:16

Reported: 02/21/2026 09:18

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650895

LIMS Reference ID: EE50895

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	East Kindergarten Center, 50 Timberline Drive Brentwood NY 11717, Brentwood Union Free School District, JCB#:23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	02/19/2026 13:16
Reported:	02/21/2026 09:18

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EES1080

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: East Kindergarten Center

EKC

Client: Brentwood Union Free School District

Retest/New Install [✓]

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4280	CR	1065	Room 43	DW	3/4/2026	7:22:00 AM
BRTWD-4282	CR	1063	Room 41	DW	3/4/2026	7:24:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 04 26, PM04:53

B 200.8 Billing 3/5/26

Building Address
50 Timberline Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 3/4/26 4:53pm

Signature: Dair Wht

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651080
LIMS Reference ID: EE51080
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/04/2026 16:53
Reported: 03/05/2026 13:50

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4280		**Lims Reference ID:**		**EE51080-01**	**Matrix: Drinking Water**				**Sampled: 03/04/26 00:00:00**
Metals									
Lead	**5.6**		1	1.0	µg/L	03/05/26 12:31	03/05/26 12:31	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4282		**Lims Reference ID:**		**EE51080-02**	**Matrix: Drinking Water**				**Sampled: 03/04/26 00:00:00**
Metals									
Lead	**11.9**		1	1.0	µg/L	03/05/26 12:32	03/05/26 12:32	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651080
LIMS Reference ID: EE51080
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/04/2026 16:53
Reported:	03/05/2026 13:50

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651080
LIMS Reference ID: EE51080
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717, Brentwood Union Free School District, #23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/04/2026 16:53
Reported:	03/05/2026 13:50

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE51193

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744
Building: East Kindergarten Center
EKC

Client:
Brentwood Union Free School District

Retest/New Install [Y
Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4280	CR	1065	Room 43	DW	3/11/2026	7:31:00 AM
BRTWD-4282	CR	1063	Room 41	DW	3/11/2026	7:32:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
MAR 11 26, PM03:37

Pb200.8
Kathleen
3/12/26

Building Address
50 Timberline Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5
Lab Recieved: 3/11/26 15:37
Signature: Kay Wagner

Samplers Name: Daniella Bologna
Samplers Signature:
JCB Project Manager: Meghan Egan

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651193
LIMS Reference ID: EE51193
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: East Kindergarten Center: 50 Timberline Drive, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/11/2026 15:37
Reported: 03/13/2026 09:05

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4280			**Lims Reference ID:**	**EE51193-01**	**Matrix: Drinking Water**				**Sampled: 03/11/26 07:31:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	03/12/26 16:26	03/12/26 16:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4282			**Lims Reference ID:**	**EE51193-02**	**Matrix: Drinking Water**				**Sampled: 03/11/26 07:32:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	03/12/26 16:28	03/12/26 16:28	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651193
LIMS Reference ID: EE51193
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	East Kindergarten Center: 50 Timberline Drive, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	03/11/2026 15:37
Reported:	03/13/2026 09:05

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062651193
LIMS Reference ID: EE51193
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: East Kindergarten Center: 50 Timberline Drive, Brentwood, NY 11717: Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 03/11/2026 15:37
Reported: 03/13/2026 09:05

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE53370

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: East Kindergarten Center

EKC

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4298	HA	N/A	Corridor Near Faculty Bathroom	WF	6/26/2026	7:12:00 AM
BRTWD-4299	HA	N/A	Corridor Near Faculty Bathroom	WC	6/26/2026	7:12:00 AM

Samples Submitted 2

PO 200.8 Billing 6/29/26

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 26 26, PM01:03

Building Address
50 Timberline Drive
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 6/26/26 1:03 pm

Signature: David Wharton

Samplers Name: Danielle Balzamino

Samplers Signature:

JCB Project Manager: Danielle Balzamino

DE 6/27/26

~~PO 200.8~~ PO 200.8 6/27/26

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653370

LIMS Reference ID: EE53370

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/26/2026 13:03

Reported: 06/29/2026 15:49

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4298		**Lims Reference ID:**		**EE53370-01**	**Matrix: Drinking Water**				**Sampled: 06/26/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/29/26 14:17	06/29/26 14:17	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4299		**Lims Reference ID:**		**EE53370-02**	**Matrix: Drinking Water**				**Sampled: 06/26/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/29/26 14:22	06/29/26 14:22	BP	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653370

LIMS Reference ID: EE53370

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	06/26/2026 13:03
Reported:	06/29/2026 15:49

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	05/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653370

LIMS Reference ID: EE53370

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	East Kindergarten Center EKC, 50 Timberline Drive, Brentwood, NY 11717, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	06/26/2026 13:03
Reported:	06/29/2026 15:49

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED 53314

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Oak Park Elementary School

OPE

Client: Brentwood Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2787	NO	1026	Nurse's Office	NS	6/6/2025	7:07:00 AM
BRTWD-2789	NO	1026A	Nurse's Office Exam Room	NS	6/6/2025	7:08:00 AM
BRTWD-2793	KI	1038	Kitchen	KC	6/6/2025	6:50:00 AM
BRTWD-2794	KI	1038	Kitchen	KC	6/6/2025	6:51:00 AM
BRTWD-2795	KI	1038	Kitchen	HW	6/6/2025	6:52:00 AM
BRTWD-2798	KI	1038	Kitchen	KC	6/6/2025	6:53:00 AM
BRTWD-2799	KI	1038	Kitchen	KC	6/6/2025	6:53:00 AM
BRTWD-2800	KI	1038	Kitchen	KC	6/6/2025	6:54:00 AM
BRTWD-2801	KI	1038	Kitchen	KC	6/6/2025	6:55:00 AM
BRTWD-2802	KI	1038	Kitchen	HW	6/6/2025	6:56:00 AM
BRTWD-2837	CR	N/A	Room 52	DW	6/6/2025	7:56:00 AM
BRTWD-2838	CR	N/A	Room 53	DW	6/6/2025	7:57:00 AM
BRTWD-2841	CR	N/A	Room 54	DW	6/6/2025	7:53:00 AM
BRTWD-2842	CR	N/A	Room 55	DW	6/6/2025	7:54:00 AM
BRTWD-2852	HA	N/A	Corridor Near Bathrooms	WC	6/6/2025	7:00:00 AM
BRTWD-2857	CR	N/A	Room 56	DW	6/6/2025	7:59:00 AM
BRTWD-2859	CR	N/A	Room 57	DW	6/6/2025	8:00:00 AM
BRTWD-2861	CR	N/A	Room 58	DW	6/6/2025	8:01:00 AM

RECEIVED
ENVL ANALYTICAL LLC.
Carle Place, NY
JUN 13 25 PM 8:55

Building Address
775 Wisconsin Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: A Stanley 6/13/25

Signature: 8:55pm

Samplers Name: Erica Wilson

Samplers Signature:

JCB Project Manager: Meghan Guzzon

Lead in Water: Chain of Custody for ED533|4

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Oak Park Elementary School

OPE

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2863	CR	N/A	Room 59	DW	6/6/2025	8:05:00 AM
BRTWD-2865	CR	N/A	Room 60	DW	6/6/2025	8:03:00 AM
BRTWD-2867	CR	N/A	Room 61	DW	6/6/2025	8:05:00 AM
BRTWD-2873	HA	N/A	Corridor Near Bathrooms	WC	6/6/2025	8:06:00 AM
BRTWD-2874	HA	N/A	Corridor Near Bathrooms	WC	6/6/2025	8:07:00 AM
BRTWD-2878	CR	N/A	Room 66	DW	6/6/2025	8:08:00 AM
BRTWD-2879	CR	N/A	Room 67	DW	6/6/2025	8:09:00 AM
BRTWD-2881	CR	N/A	Room 68	DW	6/6/2025	8:12:00 AM
BRTWD-2884	CR	N/A	Room 69	DW	6/6/2025	8:13:00 AM
BRTWD-3083	HA	1040	Corridor Near Cafeteria (1036)	WC	6/6/2025	7:01:00 AM
BRTWD-3084	HA	1040	Corridor Near Cafeteria (1036)	WF	6/6/2025	7:02:00 AM
BRTWD-3085	HA	1040	Corridor Outside Bathrooms (1023/1024)	WC	6/6/2025	7:32:00 AM
BRTWD-3086	HA	1040	Corridor Outside Bathrooms (1023/1024)	WF	6/6/2025	7:33:00 AM
BRTWD-3111	CR	1001	Room 1	DW	6/6/2025	7:29:00 AM
BRTWD-3113	CR	1003	Room 2	DW	6/6/2025	7:27:00 AM
BRTWD-3115	CR	1004	Room 3	DW	6/6/2025	7:26:00 AM
BRTWD-3117	CR	1005	Room 4	DW	6/6/2025	7:25:00 AM
BRTWD-3119	CR	1006	Room 5	DW	6/6/2025	7:24:00 AM

RECEIVED
ENVIRONMENTAL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM08-55

Building Address
775 Wisconsin Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 8:55pm

Signature:

Samplers Name: Erin Wilson

Samplers Signature:

JCB Project Manager: Meghan Grayson

Lead in Water: Chain of Custody for

EDS3314

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Oak Park Elementary School

OPE

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3121	CR	1007	Room 6	DW	6/6/2025	7:21:00 AM
BRTWD-3123	CR	1008	Room 7	DW	6/6/2025	7:20:00 AM
BRTWD-3125	CR	1009	Room 8	DW	6/6/2025	7:19:00 AM
BRTWD-3127	CR	1010	Room 9	DW	6/6/2025	7:18:00 AM
BRTWD-3129	CR	1011	Room 10	DW	6/6/2025	7:17:00 AM
BRTWD-3131	CR	1012	Room 11	DW	6/6/2025	7:15:00 AM
BRTWD-3133	CR	1013	Room 12	DW	6/6/2025	7:14:00 AM
BRTWD-3135	CR	1014	Computer Lab Room 13	DW	6/6/2025	7:13:00 AM
BRTWD-3137	CR	1015	Room 14	DW	6/6/2025	7:12:00 AM
BRTWD-3139	CR	1017	Room 15	DW	6/6/2025	7:10:00 AM
BRTWD-3141	CR	1047	Room 16	DW	6/6/2025	7:35:00 AM
BRTWD-3143	CR	1049	Room 18	DW	6/6/2025	7:37:00 AM
BRTWD-3145	CR	1050	Room 20	DW	6/6/2025	7:38:00 AM
BRTWD-3147	CR	1051	Room 21	DW	6/6/2025	7:39:00 AM
BRTWD-3149	CR	1052	Room 22	DW	6/6/2025	7:40:00 AM
BRTWD-3153	CR	1054	Room 24	DW	6/6/2025	7:41:00 AM
BRTWD-3155	CR	1055	Room 25	DW	6/6/2025	7:44:00 AM
BRTWD-3157	CR	1056	Room 26	DW	6/6/2025	7:46:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM08:55

Building Address
775 Wisconsin Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 8:55pm

Signature:

Samplers Name: Evan Wilson

Samplers Signature:

JCB Project Manager: Meghan Grogan

Lead in Water: Chain of Custody for

ED583314

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Oak Park Elementary School

OPE

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3159	CR	1057	Room 27	DW	6/6/2025	7:47:00 AM
BRTWD-3161	CR	1058	Room 28	DW	6/6/2025	7:48:00 AM
BRTWD-3163	CR	1059	Room 29	DW	6/6/2025	7:49:00 AM
BRTWD-3916	KI	1038	Kitchen	PK	6/6/2025	6:59:00 AM

Samples Submitted 58

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM08:55

Building Address
775 Wisconsin Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: A Stanley 6/13/25

Signature: 8:55pm

Samplers Name: Erik Wilson

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553314
LIMS Reference ID: ED53314
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Oak Park Elementary School, OPE, Brentwood Union Free School District, 775, Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2787		**Lims Reference ID:**		**ED53314-01**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 19:16	06/17/25 19:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2789		**Lims Reference ID:**		**ED53314-02**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	171		2	2.0	µg/L	06/17/25 19:36	06/17/25 19:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2793		**Lims Reference ID:**		**ED53314-03**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	5.2		1	1.0	µg/L	06/17/25 19:19	06/17/25 19:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2794		**Lims Reference ID:**		**ED53314-04**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 19:20	06/17/25 19:20	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2795		**Lims Reference ID:**		**ED53314-05**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	10.6		1	1.0	µg/L	06/17/25 19:21	06/17/25 19:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2798		**Lims Reference ID:**		**ED53314-06**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 19:23	06/17/25 19:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2799		**Lims Reference ID:**		**ED53314-07**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 19:24	06/17/25 19:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2800		**Lims Reference ID:**		**ED53314-08**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:30	06/17/25 20:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2801		**Lims Reference ID:**		**ED53314-09**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553314
LIMS Reference ID: ED53314
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Oak Park Elementary School, OPE, Brentwood Union Free School District, 775, Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2801 (Continued)		**Lims Reference ID:**		**ED53314-09**	**Matrix: Drinking Water**			**Sampled:**	**06/06/25 00:00:00**
Metals (Continued)									
Lead	1.6		1	1.0	µg/L	06/17/25 20:34	06/17/25 20:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2802		**Lims Reference ID:**		**ED53314-10**	**Matrix: Drinking Water**			**Sampled:**	**06/06/25 00:00:00**
Metals									
Lead	3.7		1	1.0	µg/L	06/17/25 20:35	06/17/25 20:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2837		**Lims Reference ID:**		**ED53314-11**	**Matrix: Drinking Water**			**Sampled:**	**06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:37	06/17/25 20:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2838		**Lims Reference ID:**		**ED53314-12**	**Matrix: Drinking Water**			**Sampled:**	**06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:38	06/17/25 20:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2841		**Lims Reference ID:**		**ED53314-13**	**Matrix: Drinking Water**			**Sampled:**	**06/06/25 00:00:00**
Metals									
Lead	1.3		1	1.0	µg/L	06/17/25 20:42	06/17/25 20:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2842		**Lims Reference ID:**		**ED53314-14**	**Matrix: Drinking Water**			**Sampled:**	**06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:43	06/17/25 20:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2852		**Lims Reference ID:**		**ED53314-15**	**Matrix: Drinking Water**			**Sampled:**	**06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:45	06/17/25 20:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2857		**Lims Reference ID:**		**ED53314-16**	**Matrix: Drinking Water**			**Sampled:**	**06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:46	06/17/25 20:46	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2859		**Lims Reference ID:**		**ED53314-17**	**Matrix: Drinking Water**			**Sampled:**	**06/06/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553314
LIMS Reference ID: ED53314
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Oak Park Elementary School, OPE, Brentwood Union Free School District, 775, Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2859 (Continued)		**Lims Reference ID:**		**ED53314-17**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:47	06/17/25 20:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2861		**Lims Reference ID:**		**ED53314-18**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:49	06/17/25 20:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2863		**Lims Reference ID:**		**ED53314-19**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:53	06/17/25 20:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2865		**Lims Reference ID:**		**ED53314-20**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:54	06/17/25 20:54	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2867		**Lims Reference ID:**		**ED53314-21**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:58	06/17/25 20:58	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2873		**Lims Reference ID:**		**ED53314-22**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/19/25 11:15	06/19/25 11:15	SEH	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-2874		**Lims Reference ID:**		**ED53314-23**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 20:59	06/17/25 20:59	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2878		**Lims Reference ID:**		**ED53314-24**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 21:01	06/17/25 21:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2879		**Lims Reference ID:**		**ED53314-25**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553314
LIMS Reference ID: ED53314
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Oak Park Elementary School, OPE, Brentwood Union Free School District, 775, Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2879 (Continued)		**Lims Reference ID:**		**ED53314-25**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals (Continued)									
Lead	1.2		1	1.0	µg/L	06/17/25 21:02	06/17/25 21:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2881		**Lims Reference ID:**		**ED53314-26**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	06/17/25 21:03	06/17/25 21:03	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2884		**Lims Reference ID:**		**ED53314-27**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 21:05	06/17/25 21:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3083		**Lims Reference ID:**		**ED53314-28**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/17/25 21:06	06/17/25 21:06	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3084		**Lims Reference ID:**		**ED53314-29**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/18/25 09:58	06/18/25 09:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3085		**Lims Reference ID:**		**ED53314-30**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/18/25 10:02	06/18/25 10:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3086		**Lims Reference ID:**		**ED53314-31**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/18/25 10:03	06/18/25 10:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3111		**Lims Reference ID:**		**ED53314-32**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/18/25 10:04	06/18/25 10:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3113		**Lims Reference ID:**		**ED53314-33**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553314
LIMS Reference ID: ED53314
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Oak Park Elementary School, OPE, Brentwood Union Free School District, 775, Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3113 (Continued)			**Lims Reference ID:**	**ED53314-33**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals (Continued)									
Lead	1.2		1	1.0	µg/L	06/18/25 10:06	06/18/25 10:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3115			**Lims Reference ID:**	**ED53314-34**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/18/25 10:10	06/18/25 10:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3117			**Lims Reference ID:**	**ED53314-35**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/18/25 10:11	06/18/25 10:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3119			**Lims Reference ID:**	**ED53314-36**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/18/25 10:12	06/18/25 10:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3121			**Lims Reference ID:**	**ED53314-37**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	06/18/25 10:14	06/18/25 10:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3123			**Lims Reference ID:**	**ED53314-38**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/18/25 10:15	06/18/25 10:15	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3125			**Lims Reference ID:**	**ED53314-39**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/18/25 10:16	06/18/25 10:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3127			**Lims Reference ID:**	**ED53314-40**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/18/25 10:20	06/18/25 10:20	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3129			**Lims Reference ID:**	**ED53314-41**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553314
LIMS Reference ID: ED53314
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Oak Park Elementary School, OPE, Brentwood Union Free School District, 775, Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3129 (Continued)			**Lims Reference ID:**	**ED53314-41**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals (Continued)									
Lead	**2.1**		1	1.0	µg/L	06/18/25 10:22	06/18/25 10:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3131			**Lims Reference ID:**	**ED53314-42**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	**1.2**		1	1.0	µg/L	06/18/25 10:26	06/18/25 10:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3133			**Lims Reference ID:**	**ED53314-43**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	06/18/25 10:27	06/18/25 10:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3135			**Lims Reference ID:**	**ED53314-44**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	06/18/25 10:28	06/18/25 10:28	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3137			**Lims Reference ID:**	**ED53314-45**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	**6.7**		1	1.0	µg/L	06/18/25 10:30	06/18/25 10:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3139			**Lims Reference ID:**	**ED53314-46**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/18/25 10:31	06/18/25 10:31	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3141			**Lims Reference ID:**	**ED53314-47**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/18/25 10:32	06/18/25 10:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3143			**Lims Reference ID:**	**ED53314-48**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	**2.1**		1	1.0	µg/L	06/18/25 10:34	06/18/25 10:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3145			**Lims Reference ID:**	**ED53314-49**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553314
LIMS Reference ID: ED53314
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Oak Park Elementary School, OPE, Brentwood Union Free School District, 775, Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3145 (Continued)		**Lims Reference ID:**		**ED53314-49**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	06/19/25 11:16	06/19/25 11:16	SEH	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-3147		**Lims Reference ID:**		**ED53314-50**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:49	06/24/25 16:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3149		**Lims Reference ID:**		**ED53314-51**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:51	06/24/25 16:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3153		**Lims Reference ID:**		**ED53314-52**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:52	06/24/25 16:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3155		**Lims Reference ID:**		**ED53314-53**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:53	06/24/25 16:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3157		**Lims Reference ID:**		**ED53314-54**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:55	06/24/25 16:55	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3159		**Lims Reference ID:**		**ED53314-55**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/24/25 16:59	06/24/25 16:59	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3161		**Lims Reference ID:**		**ED53314-56**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/24/25 17:00	06/24/25 17:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3163		**Lims Reference ID:**		**ED53314-57**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553314
LIMS Reference ID: ED53314
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Oak Park Elementary School, OPE, Brentwood Union Free School District, 775, Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3163 (Continued)			**Lims Reference ID:**	**ED53314-57**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals (Continued)									
Lead	**1.5**		1	1.0	µg/L	06/24/25 17:04	06/24/25 17:04	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3916			**Lims Reference ID:**	**ED53314-58**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	**2.3**		1	1.0	µg/L	06/24/25 17:05	06/24/25 17:05	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553314
LIMS Reference ID: ED53314
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Oak Park Elementary School, OPE, Brentwood Union Free School District, 775, Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553314
LIMS Reference ID: ED53314
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Oak Park Elementary School, OPE, Brentwood Union Free School District, 775, Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

ED57880

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Oak Park Elementary School

OPE

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2789	NO	1026A	Nurse's Office Exam Room	NS	12/23/2025	7:06:00 AM
BRTWD-2793	KI	1038	Kitchen	KC	12/23/2025	6:47:00 AM
BRTWD-2795	KI	1038	Kitchen	HW	12/23/2025	6:48:00 AM

Samples Submitted 3

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 23 25, PM02:15

Pb 200.8
Kathy Lw
12/24/25

Building Address
775 Wisconsin Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 12/23/25 2:15 PM

Signature:

Samplers Name: Jordan Miglino

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557880

LIMS Reference ID: ED57880

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Oak Park Elementary School OPE / 775 Wisconsin Avenue, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:15

Reported: 12/24/2025 16:51

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2789		**Lims Reference ID:**		**ED57880-01**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**31.6**		1	1.0	µg/L	12/24/25 13:01	12/24/25 13:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2793		**Lims Reference ID:**		**ED57880-02**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**4.5**		1	1.0	µg/L	12/24/25 13:02	12/24/25 13:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2795		**Lims Reference ID:**		**ED57880-03**	**Matrix: Drinking Water**				**Sampled: 12/23/25 00:00:00**
Metals									
Lead	**5.5**		1	1.0	µg/L	12/24/25 13:03	12/24/25 13:03	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557880

LIMS Reference ID: ED57880

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Oak Park Elementary School OPE / 775 Wisconsin Avenue, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:15

Reported: 12/24/2025 16:51

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557880

LIMS Reference ID: ED57880

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Oak Park Elementary School OPE / 775 Wisconsin Avenue, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/23/2025 14:15

Reported: 12/24/2025 16:51

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57904

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Oak Park Elementary School

OPE

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-3137	CR	1015	Room 14	DW	12/24/2025	7:22:00 AM
BRTWD-3151	CR	1053	Room 23	DW	12/24/2025	7:19:00 AM

Samples Submitted 2

Drop Box

200.8 Blang 12126125

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 24 25, PM05:38

Building Address
775 Wisconsin Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 12/24/25 17:38

Signature: May Hampton

Samplers Name: Jordan Miglino

Samplers Signature: J. Miglino

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557904

LIMS Reference ID: ED57904

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Oak Park Elementary School: 775 Wisconsin Avenue, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/24/2025 17:38

Reported: 12/26/2025 12:10

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3137		**Lims Reference ID:**		**ED57904-01**	**Matrix: Drinking Water**				**Sampled: 12/24/25 07:22:00**
Metals									
Lead	**1.8**		1	1.0	µg/L	12/26/25 11:00	12/26/25 11:00	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3151		**Lims Reference ID:**		**ED57904-02**	**Matrix: Drinking Water**				**Sampled: 12/24/25 07:22:00**
Metals									
Lead	**1.1**		1	1.0	µg/L	12/26/25 11:04	12/26/25 11:04	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557904

LIMS Reference ID: ED57904

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Oak Park Elementary School: 775 Wisconsin Avenue, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/24/2025 17:38
Reported:	12/26/2025 12:10

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557904

LIMS Reference ID: ED57904

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	Oak Park Elementary School: 775 Wisconsin Avenue, Bay Shore, NY 11706: Brentwood Union Free School District: Project# 23-53744
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/24/2025 17:38
Reported:	12/26/2025 12:10

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EDS7962

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Oak Park Elementary School

OPE

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48 hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2789	NO	1026A	Nurse's Office Exam Room	NS	12/30/2025	6:49:00 AM
BRTWD-2795	KI	1038	Kitchen	HW	12/30/2025	6:44:00 AM

Samples Submitted 2

Pb 200.8 BMony 12/31/25

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 30 25, PM04:39

Building Address
775 Wisconsin Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: 12/30/25 4:39PM

Signature:

Samplers Name: Danielle Belgiovi

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557962

LIMS Reference ID: ED57962

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 775 Wisconsin Avenue Bay Shore NY 11706, Oak Park Elementary School, JCB#:23-53744, Brentwood Union Free School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:39

Reported: 12/31/2025 15:16

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2789		**Lims Reference ID:**		**ED57962-01**	**Matrix: Drinking Water**				**Sampled: 12/30/25 06:49:00**
Metals									
Lead	**13.0**		1	1.0	µg/L	12/31/25 10:55	12/31/25 10:55	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2795		**Lims Reference ID:**		**ED57962-02**	**Matrix: Drinking Water**				**Sampled: 12/30/25 06:44:00**
Metals									
Lead	**10.9**		1	1.0	µg/L	12/31/25 10:57	12/31/25 10:57	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557962

LIMS Reference ID: ED57962

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 775 Wisconsin Avenue Bay Shore NY 11706, Oak Park Elementary School, JCB#:23-53744, Brentwood Union Free School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/30/2025 16:39

Reported: 12/31/2025 15:16

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557962

LIMS Reference ID: ED57962

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	775 Wisconsin Avenue Bay Shore NY 11706, Oak Park Elementary School, JCB#:23-53744, Brentwood Union Free School District
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/30/2025 16:39
Reported:	12/31/2025 15:16

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50048

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Oak Park Elementary School

OPE

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 48hr

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4268	HA	N/A	5th Grade Corridor by Gang Bathrooms	WF	1/6/2026	7:13:00 AM
BRTWD-4269	HA	N/A	5th Grade Corridor by Gang Bathrooms	WC	1/6/2026	7:13:00 AM

Samples Submitted 2

B 200.8 Billing 1/8/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 06 26, PM06:17

Drop Box

Building Address
775 Wisconsin Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 1/6/26 6:17pm

Signature: Dave Wharton

Samplers Name: Meghan Guynn

Samplers Signature: Meghan Guynn

JCB Project Manager: Meghan Guynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650048

LIMS Reference ID: EE50048

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Oak Park Elementary School OPE / 775 Wisconsin Avenue, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 01/06/2026 18:17

Reported: 01/08/2026 12:16

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4268		**Lims Reference ID:**		**EE50048-01**	**Matrix: Drinking Water**				**Sampled: 01/06/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/08/26 11:16	01/08/26 11:16	BP	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4269		**Lims Reference ID:**		**EE50048-02**	**Matrix: Drinking Water**				**Sampled: 01/06/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/08/26 11:17	01/08/26 11:17	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650048

LIMS Reference ID: EE50048

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Oak Park Elementary School OPE / 775 Wisconsin Avenue, Bay Shore, NY 11706

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 01/06/2026 18:17

Reported: 01/08/2026 12:16

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650048
LIMS Reference ID: EE50048
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 / Brentwood Union Free School District / Oak Park Elementary School OPE / 775 Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/06/2026 18:17
Reported: 01/08/2026 12:16

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE53566

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-64123

Building: Oak Park Elementary School

OPE

Client: Brentwood Union Free School District

Retest/New Install M

Turn Around: Normal 1 wk **Rush** 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4300	HA	N/A	Corridor Near Bathrooms	WF	7/9/2026	7:05:00 AM
BRTWD-4301	HA	N/A	Corridor Near Bathrooms	WC	7/9/2026	7:06:00 AM

Samples Submitted 2

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUL 09 26, PM01:13

Building Address
775 Wisconsin Avenue
Bay Shore , NY 11706

7/10/26

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 7/9/26 1:13 PM

Signature:

Samplers Name: Danielle Bolognini

Samplers Signature:

JCB Project Manager: Danielle Bolognini

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653566

LIMS Reference ID: EE53566

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name: Oak Park Elementary School OPE, 775 Wisconsin Avenue, Bay Shore, NY 11706, Brentwood Union Free School District, #26-64123

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 07/09/2026 13:13

Reported: 07/10/2026 12:13

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4300		**Lims Reference ID:**		**EE53566-01**	**Matrix: Drinking Water**				**Sampled: 07/09/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	07/10/26 11:36	07/10/26 11:36	JH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-4301		**Lims Reference ID:**		**EE53566-02**	**Matrix: Drinking Water**				**Sampled: 07/09/26 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	07/10/26 11:40	07/10/26 11:40	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653566

LIMS Reference ID: EE53566

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	Oak Park Elementary School OPE, 775 Wisconsin Avenue, Bay Shore, NY 11706, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	07/09/2026 13:13
Reported:	07/10/2026 12:13

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062653566

LIMS Reference ID: EE53566

EMSL Customer ID: JCBR50

Attention: Danielle Bolognini
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
dbolognini@jcbroderick.com

Project Name:	Oak Park Elementary School OPE, 775 Wisconsin Avenue, Bay Shore, NY 11706, Brentwood Union Free School District, #26-64123
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	07/09/2026 13:13
Reported:	07/10/2026 12:13

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED53299

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Anthony Felicio Administration Building

AFA

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2908	FL	1004	Faculty Room	KC	6/11/2025	6:53:00 AM
BRTWD-2936	OF	1007C	Maureen Belanger Board Room Kitchen	OF	6/11/2025	6:21:00 AM
BRTWD-3006	HA	1033	West Corridor	WC	6/11/2025	6:27:00 AM
BRTWD-3007	HA	1033	West Corridor	WF	6/11/2025	6:27:00 AM
BRTWD-3170	HA	1039	Main Corridor	WF	6/11/2025	6:25:00 AM
BRTWD-3171	HA	1039	Main Corridor	WC	6/11/2025	6:24:00 AM
BRTWD-3951	HA	1013	East Corridor	WC	6/11/2025	6:17:00 AM
BRTWD-3952	HA	1013	East Corridor	WF	6/11/2025	6:17:00 AM
BRTWD-3965	KI	2009D	Health Benefits Suite Kitchen Area	WF	6/11/2025	6:43:00 AM
BRTWD-3966	KI	2009D	Health Benefits Suite Kitchen Area	BW	6/11/2025	6:44:00 AM
BRTWD-3967	KI	2009D	Health Benefits Suite Kitchen Area	KC	6/11/2025	6:45:00 AM

Samples Submitted 11

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM08:58

Building Address
52 3rd Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: 6/13/25 20:58

Signature:

Samplers Name: Lexi Farwell

Samplers Signature: Lexi Farwell

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553299

LIMS Reference ID: ED53299

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Anthony Felicio Administration Building: 52 3rd Avenue, Brentwood, NY 11717; Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 20:58

Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2908		**Lims Reference ID:**		**ED53299-01**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:53:00**
Metals									
Lead	1.1		1	1.0	µg/L	06/23/25 18:30	06/23/25 18:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-2936		**Lims Reference ID:**		**ED53299-02**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:21:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 18:34	06/23/25 18:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3006		**Lims Reference ID:**		**ED53299-03**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:27:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 18:35	06/23/25 18:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3007		**Lims Reference ID:**		**ED53299-04**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:27:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 18:36	06/23/25 18:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3170		**Lims Reference ID:**		**ED53299-05**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:25:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 18:37	06/23/25 18:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3171		**Lims Reference ID:**		**ED53299-06**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:24:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 18:39	06/23/25 18:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3951		**Lims Reference ID:**		**ED53299-07**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:17:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 18:40	06/23/25 18:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3952		**Lims Reference ID:**		**ED53299-08**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:17:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	06/23/25 18:44	06/23/25 18:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3965		**Lims Reference ID:**		**ED53299-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:43:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553299
LIMS Reference ID: ED53299
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Anthony Felicio Administration Building: 52 3rd Avenue, Brentwood, NY 11717; Brentwood Union Free School District: Project# 23-53744
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:58
Reported:

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-3965 (Continued)		**Lims Reference ID:**		**ED53299-09**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:43:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 18:45	06/23/25 18:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3966		**Lims Reference ID:**		**ED53299-10**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:44:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/23/25 18:49	06/23/25 18:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3967		**Lims Reference ID:**		**ED53299-11**	**Matrix: Drinking Water**				**Sampled: 06/13/25 06:45:00**
Metals									
Lead	**1.2**		1	1.0	µg/L	06/23/25 18:51	06/23/25 18:51	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553299

LIMS Reference ID: ED53299

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Anthony Felicio Administration Building: 52 3rd Avenue, Brentwood, NY 11717; Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 20:58

Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553299

LIMS Reference ID: ED53299

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: Anthony Felicio Administration Building: 52 3rd Avenue, Brentwood, NY 11717; Brentwood Union Free School District: Project# 23-53744

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 06/13/2025 20:58

Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED5546a

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Anthony Felicio Administration Building

AFA

Client: Brentwood Union Free School District

Retest/New Install [V

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4121	HA	2010	2nd Floor Corridor	WF	8/26/2025	8:30:00 AM
BRTWD-4122	HA	2010	2nd Floor Corridor	WC	8/26/2025	8:30:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 26 25, PM03:42

Building Address
52 3rd Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 8/26/25 3:42 pm

Signature:

Samplers Name: Danielle Colapinto

Samplers Signature:

JCB Project Manager: Meghan Burgos

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555462

LIMS Reference ID: ED55462

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Anthony Felicio Administration Building AFA, 52 3rd Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/26/2025 15:42

Reported: 08/28/2025 21:41

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4121		**Lims Reference ID:**		**ED55462-01**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/28/25 19:14	08/28/25 19:14	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4122		**Lims Reference ID:**		**ED55462-02**	**Matrix: Drinking Water**				**Sampled: 08/26/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/27/25 18:40	08/27/25 18:40	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555462

LIMS Reference ID: ED55462

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Anthony Felicio Administration Building AFA, 52 3rd Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/26/2025 15:42

Reported: 08/28/2025 21:41

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062555462

LIMS Reference ID: ED55462

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Brentwood Union Free School District, Anthony Felicio Administration Building AFA, 52 3rd Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/26/2025 15:42

Reported: 08/28/2025 21:41

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

ED57530

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Anthony Felicio Administration Building

AFA

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1wk Rush 48hrs

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4261	FL	3002M	Main Office Suite Kitchen	BW	12/4/2025	7:16:00 AM
BRTWD-4262	FL	3002M	Main Office Suite Kitchen	BW	12/4/2025	7:16:00 AM
BRTWD-4264	FL	3002M	Main Office Suite Kitchen	IM	12/4/2025	7:17:00 AM

Samples Submitted 3

Drop Box

12/4/25 @ 2:00

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 04 25, PM11:01

Building Address
52 3rd Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved:

Signature:

Samplers Name: Danielle Bolognino

Samplers Signature:

JCB Project Manager: Meghan Bayne

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557530

LIMS Reference ID: ED57530

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Anthony Felicio Administration Building, Brentwood Union Free School District, 52 3rd Avenue, Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 12/05/2025 23:01

Reported: 12/06/2025 14:30

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4261		**Lims Reference ID:**		**ED57530-01**	**Matrix: Drinking Water**				**Sampled: 12/04/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/06/25 14:04	12/06/25 14:04	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4262		**Lims Reference ID:**		**ED57530-02**	**Matrix: Drinking Water**				**Sampled: 12/04/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/06/25 14:05	12/06/25 14:05	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: BRTWD-4264		**Lims Reference ID:**		**ED57530-03**	**Matrix: Drinking Water**				**Sampled: 12/04/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	12/06/25 14:07	12/06/25 14:07	JH	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557530
LIMS Reference ID: ED57530
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: JCB#: 23-53744, Anthony Felicio Administration Building, Brentwood Union Free School District, 52 3rd Avenue, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 12/05/2025 23:01
Reported: 12/06/2025 14:30

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557530

LIMS Reference ID: ED57530

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name:	JCB#: 23-53744, Anthony Felicio Administration Building, Brentwood Union Free School District, 52 3rd Avenue, Brentwood, NY 11717
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	12/05/2025 23:01
Reported:	12/06/2025 14:30

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50062

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Anthony Felicio Administration Building

AFA

Client: Brentwood Union Free School District

Retest/New Install [✓]

Turn Around: Normal 1 wk Rush 48 hour

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-4260	FL	3002M	Main Office Suite Kitchen	KC	1/7/2026	7:31:00 AM

Samples Submitted 1

Walk In

Pb 200.8 Billing 1/8/26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 07 26, PM03:49

Building Address
52 3rd Avenue
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: James Hay 1/7/26 3497PM

Signature:

Samplers Name: Danielle Bolognese

Samplers Signature:

JCB Project Manager: Meghan Gwynn

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650062
LIMS Reference ID: EE50062
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Anthony Felicio Administration Building - Brentwood Union Free School District - 52 3rd Avenue Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/07/2026 15:49
Reported: 01/08/2026 12:18

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-4260			**Lims Reference ID:**	**EE50062-01**	**Matrix: Drinking Water**			**Sampled:**	**01/07/26 07:31:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/08/26 11:40	01/08/26 11:40	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650062

LIMS Reference ID: EE50062

EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Anthony Felicio Administration Building - Brentwood Union Free School District - 52 3rd Avenue Brentwood, NY 11717

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 01/07/2026 15:49

Reported: 01/08/2026 12:18

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650062
LIMS Reference ID: EE50062
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744 - Anthony Felicio Administration Building - Brentwood Union Free School District - 52 3rd Avenue Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/07/2026 15:49
Reported: 01/08/2026 12:18

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

E0533503

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53744

Building: Special Services Building

SSB

Client: Brentwood Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
BRTWD-2949	FL	1011	Faculty Room	WC	6/6/2025	8:20:00 AM
BRTWD-3003	FL	1011	Faculty Room	KC	6/6/2025	8:23:00 AM

Samples Submitted 2

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
JUN 13 25, PM08:55

Building Address
775 Wisconsin Avenue
Bay Shore , NY 11706

Analysis Type: ELAP 200.5

Lab Recieved: ABlanchey 6/13/25

Signature: 8:55pm

Samplers Name: Erica Wilson

Samplers Signature:

JCB Project Manager: Meghan Burgess

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553303
LIMS Reference ID: ED53303
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Special Services Building, SSB, Brentwood Union Free School District, 775 Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BRTWD-2949			**Lims Reference ID:**	**ED53303-01**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 08:52	06/17/25 08:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: BRTWD-3003			**Lims Reference ID:**	**ED53303-02**	**Matrix: Drinking Water**				**Sampled: 06/06/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	06/17/25 08:56	06/17/25 08:56	SEH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553303
LIMS Reference ID: ED53303
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Special Services Building, SSB, Brentwood Union Free School District, 775 Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062553303
LIMS Reference ID: ED53303
EMSL Customer ID: JCBR50

Attention: Meghan Gwynn
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
mgwynn@jcbroderick.com

Project Name: 23-53744, Special Services Building, SSB, Brentwood Union Free School District, 775 Wisconsin Avenue, Bay Shore, NY 11706
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 06/13/2025 20:55
Reported:

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Attachment 4:

Laboratory Certifications



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2027
Issued April 01, 2026

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. DANIEL CLARKE
EMSL ANALYTICAL, INC.
528 MINEOLA AVE.
CARLE PLACE, NY 11514

NY Lab Id No: 11469

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2016) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Bacteriology

Coliform, Total / E. coli (Qualitative)	SM 21, 23 9222A,B,C
	SM 20, 21-23 9223B (-04) (Colilert)
E. coli (Enumeration)	SM 21, 23 9222A,B,C
Heterotrophic Plate Count	SM 20, 21-23 9215B (-04)

Metals I

Copper, Total	EPA 200.8 Rev. 5.4
Lead, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.8 Rev. 5.4

Miscellaneous

Asbestos	EPA 100.2

Serial No.: 72126

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/, by phone (518) 485-5570 or by email to elap@health.ny.gov.