Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

June 11, 2024

Kyle Kennerknecht
OHM BOCES Oriskany Central School District
1313 Utica Street
Oriskany, NY 13424

RE: Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Dear Kyle Kennerknecht:

Enclosed are the analytical results for sample(s) received by the laboratory on May 31, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Jack M. Germano
jack.germano@pacelabs.com
516-370-6012
Project Manager

Enclosures

cc: OHM BOCES Safety Services, OHM BOCES Oriskany Central School District

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

CERTIFICATIONS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Pace Analytical Services Long Island
575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-001 **Lab ID: 70299841001** Collected: 05/31/24 06:14 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**9.5**	ug/L	1.0	1		06/10/24 15:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-002 **Lab ID: 70299841002** Collected: 05/31/24 06:15 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**1.7**	ug/L	1.0	1		06/10/24 15:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-003 **Lab ID: 70299841003** Collected: 05/31/24 06:16 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**2.0**	ug/L	1.0	1		06/10/24 15:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-004 **Lab ID: 70299841004** Collected: 05/31/24 06:16 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 15:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-005 **Lab ID: 70299841005** Collected: 05/31/24 06:17 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**37.3**	ug/L	1.0	1		06/10/24 15:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-006 **Lab ID: 70299841006** Collected: 05/31/24 06:18 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**4.6**	ug/L	1.0	1		06/10/24 15:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-007 **Lab ID: 70299841007** Collected: 05/31/24 06:19 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**2.8**	ug/L	1.0	1		06/10/24 15:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-008 **Lab ID: 70299841008** Collected: 05/31/24 06:19 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 15:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-009 **Lab ID: 70299841009** Collected: 05/31/24 06:20 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 15:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-010 **Lab ID: 70299841010** Collected: 05/31/24 06:21 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 15:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-011 **Lab ID: 70299841011** Collected: 05/31/24 06:22 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 15:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-012 **Lab ID: 70299841012** Collected: 05/31/24 06:23 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**9.8**	ug/L	1.0	1		06/10/24 15:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-013 **Lab ID: 70299841013** Collected: 05/31/24 06:24 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**2.4**	ug/L	1.0	1		06/10/24 16:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-014 **Lab ID: 70299841014** Collected: 05/31/24 06:25 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 16:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-015 **Lab ID: 70299841015** Collected: 05/31/24 06:27 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 16:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-016 **Lab ID: 70299841016** Collected: 05/31/24 06:28 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**2.5**	ug/L	1.0	1		06/10/24 16:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-017 **Lab ID: 70299841017** Collected: 05/31/24 06:29 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 16:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-018 **Lab ID: 70299841018** Collected: 05/31/24 06:30 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**1.6**	ug/L	1.0	1		06/10/24 16:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-019 **Lab ID: 70299841019** Collected: 05/31/24 06:31 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**3.6**	ug/L	1.0	1		06/10/24 16:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-020 **Lab ID: 70299841020** Collected: 05/31/24 06:42 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 16:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-021 **Lab ID: 70299841021** Collected: 05/31/24 06:43 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**47.6**	ug/L	1.0	1		06/10/24 16:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-022 **Lab ID: 70299841022** Collected: 05/31/24 06:44 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**6.8**	ug/L	1.0	1		06/10/24 16:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-023 **Lab ID: 70299841023** Collected: 05/31/24 06:45 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**5.1**	ug/L	1.0	1		06/10/24 16:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-024 **Lab ID: 70299841024** Collected: 05/31/24 06:48 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**1.5**	ug/L	1.0	1		06/10/24 16:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-025 **Lab ID: 70299841025** Collected: 05/31/24 06:49 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**3.7**	ug/L	1.0	1		06/10/24 16:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-026 **Lab ID: 70299841026** Collected: 05/31/24 06:50 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**4.0**	ug/L	1.0	1		06/10/24 16:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-027 **Lab ID: 70299841027** Collected: 05/31/24 06:51 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**39.7**	ug/L	1.0	1		06/10/24 16:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-028 **Lab ID: 70299841028** Collected: 05/31/24 06:52 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**5.3**	ug/L	1.0	1		06/10/24 16:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-029 **Lab ID: 70299841029** Collected: 05/31/24 06:53 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**5.4**	ug/L	1.0	1		06/10/24 16:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-030 **Lab ID: 70299841030** Collected: 05/31/24 06:54 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**15.1**	ug/L	1.0	1		06/10/24 16:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-031 **Lab ID: 70299841031** Collected: 05/31/24 06:55 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**1.5**	ug/L	1.0	1		06/10/24 16:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-032 **Lab ID: 70299841032** Collected: 05/31/24 06:39 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 16:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-033 **Lab ID: 70299841033** Collected: 05/31/24 06:38 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 16:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-034 **Lab ID: 70299841034** Collected: 05/31/24 06:38 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**2.0**	ug/L	1.0	1		06/10/24 16:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-035 **Lab ID: 70299841035** Collected: 05/31/24 06:04 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**5.8**	ug/L	1.0	1		06/10/24 16:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-036 **Lab ID: 70299841036** Collected: 05/31/24 06:04 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**25.9**	ug/L	1.0	1		06/10/24 16:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-037 **Lab ID: 70299841037** Collected: 05/31/24 06:04 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**12.4**	ug/L	1.0	1		06/10/24 16:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-037A **Lab ID: 70299841038** Collected: 05/31/24 06:05 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**1.5**	ug/L	1.0	1		06/10/24 17:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-038 **Lab ID: 70299841039** Collected: 05/31/24 06:47 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 17:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-039 **Lab ID: 70299841040** Collected: 05/31/24 06:47 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 17:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-049 **Lab ID: 70299841041** Collected: 05/31/24 06:35 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**1.5**	ug/L	1.0	1		06/10/24 17:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-050 **Lab ID: 70299841042** Collected: 05/31/24 06:35 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**1.4**	ug/L	1.0	1		06/10/24 17:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-051 **Lab ID: 70299841043** Collected: 05/31/24 06:34 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 17:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-052 **Lab ID: 70299841044** Collected: 05/31/24 06:34 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 17:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-054 **Lab ID: 70299841045** Collected: 05/31/24 07:04 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**<1.0**	ug/L	1.0	1		06/10/24 17:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-055 **Lab ID: 70299841046** Collected: 05/31/24 07:03 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**2.2**	ug/L	1.0	1		06/10/24 17:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Sample: E-056 **Lab ID: 70299841047** Collected: 05/31/24 07:02 Received: 05/31/24 11:55 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	**18.7**	ug/L	1.0	1		06/10/24 17:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

QUALITY CONTROL DATA

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

QC Batch: 350968
QC Batch Method: EPA 200.8
Analysis Method: EPA 200.8
Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70299841001, 70299841002, 70299841003, 70299841004, 70299841005, 70299841006, 70299841007, 70299841008, 70299841009, 70299841010, 70299841011, 70299841012, 70299841013, 70299841014, 70299841015, 70299841016, 70299841017, 70299841018, 70299841019

METHOD BLANK: 1816984 Matrix: Water
Associated Lab Samples: 70299841001, 70299841002, 70299841003, 70299841004, 70299841005, 70299841006, 70299841007, 70299841008, 70299841009, 70299841010, 70299841011, 70299841012, 70299841013, 70299841014, 70299841015, 70299841016, 70299841017, 70299841018, 70299841019

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/10/24 15:28	

LABORATORY CONTROL SAMPLE: 1816985

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.7	101	85-115	

MATRIX SPIKE SAMPLE: 1816988

Parameter	Units	70299841001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	9.5	50	59.5	100	70-130	

MATRIX SPIKE SAMPLE: 1816990

Parameter	Units	70299841002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.7	50	62.7	122	70-130	

SAMPLE DUPLICATE: 1816987

Parameter	Units	70299841001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	9.5	9.5	1	

SAMPLE DUPLICATE: 1816989

Parameter	Units	70299841002 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.7	1.7	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

QUALITY CONTROL DATA

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

QC Batch: 350969
QC Batch Method: EPA 200.8
Analysis Method: EPA 200.8
Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70299841020, 70299841021, 70299841022, 70299841023, 70299841024, 70299841025, 70299841026, 70299841027, 70299841028, 70299841029, 70299841030, 70299841031, 70299841032, 70299841033, 70299841034, 70299841035, 70299841036, 70299841037, 70299841038, 70299841039

METHOD BLANK: 1816991
Matrix: Water
Associated Lab Samples: 70299841020, 70299841021, 70299841022, 70299841023, 70299841024, 70299841025, 70299841026, 70299841027, 70299841028, 70299841029, 70299841030, 70299841031, 70299841032, 70299841033, 70299841034, 70299841035, 70299841036, 70299841037, 70299841038, 70299841039

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/10/24 16:15	

LABORATORY CONTROL SAMPLE: 1816992

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.8	102	85-115	

MATRIX SPIKE SAMPLE: 1816994

Parameter	Units	70299841020 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	54.9	109	70-130	

MATRIX SPIKE SAMPLE: 1816996

Parameter	Units	70299841021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	47.6	50	96.9	99	70-130	

SAMPLE DUPLICATE: 1816993

Parameter	Units	70299841020 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1816995

Parameter	Units	70299841021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	47.6	46.6	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

QUALITY CONTROL DATA

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

QC Batch: 350970
QC Batch Method: EPA 200.8
Analysis Method: EPA 200.8
Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70299841040, 70299841041, 70299841042, 70299841043, 70299841044, 70299841045, 70299841046, 70299841047

METHOD BLANK: 1816997 Matrix: Water
Associated Lab Samples: 70299841040, 70299841041, 70299841042, 70299841043, 70299841044, 70299841045, 70299841046, 70299841047

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/10/24 17:04	

LABORATORY CONTROL SAMPLE: 1816998

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.2	100	85-115	

MATRIX SPIKE SAMPLE: 1817000

Parameter	Units	70299841040 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	58.2	115	70-130	

MATRIX SPIKE SAMPLE: 1817002

Parameter	Units	70299841041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.5	50	54.9	107	70-130	

SAMPLE DUPLICATE: 1816999

Parameter	Units	70299841040 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1817001

Parameter	Units	70299841041 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.5	1.5	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

QUALIFIERS

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Oriskany CSD 5/31
Pace Project No.: 70299841

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70299841001	**E-001**	EPA 200.8	350968		
70299841002	**E-002**	EPA 200.8	350968		
70299841003	**E-003**	EPA 200.8	350968		
70299841004	**E-004**	EPA 200.8	350968		
70299841005	**E-005**	EPA 200.8	350968		
70299841006	**E-006**	EPA 200.8	350968		
70299841007	**E-007**	EPA 200.8	350968		
70299841008	**E-008**	EPA 200.8	350968		
70299841009	**E-009**	EPA 200.8	350968		
70299841010	**E-010**	EPA 200.8	350968		
70299841011	**E-011**	EPA 200.8	350968		
70299841012	**E-012**	EPA 200.8	350968		
70299841013	**E-013**	EPA 200.8	350968		
70299841014	**E-014**	EPA 200.8	350968		
70299841015	**E-015**	EPA 200.8	350968		
70299841016	**E-016**	EPA 200.8	350968		
70299841017	**E-017**	EPA 200.8	350968		
70299841018	**E-018**	EPA 200.8	350968		
70299841019	**E-019**	EPA 200.8	350968		
70299841020	**E-020**	EPA 200.8	350969		
70299841021	**E-021**	EPA 200.8	350969		
70299841022	**E-022**	EPA 200.8	350969		
70299841023	**E-023**	EPA 200.8	350969		
70299841024	**E-024**	EPA 200.8	350969		
70299841025	**E-025**	EPA 200.8	350969		
70299841026	**E-026**	EPA 200.8	350969		
70299841027	**E-027**	EPA 200.8	350969		
70299841028	**E-028**	EPA 200.8	350969		
70299841029	**E-029**	EPA 200.8	350969		
70299841030	**E-030**	EPA 200.8	350969		
70299841031	**E-031**	EPA 200.8	350969		
70299841032	**E-032**	EPA 200.8	350969		
70299841033	**E-033**	EPA 200.8	350969		
70299841034	**E-034**	EPA 200.8	350969		
70299841035	**E-035**	EPA 200.8	350969		
70299841036	**E-036**	EPA 200.8	350969		
70299841037	**E-037**	EPA 200.8	350969		
70299841038	**E-037A**	EPA 200.8	350969		
70299841039	**E-038**	EPA 200.8	350969		
70299841040	**E-039**	EPA 200.8	350970		
70299841041	**E-049**	EPA 200.8	350970		
70299841042	**E-050**	EPA 200.8	350970		
70299841043	**E-051**	EPA 200.8	350970		
70299841044	**E-052**	EPA 200.8	350970		
70299841045	**E-054**	EPA 200.8	350970		
70299841046	**E-055**	EPA 200.8	350970		
70299841047	**E-056**	EPA 200.8	350970		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace® Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

WO# : 70299841

70299841

Company Name:	OHM Boces_Oriskany CSD	Contact/Report To:	Kyle Kennerknecht
Street Address:	1313 Utica Street, Oriskany, NY 13424	Phone #:	(315) 768-20258
		E-Mail:	kkennerknecht@oriskanycsd.org
		Cc E-Mail:	
Customer Project #:		Invoice To:	Kyle Kennerknecht
Project Name:	Oriskany CSD	Invoice E-Mail:	kkennerknecht@oriskanycsd.org
Site Collection Info/Facility ID (as applicable):	N.A. Walbran Elementary School	Purchase Order # (if applicable):	
		Quote #:	

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [X] ET

County / State origin of sample(s): New York

Data Deliverables:
[ ] Level II [ ] Level III [ ] Level IV
[ ] EQUIS
[ ] Other_____

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
[ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other_____
Date Results Requested: Standard 10 business day

DW PWSID # or WW Permit # as applicable:
Field Filtered (if applicable): [ ] Yes [ ] No
Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW),Sediment (SED), Sludge (SL), Caulk

Specify Container Size **
Identify Container Preservative Type***
Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: Jack Germano; AcctNum / Client ID:; Table #:; Profile / Template: x; Prelog / Bottle Ord. ID:

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start) Date	Collected (or Composite Start) Time	Composite End Date	Composite End Time	Res. Cl2	Number & Type of Containers Plastic	Number & Type of Containers Glass	200.8 Drinking Water (Pb only)	Sample Comment	Preservation non-conformance identified for sample.
E-001	DW	G	5/31/2024	6:14				1		X		
E-002				6:15								
E-003				6:16								
E-004				↓								
E-005				6:17								
E-006				6:18								
E-007				6:19								
E-008				↓								
E-009				6:20								
E-010	↓	↓		6:21				↓		↓		

Customer Remarks / Special Conditions / Possible Hazards:
Lead

Collected By:
Printed Name: William A. Kotas
Signature:

Additional Instructions from Pace®:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C)	Corrected Temp. (°C)
2	TH211	-0.1	23.4	23.3

Relinquished by/Company: (Signature) PSE	Date/Time: 5/31/2024 11:53	Received by/Company: (Signature) PACE	Date/Time: 5/31/24 11:53	Tracking Number:
Relinquished by/Company: (Signature)	Date/Time: 5/31/24 11:55	Received by/Company: (Signature) ACOM	Date/Time: 5/31/24 11:55	Delivered by: [ ] In- Person [ ] Courier
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	[ ] FedEX [ ] UPS [ ] Other
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Page: 1 of 5

Page 5 of 10

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

Scan QR Code for Instructions

Company Name:	OHM Boces_Oriskany CSD	Contact/Report To:	Kyle Kennerknecht
Street Address:	1313 Utica Street, Oriskany, NY 13424	Phone #:	(315) 768-20258
		E-Mail:	kkennerknecht@oriskanycsd.org
		Cc E-Mail:	
Customer Project #:		Invoice To:	Kyle Kennerknecht
Project Name:	Oriskany CSD	Invoice E-Mail:	kkennerknecht@oriskanycsd.org
Site Collection Info/Facility ID (as applicable):	N.A. Walbran Elementary School	Purchase Order # (if applicable):	
		Quote #:	

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT (X) ET

County / State origin of sample(s): New York

Data Deliverables:
[ ] Level II [ ] Level III [ ] Level IV
[ ] EQUIS
[ ] Other_____

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
[ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other_____

Date Results Requested: Standard 10 business day

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): [ ] Yes [ ] No

Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW),Sediment (SED), Sludge (SL), Caulk

Specify Container Size **

Identify Container Preservative Type***

Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: Jack Germano; AcctNum / Client ID:; Table #:; Profile / Template: K; Prelog / Bottle Ord. ID:

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start) Date	Collected (or Composite Start) Time	Composite End Date	Composite End Time	Res. Cl2	Number & Type of Containers Plastic	Number & Type of Containers Glass	200.8 Drinking Water (Pb only)	Sample Comment	Preservation non-conformance identified for sample.
E-011	DW	G	5/31/2024	6:22				1		X		
E-012				6:23								
E-013				6:24								
E-014				6:25								
E-015				6:27								
E-016				6:28								
E-017				6:29								
E-018				6:30								
E-019				6:31								
E-020	↓	↓	↓	6:42				↓		↓		

Customer Remarks / Special Conditions / Possible Hazards:
Lead

Collected By:
Printed Name: William A. Kotas
Signature:

Additional Instructions from Pace®:

Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Tracking Number:
PSC	5/31/2024 11:55	PACE	5/31/24 11:53	
Relinquished by/Company: (Signature)	Date/Time: 5/31/24 11:55	Received by/Company: (Signature)	Date/Time:	Delivered by: [ ] In- Person [ ] Courier
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	[ ] FedEX [ ] UPS [ ] Other
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Page: 2 of 5

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

ENV-FRM-CORQ-0019_v01_082123 ©

Pace® Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

Scan QR Code for instructions

Company Name:	OHM Boces_Oriskany CSD	Contact/Report To:	Kyle Kennerknecht
Street Address:	1313 Utica Street, Oriskany, NY 13424	Phone #:	(315) 768-20258
		E-Mail:	kkennerknecht@oriskanycsd.org
		Cc E-Mail:	
Customer Project #:		Invoice To:	Kyle Kennerknecht
Project Name:	Oriskany CSD	Invoice E-Mail:	kkennerknecht@oriskanycsd.org
Site Collection Info/Facility ID (as applicable):	N.A. Walbran Elementary School	Purchase Order # (if applicable):	
		Quote #:	

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [X] ET

County / State origin of sample(s): New York

Data Deliverables:
[ ] Level II [ ] Level III [ ] Level IV
[ ] EQUIS
[ ] Other_____

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
[ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other_____

Date Results Requested: Standard 10 business day

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): [ ] Yes [ ] No

Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW),Sediment (SED), Sludge (SL), Caulk

Specify Container Size **

Identify Container Preservative Type***

Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only
Proj. Mgr: Jack Germano
AcctNum / Client ID:
Table #:
Profile / Template: x
Prelog / Bottle Ord. ID:

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start) Date	Collected (or Composite Start) Time	Composite End Date	Composite End Time	Res. Cl2	Number & Type of Containers Plastic	Number & Type of Containers Glass	200.8 Drinking Water (Pb only)	Sample Comment	Preservation non-conformance identified for sample
E-021	DW	G	5/31/2024	6:43				1		X		
E-022				6:44								
E-023				6:45								
E-024				6:48								
E-025				6:49								
E-026				6:50								
E-027				6:51								
E-028				6:52								
E-029				6:53								
E-030	↓	↓	↓	6:54				↓		↓		

Customer Remarks / Special Conditions / Possible Hazards:
Lead

Collected By:
Printed Name: William A. Kotas
Signature: [signature]

Additional Instructions from Pace®:

Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Relinquished by/Company: (Signature) [signature] PSC	Date/Time: 5/31/2024 11:53	Received by/Company: (Signature) [signature] PACE	Date/Time: 5/31/24 11:53	Tracking Number:
Relinquished by/Company: (Signature) [signature] Curley	Date/Time: 5/31/24 11:55	Received by/Company: (Signature)	Date/Time:	Delivered by: [ ] In- Person [ ] Courier [ ] FedEx [ ] UPS [ ] Other
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Page: 3 of 5

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

Scan QR Code for instructions

Company Name:	OHM Boces_Oriskany CSD
Street Address:	1313 Utica Street, Oriskany, NY 13424
Customer Project #:	
Project Name:	Oriskany CSD
Site Collection Info/Facility ID (as applicable):	N.A. Walbran Elementary School
Contact/Report To:	Kyle Kennerknecht
Phone #:	(315) 768-20258
E-Mail:	kkennerknecht@oriskanycsd.org
Cc E-Mail:	
Invoice To:	Kyle Kennerknecht
Invoice E-Mail:	kkennerknecht@oriskanycsd.org
Purchase Order # (if applicable):	
Quote #:	

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [X] ET

County / State origin of sample(s): New York

Data Deliverables:
[ ] Level II [ ] Level III [ ] Level IV
[ ] EQUIS
[ ] Other_____

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
[ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other_____
Date Results Requested: Standard 10 business day

DW PWSID # or WW Permit # as applicable:
Field Filtered (if applicable): [ ] Yes [ ] No
Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW),Sediment (SED), Sludge (SL), Caulk

Specify Container Size **
Identify Container Preservative Type***
Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only
Proj. Mgr: Jack Germano
AcctNum / Client ID:
Table #:
Profile / Template: X
Prelog / Bottle Ord. ID:

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start) Date	Collected (or Composite Start) Time	Composite End Date	Composite End Time	Res. CL2	Number & Type of Containers Plastic	Number & Type of Containers Glass	200.8 Drinking Water (Pb only)	Sample Comment	Preservation non-conformance identified for sample
E-031	DW	G	5/31/2024	6:55				1		X		
E-032				6:39								
E-033				6:38								
E-034				↓								
E-035				6:04								
E-036				↓								
E-037				↓								
E-037A (SINK ACROSS KETTLE)				6:05								
E-038				6:47								
E-039	↓	↓	↓	↓				↓		↓		

Customer Remarks / Special Conditions / Possible Hazards:
Lead

Collected By:
Printed Name: William A. Kotas
Signature:

Additional Instructions from Pace®:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C)	Corrected Temp. (°C)

Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Tracking Number:
PSC	5/31/2024 11:53	PACE	5/31/24 11:53	
Relinquished by/Company: (Signature)	5/31/24 11:55	Received by/Company: (Signature)	Date/Time:	Delivered by: [ ] In- Person [ ] Courier
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	[ ] FedEx [ ] UPS [ ] Other
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:	Page: 4 of 5

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

ENV-FRM-CORQ-0019_v01_082123 ©

Pace® Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY- Affix Workorder/Login Label Here

WO#: 70299841

PM: JMG **Due Date: 06/11/24**

CLIENT: OriskanyCSD

Company Name:	OHM Boces_Oriskany CSD
Street Address:	1313 Utica Street, Oriskany, NY 13424
Customer Project #:	
Project Name:	Oriskany CSD
Site Collection Info/Facility ID (as applicable):	N.A. Walbran Elementary School

Contact/Report To:	Kyle Kennerknecht
Phone #:	(315) 768-20258
E-Mail:	kkennerknecht@oriskanycsd.org
Cc E-Mail:	
Invoice To:	Kyle Kennerknecht
Invoice E-Mail:	kkennerknecht@oriskanycsd.org
Purchase Order # (if applicable):	
Quote #:	

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [X] ET

County / State origin of sample(s): New York

Data Deliverables:
[ ] Level II [ ] Level III [ ] Level IV
[ ] EQUIS
[ ] Other_____

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
[ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other_____
Date Results Requested: Standard 10 business day

DW PWSID # or WW Permit # as applicable:
Field Filtered (if applicable): [ ] Yes [ ] No
Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW),Sediment (SED), Sludge (SL), Caulk

Specify Container Size **
Identify Container Preservative Type***
Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only
Proj. Mgr: Jack Germano
AcctNum / Client ID:
Table #:
Profile / Template: X
Prelog / Bottle Ord. ID:

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start) Date	Collected (or Composite Start) Time	Composite End Date	Composite End Time	Res. Cl2	Number & Type of Containers Plastic	Number & Type of Containers Glass	200.8 Drinking Water (Pb only)	Sample Comment	Preservation non-conformance identified for sample
E-049	DW	G	5/31/2024	6:35				1		X		
E-050	"	"		↓				"		"		
E-051				6:34								
E-052				↓								
E-054				7:04								
E-055				7:03								
E-056	↓	↓		7:02				↓		↓		

Customer Remarks / Special Conditions / Possible Hazards:
Lead

Collected By:
Printed Name: William A. Kotas
Signature:

Additional Instructions from Pace®:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C)	Corrected Temp. (°C)

	Date/Time		Date/Time
Relinquished by/Company: (Signature) PSC	5/31/2024 11:53	Received by/Company: (Signature) PACE	5/31/24 11:53
Relinquished by/Company: (Signature)	5/31/24 11:55	Received by/Company: (Signature)	
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:

Tracking Number:

Delivered by: [ ] In- Person [ ] Courier
[ ] FedEx [ ] UPS [ ] Other

Page: 5 of 5

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

DC#_Title: Excel Form Template
Effective Date:

WO#: 70299841
PM: JMG Due Date: 06/11/24
CLIENT: OriskanyCSD

Client Name: Oriskany CSD **Project #**

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☑ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No **Seals intact:** ☐ Yes ☒ No **Temperature Blank Present:** ☐ Yes ☐ No
Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziplo ☒ None ☐ Other **Type of Ice:** Wet Blue (None)

Thermometer Used: TH211 **Correction Factor:** -0.1 ☐ Samples on ice, cooling process has begun
Cooler Temperature(°C): 23.4 **Cooler Temperature Corrected(°C):** 23.3 **Date/Time 5035A kits placed in freezer**
Temp should be above freezing to 6.0°C

USDA Regulated Soil (☒ N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Ye ☐ No

Did samples orignate from a foreign source including Hawaii and Puerto Rico)? ☐ Yes ☐ No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: WK 6/3/24

				COMMENTS:
Chain of Custody Present:	☑Yes	☐No		1.
Chain of Custody Filled Out:	☑Yes	☐No		2.
Chain of Custody Relinquished:	☑Yes	☐No		3.
Sampler Name & Signature on COC:	☑Yes	☐No	☐N/A	4.
Samples Arrived within Hold Time:	☑Yes	☐No		5.
Short Hold Time Analysis (<72hr):	☐Yes	☑No		6.
Rush Turn Around Time Requested	☐Yes	☑No		7.
Sufficient Volume: (Triple volume provided for MS/MSD)	☑Yes	☐No		8.
Correct Containers Used:	☑Yes	☐No		9.
-Pace Containers Used:	☑Yes	☐No		
Containers Intact:	☑Yes	☐No		10.
Filtered volume received for Dissolved tests	☐Yes	☐No	☑N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: -Includes date/time/ID/Analysis Matrix: SL WT OIL OTHER	☑Yes	☐No		12.

Date and Initials of person checking preservation:

All containers needing preservation have been checked.	☑Yes	☐No	☐N/A	13. ☐ HNO_3 ☐ H_2SO_4 ☐ NaOH ☐ HCl
pH paper Lot #				Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO_3, H_2SO_4, HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	☑Yes	☐No	☐N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis				Initial when completed: / Lot # of added preservative: / Date/Time preservative added:
Samples checked for dechlorination:	☐Yes	☐No	☑N/A	14.
KI starch test strips Lot #				
Residual chlorine strips Lot #				Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sul	☐Yes	☐No	☑N/A	15.
Lead Acetate Strips Lot #				Positive for Sulfide? Y N
Headspace in ALK Bottle (>6mm):	☐Yes	☐No	☑N/A	
Headspace in VOA Vials (>6mm):	☐Yes	☐No	☑N/A	16.
Trip Blank Present:	☐Yes	☐No	☑N/A	17.
Trip Blank Custody Seals Present	☐Yes	☐No	☑N/A	

Client Notification/ Resolution: **Field Data Required?** Y / N
Person Contacted: **Date/Time:**
Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.