Conestoga Middle School_LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Main Office Work Room - Staff/Office Faucet	22434601-001SF	10/09/26	3.23
Health Room - Nurse's Sink	22434601-002NS	10/09/26	0.365
Learning Center 2-SCC Study Center 2 - Drinking Fountain	22434601-003DW	10/09/26	0.779
Learning Center 2-SCC Study Center 2 - Staff/Office Faucet *(restricted access)*	22434601-004SF	10/09/26	**14**
Hallway by Library at A2 - Drinking Fountain	22434601-005DW	10/09/26	1.07
Hallway by Library at B2 - Drinking Fountain	22434601-006DW	10/09/26	ND
Learning Computer Lab - Drinking Fountain	22434601-007DW	10/09/26	1.67
Learning Computer Lab - Classroom Faucet	22434601-008CF	10/09/26	1.89
Production Room - Drinking Fountain *(restricted access)*	22434601-009DW	10/09/26	**23.7**
Production Room - Staff/Office Faucet	22434601-010SF	10/09/26	2.06
A1 - Drinking Fountain	22434601-011DW	10/09/26	0.559
A1 - Classroom Faucet	22434601-012CF	10/09/26	1.13
A2 - Drinking Fountain	22434601-013DW	10/09/26	2.54
A2 - Classroom Faucet	22434601-014CF	10/09/26	1.05
A3 - Drinking Fountain	22434601-015DW	10/09/26	0.53
A3 - Classroom Faucet	22434601-016CF	10/09/26	1.94
A4 - Drinking Fountain	22434601-017DW	10/09/26	ND
A4 - Classroom Faucet	22434601-018CF	10/09/26	2.34
A5 - Drinking Fountain	22434601-019DW	10/09/26	1.87
A5 - Classroom Faucet	22434601-020CF	10/09/26	1.02
A6 - Drinking Fountain	22434601-021DW	10/09/26	1.04
A6 - Classroom Faucet	22434601-022CF	10/09/26	1.74
A7 - Drinking Fountain	22434601-023DW	10/09/26	0.649
A7 - Classroom Faucet	22434601-024CF	10/09/26	2.12
A10 - Drinking Fountain	22434601-025DW	10/09/26	0.616
A10 - Classroom Faucet	22434601-026CF	10/09/26	2.92
A11 - Classroom Faucet	22434601-027CF	10/09/26	5.09
A11 - Drinking Fountain	22434601-028DW	10/09/26	2.17
A12 - Classroom Faucet	22434601-029CF	10/09/26	0.73
A12 - Drinking Fountain	22434601-030DW	10/09/26	0.369
Hallway by A13 - Water Bottle Filler	22434601-031WB	10/09/26	ND
Hallway by A13 - Drinking Fountain	22434601-032DW	10/09/26	ND
A13 Break Room - Staff/Office Faucet	22434601-033SF	10/09/26	1.72
B1 - Drinking Fountain	22434601-034DW	10/09/26	8.52
B1 - Classroom Faucet *(restricted access)*	22434601-035CF	10/09/26	**16.3**
B2 - Drinking Fountain	22434601-036DW	10/09/26	2.06
B2 - Classroom Faucet *(restricted access)*	22434601-037CF	10/09/26	**17.2**
B3 - Drinking Fountain	22434601-038DW	10/09/26	1.45
B3 - Classroom Faucet	22434601-039CF	10/09/26	1.24
B4 - Drinking Fountain	22434601-040DW	10/09/26	2.5
B4 - Classroom Faucet	22434601-041CF	10/09/26	8.28
B5 - Drinking Fountain *(restricted access)*	22434601-042DW	10/09/26	**14.4**
B5 - Classroom Faucet *(restricted access)*	22434601-043CF	10/09/26	**11.1**
B6 - Drinking Fountain	22434601-044DW	10/09/26	0.214
B6 - Classroom Faucet	22434601-045CF	10/09/26	2.11
B7 - Drinking Fountain	22434601-046DW	10/09/26	0.31
B7 - Classroom Faucet	22434601-047CF	10/09/26	0.713
B10 - Drinking Fountain	22434601-048DW	10/09/26	0.397
B10 - Classroom Faucet	22434601-049CF	10/09/26	1.8
B11 - Drinking Fountain	22434601-050DW	10/09/26	0.908
B11 - Classroom Faucet	22434601-051CF	10/09/26	2.34
B12 - Drinking Fountain	22434601-052DW	10/09/26	0.809
B12 - Classroom Faucet	22434601-053CF	10/09/26	2.03
Hallway by B13 - Water Bottle Filler	22434601-054WB	10/09/26	ND
Hallway by B13 - Drinking Fountain	22434601-055DW	10/09/26	ND
B13 - Staff/Office Faucet	22434601-056SF	10/09/26	7.22
C1 - Drinking Fountain	22434601-057DW	10/09/26	1.48
C1 - Classroom Faucet	22434601-058CF	10/09/26	2.48

C2 - Drinking Fountain	22434601-059DW	10/09/26	1.99
C2 - Classroom Faucet	22434601-060CF	10/09/26	0.655
C3 - Drinking Fountain	22434601-061DW	10/09/26	1.24
C3 - Classroom Faucet	22434601-062CF	10/09/26	1.26
C4 - Drinking Fountain	22434601-063DW	10/09/26	1.08
C4 - Classroom Faucet	22434601-064CF	10/09/26	2.7
C5 - Drinking Fountain	22434601-065DW	10/09/26	0.255
C5 - Classroom Faucet	22434601-066CF	10/09/26	1.99
C6 - Drinking Fountain	22434601-067DW	10/09/26	1.6
C6 - Classroom Faucet	22434601-068CF	10/09/26	1.4
C7 - Drinking Fountain	22434601-069DW	10/09/26	ND
C7 - Classroom Faucet	22434601-070CF	10/09/26	2.62
C10 - Drinking Fountain	22434601-071DW	10/09/26	1.41
C10 - Classroom Faucet	22434601-072CF	10/09/26	1.67
C11 - Drinking Fountain	22434601-073DW	10/09/26	2.45
C11 - Classroom Faucet	22434601-074CF	10/09/26	1.2
C12 - Drinking Fountain	22434601-075DW	10/09/26	4.08
C12 - Classroom Faucet	22434601-076CF	10/09/26	1.23
Hallway by C13 - Water Bottle Filler	22434601-077WB	10/09/26	ND
Hallway by C13 - Drinking Fountain	22434601-078DW	10/09/26	ND
C13 - Staff/Office Faucet	22434601-079SF	10/09/26	1.45
E1 Band - Drinking Fountain	22434601-080DW	10/09/26	0.406
E1 Band - Classroom Faucet	22434601-081CF	10/09/26	1.54
E2 Music - Drinking Fountain	22434601-082DW	10/09/26	1.27
E2 Music - Classroom Faucet	22434601-083CF	10/09/26	2.75
Hallway at E2 - Water Bottle Filler	22434601-084WB	10/09/26	ND
Hallway at E2 - Drinking Fountain	22434601-085DW	10/09/26	ND
E3 Activity Room - Drinking Fountain	22434601-086DW	10/09/26	ND
E4 - Drinking Fountain	22434601-087DW	10/09/26	2.48
E4 - Classroom Faucet	22434601-088CF	10/09/26	1.2
E5 - Drinking Fountain	22434601-089DW	10/09/26	0.441
E5 - Classroom Faucet	22434601-090CF	10/09/26	0.949
Hallway by E4 or by Laundry Room - Drinking Fountain	22434601-091DW	10/09/26	ND
E8 - Drinking Fountain	22434601-092DW	10/09/26	0.354
E8 - Classroom Faucet	22434601-093CF	10/09/26	0.42
E8 Studio - Classroom Faucet *(restricted access)*	22434601-094CF	10/09/26	**47.7**
E8 Office 1/Lounge - Staff/Office Faucet *(restricted access)*	22434601-095SF	10/09/26	**87.9**
Small Gym - Drinking Fountain	22434601-096DW	10/09/26	0.32
Womens Locker Room - Drinking Fountain	22434601-097DW	10/09/26	ND
Hallway betw Locker Rooms - Drinking Fountain	22434601-098DW	10/09/26	ND
Mens Locker Room - Drinking Fountain	22434601-099DW	10/09/26	0.346
Stage - Drinking Fountain	22434601-100DW	10/09/26	2
Stage - Classroom Faucet	22434601-101CF	10/09/26	1.55
Hallway at Kitchen - Water Bottle Filler	22434601-102WB	10/09/26	ND
Hallway at Kitchen - Drinking Fountain	22434601-103DW	10/09/26	ND
Kitchen - Serving Line - Classroom Faucet	22434601-104CF	10/09/26	8.76
Kitchen - Kettle	22434601-105OT	10/09/26	0.461
Kitchen - Kitchen/Food Prep	22434601-106KF	10/09/26	0.497
Staff Lounge - Staff/Office Faucet	22434601-107SF	10/09/26	ND
Learning Center 3 across from workroom - Drinking Fountain	22434601-108DW	10/09/26	1.37
Learning Center 3 across from workroom - Classroom Faucet	22434601-109CF	10/09/26	0.852