Sample ID	Location	Fixture/Outlet Type	Description	Filtered	11/23/22 (PPM)	11/22/23 (PPM)	Remedial Action
MS-5	Kitchen	sink	serving line side		6	6	Add shared filter with MS-6
MS-6	Kitchen	sink	oven side		7.1	6.4	Add shared filter with MS-5
MS-7	Kitchen	sink	By walk-in cooler		1.6	1.2	
MS-8	108	sink	hot/cold mix faucet		1.2	1	
MS-9	Nurse	sink	hot/cold mix faucet		<1.0	1	
MS-10	Nurse	sink	bathroom - hot/cold mix		<1.0	1.5	
MS-11	Cafeteria	Drinking Fountain	Hall outside cafe - left (higher one) - filtered units		<1.0	<1.0	
MS-12	Cafeteria	Drinking Fountain	Hall outside cafe - right (lower one)- Filtered units		<1.0	<1.0	
MS-13	113	sink	Teacher's Lounge sink		<1.0	<1.0	
MS-23	128	Drinking Fountain	Girls locker room - Right (lower) - filtered unit		<1.0	<1.0	
MS-24	128	Drinking Fountain	Girls locker room- Left (Higher) - filtered unit		<1.0	<1.0	
MS-37	217	Drinking Fountain	Hallway outside 217- Filtered unit- Left (higher)		<1.0	<1.0	
MS-38	217	Drinking Fountain	Hallway outside 217- Filtered unit- Right (Lower)		<1.0	<1.0	
MS-54	313	Drinking Fountain	Hallway across from 313- filtered unit left (higher)		<1.0	<1.0	
MS-55	313	Drinking Fountain	Hallway across from 313- filtered unit - right (lower)		<1.0	1	