Sample ID	Location	Fixture/Outlet Type	Description	Filtered	11/23/22 (PPB)	11/22/23 (PPB)	Remedial Action
HS-4	Fitness Center	Drinking Fountain	Fountain in fitness center - left	Yes	<1.0	<1.0	Replaced in 2024
HS-5	Fitness Center	Drinking Fountain	Fountain in fitness center - right	Yes	<1.0	<1.0	Replaced in 2024
HS-6	Fitness center	Drinking Fountain	Fountain by girls bathroom - left	Yes	2.1	<1.0	Replaced in 2024
HS-7	Fitness Center	Drinking Fountain	Fountain by girls bathroom - right	Yes	2.3	1	Replaced in 2024
HS-10	Pool Area	Drinking Fountain	Fountain outside of pool doors		6	NS	Replace with filtered fountain 2
HS-12	Pool Area	Drinking Fountain	Fountain in pool area		9.1	N/S	Removed from Service
HS-13	Pool Area	Drinking Fountain	sink in pool office		2.2	<1.0	
HS-16	Boys Locker	Drinking Fountain	Boys locker room- bottle filler	Yes	<1.0	<1.0	
HS-17	Boys Locker	Drinking Fountain	Boys locker room - Fountain	Yes	<1.0	<1.0	
HS-22	Girls Locker	Drinking Fountain	Locker room bottle filler	Yes	<1.0	<1.0	
HS-23	Girls Locker	Drinking Fountain	Locker room drinking fountain	Yes	<1.0	<1.0	
HS-27	Kitchen	sink	Prep sink - west		8.1	42	Changed faucet
HS-32	Kitchen	sink	Kettle fill - east	Yes	30	<1.0	
HS-34	Kitchen	sink	Prep sink - east	Yes	50	6.8	Replace fixture 2025
HS-36	Cafeteria	Drinking Fountain	Small cafeteria fountain		3.5	1.1	Replaced in 2024
HS-37	Cafeteria	Drinking Fountain	Large Cafeteria fountain		<1.0	<1.0	Replaced in 2024
HS-39	A-102	Drinking Fountain	Hallway fountain outside boys bathroom		6.9	<1.0	Replaced in 2023
HS-43	A-wing Girls Bathroom	Drinking Fountain	Hallway fountain outside girls bathroom		3.1	<1.0	Replaced in 2024
HS-66	Staff Womens Bathroom	Drinking Fountain	hallway outside women's staff bathroom		4.6	<1.0	Replaced in 2023
HS-78	B-10	sink	classroom sink		12	6.6	Add filter system 2025
HS-87	D-2	sink	north wall sink - left				
HS-88	D-2	sink	north wall sink - right				
HS-110	E-18	Drinking Fountain	Hallway fountain outside E-18		1.2	N/S	Replaced with Filtered unit 202
HS-115	E-wing Boys bathroom	Drinking Fountain	Hallway fountain outside of boys bathroom		4	N/S	Replace with filtered fountain 2
HS-118	E-18	Drinking Fountain	Hallway fountain west of E-18		N/S	N/S	Replace with filtered fountain 2
HS-129	H-5	Drinking Fountain	Hallway fountain outside H-5		5.7	<1.0	