Sample ID	Location	Fixture/Outlet Type	Description	Filtered	11/23/22 (PPB)	11/22/2023 (PPB)	Remedial Action
ES-13	Gym	Drinking Fountain	hall between gym and 145		1.9	3.6	
ES-15	Gym	Drinking Fountain	outside of Boys PE office	Yes	7.3	<1.0	
ES-16	152	Sink	hot/cold mix faucet		1	1.6	
ES-17	152	Drinking Fountain	non-filtered unit		1.6	<1.0	
ES-18	145	Sink	hot/cold mix faucet		1.4	1	
ES-19	145	Drinking Fountain	non-filtered unit		1.2	<1.0	
ES-20	151	Sink	hot/cold mix faucet		<1.0	<1.0	
ES-21	151	Drinking Fountain	non-filtered unit		1.5	1.2	
ES-22	146	Sink	hot/cold mix faucet		1.4	1.8	
ES-23	146	Drinking Fountain	non-filtered unit		<1.0	1	
ES-24	150	Sink	hot/cold mix faucet	Yes	13	2.7	
ES-25	150	Drinking Fountain	non-filtered unit	Yes	4.9	2.7	
ES-26	147	Sink	hot/cold mix faucet		1.4	1.7	
ES-27	147	Drinking Fountain	non-filtered unit		2.3	3.1	
ES-28	149	Sink	hot/cold mix faucet	Yes	6.3	1.6	
ES-29	149	Drinking Fountain	non-filtered unit	Yes	10	1.9	
ES-30	148	Sink	hot/cold mix faucet		2.2	2.2	
ES-31	148	Drinking Fountain	non-filtered unit		4.6	<1.0	
ES-36	129	Drinking Fountain	non-filtered unit		<1.0	3.2	
ES-45	185	Drinking Fountain	hallway outside rm 185		<1.0	<1.0	
ES-46	188	Drinking Fountain	hallway outside rm 188		<1.0	<1.0	
ES-48	127	Drinking Fountain	non-filtered unit		1.2	6.3	Replace with filtered unit
ES-53	128	Drinking Fountain	non-filtered unit		1.1	2.6	
ES-54	125	sink	classroom sink	Yes	32	6.5	Replaced faucet
ES-55	124	snik	hot/cold mix faucet		2.7	3.1	
ES-56	124	Drinking Fountain	non-filtered unit		<1.0	<1.0	
ES-57	123	sink	classroom sink		1.6	1.6	
ES-58	130	sink	classroom sink		3.6	5.1	Add Filter
ES-59	130	Drinking Fountain	non-filtered unit		1.5	1	
ES-60	122	sink	classroom sink		2.1	2	
ES-61	122	Drinking Fountain	non-filtered unit		1.4	1.2	
ES-62	131	sink	classroom sink		2.1	1.2	
ES-63	131	Drinking Fountain	non-filtered unit		2.1	3.3	
ES-64	121	sink	sink by bathrooms		4.9	2.9	
ES-65	121	sink	sink/fountain combo		<1.0	4.3	
ES-66	121	Drinking Fountain	non-filtered unit		2.9	<1.0	
ES-76	12/13	Drinking Fountain	hallway between bathrooms 12 and 13		<1.0	<1.0	
ES-79	Kitchen	sink	middle sinks - left		2	2.9	
ES-82	132	sink	hot/cold mix faucet		N/S	19	Add Filter
ES-83	119	sink	classroom sink		N/S	40	Add non-potable signage
ES-84	111	sink	hot/cold mix faucet			6.1	Add non-potable signage
ES-85	Nurse	Drinking Fountain	Hallway outside nurse's office			<1	
ES-92	107	sink				3	
ES-93	205	sink	clasroom sink		11	25	Remove from service
ES-96	206	sink	classroom sink		30	31	Remove from service
ES-97	200	sink	left sink	Yes	11	52	Remove from service
ES-98	200	sink	right sink	Yes	5.2	33	Remove from service
ES-100	208	sink	classroom sink		37	53	Remove from service
ES-108	306	Drinking Fountain	Hallway outside 306		1.7	<1.0	
ES-111	308	sink	classroom sink		N/S	3.1	