*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

October 12, 2026

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Howard 1 Lead Testing Order No.: 26091057

Dear Andy Chasteen:

Neilson Research Corporation received 47 sample(s) on 9/23/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. Testing was completed in accordance with the laboratory's established quality system and standard operating procedures. For the current scope of NELAP-accredited analytes and certifications, please refer to the Certifications section at www.nrclabs.com.
If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Case Narrative

WO#: **26091057**
Date: **10/12/2026**

**CLIENT:** Medford School District
**Project:** Howard 1 Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-01** Client Sample ID: Staff Wk Rm-Sink
Collection Date: 9/23/2026 5:12:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Staff Wk Rm-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.657 | | 0.500 | ppb | 1 | 10/9/2026 | 15.0 | A |

**Lab ID:** **26091057-02** Client Sample ID: Health Rm-Sink(L)
Collection Date: 9/23/2026 5:14:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Health Rm-Sink(L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.93 | | 0.500 | ppb | 1 | 10/9/2026 | 15.0 | A |

**Lab ID:** **26091057-03** Client Sample ID: Health Rm-Sink(R)
Collection Date: 9/23/2026 5:14:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Health Rm-Sink(R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 4.87 | | 0.500 | ppb | 1 | 10/9/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-04** Client Sample ID: Health Rm-DF (R Sink)
Collection Date: 9/23/2026 5:14:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Health Rm-DF (R Sink)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 2.90 | | 0.500 | ppb | 1 | 10/9/2026 | 15.0 | A |

**Lab ID:** **26091057-05** Client Sample ID: Health Rm-Sink (Bathroom)
Collection Date: 9/23/2026 5:14:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Health Rm-Sink (Bathroom)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.972 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-06** Client Sample ID: Staff Brk Rm-Sink
Collection Date: 9/23/2026 5:18:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Staff Brk Rm-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.647 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-07** Client Sample ID: Girls RR(Across Staff Brk Rm)-Sink(L)
Collection Date: 9/23/2026 5:18:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Girls RR(Across Staff Brk Rm)-Sink(L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.717 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-08** Client Sample ID: Girls RR(Across Staff Brk Rm)-Sink(R)
Collection Date: 9/23/2026 5:18:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Girls RR(Across Staff Brk Rm)-Sink(R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.955 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-09** Client Sample ID: Boys RR(By Music Rm)-Sink(L)
Collection Date: 9/23/2026 5:20:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Boys RR(By Music Rm)-Sink(L)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.43 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-10** Client Sample ID: Boys RR(Across Music Rm)-Sink(R)
Collection Date: 9/23/2026 5:20:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Boys RR(Across Music Rm)-Sink(R)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 5.08 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-11** Client Sample ID: Rm 2-DF
Collection Date: 9/23/2026 5:21:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 2-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 3.11 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-12** Client Sample ID: Rm 2-Sink
Collection Date: 9/23/2026 5:21:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 2-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 5.88 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-13** Client Sample ID: Rm 3-DF
Collection Date: 9/23/2026 5:23:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 3-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 3.56 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-14** Client Sample ID: Rm 3-Sink
Collection Date: 9/23/2026 5:23:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 3-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 4.28 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-15** Client Sample ID: Rm 4-DF
Collection Date: 9/23/2026 5:23:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 4-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.78 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-16** Client Sample ID: Rm 4-Sink
Collection Date: 9/23/2026 5:23:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 4-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 2.29 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-17** Client Sample ID: Rm 5-DF
Collection Date: 9/23/2026 5:25:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 5-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 23.9 | *1 | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-18** Client Sample ID: Rm 5-Sink
Collection Date: 9/23/2026 5:25:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 5-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 5.40 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-19** Client Sample ID: Rm 6-DF
Collection Date: 9/23/2026 5:26:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 6-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.37 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-20** Client Sample ID: Rm 6-Sink
Collection Date: 9/23/2026 5:26:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 6-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-21** Client Sample ID: Rm 7-DF
Collection Date: 9/23/2026 5:28:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 7-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.851 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-22** Client Sample ID: Rm 7-Sink
Collection Date: 9/23/2026 5:29:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 7-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.14 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-23** Client Sample ID: Rm 11-DF
Collection Date: 9/23/2026 5:33:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 11-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.561 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-24** Client Sample ID: Rm 11-Sink
Collection Date: 9/23/2026 5:33:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 11-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.99 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-25** Client Sample ID: Rm 12-DF
Collection Date: 9/23/2026 5:33:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 12-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.905 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-26** Client Sample ID: Rm 12-Sink
Collection Date: 9/23/2026 5:33:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 12-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.30 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-27** Client Sample ID: Rm 13-DF
Collection Date: 9/23/2026 5:37:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 13-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.903 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-28** Client Sample ID: Rm 13-Sink
Collection Date: 9/23/2026 5:37:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 13-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.876 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-29** Client Sample ID: Rm 14-DF
Collection Date: 9/23/2026 5:42:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 14-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.57 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-30** Client Sample ID: Rm 14-Sink
Collection Date: 9/23/2026 5:42:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 14-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 3.20 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-31** Client Sample ID: Rm 15-DF
Collection Date: 9/23/2026 5:43:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 15-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.33 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-32** Client Sample ID: Rm 15-Sink
Collection Date: 9/23/2026 5:43:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 15-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.41 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-33** Client Sample ID: Rm 15-Sink (RR)
Collection Date: 9/23/2026 5:43:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 15-Sink (RR)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 15.7 | *1 | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-34** Client Sample ID: Rm 16-DF
Collection Date: 9/23/2026 5:46:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 16-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.683 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-35** Client Sample ID: Rm 16-Sink
Collection Date: 9/23/2026 5:46:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 16-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-36** Client Sample ID: Rm 16-Sink (RR)
Collection Date: 9/23/2026 5:46:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 16-Sink (RR)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-37** Client Sample ID: Rm 17-DF
Collection Date: 9/23/2026 5:51:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 17-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.06 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-38** Client Sample ID: Rm 17-Sink
Collection Date: 9/23/2026 5:51:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 17-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-39** Client Sample ID: Rm 17-Sink (RR)
Collection Date: 9/23/2026 5:51:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 17-Sink (RR)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 2.40 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-40** Client Sample ID: Rm 18-DF
Collection Date: 9/23/2026 5:55:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 18-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.53 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-41** Client Sample ID: Rm 18-Sink
Collection Date: 9/23/2026 5:55:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 18-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 3.92 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-42** Client Sample ID: Rm 19-DF
Collection Date: 9/23/2026 5:57:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 19-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.941 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-43** Client Sample ID: Rm 19-Sink
Collection Date: 9/23/2026 5:57:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 19-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.76 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-44** Client Sample ID: Rm 20-DF
Collection Date: 9/23/2026 5:57:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 20-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.36 | | 0.515 | ppb | 1 | 10/8/2026 | 15.0 | A |

**Lab ID:** **26091057-45** Client Sample ID: Rm 20-Sink
Collection Date: 9/23/2026 5:57:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: Rm 20-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 10/9/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Analytical Report

WO#: **26091057**
Date Reported: **10/12/2026**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 26091057
**Received Date:** 9/23/2026 10:36:00 AM
**Reported Date:** 10/12/2026 4:12:26 PM

Sample Information:

**Lab ID:** **26091057-46** Client Sample ID: O/S Staff Brk Rm Elkay Btl Filler(Up)
Collection Date: 9/23/2026 5:55:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: O/S Staff Brk Rm Elkay Btl Filler(Up)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 10/9/2026 | 15.0 | A |

**Lab ID:** **26091057-47** Client Sample ID: O/S Staff Brk Rm Elkay Btl Filler(Low)
Collection Date: 9/23/2026 5:55:00 AM Collected By: Roger Moulard
Matrix: Drinking Water Sample Location: O/S Staff Brk Rm Elkay Btl Filler(Low)

Trace Metals by EPA 200.8 ICP-MS — Analyst; MDS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 10/9/2026 | 15.0 | A |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: **26091057**

***12-Oct-26***

**Client:** Medford School District
**Project:** Howard 1 Lead Testing

**TestCode:** **LEAD_SCHOOLS**

| Sample ID: | **MB-38608** | SampType: | **MBLK** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/7/2026** | RunNo: | **73409** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **PBW** | Batch ID: | **38608** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/8/2026** | SeqNo: | **1219278** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | ND | 0.515 | | | | | | | | | |

| Sample ID: | **LCS-38608** | SampType: | **LCS** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/7/2026** | RunNo: | **73409** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **LCSW** | Batch ID: | **38608** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/8/2026** | SeqNo: | **1219279** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 98.5 | 0.520 | 100 | 0 | 98.5 | 85 | 115 | | | | |

| Sample ID: | **26091057-25AMS** | SampType: | **MS** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/7/2026** | RunNo: | **73409** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **Rm 12-DF** | Batch ID: | **38608** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/8/2026** | SeqNo: | **1219281** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 97.2 | 0.520 | 100 | 0.905 | 96.3 | 70 | 130 | | | | |

| Sample ID: | **26091057-25AMSD** | SampType: | **MSD** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/7/2026** | RunNo: | **73409** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **Rm 12-DF** | Batch ID: | **38608** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/8/2026** | SeqNo: | **1219282** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 97.2 | 0.520 | 100 | 0.905 | 96.3 | 70 | 130 | 97.2 | 0.0364 | 20 | |

**Qualifiers:**

| | | | | | |
|---|---|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode | DF | Dilution Factor |
| H | Holding times for preparation or analysis exceeded | MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| RL | Reporting Limit | | | | |

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: **26091057**

***12-Oct-26***

**Client:** Medford School District
**Project:** Howard 1 Lead Testing

**TestCode:** **LEAD_SCHOOLS**

| Sample ID: | MB-38578 | SampType: | MBLK | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 10/5/2026 | RunNo: | 73409 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | PBW | Batch ID: | 38578 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 10/8/2026 | SeqNo: | 1219306 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | ND | 0.515 | | | | | | | | | |

| Sample ID: | LCS-38578 | SampType: | LCS | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 10/5/2026 | RunNo: | 73409 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | LCSW | Batch ID: | 38578 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 10/8/2026 | SeqNo: | 1219307 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 101 | 0.520 | 100 | 0 | 101 | 85 | 115 | | | | |

| Sample ID: | 26091057-05AMS | SampType: | MS | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 10/5/2026 | RunNo: | 73409 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | Health Rm-Sink (Bat | Batch ID: | 38578 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 10/8/2026 | SeqNo: | 1219309 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 99.2 | 0.520 | 100 | 0.972 | 98.2 | 70 | 130 | | | | |

| Sample ID: | 26091057-05AMSD | SampType: | MSD | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 10/5/2026 | RunNo: | 73409 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | Health Rm-Sink (Bat | Batch ID: | 38578 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 10/8/2026 | SeqNo: | 1219310 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 100 | 0.520 | 100 | 0.972 | 99.5 | 70 | 130 | 99.2 | 1.27 | 20 | |

**Qualifiers:**

| | | | | | |
|---|---|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode | DF | Dilution Factor |
| H | Holding times for preparation or analysis exceeded | MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| RL | Reporting Limit | | | | |

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: **26091057**

***12-Oct-26***

**Client:** Medford School District
**Project:** Howard 1 Lead Testing

**TestCode:** **LEAD_SCHOOLS**

| Sample ID: | **MB-38577** | SampType: | **MBLK** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/5/2026** | RunNo: | **73409** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **PBW** | Batch ID: | **38577** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/8/2026** | SeqNo: | **1219334** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | ND | 0.500 | | | | | | | | | |

| Sample ID: | **LCS-38577** | SampType: | **LCS** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/5/2026** | RunNo: | **73409** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **LCSW** | Batch ID: | **38577** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/8/2026** | SeqNo: | **1219335** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 97.5 | 0.500 | 100 | 0 | 97.5 | 85 | 115 | | | | |

| Sample ID: | **26091052-19AMS** | SampType: | **MS** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/5/2026** | RunNo: | **73409** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **BatchQC** | Batch ID: | **38577** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/8/2026** | SeqNo: | **1219337** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 98.9 | 2.50 | 100 | 0.830 | 98.1 | 70 | 130 | | | | |

| Sample ID: | **26091052-19AMSD** | SampType: | **MSD** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/5/2026** | RunNo: | **73409** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **BatchQC** | Batch ID: | **38577** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/8/2026** | SeqNo: | **1219338** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 98.5 | 2.50 | 100 | 0.830 | 97.7 | 70 | 130 | 98.9 | 0.415 | 20 | |

**Qualifiers:**

| | | | | | |
|---|---|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode | DF | Dilution Factor |
| H | Holding times for preparation or analysis exceeded | MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| RL | Reporting Limit | | | | |

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: **26091057**

***12-Oct-26***

**Client:** Medford School District
**Project:** Howard 1 Lead Testing

**TestCode:** **LEAD_SCHOOLS**

| Sample ID: | **MB-38611** | SampType: | **MBLK** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/7/2026** | RunNo: | **73450** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **PBW** | Batch ID: | **38611** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/9/2026** | SeqNo: | **1219977** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | ND | 0.515 | | | | | | | | | |

| Sample ID: | **LCS-38611** | SampType: | **LCS** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/7/2026** | RunNo: | **73450** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **LCSW** | Batch ID: | **38611** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/9/2026** | SeqNo: | **1219978** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 99.9 | 0.520 | 100 | 0 | 99.9 | 85 | 115 | | | | |

| Sample ID: | **26091057-45AMS** | SampType: | **MS** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/7/2026** | RunNo: | **73450** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **Rm 20-Sink** | Batch ID: | **38611** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/9/2026** | SeqNo: | **1219980** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 99.2 | 0.520 | 100 | 0.495 | 98.7 | 70 | 130 | | | | |

| Sample ID: | **26091057-45AMSD** | SampType: | **MSD** | TestCode: | **LEAD_SCHO** | Units: | **ppb** | Prep Date: | **10/7/2026** | RunNo: | **73450** |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | **Rm 20-Sink** | Batch ID: | **38611** | TestNo: | **E200.8** | **E200.8** | | Analysis Date: | **10/9/2026** | SeqNo: | **1219981** |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 99.0 | 0.520 | 100 | 0.495 | 98.5 | 70 | 130 | 99.2 | 0.147 | 20 | |

**Qualifiers:**

| | | | | | |
|---|---|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode | DF | Dilution Factor |
| H | Holding times for preparation or analysis exceeded | MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| RL | Reporting Limit | | | | |

Original

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Sample Log-In Check List

Client Name: MedfordSchoolDist Work Order Number: 26091057 RcptNo: 1

| | | | |
|---|---|---|---|
| Logged by: | Ashley Spiegelberg | 9/23/2026 10:36:00 AM | |
| Completed By: | Kyler Woolsey | 9/25/2026 12:14:43 PM | |
| Reviewed By: | Dorie Evans | 10/12/2026 4:05:29 PM | |

## Chain of Custody

1. Is Chain of Custody complete? Yes ☑ No ☐ Not Present ☐
2. How was the sample delivered? Client

## Log In

3. Coolers are present? Yes ☐ No ☐ NA ☑
4. Shipping container/cooler in good condition? Yes ☑ No ☐
   Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☑ NA ☐
   No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☑
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☑
7. Sample(s) in proper container(s)? Yes ☑ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☑ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☑ No ☐
10. Was preservative added to bottles? Yes ☐ No ☑ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☑
12. Were any sample containers received broken? Yes ☐ No ☑
13. Does paperwork match bottle labels? (Note discrepancies on chain of custody) Yes ☑ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☑ No ☐
15. Is it clear what analyses were requested? Yes ☑ No ☐
16. Were all holding times able to be met? (If no, notify customer for authorization.) Yes ☑ No ☐

## Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☑

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

| Cooler No | Temp ºC | Condition | Seal Intact | Seal No | Seal Date | Signed By |
|---|---|---|---|---|---|---|

NEILSON RESEARCH CORPORATION
Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.



**Section A**
**Required Client Information**

Company: MSD 549C
Address: 900 Kenyon
Medford, OR 97501
Email: andy.chasteen@medford.k12.or.us
Phone: 541-840-4315 Fax:
Collected By (Print): Roger Maulard
Collected By (Sign):
Email Report ___ Yes ___ No Mail Report ___ Yes ___ No
Fax Report ___ Yes ___ No

**Section B**
**Required Project Information**

Project Name: Howard 1
Project Number:
Report andy.chasteen@medford.k12.or
Copy T seth.barry@medford.k12.or.us

**Section C**
**Invoice Information**

Attention: Accounting
Company Name: Medford School District
Address: 900 Kenyon
Medford, OR 97501
P.O. #

**Section D**
**Rush Status (Subject to Scheduling)**

___ Standard 10-14 Days
___ 5 Business Days (50% surcharge)
___ 3 Business Days (75% surcharge)
___ 24 - 48 hours (100% surcharge)
___ Other _____
Authorized ____ Yes ____ No

**Section E**
**Sample Information**

NRC Workorder # (Lab Use Only) 26091057

| Sample ID | Matrix* | Date Collected | Time Collect | No. of Containers | Analysis Requested | Remarks/Field Data | NRC Sample # (Lab Use Only) |
|---|---|---|---|---|---|---|---|
| Staff Work Room - Sink | DW | 9/23/2026 | 5:12 | 1 | | | 01 |
| Health Room - Sink (Left) | DW | 9/23/2026 | 5:14 | 1 | | | 02 |
| Health Room - Sink (Right) | DW | 9/23/2026 | 5:14 | 1 | | | 03 |
| Health Room - Drinking Fountain (Right Sink) | DW | 9/23/2026 | 5:14 | 1 | | | 04 |
| Health Room - Sink (Bathroom) | DW | 9/23/2026 | 5:14 | 1 | | | 05 |
| Staff Break Room - Sink | DW | 9/23/2026 | 5:18 | 1 | | | 06 |
| Girls Restroom (Across From Staff Break Room) - Sink (Left) | DW | 9/23/2026 | 5:18 | 1 | | | 07 |
| Girls Restroom (Across From Staff Break Room) - Sink (Right) | DW | 9/23/2026 | 5:18 | 1 | | | 08 |
| Boys Restroom (Across From Music Room) - Sink (Left) | DW | 9/23/2026 | 5:20 | 1 | | | 09 |
| Boys Restroom (Across From Music Room) - Sink (Right) | DW | 9/23/2026 | 5:20 | 1 | | | 10 |
| Room 2 - Drinking Fountain | DW | 9/23/2026 | 5:21 | 1 | | | 11 |
| Room 2 - Sink | DW | 9/23/2026 | 5:21 | 1 | | | 12 |
| Room 3 - Drinking Fountain | DW | 9/23/2026 | 5:23 | 1 | | | 13 |
| Room 3 - Sink | DW | 9/23/2026 | 5:23 | 1 | | | 14 |
| Room 4 - Drinking Fountain | DW | 9/23/2026 | 5:23 | 1 | | | 15 |
| Room 4 - Sink | DW | 9/23/2026 | 5:23 | 1 | | | 16 |
| Room 5 - Drinking Fountain | DW | 9/23/2026 | 5:25 | 1 | | | 17 |
| Room 5 - Sink | DW | 9/23/2026 | 5:25 | 1 | | | 18 |
| Room 6 - Drinking Fountain | DW | 9/23/2026 | 5:26 | 1 | | | 19 |
| Room 6 - Sink | DW | 9/23/2026 | 5:26 | 1 | | | 20 |
| Room 7 - Drinking Fountain | DW | 9/23/2026 | 5:28 | 1 | | | 21 |
| Room 7 - Sink | DW | 9/23/2026 | 5:29 | 1 | | | 22 |
| Room 8 - Sink | DW | 9/23/2026 | 5:30 | 1 | | | ERROR 23 |
| Room 9 - Sink | DW | 9/23/2026 | 5:32 | 1 | | | DE 24 |

| | | | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Room 11 - Drinking Fountain | DW | 9/23/2026 | 5:27 | 1 | | | | | | | | | | | 23 | 25 |
| Room 11 - Sink | DW | 9/23/2026 | 5:27 | 1 | | | | | | | | | | | 24 | 26 |
| Room 12 - Drinking Fountain | DW | 9/23/2026 | 5:33 | 1 | | | | | | | | | | | 25 | 27 |
| Room 12 - Sink | DW | 9/23/2026 | 5:33 | 1 | | | | | | | | | | | 26 | 28 |
| Room 13 - Drinking Fountain | DW | 9/23/2026 | 5:37 | 1 | | | | | | | | | | | 27 | 29 |
| Room 13 - Sink | DW | 9/23/2026 | 5:37 | 1 | | | | | | | | | | | 28 | 30 |
| Room 14 - Drinking Fountain | DW | 9/23/2026 | 5:42 | 1 | | | | | | | | | | | 29 | 31 |
| Room 14 - Sink | DW | 9/23/2026 | 5:42 | 1 | | | | | | | | | | | 30 | 32 |
| Room 15 - Drinking Fountain | DW | 9/23/2026 | 5:43 | 1 | | | | | | | | | | | 31 | 33 |
| Room 15 - Sink | DW | 9/23/2026 | 5:43 | 1 | | | | | | | | | | | 32 | 34 |
| Room 15 - Sink (Restroom) | DW | 9/23/2026 | 5:43 | 1 | | | | | | | | | | | 33 | 35 |
| Room 16 - Drinking Fountain | DW | 9/23/2026 | 5:46 | 1 | | | | | | | | | | | 34 | 36 |
| Room 16 - Sink | DW | 9/23/2026 | 5:46 | 1 | | | | | | | | | | | 35 | 37 |
| Room 16 - Sink (Restroom) | DW | 9/23/2026 | 5:46 | 1 | | | | | | | | | | | 36 | 38 |
| Room 17 - Drinking Fountain | DW | 9/23/2026 | 5:51 | 1 | | | | | | | | | | | 37 | 39 |
| Room 17 - Sink | DW | 9/23/2026 | 5:51 | 1 | | | | | | | | | | | 38 | 40 |
| Room 17 - Sink (Restroom) | DW | 9/23/2026 | 5:51 | 1 | | | | | | | | | | | 39 | 41 |
| Room 18 - Drinking Fountain | DW | 9/23/2026 | 5:55 | 1 | | | | | | | | | | | 40 | 42 |
| Room 18 - Sink | DW | 9/23/2026 | 5:55 | 1 | | | | | | | | | | | 41 | 43 |
| Room 19 - Drinking Fountain | DW | 9/23/2026 | 5:57 | 1 | | | | | | | | | | | 42 | 44 |
| Room 19 - Sink | DW | 9/23/2026 | 5:57 | 1 | | | | | | | | | | | 43 | 45 |
| Room 20 - Drinking Fountain | DW | 9/23/2026 | 5:57 | 1 | | | | | | | | | | | 44 | 46 |
| Room 20 - Sink | DW | 9/23/2026 | 5:57 | 1 | | | | | | | | | | | 45 | 47 |
| Outside Staff Breakroom Elkay Bottle Filler (Upper) | DW | 9/23/2026 | 5:53 | 1 | | | | | | | | | | | 46 | 48 |
| Outside Staff Breakroom Elkay Drinking Fountain (Lower) | DW | 9/23/2026 | 5:55 | 1 | | | | | | | | | | | 47 | 49 |
| | DW | 9/23/2026 | | 1 | | | | | | | | | | | | |
| | DW | 9/23/2026 | | 1 | | | | | | | | | | | | |
| | | | | 1 | | | | | | | | | | | | |
| | | | | 1 | | | | | | | | | | | | |
| | | | | 1 | | | | | | | | | | | | |
| | | | | 1 | | | | | | | | | | | | |
| | | | | 1 | | | | | | | | | | | | |

*Matrix: **DW** - Drinking Water **WW** - Wastewater **W** - Water **S** - Soil/Solid **SL** - Sludge **O** - Oil **WP** - Wipe **OT** - Other

**Section F**
**Relinquish/Receive**

| | Sign | Print | Date | Time |
|---|---|---|---|---|
| Relinquished By: | | Roger Mouland | 9-23-26 | 6:25 |
| Received By: | | SETH BARRY | 9/23/26 | 6:26 |
| Relinquished By: | | SETH BARRY | 9/23/26 | |
| Received By: | | | | |
| Relinquished By: | | | | |
| Received By Laboratory: | | Ashley Spiegelberg | 9/23/26 | 10:36 |

**Section G**
**Lab Use Only**

| |
|---|
| Temp: |
| 4°C +/- 2°C: Yes No |
| Received on Ice: ___ Yes ___ No |
| Number of Bottles Received: |
| pH Checked: |
| COC Seals Intact: ___ Yes ___ No ___ NA |
| Field Blank Included: ___ Yes ___ No |

Received Via ___ UPS ___ FedEX ___ Other ___ Hand

Payment: ___ Invoice ___ Cash ___ VISA, M/C ___ Check # _____ Amount _____

Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

# Data Flags

WO#: **26091057**
Date: **10/12/2026**

A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
B Analyte detected in the associated method blank.
C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF Results confirmed by re-analysis.
CU Cleanup performed as specified by method.
E Estimated value.
ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
HP Sample re-analysis performed outside of method specified holding time.
HR Sample received outside of method specified holding time.
HS Sample analyzed for volatile organics contained headspace.
HT At the client's request, the sample was analyzed outside of method specified holding time.
H Analysis performed outside of method specified holding time.
J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
N See Case Narrative on page 2 of report.
Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R Relative percent difference (RPD) is outside of the accepted recovery limits.
R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC Sub-contracted to another laboratory for analysis.
SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.

* Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
1 Value exceeds one half of the Maximum Contaminant Level.