Traut Water Analysis Lab

State of MN Laboratory ID #027-145-121
32640 County Road 133 St. Joseph, MN 56374

Property:	Stride Academy
Address:	3241 Oakham Lane St Cloud, MN 56301
Report Date:	11/13/2026
Collected By:	Kelsey Klaphake
Received By:	Kelsey Klaphake
Temperature (°C):	8.2°C

Sample Number	Analysis**	Sample Collection	Result (µg/L)	Collection Date	Collection Time	Analysis Date/Time***
262244	Lead	177	<1.0	10/27/2026	1032	11-3-2026 1248
262245	Lead	105	2.14	10/27/2026	1037	11-3-2026 1250
262246	Lead	Utility Riser	<1.0	10/27/2026	1028	11-3-2026 1251
262247	Lead	Outside 2	1.24	10/27/2026	1045	11-3-2026 1350

Comments:
samples taken after water was ran for 15 seconds

Methods & Reporting Limits:
EPA 200.8, Reporting limit: <1.0 µg/L
** This report contains data that were produced by a subcontracted lab certified for the fields of testing performed
***RMB Laboratories, 501 Highway 13 East Suite 104 Burnsville, MN 55337 ID# 027-053-475

The above analysis and report were approved by:

Kelsey Klaphake

Kelsey Klaphake