Traut Water Analysis Lab

State of MN Laboratory ID #027-145-121
32640 County Road 133 St. Joseph, MN 56374

Property:	Stride Academy Middle School
Address:	3701 33rd Street S St. Cloud, MN 56301
Report Date:	11/13/2026
Collected By:	Kelsey Klaphake
Received By:	Kelsey Klaphake
Temperature (°C):	8.2°C

Sample Number	Analysis**	Sample Collection	Result (µg/L)	Collection Date	Collection Time	Analysis Date/Time***
262230	Lead	118B	<1.0	10/27/2026	0938	11-3-2026 1218
262231	Lead	117B	<1.0	10/27/2026	0940	11-3-2026 1222
262232	Lead	209B	<1.0	10/27/2026	0943	11-3-2026 1223
262233	Lead	242A	<1.0	10/27/2026	0947	11-3-2026 1225
262234	Lead	239A	<1.0	10/27/2026	0950	11-3-2026 1229
262235	Lead	239B	<1.0	10/27/2026	0951	11-3-2026 1230
262236	Lead	237B	<1.0	10/27/2026	0954	11-3-2026 1232
262237	Lead	Outside 1	<1.0	10/27/2026	1002	11-3-2026 1233
262238	Lead	Outside 2	<1.0	10/27/2026	0959	11-3-2026 1234
262239	Lead	Outside 3	1.83	10/27/2026	0958	11-3-2026 1236
262240	Lead	Outside 5	1.09	10/27/2026	10313	11-3-2026 1237
262241	Lead	Outside 6	5.56	10/27/2026	1010	11-3-2026 1244
262242	Lead	Outside 7	6.2	10/27/2026	1008	11-3-2026 1246
262243	Lead	Outside 8	<1.0	10/27/2026	1005	11-3-2026 1247

Comments:
samples taken after water was ran for 15 seconds

Methods & Reporting Limits:
EPA 200.8, Reporting limit: <1.0 µg/L
** This report contains data that were produced by a subcontracted lab certified for the fields of testin g performed.
***RMB Laboratories, 501 Highway 13 East Suite 104 Burnsville, MN 55337 ID# 027-053-475

The above analysis and report were approved by: Kelsey Klaphake