Traut Water Analysis Lab

State of MN Laboratory ID #027-145-121
32640 County Road 133 St. Joseph, MN 56374

Property:	Stride Academy Middle School
Address:	3701 33rd Street S St. Cloud, MN 56301
Report Date:	8/5/2026
Collected By:	Kelsey Klaphake
Received By:	Kelsey Klaphake
Temperature (°C):	17.4°C

Sample Number	Analysis**	Sample Collection	Result (µg/L)	Collection Date	Collection Time	Analysis Date/Time***
260885	Lead	109A	<2.0	6/19/2026	0853	6-29-2026 1225
260886	Lead	109B	<2.0	6/19/2026	0853	6-29-2026 1233
260887	Lead	107A	<2.0	6/19/2026	0855	6-29-2026 1236
260888	Lead	107B	<2.0	6/19/2026	0855	7-2-2026 0940
260889	Lead	105A	3.1	6/19/2026	0857	7-2-2026 0953
260890	Lead	105B	<2.0	6/19/2026	0857	7-2-2026 0956
260891	Lead	103A	<2.0	6/19/2026	0859	7-2-2026 0959
260892	Lead	103B	<2.0	6/19/2026	0859	7-2-2026 1002
260893	Lead	101A	<2.0	6/19/2026	0902	6-29-2026 1239
260894	Lead	101B	<2.0	6/19/2026	0902	6-29-2026 1247
260895	Lead	100A	<2.0	6/19/2026	0904	6-29-2026 1250
260896	Lead	100B	<2.0	6/19/2026	0904	6-29-2026 1252
260897	Lead	102A	<2.0	6/19/2026	0905	6-29-2026 1255
260898	Lead	102B	<2.0	6/19/2026	0905	6-29-2026 1258
260899	Lead	104A	<2.0	6/19/2026	0906	7-2-2026 1004
260900	Lead	104B	<2.0	6/19/2026	0906	6-30-2026 1624
260901	Lead	Bathroom A	<2.0	6/19/2026	0908	6-29-2026 1300
260902	Lead	Bathroom B	<2.0	6/19/2026	0918	6-30-2026 1303
260903	Lead	116A	<2.0	6/19/2026	0911	6-29-2026 1311
260904	Lead	116B	<2.0	6/19/2026	0911	6-29-2026 1342
260905	Lead	118A	<2.0	6/19/2026	0913	6-30-2026 1356
260906	Lead	118B	5.5	6/19/2026	0913	6-30-2026 1627
260907	Lead	117A	2.8	6/19/2026	0915	6-30-2026 1635
260908	Lead	117B	5.8	6/19/2026	0915	6-30-2026 1638
260909	Lead	119A	<2.0	6/19/2026	0915	6-29-2026 1358
260910	Lead	119B	<2.0	6/19/2026	0915	6-29-2026 1401
260911	Lead	Bathroom C	<2.0	6/19/2026	0917	6-29-2026 1404
260912	Lead	124A	<2.0	6/19/2026	0922	6-30-2026 1640
260913	Lead	124B	<2.0	6/19/2026	0922	6-30-2026 1643
260914	Lead	126A	<2.0	6/19/2026	0923	6-30-2026 1648
260915	Lead	126B	<2.0	6/19/2026	0923	6-29-2026 1406
260916	Lead	128A	<2.0	6/19/2026	0924	6-29-2026 1409
260917	Lead	128B	<2.0	6/19/2026	0924	6-29-2026 1412
260918	Lead	129A	<2.0	6/19/2026	0925	6-30-2026 1708
260919	Lead	129B	<2.0	6/19/2026	0925	6-29-2026 1415
260920	Lead	127A	<2.0	6/19/2026	0927	6-30-2026 1710
260921	Lead	127B	<2.0	6/19/2026	0927	6-30-2026 1713
260922	Lead	125A	<2.0	6/19/2026	0929	6-30-2026 1716

260923	Lead	125B	<2.0	6/19/2026	0929	6-29-2026 1417
260924	Lead	132A	<2.0	6/19/2026	0938	6-29-2026 1426
260925	Lead	132B	<2.0	6/19/2026	0938	6-29-2026 1434
260926	Lead	134A	<2.0	6/19/2026	0939	6-29-2026 1437
260927	Lead	134B	<2.0	6/19/2026	0939	6-29-2026 1440
260928	Lead	137A - Drink	2.3	6/19/2026	0947	6-29-2026 1442
260929	Lead	137B - Fountain	<2.0	6/19/2026	0947	6-29-2026 1445
260930	Lead	Bathroom D	<2.0	6/19/2026	0949	6-29-2026 1448
260931	Lead	140A	<2.0	6/19/2026	0952	6-29-2026 1450
260932	Lead	140B	<2.0	6/19/2026	0952	6-29-2026 1459
260933	Lead	142A	<2.0	6/19/2026	0952	6-29-2026 1532
260934	Lead	142B	<2.0	6/19/2026	0952	6-29-2026 1534
260935	Lead	144A	<2.0	6/19/2026	0953	6-30-2026 1719
260936	Lead	144B	<2.0	6/19/2026	0953	6-29-2026 1537
260937	Lead	143A	<2.0	6/19/2026	0954	6-29-2026 1540
260938	Lead	143B	<2.0	6/19/2026	0954	6-30-2026 1722
260939	Lead	141A	<2.0	6/19/2026	0955	6-29-2026 1548
260940	Lead	141B	<2.0	6/19/2026	0955	6-29-2026 1551
260941	Lead	139A	<2.0	6/19/2026	0957	6-29-2026 1554
260942	Lead	139B	<2.0	6/19/2026	0957	6-29-2026 1556
260943	Lead	Men Bathroom 1	<2.0	6/19/2026	1000	6-29-2026 1605
260944	Lead	Women Bathroom 1	<2.0	6/19/2026	1000	6-29-2026 1607
260945	Lead	Elkay A bottle 1	<2.0	6/19/2026	1007	6-30-2026 1724
260946	Lead	Elkay B Drink 1	<2.0	6/19/2026	1007	6-29-2026 1610
260947	Lead	211	<2.0	6/19/2026	1014	6-29-2026 1613
260948	Lead	209A	2.1	6/19/2026	1018	6-29-2026 1616
260949	Lead	209B	30.5	6/19/2026	1018	6-30-2026 1727
260950	Lead	209C	<2.0	6/19/2026	1018	6-30-2026 1730
260951	Lead	209D	<2.0	6/19/2026	1018	6-29-2026 1108
260952	Lead	207A	2.6	6/19/2026	1020	6-29-2026 1116
260953	Lead	207B	2	6/19/2026	1020	7-2-2026 0815
260954	Lead	207C	<2.0	6/19/2026	1020	6-29-2026 1119
260955	Lead	207D	<2.0	6/19/2026	1020	6-29-2026 1122
260956	Lead	Bathroom E	<2.0	6/19/2026	1023	6-29-2026 1124
260957	Lead	Bathroom F	<2.0	6/19/2026	1024	6-29-2026 1127
260958	Lead	205A	<2.0	6/19/2026	1027	7-2-2026 0823
260959	Lead	205B	<2.0	6/19/2026	1027	6-29-2026 1130
260960	Lead	203A	<2.0	6/19/2026	1028	6-29-2026 1133
260961	Lead	203B	<2.0	6/19/2026	1028	6-29-2026 1141
260962	Lead	201A	<2.0	6/19/2026	1030	6-29-2026 1144
260963	Lead	201B	3.1	6/19/2026	1030	7-2-2026 0826
260964	Lead	200A	<2.0	6/19/2026	1031	6-29-2026 1146
260965	Lead	200B	<2.0	6/19/2026	1031	6-29-2026 1154
260966	Lead	202A	<2.0	6/19/2026	1033	6-29-2026 1157
260967	Lead	202B	<2.0	6/19/2026	1033	6-29-2026 1200
260968	Lead	204A	<2.0	6/19/2026	1034	6-29-2026 1203
260969	Lead	204B	<2.0	6/19/2026	1034	6-29-2026 1206
260970	Lead	Men Bathroom 2 (R)	<2.0	6/19/2026	1038	6-29-2026 1214
260971	Lead	Women Bathroom 2 (L)	<2.0	6/19/2026	1038	6-29-2026 1217
260972	Lead	217A	<2.0	6/19/2026	1041	6-29-2026 1219
260973	Lead	217B	3.1	6/19/2026	1041	7-2-2026 0828
260974	Lead	218	<2.0	6/19/2026	1043	6-29-2026 1222
260975	Lead	Bathroom G	<2.0	6/19/2026	1045	6-29-2026 1320
260976	Lead	224A	<2.0	6/19/2026	1050	6-29-2026 1323
260977	Lead	224B	<2.0	6/19/2026	1050	6-29-2026 1325
260978	Lead	226A	<2.0	6/19/2026	1050	7-2-2026 0831

260979	Lead	226B	<2.0	6/19/2026	1050	7-2-2026 0834
260980	Lead	228A	2.5	6/19/2026	1054	7-2-2026 0842
260981	Lead	228B	4.1	6/19/2026	1054	7-2-2026 0845
260982	Lead	229A	<2.0	6/19/2026	1054	7-2-2026 0847
260983	Lead	229B	<2.0	6/19/2026	1054	7-2-2026 0850
260984	Lead	227A	3.9	6/19/2026	1056	7-2-2026 0853
260985	Lead	227B	2.1	6/19/2026	1056	7-2-2026 0901
260986	Lead	225A	3.8	6/19/2026	1056	7-2-2026 0904
260987	Lead	231A	<2.0	6/19/2026	1059	6-29-2026 1328
260988	Lead	231B	<2.0	6/19/2026	1059	6-29-2026 1331
260989	Lead	233A	4.2	6/19/2026	1101	7-2-2026 0907
260990	Lead	233B	3.1	6/19/2026	1101	7-2-2026 0915
260991	Lead	Bathroom H	<2.0	6/19/2026	1103	6-29-2026 1334
260992	Lead	238A	3.8	6/19/2026	1109	7-2-2026 0918
260993	Lead	240A	4.7	6/19/2026	1111	7-2-2026 0921
260994	Lead	240B	2.2	6/19/2026	1111	7-2-2026 0923
260995	Lead	242A	7.8	6/19/2026	1112	7-2-2026 0926
260996	Lead	242B	3.8	6/19/2026	1112	7-2-2026 0929
260997	Lead	241A	3	6/19/2026	1113	7-2-2026 1007
260998	Lead	241B	2.2	6/19/2026	1113	7-2-2026 1010
260999	Lead	239A	18.3	6/19/2026	1114	7-2-2026 1013
261000	Lead	239B	5.1	6/19/2026	1114	7-2-2026 1021
261001	Lead	237A	4.3	6/19/2026	1116	7-2-2026 1024
261002	Lead	237B	5.4	6/19/2026	1116	7-2-2026 1032
261003	Lead	Elkay 2 Bottle	<2.0	6/19/2026	1120	7-2-2026 1035
261004	Lead	Elkay 2 Drink	<2.0	6/19/2026	1120	6-29-2026 1336
261005	Lead	Outside 1	119	6/19/2026	1127	7-2-2026 1132
261006	Lead	Outside 2	35.7	6/19/2026	1130	7-2-2026 1040
261007	Lead	Outside 3	87.8	6/19/2026	1133	7-2-2026 1130
261008	Lead	Outside 4	4.2	6/19/2026	1136	6-29-2026 1339
261009	Lead	Outside 5	45.6	6/19/2026	1141	7-2-2026 1046
261010	Lead	Outside 6	98	6/19/2026	1143	7-2-2026 1127
261011	Lead	Outside 7	109	6/19/2026	1145	7-2-2026 1119
261012	Lead	Outside 8	73.5	6/19/2026	1147	7-2-2026 1116

Methods & Reporting Limits:

EPA 200.9, Reporting limit: 2.0 µg/L

** This report contains data that were produced by a subcontracted lab certified for the fields of testing performed.

***RMB Laboratories, 22796 County Highway 6 Detroit Lakes, MN 56501 ID# 027-005-336

The above analysis and report were approved by:



Kelsey Klaphake