# Traut Water Analysis Lab

State of MN Laboratory ID #027-145-121
**32640 County Road 133 St. Joseph, MN 56374**

| | |
|---|---|
| **Property:** | Stride Academy |
| **Address:** | 3241 Oakham Lane St Cloud, MN 56301 |
| **Report Date:** | 8/5/2026 |
| **Collected By:** | Kelsey Klaphake |
| **Received By:** | Kelsey Klaphake |
| **Temperature (°C):** | 17.4°C |

| Sample Number | Analysis** | Sample Collection | Result (µg/L) | Collection Date | Collection Time | Analysis Date/Time*** |
|---|---|---|---|---|---|---|
| 261013 | Lead | Elkay 1 Bottle | <2.0 | 6/19/2026 | 1211 | 6-29-2026 1501 |
| 261014 | Lead | Elkay 1 Drink | <2.0 | 6/19/2026 | 1211 | 6-29-2026 1510 |
| 261015 | Lead | 163 Room | <2.0 | 6/19/2026 | 1215 | 6-29-2026 1513 |
| 261016 | Lead | 163 Bathroom | <2.0 | 6/19/2026 | 1215 | 6-29-2026 1515 |
| 261017 | Lead | Womens Bathroom | <2.0 | 6/19/2026 | 1216 | 6-29-2026 1518 |
| 261018 | Lead | 170 Kitvhen | <2.0 | 6/19/2026 | 1221 | 6-29-2026 1521 |
| 261019 | Lead | 177 | 14.3 | 6/19/2026 | 1223 | 6-30-2026 1607 |
| 261020 | Lead | Drink Fountain 1 | <2.0 | 6/19/2026 | 1223 | 6-29-2026 1524 |
| 261021 | Lead | Bath Sink 1 | <2.0 | 6/19/2026 | 1224 | 6-29-2026 1619 |
| 261022 | Lead | 187 | <2.0 | 6/19/2026 | 1225 | 6-29-2026 1627 |
| 261023 | Lead | 193A - Faucet | <2.0 | 6/19/2026 | 1227 | 6-30-2026 1616 |
| 261024 | Lead | 193B - bath | <2.0 | 6/19/2026 | 1230 | 6-29-2026 1630 |
| 261025 | Lead | 189 | <2.0 | 6/19/2026 | 1230 | 6-29-2026 1638 |
| 261026 | Lead | 196 A Faucet | <2.0 | 6/19/2026 | 1234 | 6-29-2026 1640 |
| 261027 | Lead | 196 Bath | <2.0 | 6/19/2026 | 1234 | 6-29-2026 1643 |
| 261028 | Lead | 197 Faucet | <2.0 | 6/19/2026 | 1237 | 6-29-2026 1646 |
| 261029 | Lead | 197 Bath | <2.0 | 6/19/2026 | 1237 | 6-29-2026 1649 |
| 261030 | Lead | 190 | <2.0 | 6/19/2026 | 1238 | 6-29-2026 1651 |
| 261031 | Lead | 191 | <2.0 | 6/19/2026 | 1239 | 6-29-2026 1654 |
| 261032 | Lead | 200 Faucet | <2.0 | 6/19/2026 | 1241 | 6-29-2026 1657 |
| 261033 | Lead | 200 Bath | <2.0 | 6/19/2026 | 1241 | 6-29-2026 1711 |
| 261034 | Lead | 201 | <2.0 | 6/19/2026 | 1243 | 6-29-2026 1713 |
| 261035 | Lead | 192 | <2.0 | 6/19/2026 | 1245 | 6-29-2026 1716 |
| 261036 | Lead | 202 | <2.0 | 6/19/2026 | 1247 | 6-29-2026 1719 |
| 261037 | Lead | 204 | <2.0 | 6/19/2026 | 1248 | 6-30-2026 1619 |
| 261038 | Lead | 205 | <2.0 | 6/19/2026 | 1249 | 6-29-2026 1722 |
| 261039 | Lead | 206 | <2.0 | 6/19/2026 | 1249 | 6-29-2026 1725 |
| 261040 | Lead | Elkay 2 Bottle | <2.0 | 6/19/2026 | 1252 | 6-29-2026 1727 |
| 261041 | Lead | Elkay 2 Drink | <2.0 | 6/19/2026 | 1252 | 6-29-2026 1730 |
| 261042 | Lead | 185 | <2.0 | 6/19/2026 | 1253 | 6-29-2026 1733 |
| 261043 | Lead | Bathroom sink 2 | <2.0 | 6/19/2026 | 1255 | 6-29-2026 1736 |
| 261044 | Lead | 209 | <2.0 | 6/19/2026 | 1256 | 6-29-2026 1749 |
| 261045 | Lead | 210 | <2.0 | 6/19/2026 | 1258 | 6-29-2026 1752 |
| 261046 | Lead | 211 | <2.0 | 6/19/2026 | 1258 | 6-29-2026 1755 |
| 261047 | Lead | 180 | <2.0 | 6/19/2026 | 1259 | 6-29-2026 1757 |
| 261048 | Lead | 179 | <2.0 | 6/19/2026 | 1300 | 6-29-2026 1800 |
| 261049 | Lead | 178 | <2.0 | 6/19/2026 | 1302 | 6-29-2026 1803 |
| 261050 | Lead | Drink Fountain 2 | <2.0 | 6/19/2026 | 1308 | 6-29-2026 1806 |
| 261051 | Lead | Womens Bath 2 | <2.0 | 6/19/2026 | 1310 | 6-29-2026 1808 |

| | | | | | | |
|---|---|---|---|---|---|---|
| 261052 | Lead | Mens Bath 2 | <2.0 | 6/19/2026 | 1311 | 6-29-2026 1817 |
| 261053 | Lead | 132 Faucet | <2.0 | 6/19/2026 | 1317 | 6-29-2026 1819 |
| 261054 | Lead | 132 Bath | <2.0 | 6/19/2026 | 1318 | 6-29-2026 1828 |
| 261055 | Lead | Elkay 3 Bottle | <2.0 | 6/19/2026 | 1320 | 6-29-2026 1830 |
| 261056 | Lead | Elkay 3 Drink | <2.0 | 6/19/2026 | 1320 | 6-29-2026 1833 |
| 261057 | Lead | Womens Bathroom 3 | <2.0 | 6/19/2026 | 1322 | 6-29-2026 1836 |
| 261058 | Lead | Mens Bath 3 | <2.0 | 6/19/2026 | 1323 | 6-29-2026 1839 |
| 261059 | Lead | Elkay 4 Bottle | <2.0 | 6/19/2026 | 1330 | 6-29-2026 1841 |
| 261060 | Lead | Elkay 4 Drink | <2.0 | 6/19/2026 | 1330 | 6-29-2026 1850 |
| 261061 | Lead | Womens Bath 4 | <2.0 | 6/19/2026 | 1330 | 6-29-2026 1852 |
| 261062 | Lead | Mens Bath 4 | <2.0 | 6/19/2026 | 1330 | 6-29-2026 1855 |
| 261063 | Lead | 105 | 11 | 6/19/2026 | 1337 | 6-29-2026 1858 |
| 261064 | Lead | Utility Riser | 137 | 6/19/2026 | 1338 | 7-2-2026 0932 |
| 261065 | Lead | 108 | <2.0 | 6/19/2026 | 1339 | 6-29-2026 1906 |
| 261066 | Lead | Outside 1 | <2.0 | 6/19/2026 | 1345 | 6-29-2026 1909 |
| 261067 | Lead | Outside 2 | 93.6 | 6/19/2026 | 1350 | 6-30-2026 1659 |
| 261068 | Lead | Outside 3 | 2.2 | 6/19/2026 | 1355 | 6-29-2026 1912 |

Methods & Reporting Limits:

EPA 200.9, Reporting limit: 2.0 µg/L

** This report contains data that were produced by a subcontracted lab certified for the fields of testing performed.

***RMB Laboratories, 22796 County Highway 6 Detroit Lakes, MN 56501 ID# 027-005-336

**The above analysis and report were approved by:**




Kelsey Klaphake