[CLINTON CENTRAL SCHOOL DISTRICT ELEMENTARY SCHOOL]

Lead in School Drinking Water Remedial Action Plan

Date Last Updated: 11/12/2026

School Outlet ID	Laboratory Sample ID	Outlet Location	Outlet Description	Was the outlet deemed 'Applicable' or 'Not Applicable' for sampling? *if not applicable place criteria in Notes/Comments	Sample Results (ppb or mcg/L) *if not applicable mark "N/A"		Remedial Actions (Please mark "x" for all that apply)											
											Actions Requiring Maintenance							
					Initial	Post Remediation	Date Taken out of Service	Date Returned to Service	Outlet / Plumbing Replacement	Permanent Removal	Filter Installed and Maintained	Signage	Supervision	Continuing Education	Systematic Flushing	Engineering Controls	Date(s) Remedial Action Taken	Notes/Comments
CES 57	70459062022	Elementary School	ROOM A5 / DF-R	YES	**5.2 µL**		11/9/2026									X		Unit Taken Off-line
CES 66	70459062026	Elementary School	ROOM A3 / DF-R	YES	**6.0 µL**		11/9/2026									X		Unit Taken Off-line
CES 71	70459062028	Elementary School	ROOM A1 / DF-R	YES	**5.6 µL**		11/9/2026									X		Unit Taken Off-line
CES 76	70459062030	Elementary School	ROOM A6 / CLASSROOM SINK / CW-R	YES	**11.2 µL**							X						Signage Posted
CES 89	70459062035	Elementary School	ROOM A2 / CLASSROOM SINK / CW-R	YES	**5.3 µL**							X						Signage Posted
CES 168	70459062051	Elementary School	ROOM C4 / CLASSROOM SINK / CW-R	YES	**7.1 µL**							X						Signage Posted
CES 176	70459062057	Elementary School	ROOM C5 / CLASSROOM SINK / CW-R	YES	**9.2 µL**							X						Signage Posted
CES 179	70459062059	Elementary School	ROOM C6 / CLASSROOM SINK CW-R	YES	**5.1 µL**							X						Signage Posted
CES 180	70459062060	Elementary School	ROOM C8 / CLASSROOM SINK CW-R	YES	**6.8 µL**							X						Signage Posted
CES 189	70459062066	Elementary School	ROOM 204 / CLASSROOM SINK / CW-R	YES	**5.4 µL**							X						Signage Posted
CES 195	70459062070	Elementary School	ROOM 206 / CLASSROOM SINK / CW-R	YES	**5.8 µL**							X						Signage Posted