Water Testing Results - Pleasant Hill School District
Action Level is 15 parts per billion (ppb)

Fixture Location / Description	Fixture ID #	Test Date	Test Results (ppb)
Kitchen Sink	20810000-001KF	07/08/26	1.31
Restroom Sink	20810000-002BF	07/08/26	1.02
Restroom Sink	20810002-001BF	07/08/26	1.75
Women's Restroom Sink	20810003-001BF	07/08/26	1.56
Men's Restroom Sink	20810003-002BF	07/08/26	4.22
East Drinking Fountain	20810101-001DW	07/08/26	0.364
Boy's Locker Room Sink	20810101-003OT	07/08/26	8.84
Boy's Locker Room Drinking Ftn	20810101-004DW	07/08/26	0.938
Girl's Locker Room Sink	20810101-005OT	07/08/26	**13.6**
Girl's Locker Room Drinking Ftn	20810101-006DW	07/08/26	1.74
Boy's Restroom East Sink	20810101-007BF	07/08/26	0.231
Boy's Restroom West Sink	20810101-008BF	07/08/26	0.311
Girl's Restroom South Sink	20810101-009BF	07/08/26	0.85
Girl's Restroom North Sink	20810101-010BF	07/08/26	1.39
West Drink Ftn.	20810101-002DW	07/08/26	ND

ND = Not Dectected - Lead level is below the set detection limits of .1 ppb