Water Testing Results - Pleasant Hill School District Action Level is 15 parts per billion (ppb)			
Fixture Location / Description	**Fixture ID #**	**Test Date**	**Test Results (ppb)**
Classroom #8 Drinking Fountain	20810100-016DW	09/15/26	0.136
Classroom #11 Drinking Fountain	20810100-018DW	09/15/26	0.653
Classroom #16 Drinking Fountain	20810100-019DW	09/15/26	0.156
Classroom #18 Drinking Fountain	20810100-020DW	09/15/26	0.13
Classroom #19 Drinking Fountain	20810100-021DW	09/15/26	0.118
3rd Commons Drinking Fountain	20810100-022DW	09/15/26	0.491
2nd Staff Hall Upper Drinking Fnt	20810100-023DW	09/15/26	ND
2nd Staff Hall Lower Drinking Fnt	20810100-024DW	09/15/26	ND
Nurse Room Sink	20810100-025NS	09/15/26	ND
Nurse Restroom Sink	20810100-026BF	09/15/26	ND
2nd W. Staff Restroom Sink	20810100-027BF	09/15/26	ND
2nd E. Staff Restroom Sink	20810100-028BF	09/15/26	ND
1st Staff Restroom Sink	20810100-029BF	09/15/26	ND
3rd Staff Restroom Sink	20810100-030BF	09/15/26	ND
Copy Room Sink	20810100-031SF	09/15/26	1.03
K-1 Commons Sink	20810100-032OT	09/15/26	0.279
Classroom #17 Sink	20810100-033CF	09/15/26	ND
Classroom #14 Sink	20810100-034CF	09/15/26	ND
Classroom #12 Sink	20810100-035CF	09/15/26	ND
Classroom #13 Sink	20810100-036CF	09/15/26	ND
Classroom #15 Sink	20810100-037CF	09/15/26	ND
5th Commons Sink	20810100-038OT	09/15/26	0.314
Classroom #1 Sink	20810100-039CF	09/15/26	ND
Classroom #2 Sink	20810100-040CF	09/15/26	ND
Classroom #3 Sink	20810100-041CF	09/15/26	ND
Classroom #4 Sink	20810100-042CF	09/15/26	ND
2nd Commons Sink	20810100-043OT	09/15/26	1.26
ND = Not Dectected - Lead level is below the set detection limits of .1 ppb			

Water Testing Results - Pleasant Hill School District Action Level is 15 parts per billion (ppb)			
Fixture Location / Description	**Fixture ID #**	**Test Date**	**Test Results (ppb)**
Classroom #5 Sink	20810100-044CF	09/15/26	ND
Classroom #6 Sink	20810100-045CF	09/15/26	0.111
Classroom #7 Sink	20810100-046CF	09/15/26	0.119
Classroom #8 Sink	20810100-047CF	09/15/26	ND
1st Commons Sink	20810100-048OT	09/15/26	0.332
Classroom #11 Sink	20810100-049CF	09/15/26	ND
Classroom #16 Sink	20810100-050CF	09/15/26	ND
Classroom #18 Sink	20810100-051CF	09/15/26	ND
ND = Not Dectected - Lead level is below the set detection limits of .1 ppb			