Water Testing Results - Pleasant Hill School District Action Level is 15 parts per billion (ppb)			
Fixture Location / Description	**Fixture ID #**	**Test Date**	**Test Results (ppb)**
Kitchen / Lunch Room Sink	20810209-001KF	09/29/26	ND
East Staff Restroom Sink	20810209-002BF	09/29/26	1.58
West Staff Restroom Sink	20810209-003BF	09/29/26	0.155
Restroom Sink	20810208-002BF	09/29/26	ND
Restroom Sink - Cold Tap	20810207-002BF	09/29/26	0.183
Bradley Hand Wash Sink	20810207-003CF	09/29/26	ND
Metal Quench Sink	20810207-004CF	09/29/26	1.71
Restroom Sink - Hot Tap	20810207-007BF	09/29/26	0.37
North Sink	20810206-001SF	09/29/26	0.392
Wood Shop #30 Bradley Hnd Wsh	20810204-001CF	09/29/26	0.762
Wood Shop #30 Restroom Sink	20810204-002BF	09/29/26	0.776
Art Room #25 N.W. Sink	20810204-004CF	09/29/26	0.102
Art Room #25 Ctr. Sink	20810204-005CF	09/29/26	0.128
Art Room #25 S.W. Clay Sink	20810204-006CF	09/29/26	0.102
Classroom #21 S. Sink	20810204-008CF	09/29/26	2.05
#112 Coach/Officials Restrm Sink	20810203-001SF	09/29/26	ND
#110 Up Drink Fountain	20810203-002DW	09/29/26	ND
#110 Low Drink Fountain	20810203-003DW	09/29/26	ND
#108 Girls Restroom E. Sink	20810203-004BF	09/29/26	ND
#108 Girls Restroom W. Sink	20810203-005BF	09/29/26	ND
#109 Boys Restroom E. Sink	20810203-006BF	09/29/26	ND
#109 Boys Restroom W. Sink	20810203-007BF	09/29/26	ND
Bottle Filler	20810203-010WB	09/29/26	ND
HS Kitchen Dish Ctr. Sink	20810202-005KF	09/29/26	0.126
Hs Kitchen Dish E. Sink	20810202-006KF	09/29/26	0.242
HS Kitchen Dish W. Sink	20810202-007KF	09/29/26	0.24
HS Kitchen N. Prep Sink	20810202-008KF	09/29/26	0.298
ND = Not Dectected - Lead level is below the set detection limits of .1 ppb			

Water Testing Results - Pleasant Hill School District Action Level is 15 parts per billion (ppb)			
Fixture Location / Description	**Fixture ID #**	**Test Date**	**Test Results (ppb)**
HS Kitchen S. Prep Sink	20810202-009KF	09/29/26	0.271
HS Kitchen S. Hand Sink	20810202-010KF	09/29/26	1.66
HS Kitchen Restroom Sink	20810202-011BF	09/29/26	ND
General Purpose Rm DF	20810202-012DW	09/29/26	ND
General Purpose Rm Restrm Sink	20810202-013BF	09/29/26	ND
General Purpose Rm Bottle Filler	20810202-014WB	09/29/26	ND
HS Kitchen W. Hand Sink	20810202-015KF	09/29/26	0.392
HS Kitchen CTR Prep Sink	20810202-016KF	09/29/26	0.365
ND = Not Dectected - Lead level is below the set detection limits of .1 ppb			