Water Testing Results - Pleasant Hill School District
Action Level is 15 parts per billion (ppb)

Fixture Location / Description	Fixture ID #	Test Date	Test Results (ppb)
Nurse Station Sink	20810209-004NS	10/01/26	0.104
Boys Restroom E. Sink	20810210-002BF	10/01/26	0.365
Boys Restroom W. Sink	20810210-003BF	10/01/26	0.289
Girls Restroom E. Sink	20810210-004BF	10/01/26	0.744
Girls Restroom W. Sink	20810210-005BF	10/01/26	0.437
Canteen Sink	20810210-001KF	10/01/26	0.115

ND = Not Dectected - Lead level is below the set detection limits of .1 ppb