Water Testing Results - Pleasant Hill School District Action Level is 15 parts per billion (ppb)			
Fixture Location / Description	**Fixture ID #**	**Test Date**	**Test Results (ppb)**
Canteen Drinking Fountain	20810105-001DW	07/10/26	0.785
Canteen Sink	20810105-002KF	07/10/26	ND
Music Building Sink	20810108-001CF	07/10/26	0.628
Drinking Fountain	20810109-001DW	07/10/26	0.282
Library Sink	20810109-002OT	07/10/26	0.159
Kitchen Sink	20810110-001KF	07/10/26	0.537
Drinking Fountain	20810110-002DW	07/10/26	0.116
Boy's Restroom North Sink	20810110-003BF	07/10/26	0.134
Boy's Restroom South Sink	20810110-004BF	07/10/26	ND
Girl's Restroom West Sink	20810110-005BF	07/10/26	0.146
Girl's Restroom East Sink	20810110-006BF	07/10/26	0.382
Snack Shack Sink	20810213-003KF	07/10/26	0.446
ND = Not Dectected - Lead level is below the set detection limits of .1 ppb			